

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 16/May/2017 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 149.346        | 2440.184        | 1) Gujrat                      | 0.806          | -38.054         |
| 2) Hydro            | 5.988          | 72.580          | 2) Madhya Pradesh              | 15.698         | 191.106         |
| 3) Gas              | 10.423         | 140.277         | 3) Chattisgarh                 | 5.790          | 99.840          |
| <b>Total MSPGCL</b> | <b>165.757</b> | <b>2653.041</b> | 4) Maharashtra Net             | 124.372        | 2012.959        |
| B) 1) APML          | 47.679         | 896.381         | 5) Goa (Amona)                 | -0.616         | -12.474         |
| 2) JSWEL            | 19.294         | 327.110         | <b>Total</b>                   | <b>146.050</b> | <b>2253.377</b> |
| 3) VIPL             | 13.767         | 202.706         | a) Mumbai Schedule             | 26.952         | 388.148         |
| 4) RPL(AMT)         | 18.206         | 243.998         | b) Mumbai Drawl                | 31.828         | 509.518         |
| 5) WPCL             | 2.649          | 39.144          | c) MSEDCL Bilateral *          | 38.847         | 649.888         |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | -0.620         | 132.658         |
| 7) Other IPP        | 6.135          | 87.165          | d) Mumbai Bilateral *          | 26.952         | 388.148         |
| C) 1) TPCL Thermal  | 15.687         | 235.596         | Include PX                     | 2.572          | 33.453          |
| 2) TPCL Hydro       | 4.743          | 54.179          | Include Standby                | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.496          | 71.973          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) R-INFRA Thermal  | 11.230         | 159.161         | 1) MSEDCL                      | 408.844        | 6439.151        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 67.985         | 1030.422        |
| 1) Thermal          | 283.993        | 4631.445        | <b>TOTAL STATE</b>             | <b>476.829</b> | <b>7469.573</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 10.731         | 126.759         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 14.919         | 212.250         |                                |                |                 |
| (A3+B6+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 19.481         | 220.115         |                                |                |                 |
| 6) SOLAR            | 1.654          | 25.632          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>330.778</b> | <b>5216.201</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 2 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6118                      | 6379                  | 6297                      | 5977                      |
| MSPGCL Hydro             | 468                       | 416                   | 239                       | 98                        |
| MSPGCL Gas               | 421                       | 422                   | 438                       | 444                       |
| MSPGCL Total Generation  | 7007                      | 7217                  | 6974                      | 6519                      |
| Central Sector Receipt   | 7064                      | 7131                  | 5767                      | 5279                      |
| WIND                     | 604                       | 770                   | 924                       | 1134                      |
| CPP / IPP Thermal        | 4602                      | 4577                  | 4519                      | 4148                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 245                       | 149                   | 0                         | 0                         |
| Exchange with Mumbai     | -1468                     | -1566                 | -1498                     | -1431                     |
| <b>MSEDCL DEMAND MET</b> | <b>18054</b>              | <b>18278</b>          | <b>16686</b>              | <b>15649</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 18054                     | 18278                 | 16686                     | 15649                     |
| TPCL GENERATION          | 1357                      | 1326                  | 1091                      | 703                       |
| R-INFRA GENERATION       | 503                       | 501                   | 395                       | 389                       |
| <b>MUMBAI DEMAND</b>     | <b>3328</b>               | <b>3393</b>           | <b>2984</b>               | <b>2523</b>               |
| STATE DEMAND MET         | 21382                     | 21671                 | 19670                     | 18172                     |
| <b>STATE DEMAND</b>      | <b>21382</b>              | <b>21671</b>          | <b>19670</b>              | <b>18172</b>              |
| Frequency (Hz)           | 49.91                     | 49.95                 | 49.94                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.17 Hz at 18.02 Hrs | 49.8 Hz at 11.48 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 16/May/2017

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.83         | 59.67         | 170      | 153      |
| Unit 8             | 1.62         | 155.11        | 166      | 0        |
| Unit 9             | 0.91         | 147.70        | 100      | 0        |
| Unit 10            | 2.89         | 60.56         | 228      | 65       |
| <b>Total</b>       | <b>9.26</b>  | <b>423.04</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 4.03         | 56.46         | 170      | 160      |
| Unit 4             | 9.88         | 148.73        | 490      | 340      |
| Unit 5             | 10.12        | 149.81        | 490      | 345      |
| <b>Total</b>       | <b>24.03</b> | <b>355.00</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 5.85         | 87.15         | 250      | 200      |
| Unit 7             | 5.82         | 85.75         | 252      | 194      |
| Unit 8             | 4.99         | 19.48         | 230      | 185      |
| <b>Total</b>       | <b>16.66</b> | <b>192.38</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.47         | 69.97         | 193      | 170      |
| Unit 4             | 4.58         | 61.28         | 195      | 175      |
| Unit 5             | 10.00        | 159.53        | 435      | 395      |
| Unit 6             | 10.10        | 110.08        | 455      | 360      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 9.33         | 149.39        | 450      | 338      |
| Unit 9             | 9.70         | 156.93        | 482      | 310      |
| <b>Total</b>       | <b>48.18</b> | <b>707.18</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.95         | 78.64         | 254      | 190      |
| Unit 4             | 5.94         | 80.98         | 255      | 190      |
| <b>Total</b>       | <b>11.89</b> | <b>159.61</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 4.10         | 63.70         | 180      | 160      |
| Unit 2             | 4.00         | 63.12         | 180      | 140      |
| Unit 3             | 4.01         | 66.12         | 180      | 155      |
| Unit 4             | 3.79         | 59.86         | 168      | 144      |
| Unit 5             | 9.85         | 145.04        | 435      | 380      |
| <b>Total</b>       | <b>25.75</b> | <b>397.86</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 4.52         | 69.02         | 200      | 165      |
| Unit 4             | 4.54         | 68.78         | 209      | 162      |
| Unit 5             | 4.52         | 67.32         | 205      | 160      |
| <b>Total</b>       | <b>13.59</b> | <b>205.12</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 10.42        | 140.28        | 458      | 421      |
| <b>Total</b>       | <b>10.42</b> | <b>140.28</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |

| Generating unit   | Generation    |                |          |          |
|-------------------|---------------|----------------|----------|----------|
|                   | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |               |                |          |          |
| Pench (MS)        | 0.42          | 4.09           | 24       | 0        |
| <b>Total</b>      | <b>0.42</b>   | <b>4.09</b>    |          |          |
| <b>Koyna</b>      |               |                |          |          |
| Stage 1-2         | 1.51          | 16.28          | 245      | 40       |
| Stage 4           | 0.00          | 0.82           | 0        | 0        |
| Stage 3           | 0.46          | 4.44           | 80       | 0        |
| <b>Total</b>      | <b>1.97</b>   | <b>21.53</b>   |          |          |
| <b>Hydro</b>      |               |                |          |          |
| KDPH              | 0.58          | 9.17           | 24       | 24       |
| VTRNA             | 0.59          | 9.37           | 61       | 0        |
| TILLARI           | 0.00          | 0.64           | 0        | 0        |
| BHTGR/VEER        | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.        | 0.24          | 2.67           | 77       | 0        |
| RNGR+BHTSA        | 0.31          | 3.92           | 14       | 12       |
| BHANDARDRA        | 0.45          | 7.13           | 41       | 9        |
| ELDARY            | 0.00          | 1.80           | 0        | 0        |
| SMLHY_PTN         | 0.29          | 4.61           | 20       | 9        |
| GHATGHAR          | 1.56          | 11.74          | 200      | 0        |
| <b>Total</b>      | <b>4.02</b>   | <b>51.05</b>   |          |          |
| <b>Wind</b>       |               |                |          |          |
| Total             | 19.48         | 220.12         | 0        | 0        |
| <b>Total</b>      | <b>19.48</b>  | <b>220.12</b>  |          |          |
| <b>CPP</b>        |               |                |          |          |
| APML(Mus)         | 47.68         | 896.38         | 0        | 0        |
| JSWEL(Mus)        | 19.29         | 327.11         | 0        | 0        |
| VIPL(Mus)         | 13.77         | 202.71         | 0        | 0        |
| RPLAMT(Mus)       | 18.21         | 244.00         | 0        | 0        |
| WPCL(Mus)         | 2.65          | 39.14          | 0        | 0        |
| Other(Mus)        | 6.14          | 87.16          | 0        | 0        |
| <b>Total</b>      | <b>107.73</b> | <b>1796.50</b> |          |          |
| <b>SOLAR</b>      |               |                |          |          |
| Total             | 1.65          | 25.63          | 0        | 0        |
| <b>Total</b>      | <b>1.65</b>   | <b>25.63</b>   |          |          |
| <b>Tata</b>       |               |                |          |          |
| Trombay 5         | 10.18         | 151.07         | 485      | 313      |
| Trombay 6         | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A        | 2.90          | 46.34          | 122      | 118      |
| Trombay 7B        | 1.60          | 25.63          | 67       | 66       |
| Trombay 8         | 5.50          | 84.52          | 248      | 200      |
| TATA Hydro        | 4.74          | 54.18          | 459      | 0        |
| <b>Total</b>      | <b>24.93</b>  | <b>361.75</b>  |          |          |
| <b>R-INFRA</b>    |               |                |          |          |
| DTPS U-1&2        | 11.23         | 159.16         | 509      | 388      |
| <b>Total</b>      | <b>11.23</b>  | <b>159.16</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 149.35      | 2440.18       | MSPGCL Total        | 165.76      | 2653.04       |
|                |             |         | MSPGCL Thml+Gas | 159.77      | 2580.46       | Koyna 1,2 & 4 Total | 1.51        | 17.09         |
|                |             |         | MSPGCL Hydro    | 5.99        | 72.58         | State Total         | 330.78      | 5216.20       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 16/May/2017

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |       | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|-------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS   |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 6109        | 98   | 432   | 6639   | 1128  | 4296      | 0    | 0     | 5104        | 5000        | -1556                | 15507                 | 0                    | 15507                     | 2723             | 18230           | 50.03         |
| 2                  | 5977        | 98   | 444   | 6519   | 1134  | 4148      | 0    | 0     | 5266        | 5279        | -1431                | 15649                 | 0                    | 15649                     | 2523             | 18172           | 50.00         |
| 3                  | 6293        | 98   | 444   | 6835   | 1027  | 4157      | 0    | 0     | 5401        | 5703        | -1262                | 16460                 | 0                    | 16460                     | 2358             | 18818           | 50.00         |
| 4                  | 6094        | 98   | 446   | 6638   | 957   | 4304      | 0    | 0     | 5354        | 5712        | -1158                | 16453                 | 0                    | 16453                     | 2251             | 18704           | 50.02         |
| 5                  | 6116        | 108  | 435   | 6659   | 963   | 4452      | 0    | 0     | 5240        | 5597        | -1049                | 16622                 | 0                    | 16622                     | 2202             | 18824           | 50.00         |
| 6                  | 6166        | 118  | 458   | 6742   | 884   | 4558      | 0    | 0     | 5544        | 5831        | -834                 | 17181                 | 0                    | 17181                     | 2222             | 19403           | 50.01         |
| 7                  | 6222        | 273  | 437   | 6932   | 676   | 4527      | 0    | 7     | 5558        | 5898        | -771                 | 17269                 | 0                    | 17269                     | 2194             | 19463           | 50.01         |
| 8                  | 6178        | 348  | 446   | 6972   | 632   | 4511      | 0    | 46    | 6028        | 6479        | -823                 | 17817                 | 0                    | 17817                     | 2252             | 20069           | 50.02         |
| 9                  | 6217        | 373  | 442   | 7032   | 595   | 4529      | 0    | 106   | 6203        | 6498        | -977                 | 17783                 | 0                    | 17783                     | 2508             | 20291           | 50.02         |
| 10                 | 6182        | 431  | 427   | 7040   | 530   | 4524      | 0    | 167   | 6357        | 6687        | -1032                | 17916                 | 0                    | 17916                     | 2751             | 20667           | 49.96         |
| 11                 | 6133        | 455  | 423   | 7011   | 590   | 4593      | 0    | 184   | 6552        | 6498        | -1463                | 17413                 | 0                    | 17413                     | 3237             | 20650           | 49.95         |
| 12                 | 6118        | 468  | 421   | 7007   | 604   | 4602      | 0    | 245   | 6733        | 7064        | -1468                | 18054                 | 0                    | 18054                     | 3328             | 21382           | 49.91         |
| 13                 | 6308        | 316  | 423   | 7047   | 670   | 4570      | 0    | 215   | 6857        | 6996        | -1505                | 17993                 | 0                    | 17993                     | 3327             | 21320           | 49.96         |
| 14                 | 6401        | 202  | 432   | 7035   | 714   | 4576      | 0    | 221   | 6776        | 6679        | -1474                | 17751                 | 0                    | 17751                     | 3248             | 20999           | 49.98         |
| 15                 | 6365        | 211  | 431   | 7007   | 669   | 4572      | 0    | 180   | 6806        | 7310        | -1493                | 18245                 | 0                    | 18245                     | 3312             | 21557           | 49.94         |
| 16                 | 6379        | 416  | 422   | 7217   | 770   | 4577      | 0    | 149   | 6889        | 7131        | -1566                | 18278                 | 0                    | 18278                     | 3393             | 21671           | 49.95         |
| 17                 | 6398        | 451  | 424   | 7273   | 1015  | 4583      | 0    | 91    | 6560        | 6699        | -1468                | 18193                 | 0                    | 18193                     | 3322             | 21515           | 49.95         |
| 18                 | 6272        | 184  | 426   | 6882   | 1267  | 4468      | 0    | 39    | 6326        | 6256        | -1580                | 17332                 | 0                    | 17332                     | 3241             | 20573           | 49.97         |
| 19                 | 5750        | 279  | 429   | 6458   | 1160  | 4243      | 0    | 4     | 5798        | 5360        | -1695                | 15530                 | 0                    | 15530                     | 3007             | 18537           | 50.00         |
| 20                 | 6297        | 239  | 438   | 6974   | 924   | 4519      | 0    | 0     | 5462        | 5767        | -1498                | 16686                 | 0                    | 16686                     | 2984             | 19670           | 49.94         |
| 21                 | 6373        | 176  | 440   | 6989   | 736   | 4626      | 0    | 0     | 5267        | 5543        | -1357                | 16537                 | 0                    | 16537                     | 2965             | 19502           | 49.97         |
| 22                 | 6396        | 160  | 431   | 6987   | 688   | 4618      | 0    | 0     | 5368        | 5249        | -1391                | 16151                 | 0                    | 16151                     | 2858             | 19009           | 49.97         |
| 23                 | 6388        | 169  | 441   | 6998   | 569   | 4597      | 0    | 0     | 5258        | 5449        | -1453                | 16160                 | 0                    | 16160                     | 2880             | 19040           | 49.93         |
| 24                 | 6214        | 219  | 431   | 6864   | 579   | 4580      | 0    | 0     | 5769        | 5365        | -1524                | 15864                 | 0                    | 15864                     | 2898             | 18762           | 49.99         |
| MUs                | 149.35      | 5.99 | 10.42 | 165.76 | 19.48 | 107.73    | 0.00 | 1.65  | 142.48      | 146.05      | -31.83               | 408.84                | 0.00                 | 408.84                    | 67.98            | 476.83          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 16/May/2017**

**Position as on 6.30 Hrs of 17/May/2017**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                                  |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul                                                |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 25/01/2017   | 19.32        |            | Continued. | Turbine Problem, continued under COH                                                                                                                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                                  |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                                                                                                                    |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                                                                                                                     |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |            | Continued. | EE R&M LE Work                                                                                                                                                   |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                                                          |               |
| IPP                   | SWPGL U-2               | 135      | 29/02/2016   | 21.46        |            | Continued. | No PPA                                                                                                                                                           |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 14/06/2016   | 19.35        |            | Continued. | Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)                                                                               |               |
| MSPGCL                | Uran Unit 8             | 108      | 14/08/2016   | 07.56        |            | Continued. | Maintenance work                                                                                                                                                 |               |
| RGPL                  | Dabhol 2A               | 230      | 24/08/2016   | 13.31        |            | Continued. | Change Over.                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 5           | 200      | 05/09/2016   | 00.21        |            | Continued. | ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                                                      |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                                                      |               |
| IPP                   | RPL(AMT) U-5            | 270      | 15/04/2017   | 08.59        |            | Continued. | Coal Shortage                                                                                                                                                    |               |
| IPP                   | RPL(AMT) U-4            | 270      | 15/04/2017   | 12.08        |            | Continued. | Coal Shortage                                                                                                                                                    |               |
| IPP                   | JSW (J) U2              | 300      | 11/05/2017   | 05.35        |            | Continued. | No Schedule.                                                                                                                                                     |               |
| CPP                   | SWPGL U-3               | 135      | 15/05/2017   | 02.43        |            | Continued. | ID Fan Problem                                                                                                                                                   |               |
| MSPGCL                | Koradi Unit 9           | 660      | 16/05/2017   | 10.10        |            | Continued. | Flame Failure                                                                                                                                                    |               |
| MSPGCL                | Koradi Unit-8           | 660      | 16/05/2017   | 11.54        | 16/05/2017 | 23.02      | Loss of fuel                                                                                                                                                     |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 17/05/2017   | 00.17        |            | Continued. | HP Turbine Leakage                                                                                                                                               |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/May/2017**

**Statement-VII**

**Position as on 6.30 Hrs of 17/May/2017**

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                     |
| HVDC Pole-I                            | IntraState                | 17/05/2017   | 00.01        |            | Continued. | EO          | Insulator Replacement Work                                                                                          |
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                     |
| Karad Solapur (PG)                     | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kv Solapur (PG)- Jeur from LOC 403                                                            |
| Dhule Sar'Sarovar II                   | InterState                | 15/05/2017   | 18.15        | 16/05/2017 | 07.34      | HT          | Over Voltage                                                                                                        |
| Dhule Sar'Sarovar II                   | InterState                | 16/05/2017   | 19.14        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Ektuni-Bableshtar ckt II               | IntraState                | 01/05/2017   | 22.55        |            | Continued. | HT          | to control line load.                                                                                               |
| New Koyana - Dabhol - li               | IntraState                | 15/05/2017   | 12.00        | 16/05/2017 | 10.00      | PO          | replacement of faulty insulator string.                                                                             |
| Khadka-Aurangabad (Waluj)              | IntraState                | 16/05/2017   | 00.12        | 16/05/2017 | 07.56      | HT          | Over Voltage                                                                                                        |
| Main Bus @ Taptitanda                  | IntraState                | 16/05/2017   | 11.37        | 17/05/2017 | 00.14      | PO          | extension of 400kv main bus1 for 400/220kv 500mva ict 2, charging of 400kv tie bay.                                 |
| Karad - Lonikand 1                     | IntraState                | 16/05/2017   | 12.56        | 16/05/2017 | 15.48      | T           | Distance Protection                                                                                                 |
| Ektuni-Taptitanda II                   | IntraState                | 16/05/2017   | 13.41        | 16/05/2017 | 18.15      | HT          | tripping command extended to bus2 while working on bus1.                                                            |
| Deepnagar Taptitanda                   | IntraState                | 16/05/2017   | 13.55        | 16/05/2017 | 15.22      | T           | tripping command extended to bus2 while working on bus 1.                                                           |
| Taptitanda Waluj                       | IntraState                | 16/05/2017   | 13.55        | 16/05/2017 | 15.22      | T           | tripping command extended to bus 2 while working on bus1.                                                           |
| Ektuni - Taptitanda Ckt I              | IntraState                | 16/05/2017   | 13.55        | 16/05/2017 | 15.19      | T           | tripping command extended to bus2 while working on bus 1.                                                           |
| Koradi-Bhusawal                        | IntraState                | 16/05/2017   | 15.12        | 16/05/2017 | 16.42      | T           | line reactor oil temp .meter burst.                                                                                 |
| Ektuni - Taptitanda Ckt I              | IntraState                | 16/05/2017   | 15.28        | 16/05/2017 | 15.42      | T           | dt received at ektuni.                                                                                              |
| Khadka-Aurangabad (Waluj)              | IntraState                | 16/05/2017   | 19.04        |            | Continued. | HT          | Over Voltage                                                                                                        |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                     |
| 400/220/33 Kv 500 MVA ICT-III @Girwali | IntraState                | 15/05/2017   | 18.14        | 16/05/2017 | 01.54      | EO          | OLTC trails.                                                                                                        |
| 400/220/33 Kv 500 MVA ICT-III @Girwali | IntraState                | 16/05/2017   | 04.51        | 16/05/2017 | 05.08      | T           | for normalization of tap position.                                                                                  |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                     |
| Talandage - Chikodi                    | InterState                | 16/05/2017   | 12.04        | 16/05/2017 | 18.00      | PO          | as per schedule.                                                                                                    |
| Mudshingi Chikodi                      | InterState                | 16/05/2017   | 12.06        | 16/05/2017 | 18.00      | PO          | as per schedule.                                                                                                    |
| Chandrapur GCR - Warora - I            | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                  | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Waluj - Jalna 1                        | IntraState                | 08/05/2017   | 08.35        |            | Continued. | PO          | make lilo arrangement for newly const.                                                                              |
| Pophali - New Koyana                   | IntraState                | 16/05/2017   | 06.18        |            | Continued. | PO          | conductor and insulator replacement.                                                                                |
| Temghar - Kalwa                        | IntraState                | 16/05/2017   | 07.36        | 16/05/2017 | 13.09      | PO          | Routine Maintenance Work                                                                                            |
| Apta - Hoc                             | IntraState                | 16/05/2017   | 10.59        | 16/05/2017 | 12.24      | PO          | Testing Work                                                                                                        |
| Nashik-Airoli Knowledge Park           | IntraState                | 17/05/2017   | 06.18        |            | Continued. | T           | Distance Protection                                                                                                 |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali   | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning)                                                  |
| 220/132kv 100MVA ICT I @Satara Midc    | IntraState                | 16/05/2017   | 09.30        | 16/05/2017 | 12.40      | PO          | Maintenance work.                                                                                                   |
| 220/132-110kv 100mva Ptr 2 @Oglewadi   | IntraState                | 16/05/2017   | 09.48        | 16/05/2017 | 17.24      | PO          | Testing Work                                                                                                        |
| 220/100kv 200MVA ICT @Oglewadi         | IntraState                | 16/05/2017   | 09.49        | 16/05/2017 | 17.24      | PO          | Testing Work                                                                                                        |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/May/2017**

**Statement-VII**

Position as on 6.30 Hrs of 17/May/2017

| Name of Line                            | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage  |
|-----------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-------------------|
| 220/132 Kv 200 MVA ICT-I<br>@Malegaon   | IntraState                   | 16/05/2017      | 12.20           | 16/05/2017 | 19.27         | PO             | Testing Work      |
| 220/132kv 100MVA ICT II @Satara<br>Midc | IntraState                   | 16/05/2017      | 12.50           | 16/05/2017 | 17.16         | PO             | Maintenance work. |