

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/May/2019 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	170.703	2381.682	1) Gujrat	0.247	14.186
2) Hydro	23.132	569.711	2) Madhya Pradesh	12.295	165.934
3) Gas	6.829	109.682	3) Chattisgarh	4.240	67.430
Total MSPGCL	200.664	3061.075	4) Maharashtra	116.869	1943.364
B) 1) APML	63.643	1102.720	5) Goa (Amona)	-0.440	-7.612
2) JSWEL	26.055	367.766	Total	133.211	2183.302
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.977	449.056
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	31.188	518.636
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	16.177	232.611
6) Other IPP	8.506	122.619	Include PX	-4.967	-75.437
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.977	449.056
C) 1) TPCL Thermal	10.108	206.036	Include PX	11.944	267.694
2) TPCL Hydro	9.217	71.380	Standby	0.000	0.000
3) TPCL Gas	4.348	68.862	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.526	152.878	1) MSEDCL	429.822	6826.479
D) STATE			2) Mumbai Discoms	65.387	1017.789
1) Thermal	289.541	4333.701	TOTAL STATE	495.209	7844.268
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	32.349	641.091			
3) Gas (A3+B7+C3)	11.177	178.544			
4) Wind	21.464	393.887			
6) SOLAR	7.467	113.746			
TOTAL STATE	361.998	5660.969			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	7129	7101	7185	7224
MSPGCL Hydro	492	1445	1626	217
MSPGCL Gas	279	277	284	300
MSPGCL Total Generation	7900	8823	9095	7741
Central Sector Receipt	6833	6152	4394	5027
WIND	653	718	704	1161
CPP / IPP Thermal	3996	4010	4425	4039
CPP / IPP Gas	0	0	0	0
SOLAR	1003	822	0	0
Exchange with Mumbai	-1881	-1747	-1168	-771
MSEDCL DEMAND MET	18504	18778	17450	17197
Load Shedding	0	0	0	0
MSEDCL DEMAND	18504	18778	17450	17197
TPCL GENERATION	958	1003	1106	823
AEML GENERATION	374	436	496	498
MUMBAI DEMAND	3213	3186	2770	2092
STATE DEMAND MET	21717	21964	20220	19289
STATE DEMAND	21717	21964	20220	19289
Frequency (Hz)	50.01	49.97	50.00	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 08.02 Hrs	49.82 Hz at 09.25 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 16/May/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.80	21.52	175	140
Unit 7	0.00	0.00	0	0
Unit 8	9.88	168.74	510	310
Unit 9	10.67	142.09	500	336
Unit 10	12.03	175.01	521	460
Total	36.38	507.36		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.84	141.34	505	380
Unit 5	11.75	164.21	505	360
Total	23.59	305.54		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.64	53.94	195	191
Unit 4	4.16	65.78	179	170
Unit 5	10.04	89.72	425	401
Unit 6	10.74	163.79	470	340
Unit 7	10.00	153.83	442	388
Unit 8	11.43	168.33	485	465
Unit 9	10.81	156.57	475	410
Total	61.83	851.96		
Paras				
Unit 3	6.10	90.89	256	250
Unit 4	6.07	91.52	256	250
Total	12.17	182.42		
Khaparkheda				
Unit 1	3.44	41.84	155	105
Unit 2	3.12	54.49	140	100
Unit 3	2.86	58.92	155	0
Unit 4	3.32	59.48	143	132
Unit 5	10.53	173.16	485	373
Total	23.26	387.88		
Nasik				
Unit 3	4.47	11.59	202	160
Unit 4	4.61	68.22	210	160
Unit 5	4.40	66.70	201	164
Total	13.47	146.51		
Uran				
All Units	6.83	109.68	300	266
Total	6.83	109.68		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	1.20	15	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.07	1.20		
Koyna				
Stage 1-2	5.24	108.51	495	40
Stage 4	11.78	315.76	989	0
Stage 3	3.45	92.32	290	80
Total	20.46	516.59		
Hydro				
KDPH	0.62	11.06	26	26
VTRNA	0.90	13.06	61	0
TILLARI	0.18	6.60	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.47	3.48	40	0
RNGR+BHTSA	0.24	4.00	11	10
BHANDARDRA	0.00	2.36	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.09	5.50	4	3
GHATGHAR	0.16	7.06	125	0
Total	2.67	53.12		
Wind				
Total	21.46	393.89	0	0
Total	21.46	393.89		
CPP				
APML(Mus)	63.64	1102.72	0	0
JSWEL(Mus)	26.06	367.77	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.51	122.62	0	0
Total	98.20	1593.10		
SOLAR				
Total	7.47	113.75	0	0
Total	7.47	113.75		
Tata				
Trombay 5	10.11	134.97	482	314
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	43.85	117	115
Trombay 7B	1.56	25.01	66	65
Trombay 8	0.00	71.07	0	0
TATA Hydro	9.22	71.38	459	162
Total	23.67	346.28		
AEML				
DTPS U-1&2	10.53	152.88	499	374
Total	10.53	152.88		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	170.70	2381.68	MSPGCL Total	200.66	3061.08
			MSPGCL Thml+Gas	177.53	2491.36	Koyna 1,2 & 4 Total	17.01	424.27
			MSPGCL Hydro	23.13	569.71	State Total	362.00	5660.97

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 16/May/2019

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	7117	1388	297	8802	1095	4031	0	0	5103	5105	-1252	17781	0	17781	2630	20411	49.99
2	7215	933	288	8436	1119	4027	0	0	4931	5005	-994	17593	0	17593	2429	20022	50.01
3	7247	867	289	8403	1063	4012	0	0	4821	4776	-875	17379	0	17379	2267	19646	49.97
4	7281	544	289	8114	1128	4026	0	0	4625	5099	-803	17564	0	17564	2153	19717	50.03
5	7224	217	300	7741	1161	4039	0	0	5037	5027	-771	17197	0	17197	2092	19289	50.02
6	7197	258	291	7746	1247	4082	0	0	5497	5628	-780	17923	0	17923	2140	20063	50.03
7	7090	391	290	7771	1051	4020	0	55	6043	5869	-722	18044	0	18044	2114	20158	49.99
8	6989	252	290	7531	876	4003	0	231	6079	5928	-874	17695	0	17695	2253	19948	50.05
9	6907	577	285	7769	914	4032	0	539	5760	5987	-1189	18052	0	18052	2521	20573	50.01
10	6965	549	283	7797	686	4003	0	709	6272	6126	-1532	17789	0	17789	2861	20650	49.93
11	7077	458	281	7816	642	4002	0	904	6698	6575	-1789	18150	0	18150	3121	21271	50.00
12	7129	492	279	7900	653	3996	0	1003	6940	6833	-1881	18504	0	18504	3213	21717	50.01
13	7130	892	277	8299	711	3984	0	947	6698	6410	-1863	18488	0	18488	3196	21684	49.98
14	7001	1132	266	8399	708	3966	0	939	6205	6366	-1787	18591	0	18591	3119	21710	49.99
15	7101	1445	277	8823	718	4010	0	822	6235	6152	-1747	18778	0	18778	3186	21964	49.97
16	7081	1329	278	8688	858	3979	0	680	6275	6084	-1630	18659	0	18659	3242	21901	49.98
17	7157	1365	278	8800	952	3990	0	441	6069	5869	-1565	18487	0	18487	3183	21670	50.01
18	7169	1106	270	8545	1093	4028	0	175	5724	5647	-1500	17988	0	17988	3067	21055	49.98
19	6899	1151	282	8332	1129	4049	0	22	5108	5047	-1526	17053	0	17053	2873	19926	49.99
20	7149	1539	295	8983	903	4146	0	0	4840	4706	-1432	17306	0	17306	2847	20153	49.96
21	7185	1626	284	9095	704	4425	0	0	4470	4394	-1168	17450	0	17450	2770	20220	50.00
22	7184	1451	287	8922	610	4420	0	0	4633	4676	-1135	17493	0	17493	2695	20188	49.98
23	7124	1493	287	8904	692	4484	0	0	4907	5090	-1187	17983	0	17983	2685	20668	50.00
24	7085	1677	286	9048	751	4450	0	0	5028	4812	-1186	17875	0	17875	2730	20605	49.97
MUs	170.70	23.13	6.83	200.66	21.46	98.20	0.00	7.47	134.00	133.21	-31.19	429.82	0.00	429.82	65.39	495.21	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/May/2019

Position as on 6.30 Hrs of 17/May/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
MSPGCL	Koyna STG- IV Unit - 1	250	16/05/2019	07.00	16/05/2019	07.45	Closing 4A Gate.	
MSPGCL	Koyna STG-IV Unit-2	250	16/05/2019	07.00	16/05/2019	07.45	Closing 4A Gate.	
MSPGCL	Koyna STG-IV Unit-3	250	16/05/2019	07.00	16/05/2019	07.45	Closing 4A Gate.	
MSPGCL	Koyna STG-IV Unit-4	250	16/05/2019	07.00	16/05/2019	07.45	Closing 4A Gate.	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	19/01/2019	18.21		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-1	270	20/04/2019	00.01		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-5	270	21/04/2019	00.01		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-2	270	24/04/2019	00.00		Continued.	Zero Schedule	
IPP	RPL(AMT) U-3	270	30/04/2019	17.00		Continued.	Zero Schedule	
MSPGCL	Parli Unit 8	250	01/05/2019	00.00		Continued.	Zero Schedule	
IPP	Adani U-1	660	13/05/2019	10.24	16/05/2019	19.18	APH-A Hot PA Bellow Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/May/2019

Position as on 6.30 Hrs of 17/May/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC_G	Trombay 8	250	15/05/2019	11.03	17/05/2019	13.53	Problem in Cooling water system	
MSPGCL	Khaparkheda Unit 3	210	16/05/2019	05.43	16/05/2019	09.09	Furnace Pressure High	
MSPGCL	Koyna STG-IV Unit-4	250	16/05/2019	12.49	16/05/2019	21.05	Replay replacement of lubrication oil pump control system.	
IPP	Adani U-1	660	17/05/2019	00.35		Continued.	Steam Leakage From MSSV Bonnet.	
MSPGCL	Koyna STG-IV Unit-3	250	17/05/2019	10.50	17/05/2019	20.35	feedback mechanism of guide vane found loose.	
MSPGCL	Koyna STG-IV Unit-2	250	17/05/2019	17.57	17/05/2019	19.50	Spherical value control fault.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/May/2019

Statement-VII

Position as on 6.30 Hrs of 17/May/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Tirora ckt-II	IntraState	17/05/2019	07.08	17/05/2019	09.48	PO	B-PH wavetrap chattering sound attending work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	03/05/2019	17.23	17/05/2019	06.02	EO	To rectify trip CKT faulty (RFC 20.40).
Dhule Sar'Sarovar I	InterState	17/05/2019	13.39		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	15/05/2019	17.38	16/05/2019	11.44	HT	Over Voltage
Chandrapur-Parali III	IntraState	16/05/2019	09.03	17/05/2019	05.54	PO	Replacement of Broken SP CER Cum Vibration Damper.
Khadka-Aurangabad (Waluj)	IntraState	16/05/2019	17.25	17/05/2019	12.08	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	17/05/2019	05.29	17/05/2019	12.32	PO	Cold washing of insulator.
Koradi III(Adani)-Koradi II ckt 2	IntraState	17/05/2019	07.08	17/05/2019	09.48	EO	Wave Trap Chattering Sound Attending Work.
Jaigad-New Koyna Ckt-II	IntraState	17/05/2019	08.47	17/05/2019	17.03	PO	Routine Maintenance Work
Warora -IEPL	IntraState	17/05/2019	09.24	17/05/2019	17.26	PO	Routine Maintenance Work
karad -kolhapur-I	IntraState	17/05/2019	10.51	17/05/2019	12.50	PO	To Remove The Cloth From Line.
Padghe - Kalwa- I	IntraState	17/05/2019	17.30	17/05/2019	19.46	T	Distance Protection, Kalwa End- Z1, R-E, 7.6KM, 6.1KA, Padgha End- Z1, R-E, 41.2KM, 7.6KA.
Khadka-Aurangabad (Waluj)	IntraState	17/05/2019	18.04		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.
400/220 kv 500MVA ICT-I @ Alkud	IntraState	15/05/2019	15.55	16/05/2019	00.00	T	Differential protection
400/220 Kv 315 MVA ICT-II @Chakan	IntraState	16/05/2019	09.31	16/05/2019	18.58	PO	RTV Coating.
400/220 Kv 500 Mva ICT- I @Jejuri	IntraState	16/05/2019	09.36	16/05/2019	19.30	PO	Quarterly Maintenance Work & Testing Work.
400/220/33 Kv 500 Mva ICT III @Aurangabad (Waluj)	IntraState	16/05/2019	11.18	16/05/2019	16.57	HT	Removing failed Y PH unit.
400/220/33kv, 500 MVA ICT-I @Khaparkheda	IntraState	17/05/2019	07.45	17/05/2019	15.40	PO	Routine Maintenance Work
400/220/33 Kv 315 Mva Ict 1 @Dhule	IntraState	17/05/2019	08.55	17/05/2019	12.59	PO	Routine Maintenance Work
400/220/33 Kv 500 Mva Ict-3 @Nagothane	IntraState	17/05/2019	09.17	17/05/2019	19.45	PO	Routine Maintenance Work
400 Kv 105 Mva Cgl Spare Ict @Dhule	IntraState	17/05/2019	14.58	17/05/2019	16.04	PO	Pre monsoon maintenance work.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
PARLY (PG) - OLD GCR PARLI	InterState	16/05/2019	06.25	16/05/2019	11.00	PO	Y-PH C.T Hot spot attending work.
Aurangabad PG (Chitepimpalgaon)- Chitegaon Ckt-II	InterState	17/05/2019	17.15	17/05/2019	22.45	EO	To remove cloth hanging on conductor
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/May/2019

Statement-VII

Position as on 6.30 Hrs of 17/May/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Sonkhar - Trombay	IntraState	16/05/2019	06.36	16/05/2019	14.19	PO	Premonsoon Maintenance Work.
Karad - Vita Ckt- I	IntraState	16/05/2019	08.09	16/05/2019	18.02	PO	Restraining Work.
Mahad-Kandalgaon	IntraState	16/05/2019	08.43	16/05/2019	18.23	PO	Coldline Chemical Washing.
CHAKAN (400 KV)- Chinchwad2	IntraState	16/05/2019	09.08	16/05/2019	20.04	PO	Routine Maintenance Work
Karad - Sadawagpur I	IntraState	16/05/2019	10.00	16/05/2019	18.38	PO	Premonsoon Maintenance Work.
Sadawaghapur Karad Ckt 2	IntraState	16/05/2019	10.00	16/05/2019	18.40	PO	Premonsoon Maintenance Work.
Niwali - Pawas Line	IntraState	16/05/2019	10.05	16/05/2019	16.18	PO	Coldline Chemical Washing.
Apta - Hoc	IntraState	16/05/2019	11.45	16/05/2019	16.43	PO	Replacement of Earthwire With OPGW.
220kv Lonand- Phaltan line	IntraState	16/05/2019	17.20	16/05/2019	18.51	T	Tripped with bus bar.
Lonand Sona Alloys	IntraState	16/05/2019	17.20	16/05/2019	18.47	T	Tripped with bus bar.
Jejuri- Ismt- Lonand	IntraState	16/05/2019	17.20	16/05/2019	18.10	T	Tripped with bus bar.
Lonand-Bothe	IntraState	16/05/2019	17.20	16/05/2019	18.52	T	Tripped with bus bar.
Nadgaonpeth-Amravati	IntraState	17/05/2019	06.54	17/05/2019	12.04	PO	Line Maintenance work
Chikhli-Jalna-II	IntraState	17/05/2019	07.35	17/05/2019	19.26	PO	Testing Work
Karad - Vita Ckt- I	IntraState	17/05/2019	07.50	17/05/2019	13.11	PO	Routine Maintenance Work
JATH SHEDYAL	IntraState	17/05/2019	08.40	17/05/2019	11.50	PO	Routine Maintenance Work
Osmanabad - Solapur (Bale)	IntraState	17/05/2019	10.00	17/05/2019	16.35	PO	Routine Maintenance Work
Chalisgaon-Sayne	IntraState	17/05/2019	10.30	17/05/2019	13.39	PO	Line Maintenance work
Kandalgaon - Bhira	IntraState	17/05/2019	12.18	17/05/2019	18.35	PO	Routine Maintenance Work
Eklahare (Gcr)(Nashik)- Ghatghar	IntraState	17/05/2019	13.56	17/05/2019	15.33	T	Distance Protection, Nasik End- Z1, B-E, 3.58KA, 41.91KM, Ghatgr End- Z1, B-E, 2.07KA, 52.76KM.
Dhule-Amalner(220kv)	IntraState	17/05/2019	14.20	17/05/2019	15.43	T	Removal of LT pole & associated stringing in between LOC no. 11-12.
Kalwa - Borivali	IntraState	17/05/2019	17.39	17/05/2019	20.03	HT	Load management due to tripping of 400KV kalwa padgha Ckt 1.

220 KV ICT Outages/Trippings

220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Buccholz Trip.
220/132 Kv Ict 1 200 Mva @Parbhani	IntraState	16/05/2019	07.24	16/05/2019	09.40	PO	Pre monsoon maintenance work.
220/100 Kv 200 Mva Bhel Ict 1 @Kalwa	IntraState	16/05/2019	07.32	16/05/2019	19.47	PO	CB Overhauling.
220/22 Kv 50 Mva Cgl Ptr 3 @Nalasopara	IntraState	16/05/2019	11.15	16/05/2019	15.05	PO	Hotline washing.
220/132kv 100mva Vijai Ptr No 1 @Baramati	IntraState	16/05/2019	11.45	16/05/2019	13.55	PO	Pre monsoon maintenance work.
220/132 KV 100MVA ICT-I @Walchandnagar	IntraState	16/05/2019	16.05	16/05/2019	18.02	PO	Pre monsoon maintenance work.
220/132kv 200mva Vijai Ptr 2 @Lonand	IntraState	16/05/2019	17.20	16/05/2019	18.35	T	Tripped with bus bar.
220/132kv 115mva Bhel Ptr 3 @Lonand	IntraState	16/05/2019	17.20	16/05/2019	18.49	T	Tripped with bus bar.
220/132kv 200mva Vijai Ptr 1 @Lonand	IntraState	16/05/2019	17.20	16/05/2019	18.55	T	Tripped with bus bar.
220/132 KV 100MVA ICT-II @Walchandnagar	IntraState	16/05/2019	18.10	16/05/2019	19.38	PO	Pre monsoon maintenance work.
220/132 kv 100MVA ICT-I @Ghatodi	IntraState	17/05/2019	07.20	17/05/2019	11.00	PO	Pre monsoon maintenance work.
220/132 Kv Ict 2 200 Mva @Parbhani	IntraState	17/05/2019	07.30	17/05/2019	08.55	PO	Pre monsoon maintenance work.
220/100 Kv 100 MVA ICT II @Vasai-Ii	IntraState	17/05/2019	08.00	17/05/2019	10.12	PO	Routine Maintenance Work
220/132 Kv 200 Mva Emco Ict 2 @Raymond (Nasik 2)	IntraState	17/05/2019	08.30	17/05/2019	16.24	PO	Routine Maintenance Work

132 KV LINE Outages/Trippings

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/May/2019

Statement-VII

Position as on 6.30 Hrs of 17/May/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Mansar Pench	InterState	07/03/2019	15.40		Continued.	HT	Hand trip From Pench end for system requirement.
Kanhan-Pench	IntraState	22/01/2019	18.44		Continued.	HT	After Completion of Outage.