

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/May/2021 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	98.003	1987.417	1) Gujrat	-5.193	-39.551
2) Hydro	14.677	376.634	2) Madhya Pradesh	6.910	177.495
3) Gas	9.061	152.609	3) Chattisgarh	5.020	90.920
Total MSPGCL	121.741	2516.660	4) Maharashtra	104.957	2179.580
B) 1) APML	27.702	1038.945	5) Goa (Amona)	-0.527	-27.899
2) JSWEL	19.004	293.831	Total	111.167	2380.545
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.126	392.926
4) RPL(AMT)	21.257	479.873	b) Mumbai Drawl	25.195	366.543
5) SWPGPL	5.632	106.537	c) MSEDCL Bilateral *	27.551	565.221
6) Other IPP	8.990	217.555	Include PX	-0.248	76.619
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.126	392.926
C) 1) TPCL Thermal	12.647	237.058	Include PX	11.315	161.176
2) TPCL Hydro	1.589	62.743	Standby	0.000	0.000
3) TPCL Gas	3.371	67.574	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.977	174.460	1) MSEDCL	351.467	7044.441
D) STATE			2) Mumbai Discoms	51.779	908.379
1) Thermal	202.212	4535.676	TOTAL STATE	403.246	7952.820
(A1+C1+C4+(B1-B6))					
2) Hydro	16.266	439.377			
(A2+C2)					
3) Gas	12.432	220.183			
(A3+B7+C3)					
4) Wind	56.214	262.737			
6) SOLAR	4.955	114.301			
TOTAL STATE	292.079	5572.274			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	3991	4035	3676	3742
MSPGCL Hydro	325	345	1285	1187
MSPGCL Gas	400	396	398	388
MSPGCL Total Generation	4716	4776	5359	5317
Central Sector Receipt	5149	4369	5000	5286
WIND	2626	2677	2046	2083
CPP / IPP Thermal	3419	3297	2994	3103
CPP / IPP Gas	0	0	0	0
SOLAR	550	656	0	0
Exchange with Mumbai	-772	-1236	-1270	-1409
MSEDCL DEMAND MET	15688	14539	14129	14380
Load Shedding	0	0	0	0
MSEDCL DEMAND	15688	14539	14129	14380
TPCL GENERATION	772	528	714	685
AEML GENERATION	463	287	285	285
MUMBAI DEMAND	2007	2051	2269	2379
STATE DEMAND MET	17695	16590	16398	16759
STATE DEMAND	17695	16590	16398	16759
Frequency (Hz)	50.06	49.95	49.98	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 1001 Hrs	49.78 Hz at 1416 Hrs	50	% of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 16/May/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	8.86	185.99	535	189
Unit 9	8.98	107.46	420	350
Unit 10	8.25	164.72	453	240
Total	26.09	458.17		
Bhusawal				
Unit 3	0.00	13.68	0	0
Unit 4	6.36	152.22	355	0
Unit 5	7.56	179.86	490	280
Total	13.92	345.76		
Parli				
Unit 6	0.00	17.62	0	0
Unit 7	0.00	24.02	0	0
Unit 8	0.00	26.80	0	0
Total	0.00	68.44		
Chandrapur				
Unit 3	3.11	39.59	148	125
Unit 4	0.00	0.00	0	0
Unit 5	7.24	100.17	410	280
Unit 6	7.20	149.96	410	280
Unit 7	0.00	0.00	0	0
Unit 8	6.73	124.73	285	278
Unit 9	6.72	122.76	312	272
Total	31.01	537.21		
Paras				
Unit 3	3.18	75.60	180	0
Unit 4	0.00	80.20	0	0
Total	3.18	155.79		
Khaparkheda				
Unit 1	2.57	41.24	125	90
Unit 2	0.00	0.00	0	0
Unit 3	3.50	61.64	200	135
Unit 4	3.33	44.93	180	130
Unit 5	8.10	138.89	430	300
Total	17.50	286.70		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.17	67.74	145	123
Unit 5	3.13	67.59	134	124
Total	6.30	135.34		
Uran				
All Units	9.06	152.61	420	325
Total	9.06	152.61		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.32	3.29	26	0
Total	0.32	3.29		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.46	78.98	475	35
Stage 4	2.70	137.97	500	0
Stage 3	0.75	47.28	94	0
Total	7.90	264.23		
Hydro				
KDPH	0.72	12.25	30	30
VTRNA	0.92	14.45	60	0
TILLARI	0.52	7.87	58	0
BHIRA T.R.	0.12	3.47	40	0
SMLHY_PTN	3.21	69.64	148	111
GHATGHAR	1.29	4.72	250	0
Total	6.78	112.40		
Wind				
Total	56.21	262.74	0	0
Total	56.21	262.74		
CPP				
APML(Mus)	27.70	1038.94	0	0
JSWEL(Mus)	19.00	293.83	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	21.26	479.87	0	0
SWPGPL-Mus	5.63	106.54	0	0
Other(Mus)	8.99	217.56	0	0
Total	82.58	2136.74		
SOLAR				
Total	4.96	114.30	0	0
Total	4.96	114.30		
Tata				
Trombay 5	8.42	157.29	455	278
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.02	42.87	117	62
Trombay 7B	1.35	24.70	66	48
Trombay 8	4.23	79.77	229	136
TATA Hydro	1.59	62.74	202	0
Total	17.61	367.38		
AEMIL				
DTPS U-1&2	8.98	174.46	502	284
Total	8.98	174.46		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	98.00	1987.42	MSPGCL Total	121.74	2516.66
			MSPGCL Thml+Gas	107.06	2140.03	Koyna 1,2 & 4 Total	7.15	216.95
			MSPGCL Hydro	14.68	376.63	State Total	292.08	5572.27

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 16/May/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3932	388	344	4664	2227	3628	0	0	5948	5830	-1085	15264	0	15264	2638	17902	50.01
2	3974	742	335	5051	2085	3575	0	0	5442	5843	-968	15586	0	15586	2451	18037	49.97
3	4689	806	335	5830	2084	3989	0	0	5164	4747	-989	15661	0	15661	2310	17971	50.02
4	4938	311	325	5574	2121	3934	0	0	5373	4966	-884	15711	0	15711	2183	17894	50.02
5	4834	287	333	5454	2282	3839	0	0	5372	4932	-803	15704	0	15704	2101	17805	50.00
6	4479	351	335	5165	2471	3834	0	0	5605	5113	-807	15776	0	15776	2106	17882	50.00
7	4447	253	338	5038	2567	4060	0	65	5797	5077	-538	16269	0	16269	1982	18251	50.05
8	4123	209	398	4730	2454	3836	0	202	5831	5224	-453	15993	0	15993	1930	17923	50.04
9	4055	322	420	4797	2545	3516	0	399	5539	5025	-637	15645	0	15645	1980	17625	50.05
10	3991	325	400	4716	2626	3419	0	550	4997	5149	-772	15688	0	15688	2007	17695	50.06
11	4013	353	407	4773	2758	3319	0	663	4900	4722	-1148	15087	0	15087	2011	17098	50.02
12	3948	359	396	4703	2615	3324	0	786	5244	4385	-1215	14598	0	14598	2028	16626	49.97
13	4035	345	396	4776	2677	3297	0	656	4781	4369	-1236	14539	0	14539	2051	16590	49.95
14	4015	341	383	4739	2431	3332	0	588	4237	4050	-1255	13885	0	13885	2069	15954	49.96
15	4072	609	382	5063	2399	3332	0	446	3931	3862	-1304	13798	0	13798	2123	15921	49.91
16	4090	751	384	5225	2252	3333	0	338	3768	3638	-1325	13461	0	13461	2164	15625	49.99
17	3856	872	394	5122	2211	3308	0	178	3490	3361	-1242	12938	0	12938	2106	15044	50.03
18	3797	749	394	4940	2257	3188	0	78	3212	3225	-1113	12575	0	12575	2021	14596	50.00
19	3736	760	395	4891	2279	2991	0	6	3766	3673	-1028	12812	0	12812	2023	14835	49.95
20	3767	1475	387	5629	2331	2995	0	0	4029	3779	-1091	13643	0	13643	2146	15789	49.98
21	3765	1171	396	5332	2222	3008	0	0	4391	4445	-1166	13841	0	13841	2195	16036	50.02
22	3676	1285	398	5359	2046	2994	0	0	4884	5000	-1270	14129	0	14129	2269	16398	49.98
23	3742	1187	388	5317	2083	3103	0	0	5073	5286	-1409	14380	0	14380	2379	16759	50.00
24	4029	426	398	4853	2191	3431	0	0	5195	5466	-1457	14484	0	14484	2506	16990	49.97
MUs	98.00	14.68	9.06	121.74	56.21	82.59	0.00	4.96	115.97	111.17	-25.20	351.47	0.00	351.47	51.78	403.25	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/May/2021

Position as on 6.30 Hrs of 17/May/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 4	210	16/03/2021	08.08		Continued.	Boiler Tube Leakage(converted to Capital overhaul)	
MSPGCL	Koyna Unit 6	80	22/04/2021	12.00		Continued.	UGC Oil Cooler Leakage.(Converted to Capital Overhaul from 08.00Hrs DT.23-4-2021)	21/06/2021
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Nasik Unit 3	210	03/12/2020	06.45		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).	
MSPGCL	Koyna Unit 11	80	19/01/2021	10.05		Continued.	Tripped on stator earth fault (will not be available till dt.24.05.21)	
MSPGCL	Chandrapur Unit 7	500	20/02/2021	23.43		Continued.	Generator Earth Fault.	
IPP	JSW (J) U4	300	11/04/2021	03.02		Continued.	NO SCHEDULE.	
MSPGCL	Khaparkheda Unit 2	210	15/04/2021	16.54		Continued.	Critical coal stock position	
MSPGCL	Koradi Unit 6	210	27/04/2021	19.59		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	04/05/2021	20.00		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 3	210	04/05/2021	20.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 7	250	05/05/2021	19.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	06/05/2021	19.45		Continued.	Zero Schedule	
IPP	Adani U-2	660	12/05/2021	22.35	16/05/2021	04.35	Air Preheater Bellow Leakage.	
MSPGCL	Bhusawal Unit 4	500	13/05/2021	17.11	16/05/2021	01.34	Boiler Tube Leakage	
IPP	Adani U-3	660	14/05/2021	17.29		Continued.	Low furnace pressure	
MSPGCL	Paras Unit 4	250	15/05/2021	12.36		Continued.	Coal mill problem.	
IPP	Adani U-4	660	16/05/2021	10.01		Continued.	Zero Schedule.	
MSPGCL	Paras Unit 3	250	16/05/2021	16.18	16/05/2021	19.15	Furnace Pressure High	
IPP	Adani U-1	660	16/05/2021	17.57		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 5	108	17/05/2021	11.52		Continued.	Due to jerk	
IPP	Adani U-5	660	17/05/2021	12.05		Continued.	Zero schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/May/2021

Position as on 6.30 Hrs of 17/May/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	SWPGPL U-3	135	17/05/2021	12.13		Continued.	Scrapper conveyer problem.	
MSPGCL	Nasik Unit 5	210	17/05/2021	12.50		Continued.	Zero schedule.	
MSPGCL	Uran Unit B0	120	17/05/2021	20.15		Continued.	Gas shortage	
MSPGCL	Uran Unit 8	108	17/05/2021	20.15		Continued.	Gas shortage	
MSPGCL	Uran Unit 6	108	17/05/2021	22.59		Continued.	Gas shortage.	
MSPGCL	Uran Unit A0	120	17/05/2021	22.59		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	17/05/2021	23.29		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	17/05/2021	23.50		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/May/2021

Statement-VII

Position as on 6.30 Hrs of 17/May/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Akola-II ckt-I	IntraState	16/05/2021	14.05	16/05/2021	15.34	T	Distance Protection
Koradi III - Akola II- ckt-II	IntraState	16/05/2021	14.05	16/05/2021	14.41	T	Distance Protection
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	13/05/2021	20.45	17/05/2021	04.59	HT	Over Voltage(RFC 16.00)
Dabhol Nagothane I	InterState	16/05/2021	18.12	17/05/2021	01.51	T	Distance Protection, Z-2, Y-PH, 3.785KA,132.4KM From NAGOTHANE.
Babhleshwar - RIPL(Nashik)	IntraState	18/03/2021	15.48		Continued.	PO	Hot spot attending.
Padghe - Kalwa- I	IntraState	16/05/2021	06.18	16/05/2021	09.07	EO	Replacement of decapped insulator string at Loc.No.1041 B-ph
karad -kolhapur-I	IntraState	16/05/2021	17.39		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	16/05/2021	18.11	17/05/2021	05.55	HT	Over Voltage
Padghe - Kalwa- I	IntraState	17/05/2021	10.05	17/05/2021	10.52	T	Line tripped and DT received only at Padgha end.
Padghe - Kalwa- I	IntraState	17/05/2021	12.48	17/05/2021	21.11	T	Distance Protection
Kala Kudus Ckt-II	IntraState	17/05/2021	17.40	17/05/2021	18.31	T	Distance Protection
Kala Kudus Ckt-II	IntraState	17/05/2021	18.50		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	15/05/2021	20.45	16/05/2021	00.35	HT	Hot spot on HVCT R phases.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	15/05/2021	23.52	16/05/2021	01.52	T	Trip on NDR.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	16/05/2021	00.10	16/05/2021	02.48	EO	Sparking At LV Side B-PH Isolator.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	16/05/2021	02.10	16/05/2021	02.48	HT	Sparking on LV B-isloetor.
400/220/33 Kv 500 MVA ICT-III @Parali (Girwali)	IntraState	16/05/2021	16.02	17/05/2021	01.01	T	Tripped on NDR.
400/220/33 Kv 315 Mva Ict 2 @Parali (Girwali)	IntraState	17/05/2021	01.28	17/05/2021	03.15	EO	Attending Red Hot Spot Om R-PH LV Bushing.
400/220 KV 500 MVA ICT I @ Kudus	IntraState	17/05/2021	10.55	17/05/2021	18.53	T	Tripped on NDR.
400/220 KV 500 MVA ICT-III @ Kalwa	IntraState	17/05/2021	11.23	17/05/2021	11.52	HT	Sparking on bus isolator.
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	17/05/2021	17.23	17/05/2021	21.57	T	Tripped On Buchholz.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	17/05/2021	20.30	17/05/2021	22.18	HT	Due to sparking on bus isolator.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Mahalakshmi Amona	InterState	16/05/2021	04.33	16/05/2021	07.35	HT	Over Voltage
Mahalakshmi Amona	InterState	16/05/2021	04.48	16/05/2021	07.35	T	Over Voltage
Mahalakshmi Amona	InterState	16/05/2021	16.20	16/05/2021	20.22	T	Over Voltage
Tillari Amona	InterState	16/05/2021	18.00	16/05/2021	19.29	T	Over Voltage
Borivali - Tarapur	InterState	17/05/2021	16.32		Continued.	T	Distance Protection(18/05/2021 Trial failed 18:24).
Nagothane - Ipcl	IntraState	16/05/2021	02.20	16/05/2021	10.30	T	Distance Protection
Karad - Vita Ckt- I	IntraState	16/05/2021	14.59	16/05/2021	17.21	HT	HT Due To Sparking On B-PH CT At VITA End.
Parli(U-VIII) GCR CKT	IntraState	16/05/2021	15.41	17/05/2021	01.11	T	R PH LA Burst.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/May/2021

Statement-VII

Position as on 6.30 Hrs of 17/May/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Pedambe-Nerle	IntraState	16/05/2021	16.00	16/05/2021	17.20	T	BUS BAR Operated At PEDAMBE.
New Koyna - Pedambe	IntraState	16/05/2021	16.00	16/05/2021	16.33	T	BUS BAR Operated At PEDAMBE.
Mahad - Pedambe	IntraState	16/05/2021	16.00	16/05/2021	16.57	T	BUS BAR Operated At PEDAMBE.
Pophali - Pedambe II	IntraState	16/05/2021	16.00	16/05/2021	17.15	T	BUS BAR Operated At PEDAMBE.
Pedhambe - Oni	IntraState	16/05/2021	16.00	16/05/2021	17.25	T	BUS BAR Operated At PEDAMBE.
Pedambe-Pophali	IntraState	16/05/2021	16.00	16/05/2021	16.45	T	BUS BAR Operated At PEDAMBE.
Adlabs - Pedambe	IntraState	16/05/2021	16.00	17/05/2021	18.29	T	BUS BAR Operated At PEDAMBE.
Vasai Kamba	IntraState	17/05/2021	06.02	17/05/2021	16.39	T	Distance Protection
Goregaon Versova Line 2	IntraState	17/05/2021	08.46	17/05/2021	12.35	T	Distance Protection
Bombay Dyeing - Sahara	IntraState	17/05/2021	10.45	17/05/2021	15.36	T	Distance Protection
Aurangabad (waluj)-Taptitanda ckt-2	IntraState	17/05/2021	11.11	17/05/2021	14.56	PO	LMU replacement work.
Uran - Apta II	IntraState	17/05/2021	11.51	17/05/2021	12.10	T	Distance Protection
Uran - Apta III	IntraState	17/05/2021	12.37	17/05/2021	19.53	T	Distance Protection
Trombay - Mulund	IntraState	17/05/2021	12.45	17/05/2021	14.57	T	Distance Protection
Padgha-Temghar-II	IntraState	17/05/2021	14.12	17/05/2021	17.59	T	Distance Protection
Padgha - Temghar I	IntraState	17/05/2021	14.16	17/05/2021	17.19	T	Distance Protection
Ghatghar - Bapgaon	IntraState	17/05/2021	14.20	17/05/2021	16.25	T	Distance Protection
Trombay - Mulund	IntraState	17/05/2021	15.14		Continued.	T	Distance Protection
Nalasopara-Boisar	IntraState	17/05/2021	15.52	17/05/2021	19.10	T	Distance Protection
Ghatghar - Bapgaon	IntraState	17/05/2021	17.25	17/05/2021	18.27	EO	Restraining of earth wire.
Trombay-Chembur Line 1	IntraState	17/05/2021	17.32	17/05/2021	19.35	T	Distance Protection
Apta - Taloja	IntraState	17/05/2021	17.42	17/05/2021	20.13	T	Distance Protection
BOISAR BORIVALI	IntraState	17/05/2021	19.35	17/05/2021	22.42	T	Distance Protection
220 KV ICT Outages/Trippings							
220/22 Kv 50 Mva Emco Ptr 2 @Colourchem	IntraState	15/05/2021	12.05		Continued.	T	Trip on differential protection.
220/132 Kv 100 Mva Ict 1 @Tuljapur	IntraState	15/05/2021	22.30	16/05/2021	18.25	T	Differential protection
220/22 Kv 50 Mva Cgl Ptr 3 @Nalasopara	IntraState	16/05/2021	07.35	16/05/2021	08.25	EO	Pre-monsoon Plastic wrapping in view of forecasted cyclone.
220/22kv 100MVA T/F-I @ Nalasopara	IntraState	16/05/2021	09.20	16/05/2021	10.40	EO	Plastic wrapping in view of forecasted cyclone.
220/132 Kv 200 Mva Bbl Ict 4 @Padegaon	IntraState	16/05/2021	14.30	16/05/2021	22.06	T	Differential protection
220/100 Kv 200 Mva Vijai Ict 3 @Trombay	IntraState	17/05/2021	09.31	17/05/2021	10.47	T	Bus br protection and master trip.
220/132 Kv 200 MVA ICT I @Dhule	IntraState	17/05/2021	09.35	17/05/2021	12.06	PO	Y-PH OLTC top man hole oil leakage attending work.
220/100 Kv 200 MVA ICT-I @Borivali	IntraState	17/05/2021	17.09	17/05/2021	21.17	T	ICT tripped on 100KV bus fault.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage