

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 16/May/2022 MONDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	181.313	2672.197	1) Gujrat	-4.572	-94.880
2) Hydro	30.369	321.297	2) Madhya Pradesh	7.250	90.632
3) Gas	4.230	112.308	3) Chattisgarh	3.840	58.400
<b>Total MSPGCL</b>	<b>215.912</b>	<b>3105.802</b>	4) Maharashtra	185.479	3034.937
B) 1) APLM	61.539	1053.812	5) Goa (Amona)	-1.107	-22.948
2) JSWEL	14.761	310.022	<b>Total</b>	<b>190.890</b>	<b>3066.141</b>
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.973	550.290
4) RPL(AMT)	25.203	450.918	b) Mumbai Drawl	37.686	586.802
5) SWPGPL	9.441	132.285	c) MSEDCL Bilateral *	66.456	1172.644
6) Other IPP	17.406	346.536	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.973	550.239
C) 1) TPCL Thermal	14.949	232.084	Include PX	0.000	0.000
2) TPCL Hydro	4.781	60.255	Standby	0.000	0.051
3) TPCL Gas	2.178	52.405	<b>H) ENERGY CATERED (MUs)</b>		
4) AEML Thermal	11.700	181.876	1) MSEDCL	516.244	8316.481
D) STATE			2) Mumbai Discoms	71.293	1113.405
1) Thermal	336.312	5379.730	3) Other Discoms	9.733	150.209
(A1+C1+C4+(B1-B6))			<b>TOTAL STATE</b>	<b>597.270</b>	<b>9580.095</b>
2) Hydro	35.150	381.552			
(A2+C2)					
3) Gas	6.408	164.713			
(A3+B7+C3)					
4) Wind	19.508	441.724			
6) SOLAR	9.003	146.252			
<b>TOTAL STATE</b>	<b>406.381</b>	<b>6513.971</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	7642	7722	7738	7513
MSPGCL Hydro	666	2075	2167	648
MSPGCL Gas	207	120	130	219
MSPGCL Total Generation	8515	9917	10035	8380
Central Sector Receipt	9556	8881	7380	7826
WIND	966	522	506	643
CPP / IPP Thermal	5275	5308	5297	5229
CPP / IPP Gas	0	0	0	0
SOLAR	1133	855	2	233
Exchange with Mumbai	-2099	-1940	-1503	-1477
<b>MSEDCL DEMAND MET</b>	<b>22908</b>	<b>23079</b>	<b>21272</b>	<b>20430</b>
Load Shedding	0	0	0	0
MSEDCL DEMAND	22908	23079	21272	20430
TPCL GENERATION	763	1038	1096	566
AEML GENERATION	477	476	499	413
<b>MUMBAI DEMAND</b>	<b>3339</b>	<b>3454</b>	<b>3098</b>	<b>2456</b>
<b>OTHER DISCOM DEMAND</b>	<b>438</b>	<b>464</b>	<b>445</b>	<b>404</b>
STATE DEMAND MET	26685	26997	24815	23290
<b>STATE DEMAND</b>	<b>26685</b>	<b>26997</b>	<b>24815</b>	<b>23290</b>
Frequency (Hz)	50.02	49.99	49.99	50.07

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 00:59 Hrs	49.75 Hz at 14:57 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation, Maximum, Minimum for 16/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 6	3.82	64.40	170	150
Unit 7	0.00	0.00	0	0
Unit 8	12.75	211.72	580	451
Unit 9	12.60	193.95	562	464
Unit 10	12.78	206.86	585	465
<b>Total</b>	<b>41.96</b>	<b>676.94</b>		
<b>Bhusawal</b>				
Unit 3	3.36	50.50	150	120
Unit 4	9.38	112.16	430	280
Unit 5	8.92	139.16	445	285
<b>Total</b>	<b>21.65</b>	<b>301.82</b>		
<b>Parli</b>				
Unit 6	5.57	55.57	250	159
Unit 7	4.73	60.24	227	155
Unit 8	3.04	39.41	138	119
<b>Total</b>	<b>13.34</b>	<b>155.21</b>		
<b>Chandrapur</b>				
Unit 3	3.84	59.24	175	149
Unit 4	3.16	57.20	136	119
Unit 5	8.83	136.34	375	360
Unit 6	9.56	123.28	405	375
Unit 7	9.64	144.74	418	380
Unit 8	11.17	153.35	471	460
Unit 9	10.29	160.77	441	404
<b>Total</b>	<b>56.49</b>	<b>834.93</b>		
<b>Paras</b>				
Unit 3	5.07	65.76	222	189
Unit 4	5.12	69.37	223	197
<b>Total</b>	<b>10.19</b>	<b>135.14</b>		
<b>Khaparkheda</b>				
Unit 1	3.31	46.38	145	110
Unit 2	3.61	56.99	155	145
Unit 3	4.24	52.70	179	173
Unit 4	3.36	55.02	146	130
Unit 5	11.28	177.82	475	455
<b>Total</b>	<b>25.79</b>	<b>388.90</b>		
<b>Nasik</b>				
Unit 3	3.89	61.48	182	121
Unit 4	4.07	62.10	189	137
Unit 5	3.94	55.68	189	123
<b>Total</b>	<b>11.90</b>	<b>179.26</b>		
<b>Uran</b>				
All Units	4.23	112.31	220	110
<b>Total</b>	<b>4.23</b>	<b>112.31</b>		
<b>PGPL</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>PENCH (MS)</b>				
Pench (MS)	0.08	1.66	22	0
<b>Total</b>	<b>0.08</b>	<b>1.66</b>		
<b>Koyna</b>				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	6.88	69.21	515	40
Stage 4	11.01	88.94	1015	0
Stage 3	3.95	35.53	320	80
<b>Total</b>	<b>21.84</b>	<b>193.68</b>		
<b>Hydro</b>				
KDPH	0.67	7.62	28	28
VTRNA	0.85	13.37	60	0
TILLARI	0.41	8.24	58	0
BHIRA T.R.	0.17	2.68	77	0
SMLHY_PTN	5.71	87.31	251	224
GHATGHAR	0.64	6.74	125	0
<b>Total</b>	<b>8.45</b>	<b>125.96</b>		
<b>Wind</b>				
Total	19.51	441.72	0	0
<b>Total</b>	<b>19.51</b>	<b>441.72</b>		
<b>CPP</b>				
APML(Mus)	61.54	1053.81	0	0
JSWEL(Mus)	14.76	310.02	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.20	450.92	0	0
SWPGPL-Mus	9.44	132.28	0	0
Other(Mus)	17.41	346.54	0	0
<b>Total</b>	<b>128.35</b>	<b>2293.57</b>		
<b>SOLAR</b>				
Total	9.00	146.25	0	0
<b>Total</b>	<b>9.00</b>	<b>146.25</b>		
<b>Tata</b>				
Trombay 5	9.58	152.61	438	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.19	31.33	59	49
Trombay 7B	0.99	21.07	46	37
TATA Hydro	4.78	60.26	449	11
Trombay 8	5.36	79.47	242	134
<b>Total</b>	<b>21.91</b>	<b>344.74</b>		
<b>AEML</b>				
DTPS U-1&2	11.70	181.88	500	413
<b>Total</b>	<b>11.70</b>	<b>181.88</b>		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	181.31	2672.20
MSPGCL Thml+Gas	185.54	2784.50
MSPGCL Hydro	30.37	321.30

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	215.91	3105.80
Koyna 1,2 & 4 Total	17.89	158.15
State Total	406.38	6513.97

# State Load Despatch Center, Airoli (MSETCL)

# Annexure-2

## Hourly Load Data As on 16/May/2022

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7305	1186	219	8710	1583	5339	0	0	7301	7150	-1412	21025	0	21025	2930	345	24300	50.05
2	7358	890	220	8468	1430	5341	0	0	7489	7437	-1302	21050	0	21050	2754	324	24128	50.02
3	7340	1021	209	8570	1305	5349	0	0	7180	7203	-1252	20862	0	20862	2598	313	23773	49.98
4	7319	925	219	8463	1239	5347	0	0	7192	7188	-1147	20786	0	20786	2472	304	23562	50.00
5	7334	844	210	8388	1151	5359	0	0	7267	7342	-1095	20806	0	20806	2412	339	23557	49.97
6	7458	894	219	8571	1041	5357	0	0	7354	7687	-1093	21221	0	21221	2424	342	23987	50.02
7	7633	1005	220	8858	801	5332	0	40	7361	7512	-1320	20841	0	20841	2378	382	23601	50.03
8	7513	648	219	8380	643	5229	0	233	7613	7826	-1477	20430	0	20430	2456	404	23290	50.07
9	7456	812	219	8487	641	5204	0	559	7749	8041	-1595	20906	0	20906	2706	431	24043	50.04
10	7427	797	210	8434	745	5213	0	771	8583	8314	-1681	21361	0	21361	2992	435	24788	50.03
11	7524	533	218	8275	926	5271	0	1024	9017	8940	-1933	22065	0	22065	3217	438	25720	50.02
12	7642	666	207	8515	966	5275	0	1133	9294	9556	-2099	22908	0	22908	3339	438	26685	50.02
13	7509	601	211	8321	783	5301	0	1223	9528	9575	-2090	22690	0	22690	3339	423	26452	50.01
14	7629	634	120	8383	620	5310	0	1231	9284	9378	-2008	22493	0	22493	3287	421	26201	50.00
15	7732	1451	140	9323	578	5314	0	1090	9145	9175	-2059	22996	0	22996	3394	425	26815	49.93
16	7722	2075	120	9917	522	5308	0	855	8813	8881	-1940	23079	0	23079	3454	464	26997	49.99
17	7648	2037	140	9825	466	5241	0	568	8737	8142	-1724	22055	0	22055	3420	463	25938	50.07
18	7637	1576	130	9343	534	5212	0	241	8069	7711	-1597	20975	0	20975	3274	469	24718	50.06
19	7639	2008	110	9757	503	5259	0	33	6921	7171	-1433	20828	0	20828	3111	462	24401	49.98
20	7738	2167	130	10035	506	5297	0	2	7327	7380	-1503	21272	0	21272	3098	445	24815	49.99
21	7766	1788	140	9694	533	5373	0	0	7362	7157	-1454	20870	0	20870	3042	433	24345	50.00
22	7651	1811	130	9592	559	5549	0	0	7238	6928	-1424	20771	0	20771	2994	433	24198	50.01
23	7666	1869	130	9665	649	5725	0	0	7492	7755	-1540	21849	0	21849	3133	405	25387	50.00
24	7667	2131	140	9938	784	5845	0	0	7571	7441	-1508	22106	0	22106	3070	394	25570	50.00
<b>MUs</b>	<b>181.31</b>	<b>30.37</b>	<b>4.23</b>	<b>215.91</b>	<b>19.51</b>	<b>128.35</b>	<b>0.00</b>	<b>9.00</b>	<b>190.89</b>	<b>190.89</b>	<b>-37.69</b>	<b>516.24</b>	<b>0.00</b>	<b>516.24</b>	<b>71.29</b>	<b>9.73</b>	<b>597.27</b>	<b>50.01</b>

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 16/May/2022**

Position as on 6.30 Hrs of 17/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
<b>FORCED OUTAGE</b>								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
IPP	Adani U-2	660	13/05/2022	14:24	16/05/2022	20:18	Leakage Work.	16/05/2022
MSPGCL	Uran Unit 5	108	16/05/2022	12:59		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	16/05/2022	23:53		Continued.	Coal Shortage	
TPC-G	Trombay 7B	60	16/05/2022	23:59		Continued.	Non availability of APM gas.	19/05/2022
TPC-G	Trombay 7A	120	17/05/2022	00:14		Continued.	Non availability of APM gas.	19/05/2022
MSPGCL	Bhusawal Unit 3	210	17/05/2022	07:20		Continued.	Furnace Pressure High	17/05/2022

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/May/2022**

**Statement-VII**

Position as on 6.30 Hrs of 17/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>765 KV MAINBAY Outages/Trippings</b>							
MAIN BAY - 701 OF 765/400kV 1500MVA ICT @ AKOLA 2	IntraState	17/05/2022	09:42			PO	Circuit Breaker SF6 gas analysis
<b>500 KV LINE Outages/Trippings</b>							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	16/05/2022	00:28	16/05/2022	05:27	EO	HVDC TL O&M Sub-Division, Junnar:- 1. Chemical Cleaning & cold line washing of dust contaminated insulator string from location no.1777 to 1789 in Manikdoh Area.
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	16/05/2022	15:30	16/05/2022	17:13	T	Control System/communication issue
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	16/05/2022	15:46	16/05/2022	16:14	HT	Control system /communication issue
<b>400 KV MAINBAY Outages/Trippings</b>							
MAIN BAY - 404 OF 765/400kV 1500MVA ICT @ AKOLA 2	IntraState	16/05/2022	12:04	16/05/2022	14:30	PO	Circuit Breaker SF6 gas analysis
<b>400 KV LINE Outages/Trippings</b>							
400KV NANDED(KUMBHARGAON)-PARLY CKT 2	InterState	17/05/2022	08:53			PO	Attend broken conductor strands bet loc 86 87
CHANDRAPUR 2 - WARORA CKT-2	IntraState	15/05/2022	20:15	16/05/2022	06:25	T	Earthwire of Bhadravati-Ramgundam Fell on these lines
CHANDRAPUR 2 - WARORA CKT-1	IntraState	15/05/2022	20:15	16/05/2022	05:15	T	Earthwire of Bhadravati-Ramgundam Line fell on Chandrapur-2 Warora Lines
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	15/05/2022	23:42			HT	For Load Management on Mumbai Supply Lines during the Outage of HVDC Pole-2
AKOLA-NANDGAONPETH (RPL-AMT)	IntraState	16/05/2022	06:25	16/05/2022	19:57	PO	String replacement work will be carried out during outage are 21R, 23R, 26R, 27Y, 58R, 58Y, 89RYB, 86R, 82Y, 76B, 64Y. Total 13 strings
JAIGAD - NEW KOYNA CKT - 1	IntraState	16/05/2022	09:23			PO	C.B. Overhauling work Shifting on TBC
JEJURI- KOYNA STAGE-IV	IntraState	16/05/2022	23:54	17/05/2022	07:48	T	insulator decapping found at Loc No 59. Distance protection. one charging trial failed
<b>400 KV ICT Outages/Trippings</b>							
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	16/05/2022	06:36			PO	for OLTC overhauling and Pre monsoon Maintenance work
400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	IntraState	16/05/2022	12:15	16/05/2022	22:16	PO	1. Pre monsoon Maintenance work. 2. C & Tan delta testing of ICT. 3. C & Tan delta testing of CT. 4. Supervisory trails of ICT.
<b>220 KV TBC Outages/Trippings</b>							
TBC @ VERSOVA (AEML)	IntraState	16/05/2022	09:22	16/05/2022	19:38	PO	Safety Purpose during Annual and Premonsoon maintenance of Transformer-2, NGT-2 and Bay Equipments
<b>220 KV LINE Outages/Trippings</b>							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
MUDSHINGI - CHIKODI	IntraState	16/05/2022	08:10	16/05/2022	20:37	PO	Quarterly maintenance work
MUDSHINGI - CHIKODI	IntraState	16/05/2022	08:10	16/05/2022	20:37	PO	Earth wire stringing work at T.L. no. M/C-16 to M/C-22.
MALHARPETH SATARA MIDC	IntraState	16/05/2022	10:58	16/05/2022	20:02	PO	Replacement of flashover insulator, cold line washing of insulator

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/May/2022**

**Statement-VII**

Position as on 6.30 Hrs of 17/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
OSMANABAD - PARLY (PG)	IntraState	16/05/2022	11:07	16/05/2022	18:07	T	Jumper open at Parli PG end
TALANDGE - MUDSHINGI CKT - 1	IntraState	16/05/2022	12:27	16/05/2022	20:00	PO	For stringing of earth wire between tower location no. M/C-16 to M/C-22 .
BOMBAY DYEING - SAHARA	IntraState	16/05/2022	17:36	16/05/2022	21:02	EO	1) Porcelain longrod insulator cleaning loc.85,86,87,106-111. 2)Replacement of Flashovers. 3)Replacement of polymer insulators by longrod porcelain loc.145,146,147
TALANDGE - ICHALKARANJI 1	IntraState	16/05/2022	17:53	16/05/2022	22:38	PO	1) Quarterly bay maintenance work at 220 kV Tilawani end. 2) Bay diagnostic testing work.
PADGHE - TEMGHAR - 1	IntraState	16/05/2022	23:10	17/05/2022	07:59	PO	Replacement of existing 800-400/1 ratio CT by 1600-800/1 ratio CT (03 Nos.) at Temghar SS.
<b>220 KV ICT Outages/Trippings</b>							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/33kV 100 MVA TF 2 @ VERSOVA (AEML)	IntraState	16/05/2022	09:21	16/05/2022	19:37	PO	Annual and Premonsoon maintenance of Transformer, NGT and Bay Equipments
220/33 kV 50 MVA CGL PTR 1 @ MUDSHINGI	IntraState	16/05/2022	09:39	16/05/2022	18:16	PO	Transformer LV side breaker replacement work.& Replcement work of 33KV Bus section isolator
220/132-110/11KV 200MVA VID ICT 1 @ MIRAJ	IntraState	16/05/2022	10:40	16/05/2022	13:30	PO	HV CB overhauling work
220/132KV 100MVA ICT 1 @ KATHAPUR	IntraState	16/05/2022	12:05	16/05/2022	16:40	PO	Diagnostic Testing and Half yearly maintenance work
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	17/05/2022	09:32			PO	For relay testing & premonsson maintenance work
220/132KV 100MVA ICT - 2 @ KALWAN	IntraState	17/05/2022	09:37			PO	For Oil leakage Attending work by M/s. Rega Electrical
<b>110 KV LINE Outages/Trippings</b>							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/May/2022**

**Statement-VII**

Position as on 6.30 Hrs of 17/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage