

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/May/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	172.273	2715.410	1) Gujrat	-2.357	11.467
2) Hydro	15.878	270.863	2) Madhya Pradesh	4.217	118.168
3) Gas	7.486	112.882	3) Chattisgarh	3.880	68.710
Total MSPGCL	195.637	3099.155	4) Maharashtra	185.167	2964.626
B) 1) APML	62.143	1024.809	5) Goa (Amona)	-2.414	-31.392
2) JSWEL	27.792	441.450	Total	188.493	3131.579
3) VIPL	0.000	0.000	a) Mumbai Schedule	44.835	679.935
4) RPL(AMT)	31.822	496.089	b) Mumbai Drawl	44.817	703.745
5) SWPGPL	12.446	195.604	c) MSEDCL Bilateral *	65.875	1296.740
6) Other IPP	16.649	276.482	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	44.835	679.935
C) 1) TPCL Thermal	13.868	195.820	Include PX	0.000	0.000
2) TPCL Hydro	7.014	78.877	Standby	0.000	0.000
3) TPCL Gas	4.123	61.331	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.496	151.674	1) MSEDCL	501.998	8286.332
D) STATE			2) Mumbai Discoms	81.318	1191.441
1) Thermal	348.489	5497.338	3) Other Discoms	11.839	182.620
(A1+C1+C4+(B1-B6))			TOTAL STATE	595.155	9660.393
2) Hydro (A2+C2)	22.892	349.740			
3) Gas (A3+B7+C3)	11.609	174.213			
4) Wind	8.808	236.614			
6) SOLAR	14.864	270.915			
TOTAL STATE	406.662	6528.820			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6989	7176	7449	6978
MSPGCL Hydro	194	383	1168	332
MSPGCL Gas	355	353	289	287
MSPGCL Total Generation	7538	7912	8906	7597
Central Sector Receipt	9444	9283	5710	8367
WIND	153	449	503	71
CPP / IPP Thermal	5383	5497	6740	6432
CPP / IPP Gas	0	0	0	0
SOLAR	2144	1566	0	471
Exchange with Mumbai	-2263	-2250	-1502	-1767
MSEDCL DEMAND MET	21842	21956	19837	20679
Load Shedding	0	0	0	0
MSEDCL DEMAND	21842	21956	19837	20679
TPCL GENERATION	1212	1286	1208	682
AEML GENERATION	503	503	443	366
MUMBAI DEMAND	3978	4039	3153	2815
OTHER DISCOM DEMAND	558	500	520	492
STATE DEMAND MET	26377	26496	23510	23986
STATE DEMAND	26377	26496	23510	23986
Frequency (Hz)	49.96	49.96	49.98	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 20.01 Hrs	49.85 Hz at 13.34 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 16/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.30	52.18	185	160
Unit 8	0.00	118.32	0	0
Unit 9	12.99	218.08	580	465
Unit 10	14.15	224.05	627	540
Total	31.45	612.63		
Bhusawal				
Unit 3	3.48	49.08	170	125
Unit 4	10.47	134.18	460	345
Unit 5	11.15	145.02	485	335
Total	25.10	328.28		
Parli				
Unit 6	4.44	71.92	246	147
Unit 7	4.08	69.24	202	140
Unit 8	4.42	66.09	242	145
Total	12.94	207.25		
Chandrapur				
Unit 3	3.70	57.18	163	140
Unit 4	3.72	58.79	165	138
Unit 5	9.00	138.87	425	275
Unit 6	7.80	113.44	425	145
Unit 7	8.84	146.32	440	292
Unit 8	10.22	165.40	445	345
Unit 9	10.91	176.99	489	371
Total	54.20	856.99		
Paras				
Unit 3	4.96	69.70	233	113
Unit 4	5.63	88.72	251	190
Total	10.59	158.43		
Khaparkheda				
Unit 1	3.62	56.32	170	135
Unit 2	4.36	66.38	206	152
Unit 3	4.15	62.07	175	170
Unit 4	4.24	60.42	191	161
Unit 5	11.39	146.39	496	445
Total	27.77	391.60		
Nasik				
Unit 3	3.53	45.28	169	124
Unit 4	3.82	58.72	178	125
Unit 5	2.88	56.23	130	70
Total	10.23	160.23		
Uran				
All Units	7.49	112.88	378	273
Total	7.49	112.88		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	5.04	47	0
Total	0.15	5.04		
Koyna				
Stage 1-2	4.26	64.50	520	45

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.22	108.58	803	0
Stage 3	2.53	38.69	320	0
Total	13.00	211.78		
Hydro				
KDPH	0.64	10.61	27	26
VTRNA	0.58	13.27	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.66	31.60	73	59
GHATGHAR	0.00	3.60	0	0
Total	2.87	59.08		
Wind				
Total	8.81	236.61	0	0
Total	8.81	236.61		
CPP				
APML(Mus)	62.14	1024.81	0	0
JSWEL(Mus)	27.79	441.45	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.82	496.09	0	0
SWPGPL-Mus	12.45	195.60	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.76	82.10	267	228
Other(Mus)	6.60	115.24	0	0
JPL	4.28	79.14	268	125
Total	150.85	2434.43		
SOLAR				
Total	14.86	270.92	0	0
Total	14.86	270.92		
Tata				
Trombay 5	9.13	136.11	464	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.57	37.88	108	106
Trombay 7B	1.55	23.46	65	64
TATA Hydro	7.01	78.88	437	77
Trombay 8	4.74	59.71	235	132
Total	25.00	336.03		
AEML				
DTPS U-1&2	11.50	151.67	504	366
Total	11.50	151.67		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	172.27	2715.41	MSPGCL Total	195.64	3099.16
			MSPGCL Thml+Gas	179.76	2828.29	Koyna 1,2 & 4 Total	10.48	173.08
			MSPGCL Hydro	15.88	270.86	State Total	406.66	6528.82

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 16/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7043	1502	378	8923	285	7122	0	0	8206	7962	-1678	22187	0	0	22187	3399	427	26013	50.02
2	7192	1245	364	8801	287	7086	0	0	7754	7534	-1517	21781	0	0	21781	3151	411	25342	50.01
3	7280	1130	285	8695	374	7067	0	0	7523	7288	-1517	21520	0	0	21520	2935	387	24842	49.99
4	7314	825	285	8424	370	7061	0	0	7600	7198	-1576	21088	0	0	21088	2802	389	24279	49.99
5	7359	709	286	8354	186	7062	0	0	7674	7531	-1592	21142	0	0	21142	2727	399	24268	49.99
6	7392	908	287	8587	233	7026	0	0	7755	7565	-1573	21388	0	0	21388	2719	449	24557	49.99
7	7343	857	282	8482	117	6926	0	105	7983	7763	-1540	21365	0	0	21365	2689	488	24542	50.00
8	6978	332	287	7597	71	6432	0	471	8328	8367	-1767	20679	0	0	20679	2815	492	23986	49.98
9	6874	620	287	7781	68	5597	0	1041	8703	8691	-2011	20648	0	0	20648	3150	519	24317	49.97
10	7142	249	279	7670	102	5863	0	1577	9029	8917	-2226	21365	0	0	21365	3526	537	25429	49.99
11	6833	184	273	7290	114	5412	0	1969	9724	9520	-2219	21537	0	0	21537	3825	549	25911	49.99
12	6989	194	355	7538	153	5383	0	2144	9883	9444	-2263	21842	0	0	21842	3978	558	26377	49.96
13	6886	237	353	7476	224	5365	0	2062	9939	9574	-2292	21867	0	0	21867	4023	542	26432	49.94
14	7095	187	355	7637	193	5534	0	1804	9957	8999	-2234	21423	0	0	21423	3956	510	25889	49.94
15	7176	383	353	7912	449	5497	0	1566	10015	9283	-2250	21956	0	0	21956	4039	500	26496	49.96
16	7435	531	358	8324	597	6014	0	1071	9410	8661	-2314	21826	0	0	21826	4108	526	26461	50.01
17	7348	472	360	8180	533	6012	0	654	8752	7735	-2264	20314	0	0	20314	4004	536	24854	50.04
18	6623	368	339	7330	678	5735	0	308	8213	7491	-2087	18918	0	0	18918	3764	537	23219	50.01
19	6436	487	282	7205	636	5609	0	82	8172	7541	-1953	18564	0	0	18564	3466	555	22586	50.01
20	7382	557	282	8221	823	5813	0	10	7232	6901	-1829	19403	0	0	19403	3321	537	23260	50.00
21	7546	404	286	8236	729	6571	0	0	6318	6192	-1558	19652	0	0	19652	3210	518	23380	50.02
22	7449	1168	289	8906	503	6740	0	0	5864	5710	-1502	19837	0	0	19837	3153	520	23510	49.98
23	7587	1363	290	9240	424	6940	0	0	6160	6150	-1478	20787	0	0	20787	3242	489	24518	49.99
24	7571	966	291	8828	659	6986	0	0	6288	6476	-1577	20910	0	0	20910	3316	462	24688	50.01
MUs	172.27	15.88	7.49	195.64	8.81	150.85	0.00	14.86	196.48	188.49	-44.82	502.00	0.00	0.00	502.00	81.32	11.84	595.16	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/May/2024

Position as on 6.30 Hrs of 17/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 7	108	17/05/2024	02:53		Continued.	Filter replacement work	17/05/2024
Total Capacity MSPGCL		108						
Total Capacity PLANNED OUTAGE		108						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Koradi Unit 8	660	14/05/2024	22:17		Continued.	SUSPECTED BTL	19/05/2024
Total Capacity MSPGCL		780						
IPP								
IPP	JPL Unit 2	150	16/05/2024	07:43	16/05/2024	09:05	Flame Failure	
IPP	RPL(AMT) U-5	270	17/05/2024	05:55		Continued.	Cooling Water Line Problem	19/05/2024
Total Capacity IPP		420						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1520						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	15/05/2024	02:01	16/05/2024	11:00	No Schedule from MSEDCL	
MSPGCL	Uran Unit 5	108	16/05/2024	02:00		Continued.	No Schedule from MSEDCL	
MSPGCL	Uran Unit 6	108	16/05/2024	17:50		Continued.	No Schedule from MSEDCL	
Total Capacity MSPGCL		324						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		324						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/May/2024

Position as on 6.30 Hrs of 17/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/May/2024

Statement-VII

Position as on 6.30 Hrs of 17/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (415) OF 500MVA ICT - 2 & STATION TF 4A @ DEEPNAGAR	IntraState	16/05/2024	16:20	16/05/2024	19:06	PO	For Chemical Cleaning of equipment of ICT-2 TIE Bay
400 KV MAINBAY Outages/Trippings							
MAIN BAY (414) OF 500 MVA ICT - 2 @ DEEPNAGAR	IntraState	16/05/2024	09:55	16/05/2024	11:11	PO	For Chemical Cleaning of equipment of ICT-2 Main Bay
400 KV LINE Outages/Trippings							
PADGHE - BOISAR (PG)	InterState	16/05/2024	17:46	16/05/2024	19:08	T	Tripped on distance protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
EKTUNI - BABLESHWAR CKT - 1	IntraState	15/05/2024	19:43	16/05/2024	01:10	PO	Line Maintenance Works & Bay Maintenance Works
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	16/05/2024	06:38	16/05/2024	16:00	PO	Daignostic testing and allied maintenance work
220 KV KORADI (400 KV) - BUTIBORI CKT	IntraState	16/05/2024	08:06	16/05/2024	12:05	HT	Measurement of ct tan delta & isolator routine maintenance works. (outage by 400/220kv koradi-1 s/s).
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	IntraState	16/05/2024	09:25	16/05/2024	17:43	PO	DT Work & Bay Maintenance
DHULE- - BABLESHWAR CKT - 1	IntraState	16/05/2024	12:06	16/05/2024	19:24	PO	400 kV Dhule -Bableshwar ckt 1 Routine line maintenance work
PARLI - KARJAT CKT - 2	IntraState	16/05/2024	14:43	16/05/2024	16:46	T	Tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	13/05/2024	09:45			PO	CB, CT Diagnostic Testing work
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	17/05/2024	07:28			PO	Replacement of R Ph & Y Ph Unit Neutral Bushing along with oil filtration
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
JEUR - SOLAPUR PG	InterState	16/05/2024	14:06	16/05/2024	17:17	T	Tripped on distance protection
AAREY - AEML SAKI CKT - 2	IntraState	08/05/2024	21:48			T	Tripped on Yph to ground fault
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	13/05/2024	13:27			PO	To make the LILO point connection at Loc. 1 (Loc. 19 of 220kV Nashik - Navsari Line) of new 220kV CPRI Line & substation
RANJANGAON - U TECH SUGAR CKT	IntraState	16/05/2024	05:31	16/05/2024	13:12	PO	Replacement of flashover disc insulator string at loc no. 247 R-ph, 37 B-ph, 39 R-ph, & conductor damage at loc no. 248-249

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/May/2024

Statement-VII

Position as on 6.30 Hrs of 17/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
JEJURI-PHURSUNGI 1	IntraState	16/05/2024	05:55	16/05/2024	18:07	PO	For Double Jumpering work Due to hotpost 1)L.N.-15, B Phase,82 Degree (D/C tower) 2) L.N.-21,R Phase,43 Degree (M/c tower) 3) L.N.-10,Y phase, 50 Degree 4) L.N.-6
GADCHANDUR - VIRUR-II	IntraState	16/05/2024	06:04	16/05/2024	11:44	HT	Replacement of disc insulator string at loc no. 36 B-PH AND 71 B-PH.
WAGHIVALI - DHARAVI 8	IntraState	16/05/2024	06:08	16/05/2024	09:44	PO	Work in vicinity of 110KV Mandale project
KARAD - WATHAR	IntraState	16/05/2024	06:21	16/05/2024	09:44	PO	To replace flashover R ph polymer STN insulator string at loc no Lilo- 1.
220 KV KALMESHVAR WARUD CKT I	IntraState	16/05/2024	08:25	16/05/2024	16:48	HT	Punch point rectification work in r/o phase-v.
220 KV KALMESHVAR WARUD CKT II	IntraState	16/05/2024	08:25	16/05/2024	16:50	HT	Punch point rectification work in r/o phase-v.
BADNERA - AMRAVATI	IntraState	16/05/2024	09:00	16/05/2024	13:25	HT	Replacement of flashover disc at loc no.04 b-ph, 62 b-ph, 85 r-ph normal tower.
PADGHE - PAL DOMBIVALI	IntraState	16/05/2024	10:21			PO	Permission for shifting of 220kV Padghe-Pal line on TBC for pole overhauling work of own CB of 220kV Padghe- Pal Line
TALANDAGE - CHIKODI	IntraState	16/05/2024	10:34	16/05/2024	18:41	PO	For all phases conductor restringing work between tower loc no. 271 to 280.
BHIGWAN-BARAMATI AGRO	IntraState	16/05/2024	11:10	16/05/2024	17:40	PO	For replacement of R PH CT having oil leakage(through sec bushing)
URAN - ONGC URAN	IntraState	16/05/2024	11:14	16/05/2024	19:31	PO	For Distance relay replacement work at 220kV ONGC(uran) S/S. Existing D60 GE make relay is having error while communicating, thus DR taking not possible and relay setting cannot be done in currently installed distance relay, Hence GE Engineer alongwith Uran testing team will be replacing the existing relay.
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	16/05/2024	15:17	16/05/2024	19:50	T	Tripped on distance protection
TOPWORTH - KHANDESHWAR	IntraState	16/05/2024	16:24	16/05/2024	18:35	T	Tripped on distance protection
NEW KOYNA - LOTEPARSHURAM	IntraState	16/05/2024	17:32	16/05/2024	22:50	PO	For attending hotspot at loc no. 00 and 01 of 220kV Lote LILO location, cold washing and other line maintenance work.
BHAVEGHAR - ROMA	IntraState	16/05/2024	18:41	16/05/2024	19:50	T	Tripped on distance protection
TALANDGE - ICHALKARANJI 2	IntraState	16/05/2024	21:19	17/05/2024	01:31	PO	1) For relay replacement work & testing work
BOISAR II - BOISAR (PG) CKT - 1	IntraState	17/05/2024	04:56			PO	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
WAGHIVALI - DHARAVI 8	IntraState	17/05/2024	06:06			PO	MANDALE PROJECT WORK IN VICINITY

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/May/2024

Statement-VII

Position as on 6.30 Hrs of 17/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV ICT Outages/Trippings							
220/132 KV 200 MVA ICT 1 @ AMALNER	IntraState	15/05/2024	17:04	16/05/2024	21:27	HT	SFRA & diagnostic testing related work & premonsoon activity related work.
220/33KV 25MVA PTR 3 @ @ KHAREPATAN	IntraState	16/05/2024	08:01	16/05/2024	15:12	PO	Premansoon maintenance work of EMCO make PTR-1.
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	16/05/2024	10:07	16/05/2024	17:06	PO	Diagnostic testing work, half Yearly and pre mansoon maintenance .
220/132 KV 200 MVA ICT 1@ RANJANGAON	IntraState	16/05/2024	10:59	16/05/2024	13:35	PO	For Premansoon Bay maintenance work.
220/33 KV 50MVA PTR - 1 @ KALWAN	IntraState	16/05/2024	11:10	16/05/2024	15:29	PO	Pre-monsoon maintenance work.
220/33 KV 50MVA PTR - 2 @ KALWAN	IntraState	16/05/2024	15:36	16/05/2024	18:31	PO	Pre-monsoon maintenance work
220 KV BUSBAR Outages/Trippings							
220KV BUS PT 1	IntraState	16/05/2024	12:00	16/05/2024	16:31	HT	An outage required for replacement of 220 kv main bus section 1 -r,y ph pt under les scheme.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage