

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Jun/2024 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.582	2448.075	1) Gujrat	-4.094	1.742
2) Hydro	13.030	147.732	2) Madhya Pradesh	-0.225	16.648
3) Gas	6.895	108.156	3) Chattisgarh	2.750	35.050
Total MSPGCL	156.507	2703.963	4) Maharashtra	178.763	3080.272
B) 1) APML	51.930	881.244	5) Goa (Amona)	-1.538	-31.966
2) JSWEL	23.238	400.336	Total	175.656	3101.746
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.586	698.290
4) RPL(AMT)	31.750	480.950	b) Mumbai Drawl	39.525	740.276
5) SWPGPL	12.155	194.659	c) MSEDCL Bilateral *	54.955	1332.188
6) Other IPP	12.481	236.211	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.586	698.237
C) 1) TPCL Thermal	13.384	206.418	Include PX	0.000	0.000
2) TPCL Hydro	4.185	88.385	Standby	0.000	0.053
3) TPCL Gas	4.128	64.971	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.016	140.215	1) MSEDCL	447.349	7648.563
D) STATE			2) Mumbai Discoms	66.238	1240.262
1) Thermal	286.536	4988.108	3) Other Discoms	11.295	186.102
(A1+C1+C4+(B1-B6))			TOTAL STATE	524.882	9074.927
2) Hydro	17.215	236.117			
(A2+C2)					
3) Gas	11.023	173.127			
(A3+B7+C3)					
4) Wind	16.419	330.137			
6) SOLAR	18.033	245.695			
TOTAL STATE	349.226	5973.184			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5213	6072	5701	5796
MSPGCL Hydro	149	230	1682	188
MSPGCL Gas	281	283	284	293
MSPGCL Total Generation	5643	6585	7667	6277
Central Sector Receipt	7996	8239	6515	6540
WIND	219	417	937	1093
CPP / IPP Thermal	4394	5140	6236	5903
CPP / IPP Gas	0	0	0	0
SOLAR	2433	951	0	0
Exchange with Mumbai	-1752	-1993	-1574	-1286
MSEDCL DEMAND MET	18438	18836	19285	18138
Load Shedding	0	0	0	0
MSEDCL DEMAND	18438	18836	19285	18138
TPCL GENERATION	928	670	1181	999
AEML GENERATION	156	215	214	220
MUMBAI DEMAND	2836	2878	2969	2505
OTHER DISCOM DEMAND	495	503	496	389
STATE DEMAND MET	21769	22217	22750	21032
STATE DEMAND	21769	22217	22750	21032
Frequency (Hz)	49.98	50.04	49.99	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 16.02 Hrs	49.63 Hz at 04.10 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 16/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.37	65.95	192	173
Unit 8	14.02	218.39	612	500
Unit 9	13.35	188.54	612	410
Unit 10	12.82	203.45	586	470
Total	44.56	676.33		
Bhusawal				
Unit 3	0.00	20.50	0	0
Unit 4	0.00	151.03	0	0
Unit 5	9.93	150.80	470	320
Total	9.93	322.34		
Parli				
Unit 6	0.00	34.93	0	0
Unit 7	0.00	26.47	0	0
Unit 8	0.00	38.18	0	0
Total	0.00	99.58		
Chandrapur				
Unit 3	0.00	52.57	0	0
Unit 4	3.66	57.72	164	135
Unit 5	8.75	107.78	435	275
Unit 6	8.17	89.44	404	270
Unit 7	9.30	143.35	474	286
Unit 8	7.64	139.98	440	0
Unit 9	10.83	139.26	500	288
Total	48.35	730.10		
Paras				
Unit 3	4.65	73.32	221	147
Unit 4	0.00	7.43	0	0
Total	4.65	80.75		
Khaparkheda				
Unit 1	2.34	55.02	160	0
Unit 2	2.63	64.01	192	0
Unit 3	2.52	50.17	162	0
Unit 4	2.80	65.67	189	0
Unit 5	11.68	176.14	492	480
Total	21.96	411.01		
Nasik				
Unit 3	3.59	55.02	165	119
Unit 4	0.00	19.19	0	0
Unit 5	3.56	53.75	169	123
Total	7.14	127.97		
Uran				
All Units	6.90	108.16	295	281
Total	6.90	108.16		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.42	0	0
Total	0.00	1.42		
Koyna				
Stage 1-2	3.39	46.82	405	25

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.26	35.34	753	0
Stage 3	1.64	20.11	240	0
Total	9.29	102.27		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	0.83	11.07	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.30	0.48	40	0
SMLHY_PTN	1.71	26.81	76	67
GHATGHAR	0.90	4.14	125	0
Total	3.74	45.46		
Wind				
Total	16.42	330.14	0	0
Total	16.42	330.14		
CPP				
APML(Mus)	51.93	881.24	0	0
JSWEL(Mus)	23.24	400.34	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.75	480.95	0	0
SWPGPL-Mus	12.16	194.66	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.31	91.53	267	189
Other(Mus)	1.83	63.68	0	0
JPL	5.34	81.00	271	123
Total	131.55	2193.40		
SOLAR				
Total	18.03	245.70	0	0
Total	18.03	245.70		
Tata				
Trombay 5	8.84	137.08	457	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	40.69	108	108
Trombay 7B	1.54	24.28	64	64
TATA Hydro	4.18	88.38	382	60
Trombay 8	4.55	69.34	233	133
Total	21.70	359.77		
AEML				
DTPS U-1&2	5.02	140.22	239	156
Total	5.02	140.22		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.58	2448.08	MSPGCL Total	156.51	2703.96
			MSPGCL Thml+Gas	143.48	2556.23	Koyna 1,2 & 4 Total	7.65	82.16
			MSPGCL Hydro	13.03	147.73	State Total	349.23	5973.18

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 16/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5785	1167	295	7247	1207	6221	0	0	6658	6481	-1632	19078	0	0	19078	3026	446	22550	49.95
2	5794	717	294	6805	1137	6211	0	0	6624	6518	-1495	18762	0	0	18762	2820	414	21996	50.00
3	5981	226	293	6500	1266	6178	0	0	6570	6309	-1390	18449	0	0	18449	2646	414	21509	49.99
4	5796	188	293	6277	1093	5903	0	0	6674	6540	-1286	18138	0	0	18138	2505	389	21032	49.97
5	6014	444	293	6751	1101	5809	0	0	6848	6652	-1372	18559	0	0	18559	2437	382	21378	49.91
6	6203	474	295	6972	835	6128	0	1	6845	6744	-1229	19042	0	0	19042	2441	409	21892	50.00
7	6270	601	292	7163	523	6174	0	152	6943	6960	-1194	19307	0	0	19307	2395	471	22173	50.01
8	6035	173	293	6501	496	5679	0	607	7815	7363	-1480	18701	0	0	18701	2364	465	21530	50.05
9	5445	218	289	5952	499	4589	0	1235	8300	7968	-1613	18154	0	0	18154	2452	476	21082	49.97
10	5072	227	287	5586	399	4429	0	1783	8288	8063	-1714	18043	0	0	18043	2590	503	21136	49.99
11	5351	217	286	5854	293	4482	0	2206	8163	7830	-1801	18368	0	0	18368	2733	496	21597	49.97
12	5213	149	281	5643	219	4394	0	2433	8559	7996	-1752	18438	0	0	18438	2836	495	21769	49.98
13	4949	114	283	5346	167	4354	0	2385	8515	8352	-1734	18377	0	0	18377	2838	493	21708	49.95
14	5104	144	281	5529	108	4416	0	2148	8341	8398	-1942	18183	0	0	18183	2798	474	21455	49.95
15	5672	189	283	6144	155	4549	0	1968	8348	8198	-1977	18562	0	0	18562	2862	475	21899	50.02
16	6101	149	281	6531	150	4952	0	1639	8199	7875	-1967	18690	0	0	18690	2928	490	22108	50.03
17	6072	230	283	6585	417	5140	0	951	8298	8239	-1993	18836	0	0	18836	2878	503	22217	50.04
18	5709	198	282	6189	844	5616	0	451	8054	7765	-1973	18363	0	0	18363	2806	529	21698	49.99
19	5546	224	284	6054	1137	5718	0	74	8417	7640	-1878	18208	0	0	18208	2755	537	21500	50.03
20	5608	1025	284	6917	1052	5970	0	0	7589	7323	-1604	19143	0	0	19143	2871	515	22529	50.01
21	5701	1682	284	7667	937	6236	0	0	6659	6515	-1574	19285	0	0	19285	2969	496	22750	49.99
22	5750	1663	284	7697	756	6143	0	0	6609	6467	-1602	18970	0	0	18970	3026	491	22487	49.94
23	5762	1427	287	7476	836	6115	0	0	6964	6643	-1626	18983	0	0	18983	3085	461	22529	49.87
24	5649	1184	288	7121	792	6148	0	0	7070	6817	-1697	18710	0	0	18710	3177	471	22358	49.93
MUs	136.58	13.03	6.89	156.51	16.42	131.55	0.00	18.03	181.35	175.66	-39.53	447.35	0.00	0.00	447.35	66.24	11.30	524.88	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 16/Jun/2024

Position as on 6.30 Hrs of 17/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 2	70	15/06/2024	07:10		Continued.	Govrner renovation	10/07/2024
MSPGCL	Bhusawal Unit 4	500	16/06/2024	00:00		Continued.	Annual Overhaul	06/07/2024
Total Capacity MSPGCL		570						
Total Capacity PLANNED OUTAGE		570						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	19/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
MSPGCL	Chandrapur Unit 8	500	14/06/2024	12:25	16/06/2024	02:03	Abnormal Parameters which is created due to increase in leakage of FDV 9.	16/06/2024
MSPGCL	Chandrapur Unit 3	210	15/06/2024	22.16		Continued.	Boiler Tube Leakage	19/06/2024
MSPGCL	Khaparkheda Unit 3	210	16/06/2024	16:56	17/06/2024	00:50	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 4	210	16/06/2024	16:56	17/06/2024	02:24	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 1	210	16/06/2024	16:56	17/06/2024	00:08	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 2	210	16/06/2024	17:01	17/06/2024	03:15	AC Supply failure.	
Total Capacity MSPGCL		2255						
AEML								
AEML	AEML Unit 1	250	14/06/2024	10:16		Continued.	Boiler Tube Leakage	17/06/2024
Total Capacity AEML		250						
IPP								
IPP	JPL Unit 1	150	16/06/2024	08:09	16/06/2024	12:53	Electrical protection	
IPP	JSW (J) U1	300	17/06/2024	07:25		Continued.	Condenser tube leakage.	
IPP	IEPL Unit 1	270	17/06/2024	2.31		Continued.	Critical Clinker Formation in the Boiler Furnace.	
Total Capacity IPP		720						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea.	30/09/2024

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 16/Jun/2024

Position as on 6.30 Hrs of 17/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							The outage extended for repair and re-fueling.	
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3545						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Parli Unit 7	250	08/06/2024	21:00		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 6	250	08/06/2024	21:13		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 8	250	09/06/2024	20:50		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	12/06/2024	16:15		Continued.	Zero schedule given by LM Cell Discom due to drop in demand	
Total Capacity MSPGCL		1176						
IPP								
IPP	Adani U-4	660	10/06/2024	16:16	17/06/2024	04:34	ZERO SCHEDULE BY MSEDCL	
Total Capacity IPP		660						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		1836						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaoor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 17/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
BUS COUPLER @ KALWA	IntraState	16/06/2024	06:42	16/06/2024	12:45	PO	Bay maintenance and R &M work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	13/06/2024	10:11			PO	For work in vicinity for erection of scaffolding for installation of LA�s on 220KV Bays at KVTL Vikhroli (These Bays used for feeding 220/110kV, 250MVA, ICT-1 & ICT-2 of TPC Vikhroli).
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV BUS COUPLER	IntraState	16/06/2024	16:56	16/06/2024	18:40	T	Bus-1 BB Prot Optd
40MVA 220/6.6 KV STN T/F 3	IntraState	16/06/2024	16:56	16/06/2024	19:58	T	Bus-1 BB Prot Optd
220KV MAIN BUS 1 @ 220KV KHAPARKHEDA S/S	IntraState	16/06/2024	16:56	16/06/2024	18:17	T	220 KV TBC Bay, Bus-1 isolator Yph jumpering by Hot line unit was in process .During restoration process , while moving hot line arrangement sudden rainfall started and Y phase earth fault occurred on 220 kV Bus1,through wet hot line ropes.
220 KV LINE Outages/Trippings							
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
EKLAHARE (OCR) - PADGHE	IntraState	10/06/2024	08:42			HT	H/T for load management
TIFIL - KALWA	IntraState	13/06/2024	08:55			PO	For making 220kV Pawane-TIFIL line LILO for M/s NXTRA Data Ltd for the proposed 220kV GIS S/stn.
VERSOVA - GORAI	IntraState	14/06/2024	11:49			PO	Pre-monsoon Maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 17/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TOPWORTH - KHANDESHWAR	IntraState	15/06/2024	14:24			PO	Making LILO of 220kV Khandeshwar - Topwarth line & 220kV Khandeshwar Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel
PANVEL TSS - KHANDESHWAR	IntraState	15/06/2024	14:30			PO	Making LILO of 220kV Khandeahwar Topwarth line & 220kV Khandeshwar - Panvel TSS line and commissioing of 220/33kV Timber Market GIS, Panvel
NANDED CITY - GIS KONDHWA	IntraState	15/06/2024	16:02			PO	1. Double jumpering work due to Hotspot L.N.-84 2R Phase L.N.-79 -B&R Phase L.N.-70-B Phase L.N.-65-Y Phase L.N.-5-B Phase 2. fixing of vibration Damper at various missing locations
MAIN BUS SECTION - 1 @ POPHALI	IntraState	16/06/2024	07:20	16/06/2024	18:12	PO	220 KV Main Bus Section I outage Damaged conductor replacement work related to 220 kv main bus worksd main bus isolators alignment work
PIRANGUT - HINJAWADI 2	IntraState	16/06/2024	09:50	16/06/2024	13:43	PO	Erection of monopole Loc No. 154 for height raising purpose and stringing of conductor at New Monopole Loc. No. 154-155
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	IntraState	16/06/2024	10:46	16/06/2024	14:47	PO	1) Work in vicinity of 220KV TC-7/KVTL-2 line at ash pond for daff installation activity. Activity will be carried out by environment team at Trombay generating station
PADGHE - NALASOPARA - VASAI (T)	IntraState	16/06/2024	12:56	16/06/2024	17:11	PO	1) Insulator replacement Work identified in PID. 2) Diagnostic Testing and Pre-monsoon Maintenance Work at Vasai s/stn.
KALWA - MULUND 1	IntraState	16/06/2024	13:02	16/06/2024	18:06	PO	For the installation of saver assembly sets at TL no. 4 & 7 (Total 6 sets out of 6 sets are to be installed)
KHARGHAR - BORIVALI CKT - 2	IntraState	16/06/2024	13:02	16/06/2024	16:12	PO	For the installation of saver assembly sets at TL no. 4 & 7 (Total 6 sets out of 66 sets are to be installed) Total completed - 6 sets
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA CKT 2	IntraState	16/06/2024	16:56	16/06/2024	18:17	T	Bus-1 Bus bar Protection operated
KHAPARKHEDA- SURYALAKSHMI	IntraState	16/06/2024	16:56	16/06/2024	18:49	T	Bus-1 BB Prot Optd
KHAPERKHEDA - KALMESHVAR CKT	IntraState	16/06/2024	16:56	16/06/2024	18:41	T	Bus-1 BB Prot Optd
220KV PANDHARKAWDA - WANI CKT li	IntraState	16/06/2024	17:52	16/06/2024	18:42	T	Distance protection
KALWA - BORIVALI	IntraState	16/06/2024	18:40	16/06/2024	22:14	PO	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22 & 23 (Total 17 sets out of 33 sets are to be installed) Total Completed - 16 sets
BORIVALI - CTRLS CKT	IntraState	16/06/2024	18:44	16/06/2024	22:12	PO	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22 & 23 (Total 15 sets out of 33 sets are to be installed)
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220 / 110 / 33kV 250MVA AT 2 @ BACKBAY	IntraState	15/06/2024	16:58	16/06/2024	19:11	T	110KV Bus Fault

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 17/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kV 250MVA ICT 1 @ BORIVALI (TATA)	IntraState	16/06/2024	09:32	16/06/2024	10:34	PO	OSR canopy installation
220 / 110 / 33kV 250MVA ICT 3 @ BORIVALI (TATA)	IntraState	16/06/2024	10:51	16/06/2024	11:41	PO	OSR canopy installation
40 MVA 220/6.6 KV STN TF - 1 @KHAPARKHEDA	IntraState	16/06/2024	16:56	16/06/2024	18:58	T	Bus-1 BB Prot Optd
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
110 KV LINE Outages/Trippings							
BORIVLI (T) - BORIVLI (M) - BMC - KOLSHET	IntraState	16/06/2024	08:55	16/06/2024	19:59	PO	Old OHIO Make polymer insulator replacement
KARANJADE - BHOKARPADA	IntraState	16/06/2024	09:47	16/06/2024	12:34	PO	For Bird nest removal at loc.161,183,191

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage