

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Aug/2016 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	74.229	1078.036	1) Gujrat	9.768	64.583
2) Hydro	11.481	213.853	2) Madhya Pradesh	13.567	184.946
3) Gas	6.791	137.132	3) Chattisgarh	5.590	107.840
Total MSPGCL	92.501	1429.021	4) Maharashtra Net	65.178	969.500
B) 1) APML	26.707	482.878	5) Goa (Amona)	-0.254	-10.733
2) JSWEL	21.212	326.853	6) TAPS 1&2 Injection	7.634	120.497
3) VIPL	12.436	147.575	7) RGPPL Injection	10.565	186.434
4) RPL(AMT)	0.000	0.000	8) Pench (MS)	0.195	4.024
5) WPCL	2.915	69.662	9) Pench (Excess)	-0.195	-4.024
6) PGPL	2.110	16.917	Total	111.853	1619.043
7) Other IPP	2.040	35.671	a) Mumbai Schedule	20.604	287.159
C) 1) TPCL Thermal	14.887	212.766	b) Mumbai Drawl	24.228	369.071
2) TPCL Hydro	5.979	92.727	c) MSEDCL Bilateral *	25.724	430.053
3) TPCL Gas	4.072	58.944	Include PX	-1.455	-28.686
4) R-INFRA Thermal	10.589	160.090	d) Mumbai Bilateral *	20.604	287.159
D) STATE			Include PX	1.515	31.624
1) Thermal	165.015	2513.531	Include Standby	0.000	0.000
(A1+C1+C4+(B1-B6))			H) ENERGY CATERED (MUs)		
2) Hydro	17.460	306.580	1) MSEDCL	298.766	4517.669
3) Gas	12.973	212.993	2) Mumbai Discoms	59.755	893.598
4) Wind	50.081	745.859	TOTAL STATE	358.521	5411.267
6) SOLAR	1.139	13.261			
TOTAL STATE	246.668	3792.224			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	3160	3292	2979	2977
MSPGCL Hydro	638	437	1422	143
MSPGCL Gas	288	277	281	289
MSPGCL Total Generation	4086	4006	4682	3409
Central Sector Receipt	5334	5089	5261	3298
WIND	2393	2303	1666	2169
CPP / IPP Thermal	2878	2774	2930	2340
CPP / IPP Gas	42	187	133	0
SOLAR	108	77	0	0
Exchange with Mumbai	-1342	-1440	-926	-687
MSEDCL DEMAND MET	13499	12996	13746	10529
Load Shedding	0	0	0	0
MSEDCL DEMAND	13499	12996	13746	10529
TPCL GENERATION	1296	1095	1302	634
R-INFRA GENERATION	440	402	507	402
MUMBAI DEMAND	3078	2937	2735	1723
STATE DEMAND MET	16577	15933	16481	12252
STATE DEMAND	16577	15933	16481	12252
Frequency (Hz)	50.00	49.97	49.96	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.13 Hz at 09.03 Hrs	49.74 Hz at 19.30 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 16/Aug/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.31	124.00	535	0
Total	9.31	124.00		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	10.56	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	10.56		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	2.16	28.30	185	0
Unit 4	3.88	54.02	169	135
Unit 5	9.04	129.23	400	360
Unit 6	9.64	117.25	440	355
Unit 7	9.01	134.60	400	340
Unit 8	7.07	67.73	419	209
Total	40.79	531.12		
Paras				
Unit 3	0.00	33.73	0	0
Unit 4	5.50	78.22	245	198
Total	5.50	111.94		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	10.24	159.01	470	397
Total	10.24	159.01		
Nasik				
Unit 3	4.19	62.42	200	160
Unit 4	4.21	51.78	201	162
Unit 5	0.00	10.04	0	0
Total	8.40	124.24		
Uran				
All Units	6.79	137.13	293	263
Total	6.79	137.13		
PGPL				
Unit 1	0.00	9.99	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	2.11	6.93	190	0
Total	2.11	16.92		
PENCH (MS)				
Pench (MS)	0.20	4.02	27	0
Total	0.20	4.02		
Koyna				
Stage 1-2	4.25	61.51	445	40
Stage 4	2.27	51.58	649	0
Stage 3	1.62	37.88	160	0
Total	8.14	150.97		
Hydro				
KDPH	0.00	5.89	0	0
VTRNA	0.70	14.96	59	0
TILLARI	0.37	4.45	61	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.40	7.36	80	0
RNGR+BHTSA	0.07	4.33	3	3
BHANDARDRA	0.34	7.63	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.30	5.77	22	10
GHATGHAR	1.16	12.50	240	0
Total	3.34	62.88		
Wind				
Total	50.08	745.86	0	0
Total	50.08	745.86		
CPP				
APML(Mus)	26.71	482.88	0	0
JSWEL(Mus)	21.21	326.85	0	0
VIPL(Mus)	12.44	147.58	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.92	69.66	0	0
Other(Mus)	2.04	35.67	0	0
Total	65.31	1062.64		
SOLAR				
Total	1.14	13.26	0	0
Total	1.14	13.26		
Tata				
Trombay 5	9.49	132.32	489	313
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.54	36.21	115	60
Trombay 7B	1.53	22.73	67	48
Trombay 8	5.40	80.44	248	199
TATA Hydro	5.98	92.73	390	0
Total	24.94	364.44		
R-INFRA				
1-2	10.59	160.09	507	401
Total	10.59	160.09		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	0.00	17.16
Koradi 9	0.00	0.00
Koradi 10	0.00	0.00
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	74.23	1078.04
MSPGCL Thml+Gas	81.02	1215.17
MSPGCL Hydro	11.48	213.85

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	92.50	1429.02
Koyna 1,2 & 4 Total	6.52	113.09
State Total	246.67	3792.22

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 16/Aug/2016

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3013	138	289	3440	1959	2386	0	0	3572	3739	-802	10722	0	10722	1967	12689	49.99
2	2996	133	281	3410	2096	2346	0	0	3026	3399	-727	10524	0	10524	1815	12339	49.97
3	2977	143	289	3409	2169	2340	0	0	2815	3298	-687	10529	0	10529	1723	12252	50.00
4	2973	133	278	3384	2186	2327	0	0	2803	3420	-651	10666	0	10666	1676	12342	50.02
5	3014	138	290	3442	2339	2317	0	0	2890	3594	-650	11042	0	11042	1678	12720	50.04
6	3088	128	293	3509	2153	2321	0	0	3706	4142	-675	11450	0	11450	1787	13237	50.01
7	3024	448	291	3763	2170	2495	0	3	4195	4704	-707	12428	0	12428	1949	14377	49.97
8	3161	466	283	3910	2181	2838	27	31	4643	5138	-720	13405	0	13405	2129	15534	50.00
9	3234	633	282	4149	2291	2877	38	83	4948	5412	-932	13918	0	13918	2552	16470	50.01
10	3252	501	279	4032	2400	2876	42	100	5149	5124	-1059	13515	0	13515	2857	16372	50.00
11	3160	638	288	4086	2393	2878	42	108	4968	5334	-1342	13499	0	13499	3078	16577	50.00
12	3164	607	275	4046	2309	2882	47	148	4867	5008	-1415	13025	0	13025	3117	16142	49.97
13	3184	228	290	3702	2215	2861	107	154	4833	5161	-1473	12727	0	12727	3066	15793	50.00
14	3269	184	286	3739	2251	2815	157	142	4762	4950	-1451	12603	0	12603	2955	15558	50.00
15	3271	319	277	3867	2296	2735	179	154	4677	4983	-1462	12752	0	12752	2951	15703	49.91
16	3298	349	263	3910	2239	2757	186	96	4673	5076	-1474	12790	0	12790	2963	15753	49.92
17	3292	437	277	4006	2303	2774	187	77	4522	5089	-1440	12996	0	12996	2937	15933	49.97
18	3130	350	281	3761	1966	2904	143	36	4373	4707	-1256	12261	0	12261	2895	15156	50.00
19	2930	366	277	3573	1929	2952	133	7	5050	5079	-1040	12633	0	12633	2813	15446	49.93
20	2947	1270	287	4504	1605	2922	133	0	5057	5444	-993	13615	0	13615	2795	16410	49.88
21	2979	1422	281	4682	1666	2930	133	0	4978	5261	-926	13746	0	13746	2735	16481	49.96
22	2961	995	282	4238	1616	2928	176	0	4714	4886	-758	13086	0	13086	2573	15659	49.99
23	2926	861	291	4078	1717	2930	190	0	4217	4558	-808	12665	0	12665	2433	15098	49.96
24	2986	594	281	3861	1632	2916	190	0	3971	4347	-780	12166	0	12166	2311	14477	50.00
MUs	74.23	11.48	6.79	92.50	50.08	65.31	2.11	1.14	103.41	111.85	-24.23	298.77	0.00	298.77	59.75	358.52	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 16/Aug/2016

Position as on 6.30 Hrs of 17/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkhedha Unit 1	210	25/06/2016	23.45		Continued.	Zero Schedule by MSEDCL from 00.00Hrs Dt.19-7-16 and A.O.H from 25/06/2016 to 18/07/2016	
MSPGCL	Khaparkhedha Unit 3	210	05/07/2016	23.52		Continued.	Zero Shedule By MSEDCL, converted for AOH from 00 Hrs Dt.25-7-16	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-2	270	18/06/2016	06.54		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	30/06/2016	10.11		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 5	200	01/07/2016	02.23		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Koradi Unit 7	210	01/07/2016	04.43		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-1	270	01/07/2016	18.40		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 5	500	01/07/2016	23.59		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkhedha Unit 2	210	05/07/2016	23.46		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkhedha Unit 4	210	08/07/2016	03.07		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	08/07/2016	23.57		Continued.	ID Fan Problem (Converted	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Aug/2016

Position as on 6.30 Hrs of 17/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	Adani U-4	660	13/07/2016	02.22		Continued.	to Zero schedule by MSEDCL from 11-07-2016) Zero Shedule By MSEDCL,Shedule Glven On 21/08/2016	
RGPP	Dabhol 2B	230	24/07/2016	17.13	16/08/2016	13.06	Change Over	
MSPGCL	Nasik Unit 5	210	03/08/2016	17.30		Continued.	Zero shedule	
IPP	Adani U-1	660	05/08/2016	11.44		Continued.	Zero Schedule from MSEDCL	
IPP	Adani U-5	660	06/08/2016	23.54		Continued.	Zero schedule given by MSDCL.	
MSPGCL	Paras Unit 3	250	08/08/2016	00.01		Continued.	Zero schedule given by MSDCL.	
MSPGCL	Chandrapur Unit 3	210	09/08/2016	00.08	16/08/2016	07.55	Zero Schedue	
MSPGCL	Chandrapur Unit 9	500	11/08/2016	22.11		Continued.	Oil Shortage.	
MSPGCL	Uran Unit B0	120	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Bhusawal Unit 4	500	14/08/2016	21.28		Continued.	Zero schedule given by MSEDCL	
CPP	WPCL U-4	135	15/08/2016	16.11	16/08/2016	15.50	ID Fan Problem	
RGPP	Dabhol 3A	230	16/08/2016	17.24		Continued.	Change Over	
RGPP	Dabhol 3X	290	16/08/2016	17.56	16/08/2016	23.06	Temperature problem	
RGPP	Dabhol 3B	230	16/08/2016	17.56	16/08/2016	21.56	Temperature problem	
MSPGCL	Koradi Unit-8	660	16/08/2016	18.32	17/08/2016	03.22	ID Fan Problem	
MSPGCL	Koyna Unit 6	75	17/08/2016	16.43	17/08/2016	21.25	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
MSPGCL	Koyna Unit 8	80	17/08/2016	16.43		Continued.	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
MSPGCL	Koyna Unit 7	80	17/08/2016	16.43	17/08/2016	21.45	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
MSPGCL	Koyna Unit 5	80	17/08/2016	16.43	17/08/2016	21.20	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
IPP	JSW (J) U3	300	17/08/2016	16.49	17/08/2016	18.50	Governor Valve Oil Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 17/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	16/08/2016	21.07	16/08/2016	21.56	PO	To attend spark observed on DC Filter Bank
400 KV LINE Outages/Trippings							
Chandrapur Bhadravati II	InterState	03/08/2016	01.59	16/08/2016	16.02	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	14/08/2016	00.42	17/08/2016	07.45	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	15/08/2016	23.57	16/08/2016	06.13	T	Over Voltage
Dhule Khandwa II	InterState	16/08/2016	22.21	17/08/2016	07.15	HT	Over Voltage
Akola Aurangabad(PG) II	InterState	17/08/2016	12.10	17/08/2016	17.19	PO	To attend Tie Breaker
Dhule Khandwa II	InterState	17/08/2016	23.33		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	27/07/2016	13.09		Continued.	HT	Over Voltage
Ektuni-Bableshwar ckt II	IntraState	01/08/2016	09.53		Continued.	HT	To control Padgha-BBLSR L/L
Padghe - Kharghar	IntraState	07/08/2016	17.07		Continued.	PO	Shifted on TBC at kharghar end
karad -kolhapur-I	IntraState	09/08/2016	14.48		Continued.	T	Over Voltage,Opportunity Outage from DT 16.08.2016.
Karad - Jaigad - II	IntraState	13/08/2016	13.02		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	14/08/2016	22.03	16/08/2016	07.13	HT	Over Voltage
N.Koyna-Karad -Ckt II	IntraState	15/08/2016	16.49		Continued.	HT	Over Voltage
karad -kolhapur-II	IntraState	15/08/2016	17.04	16/08/2016	07.26	T	Over Voltage
Aurangabad - Aurangabad(PG) I	IntraState	15/08/2016	18.00	16/08/2016	07.16	T	Over Voltage
Padghe - Nagothane - II	IntraState	16/08/2016	12.14	16/08/2016	16.11	EO	To attend Hot Spot
220 KV LINE Outages/Trippings							
Nasik Navsari II	InterState	16/08/2016	08.30	16/08/2016	15.18	PO	Isolator problem
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Aurangabad (Waluj)-Bhenda	IntraState	22/06/2016	23.02		Continued.	HT	Hand Tripped.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Bableshwar- Alephata	IntraState	24/07/2016	07.57		Continued.	HT	Load Diversion.
Shivajinagar - Malegaon	IntraState	15/08/2016	15.36	16/08/2016	18.41	T	Distance Protection
Khaparkheda-Kanhan	IntraState	16/08/2016	05.24	16/08/2016	16.14	T	Wave Trap Jumper Disconnected
Ghatghar - Bapgaon	IntraState	16/08/2016	07.10	16/08/2016	16.20	T	Distance Protection
Parli 3 (Oldgcr)-Harangul Ckt 2	IntraState	16/08/2016	11.20	16/08/2016	15.32	EO	To attend Hot Spot
Pophali - Pedambe II	IntraState	16/08/2016	13.10	16/08/2016	17.40	PO	Line Maintenance work
Ghatghar - Bapgaon	IntraState	17/08/2016	04.30	17/08/2016	05.15	T	Distance Protection
Padghe - Kamba	IntraState	17/08/2016	05.30	17/08/2016	06.17	T	Distance Protection(Tripped at Kamba end only)
Pandharpur - Malinagar	IntraState	17/08/2016	06.03	17/08/2016	16.44	PO	LILO arrangement on Pandhar-Malinagar line for SVSSK Ltd
Lamboti-Vita	IntraState	17/08/2016	06.03	17/08/2016	16.57	PO	LILO arrangement on Pandhar-Malinagar line for SVSSK Ltd
Ghatghar - Bapgaon	IntraState	17/08/2016	06.30	17/08/2016	20.10	T	Distance Protection
Kandalgaon - Sona Alloys	IntraState	17/08/2016	09.05		Continued.	T	Distance Protection
Ambazari-Amravati	IntraState	17/08/2016	09.54	17/08/2016	14.50	PO	Tan Delta Measurment of CTs
Khaparkheda-Kalmeshwar	IntraState	17/08/2016	10.23	17/08/2016	14.14	PO	Replacement of LA

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 17/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Theur-Jejuri	IntraState	17/08/2016	11.00	17/08/2016	13.57	PO	Line Maintenance work
Pophli Pedhmbe Line- 1	IntraState	17/08/2016	13.20	17/08/2016	18.35	PO	To attend Badly damaged conductor
Jejuri (400 Kv)-Jejuri- li	IntraState	17/08/2016	15.01	17/08/2016	17.38	PO	Line Maintenance work
Eklahare (Gcr) - Ghatghar	IntraState	17/08/2016	16.38	17/08/2016	19.18	PO	To attend problem of Bapgaon-Ghatghar line(on same Tower)
Bus Section II @ Pophali	IntraState	17/08/2016	16.40	17/08/2016	21.15	HT	Main Bus GOD B Phase Conductor Snapped of pedambe - II line
Pophali - Nerale	IntraState	17/08/2016	16.43	17/08/2016	21.35	HT	Main Bus GOD B Phase Conductor Snapped of pedambe - II line
Pophali - New Koyna	IntraState	17/08/2016	16.43	17/08/2016	21.40	HT	Main Bus GOD B Phase Conductor Snapped of pedambe - II line
Pophli Pedhmbe Line- 2	IntraState	17/08/2016	16.43	17/08/2016	21.10	HT	Main Bus GOD B Phase Conductor Snapped of pedambe - II line
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/100 Kv 200 Mva ICT III @Kalwa	IntraState	16/08/2016	05.56	16/08/2016	08.23	EO	To attend Hot Spot
220/132-110kv 100mva Imp Ptr 2 @Wathar	IntraState	16/08/2016	09.30	16/08/2016	17.45	PO	To attend Fire Detector Alarm
220/33 kV 100MVA @ Shivaji Nagar	IntraState	16/08/2016	15.52	16/08/2016	20.55	PO	Repl.of LV Jumper
132 KV LINE Outages/Trippings							
Kaulewada-Gondia-li	IntraState	16/08/2016	08.15	16/08/2016	08.30	T	Distance Protection
Phursungi(220kv)-Kothrud	IntraState	16/08/2016	09.46	16/08/2016	09.51	T	Distance Protection
132KV NIwali - Vikassugar	IntraState	16/08/2016	13.05	16/08/2016	14.58	T	Distance Protection
Mukhed - Ind Bharat	IntraState	16/08/2016	19.13	16/08/2016	19.53	T	Distance Protection
100 KV LINE Outages/Trippings							
Vasai-li - Vasai 2 Line	IntraState	13/08/2016	08.53		Continued.	HT	ICT Problem.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage