

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Aug/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	88.249	1680.125	1) Gujrat	10.184	124.447
2) Hydro	15.865	210.603	2) Madhya Pradesh	8.968	74.064
3) Gas	4.437	80.676	3) Chattisgarh	4.340	45.420
Total MSPGCL	108.551	1971.404	4) Maharashtra	110.640	2268.782
B) 1) APLM	47.517	753.952	5) Goa (Amona)	-2.375	-24.187
2) JSWEL	15.001	224.871	Total	131.757	2488.526
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.786	488.864
4) RPL(AMT)	23.709	314.216	b) Mumbai Drawl	30.642	531.548
5) SWPGPL	3.949	104.191	c) MSEDCL Bilateral *	77.527	1206.986
6) Other IPP	5.749	98.265	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.786	488.651
C) 1) TPCL Thermal	10.186	165.112	Include PX	0.000	0.000
2) TPCL Hydro	7.486	87.576	Standby	0.000	0.214
3) TPCL Gas	0.834	28.497	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.001	150.154	1) MSEDCL	355.608	6047.179
D) STATE			2) Mumbai Discoms	58.149	962.887
1) Thermal	203.361	3490.886	3) Other Discoms	8.741	138.505
(A1+C1+C4+(B1-B6))			TOTAL STATE	422.498	7148.571
2) Hydro (A2+C2)	23.351	298.179			
3) Gas (A3+B7+C3)	5.271	109.173			
4) Wind	51.638	642.410			
6) SOLAR	7.120	119.397			
TOTAL STATE	290.741	4660.045			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	3796	3714	3790	3680
MSPGCL Hydro	857	569	2014	280
MSPGCL Gas	139	136	135	272
MSPGCL Total Generation	4792	4419	5939	4232
Central Sector Receipt	6762	6205	5878	3601
WIND	1987	2220	2288	2036
CPP / IPP Thermal	4586	4261	4570	3095
CPP / IPP Gas	0	0	0	0
SOLAR	701	182	0	0
Exchange with Mumbai	-1707	-1559	-1124	-911
MSEDCL DEMAND MET	16719	15329	17149	11748
Load Shedding	0	0	0	0
MSEDCL DEMAND	16719	15329	17149	11748
TPCL GENERATION	733	818	1112	667
AEML GENERATION	339	353	499	316
MUMBAI DEMAND	2779	2730	2735	1894
OTHER DISCOM DEMAND	402	400	402	305
STATE DEMAND MET	19900	18458	20286	13947
STATE DEMAND	19900	18458	20286	13947
Frequency (Hz)	49.98	50.00	49.80	49.92

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 15:02 Hrs	49.47 Hz at 19:23 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 16/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	1.99	40.23	110	50
Unit 7	0.00	0.00	0	0
Unit 8	8.38	61.54	385	320
Unit 9	0.00	46.51	0	0
Unit 10	9.47	164.89	425	376
Total	19.84	313.17		
Bhusawal				
Unit 3	0.13	7.23	50	0
Unit 4	8.29	129.20	435	285
Unit 5	0.00	55.81	0	0
Total	8.42	192.24		
Parli				
Unit 6	4.08	64.71	193	148
Unit 7	3.98	56.12	184	148
Unit 8	3.76	58.83	184	139
Total	11.83	179.66		
Chandrapur				
Unit 3	0.00	32.41	0	0
Unit 4	0.00	12.42	0	0
Unit 5	4.69	82.45	220	150
Unit 6	4.37	76.62	220	145
Unit 7	5.47	15.26	254	205
Unit 8	7.68	142.53	369	285
Unit 9	7.91	146.30	382	283
Total	30.13	507.99		
Paras				
Unit 3	0.00	52.79	0	0
Unit 4	2.63	57.87	137	91
Total	2.63	110.66		
Khaparkheda				
Unit 1	0.20	37.40	60	0
Unit 2	0.80	40.43	80	0
Unit 3	1.84	53.71	130	0
Unit 4	0.00	35.99	0	0
Unit 5	6.99	114.19	380	270
Total	9.84	281.72		
Nasik				
Unit 3	2.94	48.08	144	75
Unit 4	0.00	0.00	0	0
Unit 5	2.63	46.62	140	25
Total	5.56	94.70		
Uran				
All Units	4.44	80.68	272	133
Total	4.44	80.68		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.59	9.56	27	23
Total	0.59	9.56		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.68	40.98	485	35
Stage 4	2.06	29.18	744	0
Stage 3	1.86	24.53	240	0
Total	7.60	94.69		
Hydro				
KDPH	0.86	4.64	36	36
VTRNA	0.97	9.18	61	0
TILLARI	0.70	8.38	58	0
BHIRA T.R.	0.52	7.30	80	0
SMLHY_PTN	4.28	74.07	190	169
GHATGHAR	0.34	2.79	125	0
Total	7.67	106.35		
Wind				
Total	51.64	642.41	0	0
Total	51.64	642.41		
CPP				
APML(Mus)	47.52	753.95	0	0
JSWEL(Mus)	15.00	224.87	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	23.71	314.22	0	0
SWPGPL-Mus	3.95	104.19	0	0
Other(Mus)	5.75	98.26	0	0
Total	95.92	1495.50		
SOLAR				
Total	7.12	119.40	0	0
Total	7.12	119.40		
Tata				
Trombay 5	6.84	110.03	448	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.73	16.90	115	0
Trombay 7B	0.10	11.59	66	0
TATA Hydro	7.49	87.58	443	217
Trombay 8	3.35	55.09	214	131
Total	18.51	281.18		
AEMIL				
DTPS U-1&2	9.00	150.15	501	286
Total	9.00	150.15		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	88.25	1680.12	MSPGCL Total	108.55	1971.40
			MSPGCL Thml+Gas	92.69	1760.80	Koyna 1,2 & 4 Total	5.74	70.16
			MSPGCL Hydro	15.86	210.60	State Total	290.74	4660.04

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 16/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	3631	270	262	4163	2246	3442	0	0	3649	3516	-958	12081	0	12081	2011	329	14420	50.03
2	3680	280	272	4232	2036	3095	0	0	3487	3601	-911	11748	0	11748	1894	305	13947	49.92
3	3672	287	272	4231	2180	3309	0	0	3496	3455	-851	12036	0	12036	1809	288	14133	49.92
4	3619	309	262	4190	1975	3372	0	0	3704	3987	-841	12400	0	12400	1756	283	14439	50.02
5	3672	283	272	4227	1910	3590	0	0	4074	4214	-844	12801	0	12801	1765	295	14862	50.04
6	3945	303	272	4520	2040	4063	0	5	4352	4352	-842	13812	0	13812	1857	325	15995	50.06
7	3943	342	269	4554	2009	4604	0	35	5062	5184	-931	15104	0	15104	1949	351	17404	49.99
8	3859	919	259	5037	2059	4565	0	207	5221	5506	-1141	15857	0	15857	2153	377	18386	49.99
9	3791	982	245	5018	2021	4546	0	440	6018	6412	-1430	16609	0	16609	2479	397	19486	50.03
10	3796	857	139	4792	1987	4586	0	701	6713	6762	-1707	16719	0	16719	2779	402	19900	49.98
11	3685	526	137	4348	1959	4356	0	839	7116	6852	-1805	16150	0	16150	2943	399	19492	50.05
12	3397	504	138	4039	2006	3712	0	934	7266	7346	-1874	15773	0	15773	2956	390	19119	49.99
13	3483	592	138	4213	2079	3600	0	987	6466	6387	-1836	15052	0	15052	2926	378	18356	49.92
14	3484	467	138	4089	2080	3498	0	894	6340	6145	-1703	14626	0	14626	2776	376	17779	49.97
15	3410	411	137	3958	2565	3437	0	870	6393	6174	-1705	14922	0	14922	2746	377	18045	50.05
16	3355	436	136	3927	2674	3458	0	618	6430	6137	-1715	14712	0	14712	2756	386	17855	50.00
17	3508	633	133	4274	2498	3594	0	384	6294	6438	-1678	15120	0	15120	2735	390	18245	49.84
18	3714	569	136	4419	2220	4261	0	182	6139	6205	-1559	15329	0	15329	2730	400	18458	50.00
19	3729	950	135	4814	2285	4585	0	24	6504	6123	-1412	16008	0	16008	2720	411	19139	49.96
20	3790	2014	135	5939	2288	4570	0	0	5571	5878	-1124	17149	0	17149	2735	402	20286	49.80
21	3805	1809	137	5751	2352	4611	0	0	5281	5233	-972	16590	0	16590	2638	385	19613	50.01
22	3789	1218	138	5145	2201	4561	0	0	5029	5118	-995	15649	0	15649	2475	381	18505	50.03
23	3775	492	137	4404	2049	4522	0	0	5575	5313	-958	14965	0	14965	2339	365	17669	50.04
24	3717	412	138	4267	1919	3987	0	0	5259	5419	-850	14395	0	14395	2222	347	16964	50.04
MUs	88.25	15.86	4.44	108.55	51.64	95.92	0.00	7.12	131.44	131.76	-30.64	355.61	0.00	355.61	58.15	8.74	422.50	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 16/Aug/2022

Position as on 6.30 Hrs of 17/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
IPP	Adani U-3	660	27/07/2022	00:05		Continued.	Annual Overhaul	19/08/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Koyna STG-IV Unit-4	250	13/08/2022	10:06		Continued.	Commissioning and installation of new TSLG Governor	21/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	24/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 4	210	09/08/2022	20:25		Continued.	FURNACE DRAFT VERY HIGH	18/08/2022
TPC-G	Trombay 7B	60	10/08/2022	22:50	16/08/2022	21:55	zero Schedule.	17/08/2022
TPC-G	Trombay 7A	120	10/08/2022	23:15	16/08/2022	17:00	Zero Schedule.	17/08/2022
MSPGCL	Khaparkheda Unit 4	210	10/08/2022	23:58		Continued.	UNIT IS READY FROM 13.08.2022 (DALAY TO LIGHT UP DUE TO WET	18/08/2022

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Aug/2022

Position as on 6.30 Hrs of 17/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							COAL).	
MSPGCL	Uran Unit A0	120	14/08/2022	09:24		Continued.	Gas shortage	
MSPGCL	Uran Unit B0	120	14/08/2022	09:24	16/08/2022	08:50	Gas shortage	
MSPGCL	Paras Unit 3	250	15/08/2022	08:50	17/08/2022	01:32	CHP coal feeding problem	16/08/2022
MSPGCL	Chandrapur Unit 3	210	15/08/2022	12:50		Continued.	Poor Coal Receipt	18/08/2022
MSPGCL	Uran Unit 5	108	15/08/2022	19:41		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	16/08/2022	03:44		Continued.	Wet coal problem.	20/08/2022
MSPGCL	Khaparkheda Unit 1	210	16/08/2022	04:28		Continued.	DUE TO WET STEAM PROTECTION	
MSPGCL	Khaparkheda Unit 3	210	16/08/2022	08:09	16/08/2022	15:01	Furnace Pressure High	
MSPGCL	Uran Unit 6	108	16/08/2022	08:30		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 2	210	16/08/2022	15:09		Continued.	Flame Failure	19/08/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 17/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Trippings							
Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	16/08/2022	15:11			HT	This breaker put in lock out at 15:06hrs dt.15.08.2022 and this filter is under breakdown and expert service are required for
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	17/08/2022	01:19	17/08/2022	05:14	EO	For attending water leakages in B phase thyristor valve inside Pole 1 Valve hall.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	05/08/2022	00:06			HT	For load management
KHADKA-AURANGABAD (WALUJ)	IntraState	12/08/2022	20:36			HT	HT due to overvoltage
JAIGAD - KARAD CKT - 2	IntraState	15/08/2022	01:25	17/08/2022	10:50	HT	H/T to Control Over Voltages.
PADGHE - NAGOTHANE CKT - 2	IntraState	15/08/2022	01:32	16/08/2022	11:39	HT	H/T to Control Over Voltages.
LONIKAND I - KOYNA STAGE-IV	IntraState	16/08/2022	00:17	16/08/2022	07:15	HT	HAND TRIPPED TO CONTROL OVER VOLTAGE.
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	16/08/2022	08:33	16/08/2022	23:07	PO	Retrofitting of Main-I & Main-2 line differential relay work
WARORA - WARORA (PG)	IntraState	16/08/2022	15:29	16/08/2022	19:11	HT	Emergency outage availed for attending hot spot near Line side Isolator (412-89L- B phase) Jumper
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	17/08/2022	08:21			PO	Retrofitting of Main-I & Main-2 line differential relay work
KORADI-NANDGAONPETH (RPL)	IntraState	17/08/2022	09:40	17/08/2022	16:12	PO	400KV RPL line Reactor DFRA testing work
TBC @ KHADKA	IntraState	17/08/2022	10:45			PO	FOR MTAMC WORK.
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	IntraState	16/08/2022	04:55	16/08/2022	09:05	PO	Outage Requirement for TMS Installation under MTAMC project
400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	IntraState	17/08/2022	10:33			PO	Tan Delta & Capacitance of Line CTs, Main CTs & IR values of LA
220 KV TBC Outages/Trippings							
BUS SECTIONALIZER @ TAMBATI	IntraState	16/08/2022	12:23	16/08/2022	14:23	EO	Heavy sparking observed at R phase CB pole bottom palm and Red hot spots attending work
220 KV LINE Outages/Trippings							
SONKHAR - TROMBAY	IntraState	16/08/2022	00:24	16/08/2022	14:38	T	Tripped on distance protection.
PADGHE - JINDAL	IntraState	16/08/2022	02:05	16/08/2022	03:57	T	TRIPPED DUE TO BREAKER PROBLEM AT JINDAL END.
URAN - APTA 3	IntraState	16/08/2022	0939	16/08/2022	18:23	PO	For MAIN BUS insulator and stub Bus insulator string replacement work.
URAN - KHARGHAR 1	IntraState	16/08/2022	09:26	16/08/2022	18:50	PO	1) For MAIN BUS insulator and stub Bus insulator string replacement work.
GOREGAON - AAREY CKT - 2	IntraState	16/08/2022	09:45	16/08/2022	20:20	PO	Under MMRC Line Diversion scheme for Metro-3 project 220kv conductor removal from Tower no. VA-38 to Aarey Gantry

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 17/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
INFOSYS - HINJAWADI 1	IntraState	16/08/2022	10:37	16/08/2022	18:57	PO	A) Tower Erection - 72MT MCTT Tower Main Body Erection B) Erection of one side Cross Arm (Road Side) C) Tower Tightneing
TALANDAGE - FIVE STAR MIDC 2	IntraState	16/08/2022	11:35	16/08/2022	13:42	EO	The Distance Relay ABB REL 670 have display problem. Relay need to be tested
MHAISAL - ALKUD	IntraState	16/08/2022	14:25	16/08/2022	18:12	PO	PID testing work
BHUGAON - WARDHA (PG)	IntraState	16/08/2022	19:18	16/08/2022	20:15	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
WALUJ - CHITEGAON II	IntraState	16/08/2022	19:26	16/08/2022	20:11	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
OSMANABAD - PARLY (PG)	IntraState	16/08/2022	19:32	16/08/2022	20:08	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	16/08/2022	22:05	16/08/2022	22:45	T	TRIPPED ON DISTANCE PROTECTION
INFOSYS - HINJAWADI 1	IntraState	17/08/2022	07:43			PO	A) Tower Erection - 72MT MCTT Tower Main Body Erection B) Erection of one side Cross Arm (Road Side) C) Tower Tightneing
AEML BORIVALI -MSETCL BORIVALI CKT -1	IntraState	17/08/2022	09:39	17/08/2022	16:33	PO	Annual maintenance of Bay equipments.
MHAISAL - ALKUD	IntraState	17/08/2022	09:55			PO	PID testing work
BORIVALI - TARAPUR	IntraState	17/08/2022	12:27	17/08/2022	12:47	T	A/R successful at Borvali end . Tripped at Tarapur end
TBC @ SOUTH SOLAPUR	IntraState	17/08/2022	13:12	17/08/2022	14:06	PO	Outage is required for Quarterly Maintenance
OSMANABAD - BARSHI	IntraState	17/08/2022	14:25	17/08/2022	16:54	PO	Quarterly Maintenance and CB CRM & Timing test
MAHALAXMI - AMONA	IntraState	17/08/2022	15:43	17/08/2022	17:07	T	Tripped on Distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220kV GT UNIT-6 @ URAN-220 KV	IntraState	16/08/2022	10:26			PO	1) For GT6 bay decapped hanging Tension string replacement work (it is hanging on BUS-2)
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	16/08/2022	10:26	16/08/2022	19:45	PO	1) For MAIN BUS insulator and stub Bus insulator string replacement work & GT6 bay decapped hanging Tension string replacement work
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 17/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage