

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 16/Aug/2024 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 149.380        | 2031.971        | 1) Gujrat                      | 13.851         | 149.114         |
| 2) Hydro            | 15.750         | 216.657         | 2) Madhya Pradesh              | 5.180          | 64.702          |
| 3) Gas              | 7.128          | 104.335         | 3) Chattisgarh                 | 2.260          | 35.240          |
| <b>Total MSPGCL</b> | <b>172.258</b> | <b>2352.963</b> | 4) Maharashtra                 | 165.401        | 2533.932        |
| B) 1) APLM          | 68.555         | 868.632         | 5) Goa (Amona)                 | -1.959         | -30.679         |
| 2) JSWEL            | 26.420         | 343.224         | <b>Total</b>                   | <b>184.733</b> | <b>2752.309</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 36.826         | 576.932         |
| 4) RPL(AMT)         | 12.727         | 259.797         | b) Mumbai Drawl                | 39.032         | 645.198         |
| 5) SWPGPL           | 9.285          | 141.851         | c) MSEDCL Bilateral *          | 52.636         | 1210.905        |
| 6) Other IPP        | 4.256          | 142.518         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 36.826         | 576.881         |
| C) 1) TPCL Thermal  | 12.667         | 156.715         | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 7.314          | 101.566         | Standby                        | 0.000          | 0.052           |
| 3) TPCL Gas         | 4.140          | 57.257          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.124          | 120.180         | 1) MSEDCL                      | 448.646        | 6772.361        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 72.277         | 1080.916        |
| 1) Thermal          | 292.414        | 4064.888        | 3) Other Discoms               | 11.323         | 180.042         |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>532.246</b> | <b>8033.319</b> |
| 2) Hydro            | 23.064         | 318.223         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.268         | 161.592         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 6.194          | 508.265         |                                |                |                 |
| 6) SOLAR            | 14.573         | 228.042         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>347.513</b> | <b>5281.010</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6566                      | 6486                  | 6277                      | 5890                      |
| MSPGCL Hydro               | 514                       | 377                   | 2005                      | 180                       |
| MSPGCL Gas                 | 279                       | 274                   | 368                       | 281                       |
| MSPGCL Total Generation    | 7359                      | 7137                  | 8650                      | 6351                      |
| Central Sector Receipt     | 8218                      | 8064                  | 8299                      | 5858                      |
| WIND                       | 151                       | 181                   | 232                       | 267                       |
| CPP / IPP Thermal          | 4812                      | 4726                  | 5400                      | 4922                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2022                      | 2239                  | 0                         | 0                         |
| Exchange with Mumbai       | -2027                     | -2094                 | -1555                     | -1211                     |
| <b>MSEDCL DEMAND MET</b>   | <b>20029</b>              | <b>19742</b>          | <b>20504</b>              | <b>15821</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 20029                     | 19742                 | 20504                     | 15821                     |
| TPCL GENERATION            | 1126                      | 1021                  | 1259                      | 786                       |
| AEML GENERATION            | 483                       | 473                   | 473                       | 315                       |
| <b>MUMBAI DEMAND</b>       | <b>3636</b>               | <b>3588</b>           | <b>3287</b>               | <b>2312</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>506</b>                | <b>511</b>            | <b>522</b>                | <b>366</b>                |
| STATE DEMAND MET           | 24171                     | 23841                 | 24313                     | 18499                     |
| <b>STATE DEMAND</b>        | <b>24171</b>              | <b>23841</b>          | <b>24313</b>              | <b>18499</b>              |
| Frequency (Hz)             | 50.01                     | 49.94                 | 49.99                     | 49.93                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.13 Hz at 16.01 Hrs | 49.83 Hz at 19.12 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 16/Aug/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.60         | 42.73         | 168      | 117      |
| Unit 8             | 11.85        | 172.83        | 528      | 457      |
| Unit 9             | 11.92        | 171.21        | 523      | 477      |
| Unit 10            | 11.51        | 169.34        | 508      | 461      |
| <b>Total</b>       | <b>38.88</b> | <b>556.11</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.57         | 40.54         | 165      | 130      |
| Unit 4             | 9.46         | 120.03        | 490      | 285      |
| Unit 5             | 9.43         | 121.50        | 480      | 285      |
| <b>Total</b>       | <b>22.46</b> | <b>282.07</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 10.63         | 0        | 0        |
| Unit 7             | 3.68         | 60.09         | 202      | 97       |
| Unit 8             | 0.00         | 47.21         | 0        | 0        |
| <b>Total</b>       | <b>3.68</b>  | <b>117.93</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 34.34         | 0        | 0        |
| Unit 4             | 2.64         | 34.88         | 116      | 106      |
| Unit 5             | 8.10         | 111.36        | 375      | 295      |
| Unit 6             | 6.74         | 101.01        | 308      | 250      |
| Unit 7             | 7.76         | 99.59         | 372      | 286      |
| Unit 8             | 9.88         | 36.55         | 475      | 369      |
| Unit 9             | 9.89         | 137.22        | 450      | 348      |
| <b>Total</b>       | <b>45.00</b> | <b>554.96</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.38         | 26.29         | 245      | 203      |
| Unit 4             | 5.39         | 62.76         | 234      | 212      |
| <b>Total</b>       | <b>10.78</b> | <b>89.05</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 0.00         | 30.09         | 0        | 0        |
| Unit 2             | 3.56         | 51.94         | 164      | 129      |
| Unit 3             | 3.54         | 53.38         | 155      | 134      |
| Unit 4             | 3.99         | 56.93         | 188      | 143      |
| Unit 5             | 8.59         | 145.03        | 425      | 270      |
| <b>Total</b>       | <b>19.68</b> | <b>337.37</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.17         | 15.90         | 163      | 112      |
| Unit 4             | 3.06         | 45.07         | 143      | 85       |
| Unit 5             | 2.67         | 33.51         | 127      | 58       |
| <b>Total</b>       | <b>8.89</b>  | <b>94.48</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.13         | 104.34        | 371      | 270      |
| <b>Total</b>       | <b>7.13</b>  | <b>104.34</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 1.05         | 17.81         | 45       | 43       |
| <b>Total</b>       | <b>1.05</b>  | <b>17.81</b>  |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 3.84         | 45.43         | 540      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 5.09          | 59.25          | 939      | 0        |
| Stage 3         | 2.01          | 27.29          | 320      | 0        |
| <b>Total</b>    | <b>10.94</b>  | <b>131.97</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 6.37           | 0        | 0        |
| VTRNA           | 0.00          | 1.62           | 0        | 0        |
| TILLARI         | 0.58          | 9.65           | 60       | 0        |
| BHIRA T.R.      | 0.32          | 5.34           | 40       | 0        |
| SMLHY_PTN       | 3.28          | 55.67          | 147      | 130      |
| GHATGHAR        | 0.62          | 6.04           | 125      | 0        |
| <b>Total</b>    | <b>4.81</b>   | <b>84.68</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 6.19          | 508.26         | 0        | 0        |
| <b>Total</b>    | <b>6.19</b>   | <b>508.26</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 68.56         | 868.63         | 0        | 0        |
| JSWEL(Mus)      | 26.42         | 343.22         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 12.73         | 259.80         | 0        | 0        |
| SWPGPL-Mus      | 9.28          | 141.85         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 0.00          | 55.19          | 0        | 0        |
| Other(Mus)      | 1.25          | 19.90          | 0        | 0        |
| JPL             | 3.01          | 67.44          | 135      | 119      |
| <b>Total</b>    | <b>121.24</b> | <b>1756.02</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 14.57         | 228.04         | 0        | 0        |
| <b>Total</b>    | <b>14.57</b>  | <b>228.04</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 8.36          | 92.10          | 454      | 260      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.59          | 34.76          | 108      | 106      |
| Trombay 7B      | 1.55          | 22.50          | 65       | 64       |
| TATA Hydro      | 7.31          | 101.57         | 410      | 181      |
| Trombay 8       | 4.31          | 64.62          | 232      | 130      |
| <b>Total</b>    | <b>24.12</b>  | <b>315.54</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 9.12          | 120.18         | 490      | 299      |
| <b>Total</b>    | <b>9.12</b>   | <b>120.18</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 149.38      | 2031.97       | MSPGCL Total        | 172.26      | 2352.96       |
|                |             |         | MSPGCL Thml+Gas | 156.51      | 2136.31       | Koyna 1,2 & 4 Total | 8.93        | 104.68        |
|                |             |         | MSPGCL Hydro    | 15.75       | 216.66        | State Total         | 347.51      | 5281.01       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 16/Aug/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |      | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 6157        | 175   | 281  | 6613   | 201  | 4688      | 0    | 0     | 6542        | 6345        | -1391                | 16046                  | 0                | 0                           | 16046                         | 2669             | 410                       | 19125           | 50.03         |
| 2                  | 5988        | 181   | 281  | 6450   | 262  | 4874      | 0    | 0     | 6462        | 6123        | -1254                | 16061                  | 0                | 0                           | 16061                         | 2462             | 394                       | 18917           | 50.00         |
| 3                  | 5890        | 180   | 281  | 6351   | 267  | 4922      | 0    | 0     | 6558        | 5858        | -1211                | 15821                  | 0                | 0                           | 15821                         | 2312             | 366                       | 18499           | 49.93         |
| 4                  | 5913        | 179   | 282  | 6374   | 239  | 5009      | 0    | 0     | 6518        | 5869        | -1167                | 15942                  | 0                | 0                           | 15942                         | 2219             | 382                       | 18543           | 49.97         |
| 5                  | 5973        | 179   | 282  | 6434   | 240  | 5025      | 0    | 0     | 7085        | 6206        | -1116                | 16398                  | 0                | 0                           | 16398                         | 2186             | 391                       | 18975           | 50.02         |
| 6                  | 5966        | 175   | 283  | 6424   | 236  | 4707      | 0    | 0     | 7915        | 7759        | -1138                | 17570                  | 0                | 0                           | 17570                         | 2278             | 418                       | 20266           | 50.04         |
| 7                  | 6066        | 870   | 281  | 7217   | 206  | 5262      | 0    | 86    | 8023        | 7777        | -1263                | 18824                  | 0                | 9                           | 18824                         | 2433             | 461                       | 21718           | 50.01         |
| 8                  | 6199        | 1074  | 283  | 7556   | 200  | 5319      | 0    | 501   | 8175        | 7930        | -1512                | 19504                  | 0                | 10                          | 19504                         | 2645             | 490                       | 22639           | 50.02         |
| 9                  | 6539        | 404   | 286  | 7229   | 207  | 5118      | 0    | 974   | 8444        | 8265        | -1770                | 19528                  | 0                | 6                           | 19528                         | 2976             | 495                       | 22999           | 49.93         |
| 10                 | 6604        | 526   | 285  | 7415   | 232  | 4893      | 0    | 1451  | 8661        | 8609        | -2018                | 20072                  | 0                | 11                          | 20072                         | 3305             | 510                       | 23887           | 50.00         |
| 11                 | 6521        | 816   | 278  | 7615   | 207  | 4662      | 0    | 1765  | 8508        | 8494        | -2242                | 19997                  | 0                | 15                          | 19997                         | 3551             | 504                       | 24052           | 50.02         |
| 12                 | 6566        | 514   | 279  | 7359   | 151  | 4812      | 0    | 2022  | 8551        | 8218        | -2027                | 20029                  | 0                | 13                          | 20029                         | 3636             | 506                       | 24171           | 50.01         |
| 13                 | 6486        | 377   | 274  | 7137   | 181  | 4726      | 0    | 2239  | 8214        | 8064        | -2094                | 19742                  | 0                | 11                          | 19742                         | 3588             | 511                       | 23841           | 49.94         |
| 14                 | 6335        | 250   | 278  | 6863   | 210  | 4436      | 0    | 1957  | 8137        | 8130        | -1970                | 19136                  | 0                | 14                          | 19136                         | 3460             | 490                       | 23086           | 50.02         |
| 15                 | 6233        | 180   | 274  | 6687   | 287  | 4785      | 0    | 1543  | 8469        | 8353        | -1999                | 19156                  | 0                | 17                          | 19156                         | 3506             | 500                       | 23162           | 50.03         |
| 16                 | 6244        | 237   | 270  | 6751   | 468  | 5112      | 0    | 1082  | 8351        | 8660        | -1849                | 19711                  | 0                | 6                           | 19711                         | 3547             | 513                       | 23771           | 50.05         |
| 17                 | 6267        | 383   | 274  | 6924   | 543  | 5044      | 0    | 644   | 8718        | 8743        | -2081                | 19303                  | 0                | 0                           | 19303                         | 3476             | 514                       | 23293           | 50.01         |
| 18                 | 6239        | 788   | 350  | 7377   | 498  | 5265      | 0    | 260   | 8320        | 8253        | -2110                | 19028                  | 0                | 0                           | 19028                         | 3389             | 515                       | 22932           | 50.01         |
| 19                 | 6305        | 1683  | 371  | 8359   | 283  | 5336      | 0    | 49    | 8266        | 8138        | -1900                | 19737                  | 0                | 0                           | 19737                         | 3293             | 528                       | 23558           | 50.03         |
| 20                 | 6277        | 2005  | 368  | 8650   | 232  | 5400      | 0    | 0     | 8432        | 8299        | -1555                | 20504                  | 0                | 0                           | 20504                         | 3287             | 522                       | 24313           | 49.99         |
| 21                 | 6267        | 1323  | 369  | 7959   | 228  | 5454      | 0    | 0     | 8247        | 8311        | -1429                | 20026                  | 0                | 0                           | 20026                         | 3150             | 497                       | 23673           | 50.05         |
| 22                 | 6286        | 948   | 356  | 7590   | 202  | 5455      | 0    | 0     | 7517        | 7762        | -1320                | 19210                  | 0                | 0                           | 19210                         | 3025             | 479                       | 22714           | 50.04         |
| 23                 | 6084        | 1208  | 281  | 7573   | 205  | 5468      | 0    | 0     | 7171        | 7530        | -1340                | 18964                  | 0                | 0                           | 18964                         | 2955             | 472                       | 22391           | 50.04         |
| 24                 | 5975        | 1095  | 281  | 7351   | 209  | 5471      | 0    | 0     | 7105        | 7037        | -1276                | 18338                  | 0                | 0                           | 18338                         | 2929             | 454                       | 21721           | 50.03         |
| MUs                | 149.38      | 15.75 | 7.13 | 172.26 | 6.19 | 121.24    | 0.00 | 14.57 | 188.39      | 184.73      | -39.03               | 448.65                 | 0.00             | 0.11                        | 448.65                        | 72.28            | 11.32                     | 532.25          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

132kv BBLR to Rahuri line over load.

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 16/Aug/2024

Position as on 6.30 Hrs of 17/Aug/2024

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Parli Unit 6            | 250      | 04/08/2024   | 00:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 25/08/2024    |
| MSPGCL                        | Chandrapur Unit 3       | 210      | 15/08/2024   | 17:45        |            | Continued. | Converted into AOH at 12:42 hrs dt.17.08.2024.                                                                                                          | 09/09/2024    |
| Total Capacity MSPGCL         |                         | 460      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | RPL(AMT) U-1            | 270      | 01/07/2024   | 07:00        | 16/08/2024 | 18:54      | Annual Overhaul                                                                                                                                         | 17/08/2024    |
| IPP                           | SWPGPL U-2              | 135      | 01/08/2024   | 01:50        |            | Continued. | Annual Overhaul                                                                                                                                         | 25/08/2024    |
| IPP                           | IEPL Unit 1             | 270      | 11/08/2024   | 23:56        |            | Continued. | Annual Overhaul                                                                                                                                         | 21/08/2024    |
| IPP                           | JPL Unit 1              | 150      | 15/08/2024   | 02:10        |            | Continued. | Annual Overhaul                                                                                                                                         | 30/08/2024    |
| Total Capacity IPP            |                         | 825      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE |                         | 1285     |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/08/2024    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 26/08/2024    |
| MSPGCL                        | Khaparkheda Unit 1      | 210      | 13/08/2024   | 00:04        |            | Continued. | Due to Boiler Drum heavy steam leakage,generator seal oil leakage.                                                                                      | 20/08/2024    |
| MSPGCL                        | Parli Unit 8            | 250      | 13/08/2024   | 12:10        |            | Continued. | All DCS supply fail.                                                                                                                                    | 19/08/2024    |
| MSPGCL                        | Nasik Unit 5            | 210      | 15/08/2024   | 18:42        | 16/08/2024 | 00:04      | Furnace Pressure High                                                                                                                                   |               |
| MSPGCL                        | Koyna Unit 2            | 70       | 17/08/2024   | 09:00        |            | Continued. | Due to water ingress in Turbine Guide Bearing.                                                                                                          |               |
| MSPGCL                        | Chandrapur Unit 5       | 500      | 17/08/2024   | 17:04        |            | Continued. | CHP BUNKERING PROBLEM.                                                                                                                                  | 19/08/2024    |
| Total Capacity MSPGCL         |                         | 1485     |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                                                                  | 31/08/2024    |
| IPP                           | RPL(AMT) U-4            | 270      | 15/08/2024   | 13:24        |            | Continued. | Bottom ash evacuation problem                                                                                                                           | 18/08/2024    |
| Total Capacity IPP            |                         | 540      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 30/12/2024    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/11/2024    |
| Total Capacity CENT.SECTOR    |                         | 320      |              |              |            |            |                                                                                                                                                         |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 16/Aug/2024**

**Position as on 6.30 Hrs of 17/Aug/2024**

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                        | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------|---------------|
| Total Capacity FORCED OUTAGE                  |                         | 2345     |              |              |            |            |                                         |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |            |            |                                         |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                         |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 31/07/2024   | 17:38        |            | Continued. | Zero Schedule given by MSEDCL           |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 15/08/2024   | 07:59        | 16/08/2024 | 16:55      | Zero Schedule given by MSEDCL           |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 16/08/2024   | 21:58        | 17/08/2024 | 05:02      | Zero Schedule given BY MSEDCL           |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 17/08/2024   | 08:29        | 17/08/2024 | 16:55      | Zero Schedule given BY MSEDCL           |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 17/08/2024   | 22:00        |            | Continued. | Zero Schedule given BY MSEDCL           |               |
| Total Capacity MSPGCL                         |                         | 540      |              |              |            |            |                                         |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 540      |              |              |            |            |                                         |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |            |            |                                         |               |
| IPP                                           |                         |          |              |              |            |            |                                         |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                    |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                    |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019) |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)  |               |
| Total Capacity IPP                            |                         | 988      |              |              |            |            |                                         |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |            |            |                                         |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/Aug/2024**

**Statement-VII**

Position as on 6.30 Hrs of 17/Aug/2024

| Name of Line                                        | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                 |
|-----------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV TIEBAY Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| TIE BAY (405) OF PARLI CKT - 1 AND ICT - 2 @ KARJAT | IntraState                | 17/08/2024   | 18:04        |            | Continued. | PO          | All Isolator Alignment work to be done by agency (404-89B, 405-89A, 404-89L). Diagnostic testing, Relay Testing and Maintenance work.                                                                                                                                            |
| <b>400 KV MAINBAY Outages/Trippings</b>             |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| MAIN BAY (404) OF PARLI CKT -1 @ KARJAT             | IntraState                | 17/08/2024   | 18:04        |            | Continued. | PO          | All Isolator Alignment work to be done by agency (404-89B, 405-89A, 404-89L). Diagnostic testing, Relay Testing and Maintenance work.                                                                                                                                            |
| <b>400 KV LINE Outages/Trippings</b>                |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| BUS REACTOR (50MVAR) @ PARLI                        | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.                                                                                                                                                                                                              |
| CHANDRAPUR GCR - CHANDRAPUR HVDC - 2                | IntraState                | 12/08/2024   | 15:30        | 16/08/2024 | 20:55      | EO          | To rectify/attend earth leakage and SF6 gas leakage problem.                                                                                                                                                                                                                     |
| KHADKA-AURANGABAD (WALUJ)                           | IntraState                | 14/08/2024   | 22:33        | 16/08/2024 | 08:43      | HT          | HT for Overvoltage                                                                                                                                                                                                                                                               |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2                 | IntraState                | 14/08/2024   | 23:06        |            |            | HT          | HT for Load Management                                                                                                                                                                                                                                                           |
| JAIGAD - KARAD CKT - 1                              | IntraState                | 16/08/2024   | 00:01        | 16/08/2024 | 08:49      | HT          | HT for Overvoltage                                                                                                                                                                                                                                                               |
| KHADKA-AURANGABAD (WALUJ)                           | IntraState                | 17/08/2024   | 22:10        |            | Continued. | HT          | overvoltage                                                                                                                                                                                                                                                                      |
| <b>400 KV ICT Outages/Trippings</b>                 |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| STATION TF No 3 @ CHANDRAPUR GCR                    | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                                                                   |
| 400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS            | IntraState                | 10/02/2024   | 17:40        |            |            | HT          | H/T For LV only.                                                                                                                                                                                                                                                                 |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA                 | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                                                                          |
| 400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR            | IntraState                | 16/08/2024   | 12:42        | 16/08/2024 | 14:02      | EO          | ICT-1 Main Bay R phase C.B. pole SF6 Gas Pressure Low (below 0.8 bar) alarm indication appeared on SCADA hence for refilling the SF6 Gas in the R-phase is required.                                                                                                             |
| 400/220/33 KV 500MVA ICT - 2 @ KORADI 2             | IntraState                | 16/08/2024   | 13:01        | 16/08/2024 | 16:48      | T           | Tripped on LBB protection.                                                                                                                                                                                                                                                       |
| 400/220/33 KV 500 MVA ICT - 3 @ DHULE               | IntraState                | 17/08/2024   | 15:25        | 17/08/2024 | 16:16      | HT          | HT since heaving sparking on R pg PG isolator 89 B                                                                                                                                                                                                                               |
| <b>220 KV TBC Outages/Trippings</b>                 |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| TBC BAY @ TALOJA                                    | IntraState                | 16/08/2024   | 10:45        | 17/08/2024 | 12:00      | PO          | For attending Bus side isolator closing problem.                                                                                                                                                                                                                                 |
| BUS COUPLER @ STT-GIS                               | IntraState                | 17/08/2024   | 10:43        | 17/08/2024 | 12:49      | T           | Tripped during AC supply switchover                                                                                                                                                                                                                                              |
| <b>220 KV MAINBAY Outages/Trippings</b>             |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| 220KV BUS SECTION BAY @ PEDAMBE                     | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                     |
| <b>220 KV LINE Outages/Trippings</b>                |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| BALE - SOLAPUR (PG)                                 | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37) |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/Aug/2024**

**Statement-VII**

Position as on 6.30 Hrs of 17/Aug/2024

| Name of Line                          | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
|---------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| OSMANABAD - SOLAPUR (BALE)            | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2 | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| GHODBUNDER - GORAI                    | IntraState                | 29/07/2024   | 12:14        |            |            | PO          | Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| EKLAHARE (OCR) - PADGHE               | IntraState                | 05/08/2024   | 08:21        |            | Continued. | HT          | for load management                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| KARAD - VITA CKT- 1                   | IntraState                | 12/08/2024   | 09:16        | 16/08/2024 | 17:26      | PO          | For Distance Relay Retrofitting work and Relay Rewiring work at Karad end.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| PADGHE - NALASOPARA - VASAI (T)       | IntraState                | 15/08/2024   | 11:23        |            |            | PO          | For NHSRCL diversion of 220kV Padgha-Nalasopara-Vasai Tap Line & 220kV Kamba-Vasai Lione between Loc no. 9-18 following work network changes required<br>1) 220kV Padgha-Nalasopara-Vasai Tap line jumper will be open at Loc no. 33 and after that 220kV Boisar-Borivali line tapping will be done to 220kV Padgha-Nalasopara line at Loc no. 203 and 220kV Boisar-Nalasopara-Vasai Tap Line will be formed for 21 days.<br>2) 220kV Kamba-Vasai line outage will be taken on daily basis for 21 days (as per requirement).<br>3) 220kV Boisar-Borivali Line jumper will be opened at Loc no. 204 for 21 continuous Days .<br>4) 220kV Boisar-Borivali line tapping will be done to 220kV Padgha-Nalasopara Line at loc no. 203 after that feeding will be done from 220kV Boisar 2II S/stn via 220kV Boisar-Nalasopara-Vasai tap line.<br>After Tapping 220kV Boisar-Nalasopara-Vasai Tap line will be charged at 18:00 Hrs of 16.08.2024 and it will be in service till 03.09.2024.<br>5) 220kV Borivali-Ghodbunder Line outage will be required for safety purpose only for one day i.e 16.08.2024 @ 09:00 Hrs to 18:00 Hrs. |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/Aug/2024**

**Statement-VII**

**Position as on 6.30 Hrs of 17/Aug/2024**

| Name of Line              | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
|---------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| BORIVALI - BOISAR II LINE | IntraState                   | 15/08/2024      | 11:54           |            |               | PO             | <p>For NHSRCL diversion of 220kV Padgha-Nalasopara-Vasai Tap Line &amp; 220kV Kamba-Vasai Line between Loc no. 9-18</p> <p>1) 220kV Padgha-Nalasopara-Vasai Tap line jumper will be open at Loc no. 33 and after that 220kV Boisar-Borivali line tapping will be done to 220kV Padgha-Nalasopara line at Loc no. 203 and 220kV Boisar-Nalasopara-Vasai Tap Line will be formed for 21 days.</p> <p>2) 220kV Kamba-Vasai line outage will be taken on daily basis for 21 days (as per requirement).</p> <p>3) 220kV Boisar-Borivali Line jumper will be opened at Loc no. 204 for 21 continuous Days .</p> <p>4) 220kV Boisar-Borivali line tapping will be done to 220kV Padgha-Nalasopara Line at loc no. 203 after that feeding will be done from 220kV Boisar 2II S/stn via 220kV Boisar-Nalasopara-Vasai tap line.</p> <p>After Tapping 220kV Boisar-Nalasopara-Vasai Tap line will be charged at 18:00 Hrs of 16.08.2024 and it will be in service till 03.09.2024.</p> <p>5) 220kV Borivali-Ghodbunder Line outage will be required for safety purpose only for one day i.e 16.08.2024 @ 09:00 Hrs to 18:00 Hrs.</p> |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/Aug/2024**

**Statement-VII**

Position as on 6.30 Hrs of 17/Aug/2024

| Name of Line                              | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
|-------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| GHODBUNDER - MSETCL BOISAR                | IntraState                   | 15/08/2024      | 14:07           |            |               | PO             | For safety purpose for carrying out following network changes in r/o NHSRCL diversion of 220kV Padgha-Nalasopara-Vasai Tap Line & 220kV Kamba-Vasai Lione between Loc no. 9-18:<br>1) 220kV Padgha-Nalasopara-Vasai Tap line jumper will be open at Loc no. 33 and after that 220kV Boisar-Borivali line tapping will be done to 220kV Padgha-Nalasopara line at Loc no. 203 and 220kV Boisar-Nalasopara-Vasai Tap Line will be formed for 21 days.<br>2) 220kV Kamba-Vasai line outage will be taken on daily basis for 21 days (as per requirement).<br>3) 220kV Boisar-Borivali Line jumper will be opened at Loc no. 204 for 21 continuous Days .<br>4) 220kV Boisar-Borivali line tapping will be done to 220kV Padgha-Nalasopara Line at loc no. 203 after that feeding will be done from 220kV Boisar 2II S/stn via 220kV Boisar-Nalasopara-Vasai tap line.<br>After Tapping 220kV Boisar-Nalasopara-Vasai Tap line will be charged at 18:00 Hrs of 16.08.2024 and it will be in service till 03.09.2024.<br>5) 220kV Borivali-Ghodbunder Line outage will be required for safety purpose only for one day i.e 16.08.2024 @ 09:00 Hrs to 18:00 Hrs. |
| COLOURCHEM - TEMGHAR                      | IntraState                   | 16/08/2024      | 05:44           | 16/08/2024 | 19:49         | PO             | 220kV COLOURCHEM - TEMGHAR line outage is required during Jumpering work for bypass the 220 KV Bus section 1 Isolator in order to replacement of 220 KV Bus section 1 Isolator work against bay strengthening scheme work                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| BUS SECTION-1 @ TEMGHAR                   | IntraState                   | 16/08/2024      | 05:53           | 16/08/2024 | 19:12         | PO             | 1) Jumpering work for bypass the 220 KV Bus section 1 Isolator in order to replacement of 220 KV Bus section 1 Isolator work against bay strengthening scheme work                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| SATANA - GANGAPUR                         | IntraState                   | 16/08/2024      | 09:04           | 17/08/2024 | 03:43         | T              | B-ph coupling capacitor burst                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| 220 KV ANJANGAON (VIHIGAON) - AKOLA CKT I | IntraState                   | 16/08/2024      | 09:25           | 16/08/2024 | 12:16         | PO             | FLASHOVER<br>DISC<br>REPLACEMENT<br>WORK AT LOC<br>NO. 61R PHASE                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| POPHALI - KDPH                            | IntraState                   | 16/08/2024      | 09:30           | 16/08/2024 | 17:26         | PO             | For jump replacement at loc no. 23R ph, 14 tap line & loc no. 42 LILO tower Y ph, Replacement of conductor at loc no- 9 Y ph Pophali side.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| SHEDYAL-JATH                              | IntraState                   | 16/08/2024      | 09:45           | 16/08/2024 | 18:25         | PO             | Hardware tightening & rusted Nutbolt replacement work                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/Aug/2024**

**Statement-VII**

Position as on 6.30 Hrs of 17/Aug/2024

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------|
| GADCHANDUR - VIRUR-II                      | IntraState                | 16/08/2024   | 09:55        | 16/08/2024 | 14:45      | PO          | 1) FOR DIAGNOSTIC TESTNG WORK.<br>2) DURING OUTAGE PERIOD FLASHOVER<br>DISC REPLACEMENT WORK AT LOC.<br>86 & 88 BY AGENCY WILL BE CARRIED OUT B |
| KARAD - WATHAR                             | IntraState                | 16/08/2024   | 10:00        | 16/08/2024 | 16:24      | PO          | Conversion of STN to DTN strings at loc No.4,5 & 6                                                                                              |
| PADGHE - TEMGHAR - 1                       | IntraState                | 16/08/2024   | 10:02        | 16/08/2024 | 19:48      | HT          | H/T for load management.                                                                                                                        |
| 220 KV CHALISGAON - DHULE CKT              | IntraState                | 16/08/2024   | 11:12        | 16/08/2024 | 15:04      | PO          | FOR FITTING OF MISSING NUT BOLT TO HANGER D SHACKLE AT TL NO.121(Y PHASE)                                                                       |
| KALYANI - BARAMATI AGRO                    | IntraState                | 16/08/2024   | 11:33        | 16/08/2024 | 15:35      | PO          | Hot spot attending & diagnostic testing work of 220 kv Kalyani bay                                                                              |
| BUTIBORI 3 - WARDHA                        | IntraState                | 16/08/2024   | 18:21        | 16/08/2024 | 19:03      | HT          | 1) FOR DIAGNOSTIC TESTNG WORK.<br>2) DURING OUTAGE PERIOD FLASHOVER<br>DISC REPLACEMENT WORK AT LOC.<br>86 & 88 BY AGENCY WILL BE CARRIED OUT B |
| ALEPHATA-PARGAON(KATHAPUR)                 | IntraState                | 17/08/2024   | 06:40        | 17/08/2024 | 21:37      | HT          | for load management                                                                                                                             |
| POPHLI PEDHMBE LINE- 1                     | IntraState                | 17/08/2024   | 08:02        | 17/08/2024 | 13:45      | PO          | For replacement of damaged conductor loc no. 33 to Gantry Y ph & Pedhambe yard & line side jump replacement & other line maintenance work.      |
| SALSETTE - VIKHROLI (GIS) CKT-1            | IntraState                | 17/08/2024   | 08:15        | 17/08/2024 | 20:53      | PO          | Defective polymer insulator replacement at Loc.71 and 72                                                                                        |
| HINJAWADI I- CHINCHWAD                     | IntraState                | 17/08/2024   | 08:18        | 17/08/2024 | 21:39      | HT          | load management                                                                                                                                 |
| MHAISHAL - SHEDYAL                         | IntraState                | 17/08/2024   | 09:38        | 17/08/2024 | 17:56      | PO          | Hardware tightening & rusted nutbolt replacement work                                                                                           |
| KARAD -MUDSHINGI CKT- 4                    | IntraState                | 17/08/2024   | 10:04        | 17/08/2024 | 16:37      | PO          | Conversion of STN to DTN strings at Loc No.4,5,6                                                                                                |
| MAIN BUS SECTION - 2 @ PANDHARPUR          | IntraState                | 17/08/2024   | 10:18        | 17/08/2024 | 12:44      | EO          | Outage is required for To Attend the Hotspot of 220/33kv 50MVA CGL T/F-2 HV Bus side isolator R-ph palm                                         |
| ADLABS - PEDAMBE                           | IntraState                | 17/08/2024   | 10:37        | 17/08/2024 | 11:28      | T           | Tripped on distance protection from Pedambe end only.                                                                                           |
| TIFIL - STT GIS                            | IntraState                | 17/08/2024   | 10:43        | 17/08/2024 | 12:48      | T           | Tripped during AC supply switchover                                                                                                             |
| NEW TPS - WAGHALA CKT 1                    | IntraState                | 17/08/2024   | 12:28        | 17/08/2024 | 16:06      | PO          | Fixing of Turbo Wind Driven Bird Guard                                                                                                          |
| ADLABS - PEDAMBE                           | IntraState                | 17/08/2024   | 12:36        | 17/08/2024 | 18:19      | T           | Tripped on distance protection from Pedambe end only.                                                                                           |
| BUTIBORI 3 - WARDHA                        | IntraState                | 17/08/2024   | 12:52        | 17/08/2024 | 15:57      | HT          | For Load management                                                                                                                             |
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II | IntraState                | 17/08/2024   | 13:40        | 17/08/2024 | 15:40      | HT          | B phase current is showing less                                                                                                                 |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/Aug/2024**

**Statement-VII**

Position as on 6.30 Hrs of 17/Aug/2024

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                        |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| JEJURI ( 400 KV)-JEJURI- II             | IntraState                | 17/08/2024   | 14:10        | 17/08/2024 | 17:39      | EO          | Busbar protection Block alarm observed on 220 KV Busbar relay and after verifying measurement current values of each bay it is observed that 220 KV Jejuri ckt 2-line current values are unbalance. Hence 220 KV Jejuri 2-line bay CT and CT circuit need to be tested on urgent basis. |
| GADCHANDUR - VIRUR-II                   | IntraState                | 17/08/2024   | 15:10        | 17/08/2024 | 19:19      | PO          | Broken Earth Wire Re Fixing and restringing work                                                                                                                                                                                                                                        |
| GADCHANDUR - VIRUR-II                   | IntraState                | 17/08/2024   | 22:44        | 17/08/2024 | 23:35      | T           | Distance Protection                                                                                                                                                                                                                                                                     |
| GADCHANDUR - VIRUR-I                    | IntraState                | 17/08/2024   | 22:44        | 17/08/2024 | 22:58      | T           | Distance Protection                                                                                                                                                                                                                                                                     |
| <b>220 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                         |
| 220/132 KV 100 MVA ICT 1@ BABHALESHWAR  | IntraState                | 12/07/2024   | 13:35        |            |            | PO          | Augmentation of 220/132kv 100MVA to 220/132kv 200MVA at Babheshwar.                                                                                                                                                                                                                     |
| 220/100 KV 100 MVA ICT 1 @ KANDALGAON   | IntraState                | 15/07/2024   | 05:28        |            |            | T           | Differential Protection                                                                                                                                                                                                                                                                 |
| 220/22-22 KV 80 MVA PTR 2 @ COLOURCHEM  | IntraState                | 18/07/2024   | 14:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                                     |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2        | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                                                                                                                                                                                             |
| 220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA   | IntraState                | 16/08/2024   | 10:07        | 16/08/2024 | 16:35      | PO          | 1.SFRA (Sweep Frequency Response Analysis) 2.Tan Delta test for the winding and bushing&#8194;3.Winding resistance measurement & general bay maintenance                                                                                                                                |
| 220/132-110 KV 100 MVA ICT 2            | IntraState                | 16/08/2024   | 10:34        | 16/08/2024 | 14:21      | PO          | 1.Relay Testing Work 2.Quarterly Maintenance Work                                                                                                                                                                                                                                       |
| 220/33KV 50MVA TF NO.2 @ SAYNE          | IntraState                | 16/08/2024   | 12:28        | 16/08/2024 | 19:42      | PO          | For testing of REF, Differential & HV/LV Backup relays of PTR-II                                                                                                                                                                                                                        |
| 220/22 KV 50 MVA PTR 1 @ ANANDNAGAR     | IntraState                | 16/08/2024   | 13:10        | 16/08/2024 | 14:45      | PO          | For New earthpit connection work                                                                                                                                                                                                                                                        |
| 220/132 KV 100 MVA ICT - 2 @ ALEPHATA   | IntraState                | 16/08/2024   | 14:40        | 16/08/2024 | 19:14      | PO          | 1.SFRA (Sweep Frequency Response Analysis) 2.Tan Delta test for the winding and bushing&#8194;3.Winding resistance measurement & general bay maintenance                                                                                                                                |
| 220/33 KV 50 MVA PTR 1 @ BHENDA         | IntraState                | 17/08/2024   | 09:50        | 17/08/2024 | 14:00      | PO          | OLTC overhauling work carried out by agency                                                                                                                                                                                                                                             |
| 220/132KV 100 MVA ICT 2@ PETH           | IntraState                | 17/08/2024   | 10:00        | 17/08/2024 | 13:08      | PO          | Quarterly maintenance & CT jump replacement work                                                                                                                                                                                                                                        |
| 220/132 KV 200 MVA ICT 1@ BALE(SOLAPUR) | IntraState                | 17/08/2024   | 11:22        | 17/08/2024 | 16:13      | EO          | For checking & attending Fire Detector Trip alarm on Nitrogen fire fighting system                                                                                                                                                                                                      |
| 220/33 KV 50 MVA PTR 2 @ BHENDA         | IntraState                | 17/08/2024   | 14:13        | 17/08/2024 | 16:46      | PO          | OLTC overhauling work carried out by agency                                                                                                                                                                                                                                             |
| <b>220 KV BUSBAR Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                         |
| BUS SECTION-2 @ TEMGHAR                 | IntraState                | 16/08/2024   | 05:53        | 16/08/2024 | 19:12      | PO          | For replacement of existing Twin 0.4 ACSR Zebra Bus conductor with Twin 0.5 Moose conductor of 220 KV Bus section 2 under bay strengthening scheme                                                                                                                                      |
| <b>132 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                         |
| PARTUR-BAGHESWARI LINE                  | IntraState                | 17/08/2024   | 04:55        | 17/08/2024 | 12:43      | T           | Distance Protection                                                                                                                                                                                                                                                                     |
| <b>110 KV BUSBAR Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                         |
| ZONE - 2 @ KALYAN                       | IntraState                | 17/08/2024   | 00:47        | 17/08/2024 | 02:51      | PO          | For Removal of Shield wires                                                                                                                                                                                                                                                             |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage