

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Oct/2017 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	129.187	1771.502	1) Gujrat	-6.018	-40.875
2) Hydro	6.188	143.255	2) Madhya Pradesh	6.525	194.958
3) Gas	6.541	117.172	3) Chattisgarh	5.860	109.350
Total MSPGCL	141.916	2031.929	4) Maharashtra Net	109.216	1925.522
B) 1) APML	52.563	746.508	5) Goa (Amona)	-0.242	-3.344
2) JSWEL	26.620	406.576	Total	115.341	2185.611
3) VIPL	11.888	139.302	a) Mumbai Schedule	20.152	409.689
4) RPL(AMT)	7.982	187.444	b) Mumbai Drawl	32.980	538.582
5) WPCL	2.806	34.473	c) MSEDCL Bilateral *	31.705	564.489
6) PGPL	0.000	0.000	Include PX	0.000	49.325
7) Other IPP	5.778	100.888	d) Mumbai Bilateral *	20.152	408.839
C) 1) TPCL Thermal	12.032	226.410	Include PX	0.125	79.057
2) TPCL Hydro	5.282	66.185	Include Standby	0.000	0.850
3) TPCL Gas	2.605	43.884	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	10.937	120.843	1) MSEDCL	336.496	5395.675
D) STATE			2) Mumbai Discoms	63.836	995.902
1) Thermal	259.793	3733.946	TOTAL STATE	400.332	6391.577
(A1+C1+C4+(B1-B6))					
2) Hydro	11.470	209.440			
(A2+C2)					
3) Gas	9.146	161.056			
(A3+B6+C3)					
4) Wind	1.323	61.783			
6) SOLAR	3.259	39.743			
TOTAL STATE	284.991	4205.968			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5315	4999	5610	4974
MSPGCL Hydro	284	229	842	131
MSPGCL Gas	269	268	272	285
MSPGCL Total Generation	5868	5496	6724	5390
Central Sector Receipt	5215	5487	5511	4296
WIND	78	68	32	57
CPP / IPP Thermal	4440	4328	4815	4086
CPP / IPP Gas	0	0	0	0
SOLAR	467	490	0	0
Exchange with Mumbai	-1593	-1491	-1290	-1179
MSEDCL DEMAND MET	14475	14378	15792	12650
Load Shedding	0	0	0	0
MSEDCL DEMAND	14475	14378	15792	12650
TPCL GENERATION	1175	1246	1266	304
R-INFRA GENERATION	499	500	499	377
MUMBAI DEMAND	3267	3237	3055	1860
STATE DEMAND MET	17742	17615	18847	14510
STATE DEMAND	17742	17615	18847	14510
Frequency (Hz)	50.04	49.95	50.00	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.02 Hz at 13.03 Hrs	49.77 Hz at 18.26 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 16/Oct/2017

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.13	168.12	483	437
Unit 9	0.00	0.00	0	0
Unit 10	12.11	159.98	555	460
Total	23.24	328.10		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	9.54	126.89	455	360
Unit 5	9.67	125.64	465	370
Total	19.22	252.53		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	60.41	0	0
Unit 7	0.00	34.96	0	0
Unit 8	3.96	21.37	173	149
Total	3.96	116.73		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	4.10	37.85	184	155
Unit 5	9.55	148.14	420	360
Unit 6	8.81	66.76	433	315
Unit 7	10.31	150.46	471	360
Unit 8	9.51	129.31	455	330
Unit 9	9.41	122.91	444	355
Total	51.69	655.43		
Paras				
Unit 3	4.98	47.65	246	165
Unit 4	5.44	70.02	252	190
Total	10.42	117.67		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	3.48	10.12	155	130
Unit 3	0.00	0.00	0	0
Unit 4	3.67	30.74	163	146
Unit 5	9.74	145.94	450	360
Total	16.88	186.81		
Nasik				
Unit 3	3.78	38.94	161	155
Unit 4	0.00	18.47	0	0
Unit 5	0.00	56.82	0	0
Total	3.78	114.24		
Uran				
All Units	6.54	117.17	285	265
Total	6.54	117.17		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.77	8.34	33	31
Total	0.77	8.34		
Koyna				
Stage 1-2	2.24	50.69	340	40
Stage 4	0.36	45.92	225	0
Stage 3	1.22	23.27	160	0
Total	3.82	119.88		
Hydro				
KDPH	0.88	1.77	37	36
VTRNA	0.00	4.68	0	0
TILLARI	0.00	0.23	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.26	4.29	80	0
RNGR+BHTSA	0.26	4.55	18	4
BHANDARDRA	0.00	1.56	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.97	4.23	41	40
GHATGHAR	0.00	2.07	0	0
Total	2.37	23.37		
Wind				
Total	1.32	61.78	0	0
Total	1.32	61.78		
CPP				
APML(Mus)	52.56	746.51	0	0
JSWEL(Mus)	26.62	406.58	0	0
VIPL(Mus)	11.89	139.30	0	0
RPLAMT(Mus)	7.98	187.44	0	0
WPCL(Mus)	2.81	34.47	0	0
Other(Mus)	5.78	100.89	0	0
Total	107.64	1615.19		
SOLAR				
Total	3.26	39.74	0	0
Total	3.26	39.74		
Tata				
Trombay 5	6.61	139.56	483	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.46	24.94	75	55
Trombay 7B	1.14	18.94	55	44
Trombay 8	5.42	86.84	248	200
TATA Hydro	5.28	66.18	459	0
Total	19.92	336.48		
R-INFRA				
DTPS U-1&2	10.94	120.84	501	375
Total	10.94	120.84		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	129.19	1771.50	MSPGCL Total	141.92	2031.93
			MSPGCL Thml+Gas	135.73	1888.67	Koyna 1,2 & 4 Total	2.60	96.61
			MSPGCL Hydro	6.19	143.26	State Total	284.99	4205.97

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 16/Oct/2017

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5489	121	276	5886	51	4131	0	0	4431	4290	-1499	12859	0	12859	2223	15082	50.00
2	5352	121	275	5748	62	4364	0	0	4342	3917	-1375	12716	0	12716	2052	14768	50.01
3	4973	126	275	5374	66	4283	0	0	4267	4117	-1255	12585	0	12585	1936	14521	50.01
4	4974	131	285	5390	57	4086	0	0	4425	4296	-1179	12650	0	12650	1860	14510	50.04
5	4939	121	275	5335	81	4222	0	0	4315	4306	-1158	12786	0	12786	1837	14623	49.99
6	5475	287	273	6035	64	4564	0	0	4425	4321	-1192	13792	0	13792	1895	15687	49.97
7	5675	142	284	6101	70	4764	0	5	4961	4585	-1270	14255	0	14255	2015	16270	49.94
8	5529	132	275	5936	77	4684	0	97	4916	4767	-1271	14290	0	14290	2225	16515	49.95
9	5519	126	273	5918	51	4607	0	239	4954	4854	-1536	14133	0	14133	2631	16764	49.96
10	5501	129	271	5901	50	4479	0	339	5097	4969	-1576	14162	0	14162	2906	17068	49.94
11	5480	201	270	5951	58	4400	0	423	5187	5153	-1629	14356	0	14356	3237	17593	50.02
12	5315	284	269	5868	78	4440	0	467	5410	5215	-1593	14475	0	14475	3267	17742	50.04
13	4999	229	268	5496	68	4328	0	490	5388	5487	-1491	14378	0	14378	3237	17615	49.95
14	4931	219	266	5416	46	4346	0	427	5227	5316	-1451	14100	0	14100	3151	17251	50.04
15	4955	409	265	5629	57	4310	0	341	5213	5327	-1462	14202	0	14202	3173	17375	49.94
16	5319	525	267	6111	71	4166	0	275	5226	5278	-1568	14333	0	14333	3193	17526	49.96
17	5573	309	265	6147	38	4425	0	130	4919	5079	-1521	14298	0	14298	3159	17457	49.94
18	5571	294	269	6134	43	4637	0	26	5115	4679	-1534	13985	0	13985	3098	17083	49.94
19	5596	710	269	6575	59	4765	0	0	5214	5091	-1333	15157	0	15157	3094	18251	49.92
20	5610	842	272	6724	32	4815	0	0	5402	5511	-1290	15792	0	15792	3055	18847	50.00
21	5619	295	280	6194	38	4816	0	0	5340	5238	-1247	15039	0	15039	2882	17921	50.01
22	5639	165	271	6075	45	4795	0	0	4801	4926	-1194	14647	0	14647	2770	17417	49.95
23	5658	135	273	6066	31	4724	0	0	4634	4297	-1121	13997	0	13997	2583	16580	50.03
24	5496	135	275	5906	30	4486	0	0	4518	4322	-1235	13509	0	13509	2357	15866	49.99
MUs	129.19	6.19	6.54	141.92	1.32	107.64	0.00	3.26	117.73	115.34	-32.98	336.50	0.00	336.50	63.84	400.33	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Oct/2017

Position as on 6.30 Hrs of 17/Oct/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown.	
CENT.SECTOR	TARAPUR 4	540	23/04/2017	19:55		Continued.	Annual Maintenance	
CENT.SECTOR	Tarapur 1	160	04/06/2017	19.09		Continued.	3 months outage for refuelling.	
MSPGCL	Koradi Unit 9	660	07/09/2017	00.38		Continued.	Coal shortage form 12.09.2017 converted to AOH dt.1.10.2017.	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Shutdown	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Ghatghar Unit-2	125	28/07/2017	00.00		Continued.	due to common pressure shaft with unit 1.	
CPP	SWPGL U-3	135	26/08/2017	17.40		Continued.	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 3	210	27/08/2017	07.43		Continued.	Coal Shortage From 29.08.2017.	
MSPGCL	Khaparkhedha Unit 1	210	08/09/2017	12.23		Continued.	Coal Shortage	
MSPGCL	Khaparkhedha Unit 3	210	12/09/2017	00.00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 3	210	12/09/2017	00.00		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	12/09/2017	00.12		Continued.	Coal Shortage	
IPP	RPL(AMT) U-3	270	17/09/2017	00.02		Continued.	Coal Shortage	
IPP	RPL(AMT) U-5	270	17/09/2017	02.01		Continued.	Coal Shortage	
MSPGCL	Uran Unit 7	108	05/10/2017	00.06		Continued.	Gas Turbine Work	
MSPGCL	Uran Unit B0	120	05/10/2017	00.11		Continued.	Gas Turbine Work	
IPP	RPL(AMT) U-1	270	06/10/2017	00.45		Continued.	Problem in submerged Scraper chain	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Oct/2017

Position as on 6.30 Hrs of 17/Oct/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 7	250	12/10/2017	00.00		Continued.	ZERO SCHEDULE.	
IPP	Adani U-5	660	13/10/2017	21.54		Continued.	APHP outlet PA below leakage	
MSPGCL	Parli Unit 6	250	14/10/2017	17.04		Continued.	zero schedule by msedcl.	
MSPGCL	Nasik Unit 5	210	14/10/2017	21.05		Continued.	zero schedule by msedcl.	
MSPGCL	Nasik Unit 4	210	14/10/2017	23.10	17/10/2017	03.34	zero schedule given by msedcl.	
TPC-G	Trombay 5	500	14/10/2017	23.30	16/10/2017	07.05	Boiler Tube Leakage	
IPP	RPL(AMT) U-4	270	16/10/2017	14.47		Continued.	Flame Failure Converted into zero schedule.(21.30 hrs. Dt 16-10-2017)	
IPP	VIPL U-2	300	17/10/2017	02.27	17/10/2017	05.12	FD Fan Problem.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Oct/2017

Statement-VII

Position as on 6.30 Hrs of 17/Oct/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kv Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	11/10/2017	19.34	16/10/2017	11.35	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	16/10/2017	18.32		Continued.	HT	Over Voltage
Ektuni-Bableshwar ckt II	IntraState	06/10/2017	15.03		Continued.	EO	To attend Hot Spot
karad -kolhapur-I	IntraState	12/10/2017	00.30	16/10/2017	09.20	HT	Over Voltage
Karad - Jaigad - II	IntraState	12/10/2017	00.33	16/10/2017	09.38	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	13/10/2017	20.13		Continued.	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	16/10/2017	09.47	16/10/2017	19.03	PO	CVT Replacement Work.
Padghe - Nagothane - II	IntraState	16/10/2017	11.48	16/10/2017	20.40	EO	Attending Hot Spot
karad -kolhapur-II	IntraState	16/10/2017	15.42		Continued.	HT	Over Voltage
Karad - Lonikand 1	IntraState	16/10/2017	17.57		Continued.	T	Tripped on DT received at lonikand.
Karad-Jaigad - I	IntraState	16/10/2017	18.39		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 MVA ICT I @Babhleshwar	IntraState	10/10/2017	17.43		Continued.	PO	Oil Filtration Work.
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	15/10/2017	22.24	16/10/2017	03.56	EO	To attend Hot Spot
400/220 KV 315 MVA ICT- I @Koradi	IntraState	16/10/2017	09.16	16/10/2017	17.58	PO	Testing Work
400/220kv 315MVA ICT 2 @ Kolhapur	IntraState	16/10/2017	10.00	16/10/2017	20.03	PO	Quarterly Maintenance Work
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	NO SCHEDULE.
Vasai Boiser(PG)	InterState	15/10/2017	10.02		Continued.	PO	Reorientation work.
Boisar(MS) - Boisar (PG) - I	InterState	15/10/2017	16.10		Continued.	T	Distance Protection
Mahalakshmi Amona	InterState	16/10/2017	00.55	16/10/2017	07.11	T	Over Voltage
Tillari Amona	InterState	16/10/2017	02.12	16/10/2017	07.11	T	Over Voltage
Tillari Amona	InterState	16/10/2017	20.58	16/10/2017	23.04	T	Distance Protection
Tillari Amona	InterState	17/10/2017	00.07		Continued.	T	Distance Protection
Boisar(MS) - Boisar (PG) II	InterState	17/10/2017	05.54		Continued.	T	For safety purpose.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Pusad - Hingoli	IntraState	11/09/2017	20.06		Continued.	HT	Distance Relay Faulty at pusad end
Pedambe-Nerle	IntraState	23/09/2017	00.50		Continued.	T	B Phase CT Burst at Pedambe End
New Koyana - Pedambe	IntraState	15/10/2017	16.30	16/10/2017	15.28	PO	Isolator sparking at pedambe.
Padghe - Nalasopara	IntraState	16/10/2017	08.50	16/10/2017	18.02	PO	Line Maintenance work
Nashik-Padgha	IntraState	16/10/2017	09.25	17/10/2017	06.55	HT	Controlling Line Loading Bableshwar-nashik.
Paras-Chikhali Ckt No-I	IntraState	16/10/2017	09.49	16/10/2017	19.35	PO	Repl of B PH bend cross arm and repl of conductor loc 8,9 of 220kv balapur Malegaon ckt (ckt in induction zone).
Paras-Chikhali Ckt No-II	IntraState	16/10/2017	09.49	16/10/2017	19.35	PO	Repl of B PH bend cross arm and repl of conductor loc 8,9 of 220kv

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Oct/2017

Statement-VII

Position as on 6.30 Hrs of 17/Oct/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							balapur Malegaon ckt (ckt in induction zone).
Butibori-Khaperkheda	IntraState	16/10/2017	10.11	16/10/2017	13.31	PO	Line Maintenance work
Padegaon-Sawangi	IntraState	16/10/2017	11.15	16/10/2017	15.54	EO	Attending Hot Spot
Miraj - Tilwani	IntraState	16/10/2017	12.35	16/10/2017	12.52	T	Distance Protection
sawangi-Phulambri	IntraState	16/10/2017	13.15	16/10/2017	16.10	T	Distance Protection
Trombay-Chembur Line 2	IntraState	16/10/2017	14.23	16/10/2017	17.02	PO	Replacement Of Relay.
Uran - Jnpt	IntraState	16/10/2017	14.51	16/10/2017	19.59	EO	Attending Hot Spot
Lonikand - Bhosari	IntraState	16/10/2017	20.44	16/10/2017	23.08	EO	Attending Hot Spot
Chakan-Chinchwad	IntraState	17/10/2017	00.13		Continued.	T	Distance Protection
Boisar Versova Line	IntraState	17/10/2017	05.40		Continued.	HT	To control load on boiser-boiser PG lines.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/110kv 100MVA ICT-II @Miraj	IntraState	18/09/2017	11.27		Continued.	PO	Replacement Of Ict-2.
220/132-110kv 100mva Imp Ptr 1 @Wathar	IntraState	16/10/2017	11.25	16/10/2017	14.10	PO	Checking FDR Alarm.
100 KV LINE Outages/Trippings							
Padghe - Bhiwandi 2	IntraState	16/10/2017	09.23	16/10/2017	09.37	T	FTR operated.
Padghe - Mohane	IntraState	16/10/2017	09.23	16/10/2017	09.37	T	FTR operated.
Padghe - Ambernath	IntraState	16/10/2017	09.23	16/10/2017	09.39	T	FTR operated.
Padghe - Murbad 1	IntraState	16/10/2017	09.23	16/10/2017	09.36	T	FTR operated.
Padghe - Murbad 2	IntraState	16/10/2017	09.23	16/10/2017	09.36	T	FTR operated.
Padghe - Bhiwandi 1	IntraState	16/10/2017	09.23	16/10/2017	09.37	T	FTR operated.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage