

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Oct/2019 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	109.490	1910.528	1) Gujrat	11.348	237.526
2) Hydro	9.894	99.182	2) Madhya Pradesh	11.405	148.609
3) Gas	11.668	147.440	3) Chattisgarh	3.950	49.220
Total MSPGCL	131.052	2157.150	4) Maharashtra	133.683	2080.640
B) 1) APML	61.402	560.341	5) Goa (Amona)	-0.484	-7.788
2) JSWEL	21.584	302.479	Total	159.902	2508.207
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.053	503.275
4) RPL(AMT)	23.979	336.867	b) Mumbai Drawl	39.435	566.311
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	15.291	378.188
6) Other IPP	9.049	136.412	Include PX	-0.002	82.243
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.053	503.275
C) 1) TPCL Thermal	13.628	208.465	Include PX	9.934	219.471
2) TPCL Hydro	5.243	61.734	Standby	0.000	0.000
3) TPCL Gas	4.241	55.890	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.169	115.267	1) MSEDCL	388.700	5642.610
D) STATE			2) Mumbai Discoms	67.715	1007.663
1) Thermal	244.301	3570.359	TOTAL STATE	456.415	6650.273
(A1+C1+C4+(B1-B6))					
2) Hydro	15.137	160.916			
(A2+C2)					
3) Gas	15.909	203.330			
(A3+B7+C3)					
4) Wind	14.279	108.716			
6) SOLAR	6.888	98.749			
TOTAL STATE	296.514	4142.070			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4640	4600	4640	4024
MSPGCL Hydro	254	320	1373	65
MSPGCL Gas	539	404	414	563
MSPGCL Total Generation	5434	5324	6427	4652
Central Sector Receipt	7374	7571	6547	5965
WIND	692	694	435	639
CPP / IPP Thermal	4830	4821	5085	4408
CPP / IPP Gas	0	0	0	0
SOLAR	968	792	0	0
Exchange with Mumbai	-2178	-2111	-1578	-1227
MSEDCL DEMAND MET	17120	17091	16916	14437
Load Shedding	0	0	0	0
MSEDCL DEMAND	17120	17091	16916	14437
TPCL GENERATION	930	987	1265	688
AEML GENERATION	193	192	250	191
MUMBAI DEMAND	3301	3290	3093	2106
STATE DEMAND MET	20421	20381	20009	16543
STATE DEMAND	20421	20381	20009	16543
Frequency (Hz)	50.01	49.99	50.04	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 10.02 Hrs	49.82 Hz at 06.14 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 16/Oct/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	34.05	0	0
Unit 9	11.94	169.49	580	445
Unit 10	10.45	164.70	505	350
Total	22.38	368.24		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.26	148.68	480	350
Unit 5	3.94	73.64	455	0
Total	14.20	222.32		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.46	36.08	250	185
Unit 7	5.48	77.91	249	187
Unit 8	0.29	71.04	175	0
Total	11.23	185.03		
Chandrapur				
Unit 3	4.23	46.21	188	163
Unit 4	3.79	57.18	170	128
Unit 5	8.87	129.50	395	340
Unit 6	7.78	131.17	450	0
Unit 7	0.00	0.00	0	0
Unit 8	8.39	141.12	390	305
Unit 9	9.40	137.79	460	358
Total	42.46	642.97		
Paras				
Unit 3	4.70	60.34	250	140
Unit 4	0.00	0.00	0	0
Total	4.70	60.34		
Khaparkheda				
Unit 1	0.00	30.23	0	0
Unit 2	0.00	35.13	0	0
Unit 3	0.00	44.89	0	0
Unit 4	0.00	53.98	0	0
Unit 5	10.58	153.00	500	360
Total	10.58	317.23		
Nasik				
Unit 3	0.00	24.52	0	0
Unit 4	0.00	31.55	0	0
Unit 5	3.94	58.32	190	140
Total	3.94	114.39		
Uran				
All Units	11.67	147.44	566	404
Total	11.67	147.44		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	12.50	50	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.13	12.50		
Koyna				
Stage 1-2	4.24	44.82	495	40
Stage 4	3.45	20.88	743	0
Stage 3	1.36	15.58	160	0
Total	9.05	81.28		
Hydro				
KDPH	0.09	4.03	19	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	2.67	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.29	4.37	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.00	0.97	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.00	3.37	0	0
GHATGHAR	0.46	2.50	125	0
Total	0.84	17.91		
Wind				
Total	14.28	108.72	0	0
Total	14.28	108.72		
CPP				
APML(Mus)	61.40	560.34	0	0
JSWEL(Mus)	21.58	302.48	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	23.98	336.87	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	9.05	136.41	0	0
Total	116.01	1336.10		
SOLAR				
Total	6.89	98.75	0	0
Total	6.89	98.75		
Tata				
Trombay 5	8.80	131.67	446	313
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.68	34.37	117	109
Trombay 7B	1.56	21.52	67	64
Trombay 8	4.83	76.79	207	197
TATA Hydro	5.24	61.73	459	10
Total	23.11	326.09		
AEML				
DTPS U-1&2	5.17	115.27	250	191
Total	5.17	115.27		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	109.49	1910.53	MSPGCL Total	131.05	2157.15
			MSPGCL Thml+Gas	121.16	2057.97	Koyna 1,2 & 4 Total	7.70	65.70
			MSPGCL Hydro	9.89	99.18	State Total	296.51	4142.07

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 16/Oct/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4577	45	482	5104	736	4505	0	0	6137	6057	-1585	14817	0	14817	2593	17410	49.98
2	4220	50	506	4776	700	4478	0	0	5879	5897	-1405	14446	0	14446	2371	16817	49.95
3	4091	195	565	4851	748	4472	0	0	5550	5729	-1308	14492	0	14492	2216	16708	49.97
4	4024	65	563	4652	639	4408	0	0	5771	5965	-1227	14437	0	14437	2106	16543	49.98
5	4524	45	553	5122	578	4418	0	0	5973	6071	-1192	14997	0	14997	2071	17068	49.99
6	4801	50	565	5416	611	4716	0	0	6250	6300	-1232	15811	0	15811	2127	17938	49.99
7	4909	746	563	6218	617	4862	0	17	6545	6710	-1183	17241	0	17241	2227	19468	49.96
8	4944	802	566	6312	561	4907	0	187	6576	6654	-1221	17400	0	17400	2367	19767	50.05
9	4879	202	549	5630	504	4858	0	485	6882	6834	-1488	16824	0	16824	2656	19480	50.03
10	4875	184	554	5612	615	4820	0	727	6905	7033	-1888	16920	0	16920	2971	19890	50.01
11	4679	278	529	5486	718	4775	0	909	7102	7181	-2086	16984	0	16984	3201	20184	50.04
12	4640	254	539	5434	692	4830	0	968	7577	7374	-2178	17120	0	17120	3301	20421	50.01
13	4534	170	512	5216	633	4947	0	995	7458	7385	-2185	16991	0	16991	3292	20283	50.02
14	4556	112	414	5082	726	4911	0	889	7351	7295	-2083	16820	0	16820	3213	20033	49.98
15	4600	320	404	5324	694	4821	0	792	7336	7571	-2111	17091	0	17091	3290	20381	49.99
16	4516	389	414	5319	551	4845	0	568	7610	7595	-1935	16943	0	16943	3377	20320	49.98
17	4478	874	406	5758	541	4924	0	289	7025	7344	-1831	17025	0	17025	3330	20355	50.01
18	4442	1109	408	5959	415	4990	0	60	6499	6510	-1706	16228	0	16228	3230	19458	50.00
19	4479	1421	418	6318	388	5040	0	2	6330	6572	-1680	16640	0	16640	3198	19838	50.01
20	4640	1373	414	6427	435	5085	0	0	6359	6547	-1578	16916	0	16916	3093	20009	50.04
21	4558	526	427	5511	502	5167	0	0	6298	6502	-1512	16170	0	16170	2960	19130	50.02
22	4525	223	439	5187	522	5181	0	0	6222	6276	-1476	15690	0	15690	2870	18560	50.01
23	4532	205	432	5169	554	5076	0	0	6223	6366	-1617	15548	0	15548	2844	18392	50.01
24	4467	255	446	5168	599	4977	0	0	6053	6134	-1728	15150	0	15150	2812	17962	50.00
MUs	109.49	9.89	11.67	131.05	14.28	116.01	0.00	6.89	157.91	159.90	-39.44	388.70	0.00	388.70	67.72	456.42	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Oct/2019

Position as on 6.30 Hrs of 17/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn on shaft seal water leakage. Converted to AOH from 1 Nov 2019.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koyana Unit 10	80	05/08/2019	20.05		Continued.	Stator Earth Fault	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-1	660	19/09/2019	01.43		Continued.	Due to Low Coal Stock.	
AEML	AEML Unit 2	250	07/10/2019	21.18		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Nasik Unit 4	210	09/10/2019	23.59		Continued.	Zero schedule.	
MSPGCL	Koradi Unit-8	660	11/10/2019	22.36		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
RGPL	Dabhol 3B	230	13/10/2019	01.20	17/10/2019	04.26	Unit changeover.	
RGPL	Dabhol 3X	290	13/10/2019	01.20	17/10/2019	06.21	Unit changeover.	
MSPGCL	Khaparkheda Unit 3	210	13/10/2019	19.57		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 4	210	14/10/2019	23.51		Continued.	Zero Schedule	
MSPGCL	Chandrapur Unit 6	500	15/10/2019	16.15	16/10/2019	04.01	Drum level low	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Oct/2019

Position as on 6.30 Hrs of 17/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	15/10/2019	17.39	16/10/2019	23.27	Changeover of unit auxillary transfoer.	
MSPGCL	Parli Unit 8	250	16/10/2019	01.36		Continued.	Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)	
MSPGCL	Bhusawal Unit 5	500	16/10/2019	10.02		Continued.	Boiler Tube Leakage	
RGPPL	Dabhol 2A	230	16/10/2019	20.23	16/10/2019	21.57	Due to combustion trouble.	
MSPGCL	Uran Unit 8	108	17/10/2019	00.24	17/10/2019	11.40	Fuel gas shutoff valve problem.	
IPP	RPL(AMT) U-4	270	17/10/2019	10.41	17/10/2019	12.33	Low Vaccum Turbine trip.	
MSPGCL	Uran Unit 8	108	17/10/2019	13.47	17/10/2019	19.54	High Vibration Compressor Bearing.	
MSPGCL	Parli Unit 6	250	17/10/2019	23.25		Continued.	Poor Coal Receipt.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 17/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Padgha Tarapur I	InterState	16/10/2019	02.30	16/10/2019	08.41	T	Over Voltage
Chandrapur II - Dhariwal -I	InterState	16/10/2019	09.46	16/10/2019	22.24	PO	Daignostic Testing Work.
Parli(MS)-Parli (PG) II	InterState	16/10/2019	10.24	16/10/2019	16.33	PO	CT Tan Delta Wrok.
Akola Aurangabad(PG) I	InterState	17/10/2019	10.11	17/10/2019	19.31	PO	Stringing Of Conductor.
Akola Aurangabad(PG) II	InterState	17/10/2019	10.30	17/10/2019	19.31	PO	Stringing Of Conductor.
Dabhol Nagothane II	InterState	17/10/2019	16.48	17/10/2019	17.29	T	Tripped At Dabhol End.
Khadka-Aurangabad (Waluj)	IntraState	15/10/2019	22.27	16/10/2019	07.24	HT	Over Voltage
Koradi-Bhusawal	IntraState	16/10/2019	08.21	16/10/2019	18.14	PO	Tower Errection Work For Railway Crossing.
Cahndrapur II - Dhariwal II	IntraState	16/10/2019	09.46	16/10/2019	22.24	PO	Daignostic Testing Work.
Pune(GIS)-Talegaon(PG) Ckt 3	IntraState	16/10/2019	11.15	16/10/2019	13.34	PO	SF6 Gas Filling Work.
Babhaleshwar - Padghe-II	IntraState	17/10/2019	07.56	17/10/2019	18.55	PO	Auto Recloser Out.
Girwali - Lonikand 1	IntraState	17/10/2019	11.27	17/10/2019	15.51	PO	Line Maintenance work
Main Bus 1 @ New Koyna	IntraState	17/10/2019	12:26		Continued.	PO	Cold Washing.
Khadka-Aurangabad (Waluj)	IntraState	17/10/2019	19.37		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220 Kv 200 Mva Bhel Spare Ict 2 @Kalwa	IntraState	16/10/2019	09.09	16/10/2019	19.30	PO	OLTC Overhauling Work.
400/220 Kv 500 Mva Ict 1 @Lamboti	IntraState	16/10/2019	10.01	16/10/2019	16.51	PO	Testing Work
400/220 Kv 315 MVA ICT -I @New Koyna	IntraState	16/10/2019	12.37	16/10/2019	16.52	PO	Tan DElta Work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
PARLY (PG) - OSMANABAD	InterState	15/10/2019	08.04		Continued.	PO	Tower Shifting Work of NH Crossing
Borivali - Tarapur	InterState	17/10/2019	06.00	17/10/2019	09.20	EO	Attending Hot Spot
Solapur (Pg) South Solapur I	InterState	17/10/2019	10.40	17/10/2019	19.00	PO	bay AMC Work.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Lonand-Baramati	IntraState	17/09/2019	11.13		Continued.	HT	To Control Overloading of Lonand -Jejuri Line.
Nanded-Ghatodi	IntraState	16/10/2019	04.04	17/10/2019	09.07	T	Distance Protection
Badnera-Akola I	IntraState	16/10/2019	08.07		Continued.	PO	Erection Of inline 220Kv Towers.
Badnera-Akola li	IntraState	16/10/2019	08.07		Continued.	PO	Erection Of inline 220Kv Towers.
Karad - Kadegaon	IntraState	16/10/2019	09.01	16/10/2019	19.21	T	Distance Protection Relay Retro Fitting.
Butibori - Purti	IntraState	16/10/2019	09.10	16/10/2019	17.04	PO	Conversion From SSN To DSN
Dhamangaon New- Tss -I	IntraState	16/10/2019	09.46	16/10/2019	22.24	PO	Diagnostic Testing Work.
Uran - Hoc 1	IntraState	16/10/2019	09.58	16/10/2019	21.31	PO	Testing Work
Kalwa - Siemens	IntraState	16/10/2019	10.03	16/10/2019	22.07	PO	Line Bays Distance Relays To Be Replaced By Line Differential Relays At kalwa.
Nagothane - Posco	IntraState	16/10/2019	10.20	16/10/2019	19.21	PO	Routine Maintenance Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 17/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
karad - Dasgaon	IntraState	16/10/2019	10.35	16/10/2019	18.10	PO	line bay Maintenance.
Tembhurni - Jeur	IntraState	16/10/2019	10.45	16/10/2019	13.25	PO	CT Oil Leakage.
Kalwa 52B Interconnector CB	IntraState	16/10/2019	10.52	16/10/2019	16.41	PO	Due To Line Loading.
Mudshingi-Belewadi	IntraState	16/10/2019	11.55	16/10/2019	13.21	PO	Routine Maintenance Work
Ekalahara(Ocr)(Nashik)-Navasari II	IntraState	16/10/2019	12.39	16/10/2019	15.46	HT	Attending Hot Spot
Dahanu-Viraj	IntraState	16/10/2019	15.23	16/10/2019	16.53	HT	Attending Hot Spot
Trombay - Kalwa	IntraState	16/10/2019	20.03	17/10/2019	07.13	PO	Tower Pilling Work.
Ambazari-Amravati	IntraState	17/10/2019	09.14	17/10/2019	17.55	PO	Conversion Of SSN IN To DSN.
karad - Dasgaon	IntraState	17/10/2019	09.44	17/10/2019	19.13	PO	Line Maintenance work
Kharghar-Borivali ckt II	IntraState	17/10/2019	09.51	17/10/2019	17.41	PO	Bus Isolator maintenance Work by Hot Line.
Gadchandur - Grace	IntraState	17/10/2019	10.01	17/10/2019	14.07	PO	Fixing Of Side Plate Of suspension Clamp of Pilot String At LOc No.151 (RPH).Fixing Of Suspension Clamp U Bolt At loc.no. 144(Y-PH).
Chandrapur GCR - Sicom II	IntraState	17/10/2019	10.14	17/10/2019	17.14	PO	Tree Cutting & Trimming Work.
Walchandnagar-Bhigwan	IntraState	17/10/2019	10.35	17/10/2019	17.30	PO	Diagnostic Work.
Koradi-Khaperkheda	IntraState	17/10/2019	10.56	17/10/2019	18.17	PO	Line Signature Test.
OSMANABAD PARANDA	IntraState	17/10/2019	18.37	17/10/2019	21.01	HT	To Remove the T & P Of Hot Line.
Midc Chandrapur-Gadchandur	IntraState	17/10/2019	20.20	17/10/2019	20.40	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132kv 200mva Emco ICT-1 @Kurkumbh	IntraState	15/10/2019	10.00		Continued.	PO	Oil Leakage Work.
100 MVA ICT I at Kandalgaon	IntraState	16/10/2019	10.00	16/10/2019	16.15	PO	Oil Top Up
220/22 Kv 50 Mva Imp Ptr 1 @Airoli Knowledge Park	IntraState	16/10/2019	10.25	16/10/2019	15.00	PO	Routine Maintenance Work
220/132 Kv 200 Mva Cgl Ict 1 @Bale (Solapur 2)	IntraState	16/10/2019	10.35	16/10/2019	12.20	PO	Quarterly Maintainance Work
220/132 KV 100 MVA ICT - II @ Ghatodi	IntraState	16/10/2019	11.13	16/10/2019	18.31	PO	Diagnostic Testing Work.
220/132 KV ICT II @ Kopergaon	IntraState	17/10/2019	08.05	17/10/2019	12.00	PO	Routine Maintenance Work
220/100 kV 200 MVA ICT II @Padghe	IntraState	17/10/2019	09.02	17/10/2019	17.45	PO	Routine Maintenance Work
220/132kv 100 Mva Imp Ict 1 @Limbala Midc Hingoli	IntraState	17/10/2019	10.21	17/10/2019	18.51	PO	Quarterly Maintainance Work
220/132KV 100MVA -1@Alephata	IntraState	17/10/2019	11.16	17/10/2019	19.13	PO	For Removing Bird Nest.
220/66 Kv 150 Mva Ngef Ict 1 @Gadchandur	IntraState	17/10/2019	13.25	17/10/2019	17.50	PO	For Attending Of Oil Leakages From top & Diagnostic Testing.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage