

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Nov/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.491	2324.592	1) Gujrat	-5.922	-134.269
2) Hydro	9.702	135.285	2) Madhya Pradesh	-0.599	-31.806
3) Gas	2.210	29.275	3) Chattisgarh	6.510	96.940
Total MSPGCL	152.403	2489.152	4) Maharashtra	182.610	2691.625
B) 1) APLM	75.961	1006.238	5) Goa (Amona)	-1.171	-22.751
2) JSWEL	12.052	202.464	Total	181.428	2599.739
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.369	513.473
4) RPL(AMT)	25.529	408.569	b) Mumbai Drawl	39.330	579.785
5) SWPGPL	7.697	110.644	c) MSEDCL Bilateral *	73.547	1121.982
6) Other IPP	38.753	505.297	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.369	513.473
C) 1) TPCL Thermal	10.914	173.878	Include PX	0.000	0.000
2) TPCL Hydro	4.242	61.333	Standby	0.000	0.000
3) TPCL Gas	0.000	6.990	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.104	140.841	1) MSEDCL	462.577	7013.128
D) STATE			2) Mumbai Discoms	63.590	962.827
1) Thermal	320.501	4872.523	3) Other Discoms	9.440	149.514
(A1+C1+C4+(B1-B6))			TOTAL STATE	535.607	8125.469
2) Hydro (A2+C2)	13.944	196.618			
3) Gas (A3+B7+C3)	2.210	36.265			
4) Wind	5.428	229.711			
6) SOLAR	12.096	190.613			
TOTAL STATE	354.179	5525.730			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6044	5898	6038	5692
MSPGCL Hydro	326	199	1846	124
MSPGCL Gas	91	89	89	94
MSPGCL Total Generation	6461	6186	7973	5910
Central Sector Receipt	9208	9032	6741	5657
WIND	114	101	199	513
CPP / IPP Thermal	6671	6732	6633	6740
CPP / IPP Gas	0	0	0	0
SOLAR	1595	1379	0	0
Exchange with Mumbai	-1951	-1893	-1544	-1602
MSEDCL DEMAND MET	21675	21124	19551	16838
Load Shedding	0	0	0	0
MSEDCL DEMAND	21675	21124	19551	16838
TPCL GENERATION	734	763	1048	473
AEML GENERATION	481	466	453	315
MUMBAI DEMAND	3166	3122	3045	2390
OTHER DISCOM DEMAND	423	413	451	380
STATE DEMAND MET	25264	24659	23047	19608
STATE DEMAND	25264	24659	23047	19608
Frequency (Hz)	50.00	50.04	50.06	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 18.01 Hrs	49.76 Hz at 06.35 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 16/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.06	74.22	215	205
Unit 7	0.00	0.00	0	0
Unit 8	14.06	203.97	628	550
Unit 9	13.56	203.11	606	500
Unit 10	0.00	91.74	0	0
Total	32.68	573.04		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.38	147.06	420	340
Unit 5	9.40	150.36	420	350
Total	18.78	297.42		
Parli				
Unit 6	4.39	63.53	228	150
Unit 7	3.67	59.76	220	126
Unit 8	4.13	51.74	201	143
Total	12.19	175.03		
Chandrapur				
Unit 3	3.08	50.08	145	117
Unit 4	3.27	46.69	156	119
Unit 5	7.14	102.05	330	275
Unit 6	3.79	107.25	290	0
Unit 7	7.44	116.97	348	268
Unit 8	9.78	157.86	459	298
Unit 9	9.30	150.54	431	309
Total	43.80	731.44		
Paras				
Unit 3	5.03	76.99	231	190
Unit 4	5.33	31.54	245	191
Total	10.36	108.53		
Khaparkheda				
Unit 1	2.66	43.48	125	95
Unit 2	2.76	42.64	130	100
Unit 3	0.09	48.11	71	0
Unit 4	3.61	55.09	166	130
Unit 5	6.63	157.92	280	262
Total	15.74	347.24		
Nasik				
Unit 3	0.00	1.31	0	0
Unit 4	3.62	40.97	176	114
Unit 5	3.32	49.63	155	112
Total	6.93	91.90		
Uran				
All Units	2.21	29.28	95	89
Total	2.21	29.28		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.28	10.86	27	0
Total	0.28	10.86		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.84	37.22	355	35
Stage 4	3.68	31.07	982	0
Stage 3	1.12	15.12	240	0
Total	6.63	83.41		
Hydro				
KDPH	0.43	5.06	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.35	2.61	58	0
BHIRA T.R.	0.18	3.06	77	0
SMLHY_PTN	1.54	25.84	66	61
GHATGHAR	0.28	4.46	125	0
Total	2.79	41.02		
Wind				
Total	5.43	229.71	0	0
Total	5.43	229.71		
CPP				
APML(Mus)	75.96	1006.24	0	0
JSWEL(Mus)	12.05	202.46	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.53	408.57	0	0
SWPGPL-Mus	7.70	110.64	0	0
Other(Mus)	38.75	505.30	0	0
Total	159.99	2233.21		
SOLAR				
Total	12.10	190.61	0	0
Total	12.10	190.61		
Tata				
Trombay 5	7.42	117.88	427	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.91	0	0
Trombay 7B	0.00	3.08	0	0
TATA Hydro	4.24	61.33	427	8
Trombay 8	3.50	55.99	194	131
Total	15.16	242.20		
AEML				
DTPS U-1&2	9.10	140.84	492	279
Total	9.10	140.84		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.49	2324.59	MSPGCL Total	152.40	2489.15
			MSPGCL Thml+Gas	142.70	2353.87	Koyna 1,2 & 4 Total	5.51	68.29
			MSPGCL Hydro	9.70	135.28	State Total	354.18	5525.73

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 16/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5422	114	94	5630	464	6594	0	0	6482	6354	-1528	17159	0	17159	2295	355	19809	50.01
2	5390	118	95	5603	496	6613	0	0	6255	6374	-1411	17358	0	17358	2125	317	19800	49.99
3	5684	118	94	5896	457	6620	0	0	6116	6225	-1308	17592	0	17592	2000	298	19890	49.98
4	5634	118	94	5846	380	6639	0	0	6250	6218	-1230	17554	0	17554	1923	299	19776	49.98
5	5843	118	94	6055	324	6644	0	0	6514	6633	-1214	18138	0	18138	1906	304	20348	50.00
6	5919	118	94	6131	268	6655	0	0	7347	7751	-1307	19153	0	19153	2009	345	21507	49.99
7	5935	635	94	6664	167	6644	0	24	7989	8054	-1393	19783	0	19783	2169	377	22329	49.89
8	6116	1021	95	7232	144	6666	0	304	7972	7808	-1478	20283	0	20283	2347	393	23023	50.00
9	6124	804	94	7022	113	6685	0	846	8105	8140	-1725	20662	0	20662	2664	419	23745	50.04
10	5920	295	92	6307	93	6648	0	1313	8519	8867	-1736	21059	0	21059	2975	433	24467	49.99
11	6044	326	91	6461	114	6671	0	1595	9226	9208	-1951	21675	0	21675	3166	423	25264	50.00
12	6092	184	91	6367	99	6650	0	1786	9233	9041	-2025	21493	0	21493	3237	425	25155	50.04
13	5683	199	90	5972	81	6644	0	1765	8959	8890	-1995	20937	0	20937	3203	420	24560	50.02
14	5689	234	90	6013	94	6676	0	1639	8353	8371	-1869	20504	0	20504	3093	420	24017	50.00
15	5898	199	89	6186	101	6732	0	1379	8796	9032	-1893	21124	0	21124	3122	413	24659	50.04
16	5930	200	89	6219	99	6706	0	953	9295	9072	-1998	20627	0	20627	3135	424	24186	50.00
17	6025	213	89	6327	105	6714	0	448	8994	8635	-1892	19915	0	19915	3108	422	23445	49.96
18	6072	935	89	7096	149	6661	0	44	7620	7607	-1686	19436	0	19436	3063	435	22934	50.01
19	6038	1846	89	7973	199	6633	0	0	6745	6741	-1544	19551	0	19551	3045	451	23047	50.06
20	6105	1140	91	7336	226	6685	0	0	7144	7504	-1631	19689	0	19689	2907	431	23027	50.02
21	5796	304	91	6191	184	6698	0	0	7013	6941	-1687	17895	0	17895	2699	432	21026	50.00
22	5619	215	93	5927	197	6673	0	0	6553	6527	-1639	17270	0	17270	2552	415	20237	50.03
23	5821	124	94	6039	361	6701	0	0	6197	5778	-1588	16882	0	16882	2457	409	19748	49.99
24	5692	124	94	5910	513	6740	0	0	6145	5657	-1602	16838	0	16838	2390	380	19608	50.01
MUs	140.49	9.70	2.21	152.40	5.43	159.99	0.00	12.10	181.82	181.43	-39.33	462.58	0.00	462.58	63.59	9.44	535.61	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Nov/2022

Position as on 6.30 Hrs of 17/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33	17/11/2022	04:48	Furnace Pressure High(converted into coal shortage from 15-10-2022)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	16/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	16/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	
CENT.SECTOR	Tarapur 3	540	07/11/2022	02:00		Continued.	For maintenance on reactor side	19/11/2022
IPP	JSW (J) U3	300	09/11/2022	08:08		Continued.	Generator Elect. Fault	16/11/2022
MSPGCL	Uran Unit 6	108	10/11/2022	10:44		Continued.	Gas shortage	
MSPGCL	Koradi Unit-10	660	10/11/2022	22:13		Continued.	Boiler Tube Leakage	16/11/2022
MSPGCL	Nasik Unit 3	210	11/11/2022	03:16		Continued.	Boiler Tube Leakage (under tolling from 06:33 hrs dtd-13/11/2022)	20/11/2022
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scraper Conveyor Scraper bar problem.	18/11/2022
MSPGCL	Koyana Unit 2	70	14/11/2022	09:55	16/11/2022	16:30	TGB Cooler leakage	16/11/2022
MSPGCL	Khaparkheda Unit 3	210	14/11/2022	19:00	16/11/2022	22:32	Boiler Tube Leakage	16/11/2022
MSPGCL	Chandrapur Unit 6	500	16/11/2022	14:06		Continued.	ID Fan Problem	20/11/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 17/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 701 OF 765/400kV 1500MVA ICT @ AKOLA 2	IntraState	16/11/2022	09:47	16/11/2022	18:09	PO	Annual Maintenance of Bay Equipment
500 KV LR Outages/Trippings							
Pole-2 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	16/11/2022	15:00	16/11/2022	17:29	EO	hotspot
400 KV TIEBAY Outages/Trippings							
TIE BAY- 402 OF 400/220/33 KV 500 MVA ICT - 1 AND PARLI @ LAMBOTI	IntraState	14/11/2022	10:43			PO	Overhauling of 402-52 CB
TBC @ PADGHE	IntraState	16/11/2022	10:20	16/11/2022	17:02		1) Bay maint work 2) MTAMC work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KALWA - TALEGAON (PG)	InterState	16/11/2022	22:35	17/11/2022	07:39	EO	To apply repair sleeve on broken conductor strand near vibration damper at, 178, 179, 159,162.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
BUS - 1 @ NEW KOYNA	IntraState	09/11/2022	13:07	16/11/2022	18:33	PO	1) 09/11/2022 to 10/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 11/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 and damage conductor replacement work 3) 12/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 13/11/2022 Bus Insulator replacement work at section Koyana - I & II 5) 14/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 15/11/2022 to 16/11/2022 Bus Insulator replacement work at section Jaigad - I & II
GT-10 @ KORADI-2	IntraState	12/11/2022	11:44				1) Routine maintenance of isolator. 2) Health check up of CB 402-Q52 by M/S Siemens(OEM) 3) Routine Bay maintenance work. 4) Erection, testing and commissioning of dedicated metering CT and IVT for the metering arrangement for GT-10 bay at 400 kV Koradi II S/s.
KARAD - TALANDGE CKT - 1	IntraState	15/11/2022	17:03			PO	Overhauling of A bus, B Bus PG isolators.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	16/11/2022	08:42	16/11/2022	17:11	PO	Conductor & Earthwire Hardware tightening work & Replacement of Broken disc Insulator
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	16/11/2022	11:12	16/11/2022	19:11	PO	1) String Disc Replacement Work 2) Maintenance Work
400 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 17/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ KORADI	IntraState	16/11/2022	08:51	16/11/2022	19:35	PO	400KV CT TAN DELTA, SFRA & DFRA OF ICT & OIL TOP UP OF ICT
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	17/11/2022	07:09			PO	Dismantling of 400 kV bushing is required for internal inspection of ICT-I R ph unit. So while dismantling of 400 kV bushing,for safety from induction zone of R ph CT to 400 kV gantry jump which is now in live condition.For this outage is required on ICT-I
400 KV BR Outages/Trippings							
80 MVar Bus reactor @ Talandge	IntraState	17/11/2022	09:40			PO	AMP and relay testing works.
220 KV TBC Outages/Trippings							
TBC @ VERSOVA (AEML)	IntraState	16/11/2022	09:08	16/11/2022	21:38	PO	afety purpose during replacement of B-phase bushing of NGT-2.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/11/2022	08:24			HT	For Load Management
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARA(OCR)-RAYMOND	IntraState	14/11/2022	10:00			PO	CB Mechanism overhauling & CB pole overhauling work due to SF6 Gas purity of CB is below the acceptable limit
EKLAHARE (OCR) - PADGHE	IntraState	15/11/2022	08:45			HT	For Load Management
URAN - ONGC URAN	IntraState	16/11/2022	10:47	16/11/2022	19:35	PO	1) Disc Insulator Replacement Work at Uran End. 2) Isolator Replacement Work by Discom at ONGC End.
MAIN BUS @ TEMBHURNI	IntraState	16/11/2022	11:15	16/11/2022	17:58	PO	Outage is required for Quarterly Maintenance
MALINAGAR - TEMBHURNI	IntraState	16/11/2022	11:15	16/11/2022	18:34	PO	Outage is required for Quarterly Maintenance
TBC @ SOUTH SOLAPUR	IntraState	16/11/2022	11:30	16/11/2022	14:03	PO	Outage is required for Quarterly Maintenance
APTA - KALWA	IntraState	16/11/2022	12:15	16/11/2022	14:50	EO	Replacement of rusted D-sackel & suspension clamp at Loc no. 586 (Top & Middle) & 589 (All phases)
APTA - TALOJA	IntraState	16/11/2022	14:50	16/11/2022	16:38	EO	Replacement of rusted D-sackel & suspension clamp at Loc no. 589 (All phases)
TROMBAY SALSETTE LINE-2	IntraState	17/11/2022	03:43	17/11/2022	04:26	PO	Project work in Vicinity of line to Close loop of 110 KV Dharavi - Vikhroli and Dharavi Powai line of A Phase at Loc. 58.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 17/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
URAN - APTA 2	IntraState	17/11/2022	08:58			PO	"1) For Insulator string replacement work. 2) Bay Maintenance Work and Diagnostic Testing Work."
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/33kV 100 MVA TF 2 @ VERSOVA (AEML)	IntraState	16/11/2022	09:01	16/11/2022	21:35	PO	Replacement of B-phase bushing of NGT-2 due to high tandelta value. Checking of R phase Cable chamber of 33 kV Sw No 84 i.e. 100 MVA Tr-2 I/C 1 by OEM
220/132-110 KV 100MVA ICT No-01 @ OGLEWADI	IntraState	16/11/2022	09:13	16/11/2022	17:02	PO	1.Diagnostic testing work 2.Quarterly Maintenance Work 3.Oil leakage attending work
220/110 KV 200 MVA ICT 2 @ MUDSHINGI	IntraState	16/11/2022	09:43			PO	HV CB overhauling in presence of Siemens Engineer, TF oil filtration work & QM work
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	17/11/2022	08:40			PO	Diagnosis of testing work
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	16/11/2022	09:55	16/11/2022	17:45	PO	1) For MAIN BUS 2 insulator string replacement work.
MAIN BUS - 2 @ URAN	IntraState	17/11/2022	09:36			PO	1) For MAIN BUS 2 insulator string replacement work.
132 KV LINE Outages/Trippings							
KANHAN-MANSAR	IntraState	16/11/2022	11:29	16/11/2022	18:05	PO	Routine Maintenance work.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03	17/11/2022	05:30	PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03	17/11/2022	06:20	PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
BHIRA (T) - KHOPOLI 2	IntraState	16/11/2022	10:09	16/11/2022	19:57	PO	For CVT and Relay testing at Bhira End.
AMBERNATH - KALYAN CKT - 1	IntraState	17/11/2022	08:35			PO	Project work for installation of New 110 KV breaker at OFA.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage