

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Jan/2019 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.060	2452.426	1) Gujrat	3.618	36.626
2) Hydro	6.370	113.985	2) Madhya Pradesh	10.418	136.374
3) Gas	7.203	113.796	3) Chattisgarh	3.740	64.540
Total MSPGCL	156.633	2680.207	4) Maharashtra	110.722	1569.660
B) 1) APMIL	66.889	1165.135	5) Goa (Amona)	-0.154	-3.674
2) JSWEL	22.290	385.590	Total	128.344	1803.526
3) VIPL	0.033	81.108	a) Mumbai Schedule	27.484	324.794
4) RPL(AMT)	5.002	19.010	b) Mumbai Drawl	30.012	393.497
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	9.051	180.148
6) Other IPP	11.392	247.815	Include PX	-3.416	-84.622
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.484	324.644
C) 1) TPCL Thermal	5.255	172.320	Include PX	15.270	58.599
2) TPCL Hydro	5.302	64.748	Standby	0.000	0.150
3) TPCL Gas	4.394	74.242	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.803	81.230	1) MSEDCL	371.396	6189.310
D) STATE			2) Mumbai Discoms	49.766	786.039
1) Thermal	258.724	4604.634	TOTAL STATE	421.162	6975.349
(A1+C1+C4+(B1-B6))					
2) Hydro	11.672	178.733			
(A2+C2)					
3) Gas	11.597	188.038			
(A3+B7+C3)					
4) Wind	5.185	103.410			
6) SOLAR	5.640	97.006			
TOTAL STATE	292.818	5171.821			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6567	6522	5974	5318
MSPGCL Hydro	435	255	298	90
MSPGCL Gas	296	274	302	314
MSPGCL Total Generation	7298	7051	6574	5722
Central Sector Receipt	6667	5863	5495	4256
WIND	215	255	262	157
CPP / IPP Thermal	4993	4729	4468	3756
CPP / IPP Gas	0	0	0	0
SOLAR	732	877	0	0
Exchange with Mumbai	-1606	-1576	-1448	-809
MSEDCL DEMAND MET	18299	17199	15351	13082
Load Shedding	0	0	0	0
MSEDCL DEMAND	18299	17199	15351	13082
TPCL GENERATION	762	806	825	385
AEML GENERATION	194	190	192	190
MUMBAI DEMAND	2562	2572	2465	1384
STATE DEMAND MET	20861	19771	17816	14466
STATE DEMAND	20861	19771	17816	14466
Frequency (Hz)	49.99	49.99	49.96	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 15.10 Hrs	49.79 Hz at 06.01 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 17/Jan/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.46	36.88	170	125
Unit 7	3.34	58.59	155	130
Unit 8	12.01	100.56	660	400
Unit 9	12.56	140.92	660	400
Unit 10	0.00	149.01	0	0
Total	31.37	485.96		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.40	164.92	500	350
Unit 5	9.36	164.95	500	350
Total	18.76	329.87		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	56.43	0	0
Total	0.00	56.43		
Chandrapur				
Unit 3	4.24	71.96	190	163
Unit 4	3.93	66.77	176	144
Unit 5	9.25	157.36	405	364
Unit 6	9.40	164.83	460	355
Unit 7	9.63	160.65	440	358
Unit 8	10.78	178.27	490	365
Unit 9	10.49	178.23	487	365
Total	57.72	978.08		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	5.60	91.46	259	191
Total	5.60	91.46		
Khaparkheda				
Unit 1	3.72	62.32	165	145
Unit 2	3.78	61.27	160	145
Unit 3	3.75	63.39	167	149
Unit 4	3.78	62.41	165	150
Unit 5	10.41	168.48	500	374
Total	25.43	417.88		
Nasik				
Unit 3	0.00	22.11	0	0
Unit 4	4.18	70.64	204	161
Unit 5	0.00	0.00	0	0
Total	4.18	92.76		
Uran				
All Units	7.20	113.80	318	272
Total	7.20	113.80		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.05	0.82	23	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.05	0.82		
Koyna				
Stage 1-2	1.78	31.62	260	40
Stage 4	0.39	8.32	152	0
Stage 3	0.40	8.93	144	0
Total	2.57	48.87		
Hydro				
KDPH	0.43	5.96	18	18
VTRNA	0.55	8.57	60	0
TILLARI	0.36	7.46	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.35	3.20	80	0
RNGR+BHTSA	0.30	4.98	14	0
BHANDARDRA	0.00	0.06	0	0
ELDARY	0.00	2.78	0	0
SMLHY_PTN	0.52	6.54	30	19
GHATGHAR	1.28	25.58	250	0
Total	3.80	65.11		
Wind				
Total	5.18	103.41	0	0
Total	5.18	103.41		
CPP				
APML(Mus)	66.89	1165.14	0	0
JSWEL(Mus)	22.29	385.59	0	0
VIPL(Mus)	0.03	81.11	0	0
RPLAMT(Mus)	5.00	19.01	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	11.39	247.82	0	0
Total	105.61	1898.66		
SOLAR				
Total	5.64	97.01	0	0
Total	5.64	97.01		
Tata				
Trombay 5	0.00	83.46	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	47.00	117	115
Trombay 7B	1.61	27.25	68	66
Trombay 8	5.26	88.86	232	201
TATA Hydro	5.30	64.75	433	0
Total	14.95	311.31		
AEML				
DTPS U-1&2	4.80	81.23	252	190
Total	4.80	81.23		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.06	2452.43	MSPGCL Total	156.63	2680.21
			MSPGCL Thml+Gas	150.26	2566.22	Koyna 1,2 & 4 Total	2.17	39.94
			MSPGCL Hydro	6.37	113.98	State Total	292.82	5171.82

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Jan/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5333	462	302	6097	81	3841	0	0	4186	4464	-944	13539	0	13539	1566	15105	50.00
2	5332	143	312	5787	134	3772	0	0	4807	4391	-878	13206	0	13206	1452	14658	50.01
3	5318	90	314	5722	157	3756	0	0	4288	4256	-809	13082	0	13082	1384	14466	49.98
4	5324	96	304	5724	201	3773	0	0	4121	4346	-770	13274	0	13274	1346	14620	50.01
5	5320	91	317	5728	243	3818	0	0	4670	4672	-786	13675	0	13675	1362	15037	50.01
6	5599	91	316	6006	310	4071	0	0	5276	5513	-917	14983	0	14983	1498	16481	50.00
7	6074	187	317	6578	295	4691	0	4	5902	5509	-1075	16002	0	16002	1711	17713	50.00
8	6293	636	318	7247	297	5066	0	53	5986	5766	-1104	17325	0	17325	1896	19221	49.92
9	6401	622	305	7328	218	5174	0	256	6138	6138	-1345	17769	0	17769	2156	19925	50.01
10	6491	633	312	7436	205	5141	0	529	6468	6092	-1507	17896	0	17896	2410	20306	50.05
11	6567	435	296	7298	215	4993	0	732	6619	6667	-1606	18299	0	18299	2562	20861	49.99
12	6558	393	290	7241	209	4959	0	757	6497	6382	-1582	17966	0	17966	2612	20578	50.01
13	6522	255	274	7051	255	4729	0	877	6109	5863	-1576	17199	0	17199	2572	19771	49.99
14	6372	231	284	6887	266	4626	0	819	5862	5648	-1510	16736	0	16736	2439	19175	50.03
15	6393	108	282	6783	242	4312	0	715	5921	6121	-1479	16694	0	16694	2457	19151	49.98
16	6406	236	272	6914	229	4259	0	540	5841	5839	-1433	16348	0	16348	2457	18805	49.90
17	6339	96	286	6721	225	4494	0	294	5787	5781	-1470	16045	0	16045	2470	18515	50.01
18	6167	126	291	6584	214	4456	0	64	5257	5305	-1427	15196	0	15196	2439	17635	49.97
19	5974	298	302	6574	262	4468	0	0	5312	5495	-1448	15351	0	15351	2465	17816	49.96
20	5947	381	295	6623	258	4484	0	0	5108	5167	-1439	15093	0	15093	2434	17527	49.97
21	5721	236	296	6253	238	4328	0	0	4885	5048	-1354	14513	0	14513	2262	16775	49.97
22	5633	271	308	6212	157	4218	0	0	4743	4730	-1272	14045	0	14045	2114	16159	49.98
23	5494	161	300	5955	118	4159	0	0	4701	4548	-1202	13578	0	13578	1946	15524	49.97
24	5482	92	310	5884	156	4019	0	0	4590	4603	-1079	13583	0	13583	1756	15339	49.99
MUs	143.06	6.37	7.20	156.63	5.18	105.61	0.00	5.64	129.07	128.34	-30.01	371.40	0.00	371.40	49.77	421.16	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Jan/2019

Position as on 6.30 Hrs of 18/Jan/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 5	210	22/11/2018	03.50		Continued.	Boiler Tube Leakage Work Completed On 24/11/2018. Available Against Case 4 From 25/11/2018. Converted To COH From 00:00 Hrs of 05/12/2018 (Converted COH to Zero sch by MSEDCL from 29.01.2019)	
AEML	AEML Unit 1	250	23/12/2018	06.06		Continued.	For COH.	
TPC-G	Trombay 5	500	11/01/2019	23.56		Continued.	Annual Overhaul	
MSPGCL	Koyana STG-IV Unit-2	250	14/01/2019	09:40		Continued.	Routine Maintenance work.	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
MSPGCL	Koyana Unit 1	70	26/11/2018	00.00		Continued.	Oil Cooler Leakage.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	14/12/2018	16.30		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	RPL(AMT) U-2	270	27/12/2018	19.30		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/01/2019	19.30		Continued.	Zero Schedule	
IPP	Dhariwal	300	12/01/2019	10.15		Continued.	Coal Shortage	
MSPGCL	Parli Unit 8	250	12/01/2019	12.00		Continued.	Zero Schedule by MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Jan/2019

Position as on 6.30 Hrs of 18/Jan/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 10	660	15/01/2019	23.25		Continued.	Condenser Tube Cleaning Work & PCR.	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
IPP	RPL(AMT) U-1	270	18/01/2019	19.30		Continued.	Zero Schedule.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 18/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	17/01/2019	20.24	18/01/2019	03.11	EO	To attend Pole-2 Conversion T/F OLTC oil Leakage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	10/01/2019	16.32		Continued.	HT	Over Voltage
Dabhol Nagothane I	InterState	18/01/2019	11.52		Continued.	PO	String Replacement of Insulator Strings.
Jaigad-Karad Ckt-I	IntraState	16/01/2019	12.50	17/01/2019	09.20	EO	Emergency HT sparking observed at karad end(RFC 13.32 16.01.2019)
Khadka-Aurangabad (Waluj)	IntraState	16/01/2019	18.20	17/01/2019	07.07	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	17/01/2019	00.52	17/01/2019	07.16	HT	Over Voltage
Deepnagar - Aurangabad	IntraState	17/01/2019	07.17	17/01/2019	15.13	PO	Mid Span and Dead end replacement
Nagothane - Dabhol I	IntraState	17/01/2019	09.25	17/01/2019	19.01	PO	Insulator String replacement
Girwali - Lonikand 1	IntraState	17/01/2019	10.36	17/01/2019	17.05	PO	Half yearly maintenance work
Bhusawal-Aurangabad	IntraState	17/01/2019	16.13	18/01/2019	07.42	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	18/01/2019	00.01	18/01/2019	07.34	HT	Over Voltage
Warora -IEPL	IntraState	18/01/2019	10.38	18/01/2019	18.18	PO	Tightening of Nut Bolts.
Girwali - Lonikand 1	IntraState	18/01/2019	14.12	18/01/2019	16.52	EO	Attending Hot Spot on R PH CT Stud.
Khadka-Aurangabad (Waluj)	IntraState	18/01/2019	17.31		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220kv 315 Mva ICT III @Karad	IntraState	17/01/2019	08.55	17/01/2019	18.29	PO	Tan Delta Measurment of CTs
400/220 KV 500MVA ICT II @ Nanded	IntraState	17/01/2019	11.27	17/01/2019	17.59	PO	Tan Delta Measurment of CTs
400/220KV 315MVA ICT3@Bhusawal II (khadaka)	IntraState	17/01/2019	12.22	17/01/2019	20.52	PO	Commissioning of CSD Relay
400/220 Kv 315 MVA ICT-II @Chakan	IntraState	17/01/2019	13.02	17/01/2019	19.11	PO	Testing Work
400/220kv, 500 Mva ICT-1 @Deepnagar	IntraState	18/01/2019	15.45	18/01/2019	16.41	EO	Tightning of Tubes Connecting R & Y Phase For Delta Formation of Tertiary Winding.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.
Nanded - Parli Ext. Ckt I	IntraState	06/12/2018	07.02		Continued.	HT	Waghala-Kumbhargaoon CKT O/L.
Wadkhal-ARCL-2	IntraState	15/01/2019	11.25	17/01/2019	17.00	PO	Replacement of PT.
TPC Borivali Aarey Line 1	IntraState	17/01/2019	00.35	17/01/2019	05.17	PO	Girder erection work by DMRC
REL Borivali Aarey Line	IntraState	17/01/2019	00.52	17/01/2019	05.41	PO	Girder erection work by DMRC
Nagothane - Spcl	IntraState	17/01/2019	06.19	17/01/2019	19.20	EO	CT Replacement
IPCL - SPCL	IntraState	17/01/2019	06.19	17/01/2019	10.46	T	R Phase Bus PT Burst at SPCL

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 18/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kalwa - Colourchem	IntraState	17/01/2019	08.25	17/01/2019	18.00	PO	Replacement of Insulator String
Adlabs - Pedambe	IntraState	17/01/2019	09.05	17/01/2019	17.20	PO	Washing of Insulator String
Chakan-Chinchwad	IntraState	17/01/2019	10.01	17/01/2019	19.35	PO	Conversion of SSN to DSN
Ghatghar - Jindal	IntraState	17/01/2019	10.50	17/01/2019	17.51	PO	E/W replacement work
Main Bus-III @ Mudshingi	IntraState	17/01/2019	11.45	17/01/2019	19.45	PO	Caution permit for hot line work
Shirsuphal-Bhigwan	IntraState	17/01/2019	12.50	17/01/2019	14.55	PO	Testing Work
Trombay - Kalwa	IntraState	17/01/2019	14.03	17/01/2019	16.48	T	Distance Protection B-E
Raymond - Washala	IntraState	17/01/2019	15.45	17/01/2019	17.35	PO	Tan Delta Measurment of CTs
Kalwa - Colourchem	IntraState	17/01/2019	19.56	18/01/2019	07.27	T	Tripped at Kalwa Zone 1, R & Y Phase to ground
Kalwa - Borivali	IntraState	18/01/2019	07.30	18/01/2019	10.10	EO	Attending Hot Spot
Washala - Ghatghar	IntraState	18/01/2019	08.52	18/01/2019	18.34	PO	Earthwire Replacement Work.
Nanded-Parbhani	IntraState	18/01/2019	09.21	18/01/2019	21.52	T	In View of Outage of Bus Section At Yavatmal.
Ghatghar - Jindal	IntraState	18/01/2019	09.25	18/01/2019	19.06	PO	Earthwire Replacement Work.
Pusad-Ghatodi	IntraState	18/01/2019	09.35	18/01/2019	21.52	T	In View of Outage of Bus Section At Yavatmal.
Pusad - Hingoli	IntraState	18/01/2019	09.35	18/01/2019	21.50	T	In View of Outage of Bus Section At Yavatmal.
220KV Chalisagaon-Kopergaon	IntraState	18/01/2019	10.01	18/01/2019	17.25	PO	Replacement of CT.
Pusad-Ghatodi	IntraState	18/01/2019	10.10	18/01/2019	18.09	PO	Diagnostic Testing Work, Measurement of Tan Delta of CT.
Nalasopara-Boisar	IntraState	18/01/2019	10.41	18/01/2019	17.25	PO	Routine Maintenance Work
Half Bus section-I @ Yavatmal	IntraState	18/01/2019	10.56	18/01/2019	21.16	PO	Jumper Replacement work.
Kanhan-Bhandara I	IntraState	18/01/2019	11.22	18/01/2019	17.37	PO	Diagnostic Testing Work.
Chakan-Chinchwad	IntraState	18/01/2019	13.41	18/01/2019	15.09	T	Distance Protection, Zone1, R&Y PH. 12KA.
Topworth - Kharghar	IntraState	18/01/2019	23.05	18/01/2019	23.16	HT	Hand tripped Due To AR Successful But Unbalance Load RYB Phase.
220 KV ICT Outages/Trippings							
220/110KV, 200MVA T/F-III at Mudshingi	InterState	18/01/2019	10.30	18/01/2019	13.25	PO	Quarterly Maintenance Work
220/132 Kv 100mva Cgl Ptr No 6 @Chinchwad	IntraState	17/01/2019	09.55	17/01/2019	14.49	PO	Testing Work
220/100 Kv 200 MVA ICT II @Kolshet	IntraState	17/01/2019	11.45	17/01/2019	15.37	PO	WTI/OTI replacement work
220/33 Kv 50 Mva Apex Ptr 1 @Boisar-Ii	IntraState	18/01/2019	07.15	18/01/2019	10.00	PO	Diagnostic Testing Work.
220/22 Kv 50 Mva Bhel Ptr 1 @Padghe	IntraState	18/01/2019	10.07	18/01/2019	18.26	PO	Diagnostic Testing Work.
220/22 Kv 50 Mva Cgl Ptr 1 @Kalwa	IntraState	18/01/2019	11.34	18/01/2019	16.04	PO	Maintenance Work of Isolators.
220/33kV 100 MVA ICT-II @ Boisar	IntraState	18/01/2019	15.10	18/01/2019	20.07	PO	Diagnostic Testing Work.
132 KV LINE Outages/Trippings							
Pusad-Jambazar	IntraState	18/01/2019	09.06	18/01/2019	21.53	T	In View of Outage of Bus Section At Yavatmal.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage