

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Feb/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.583	2601.876	1) Gujrat	3.766	-76.114
2) Hydro	14.857	214.291	2) Madhya Pradesh	3.521	74.493
3) Gas	3.229	85.691	3) Chattisgarh	4.990	78.210
Total MSPGCL	177.669	2901.858	4) Maharashtra	156.097	2933.977
B) 1) APLM	76.179	1234.861	5) Goa (Amona)	-1.361	-23.178
2) JSWEL	23.811	326.096	Total	167.013	2987.388
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.871	502.224
4) RPL(AMT)	31.141	511.608	b) Mumbai Drawl	38.907	587.625
5) SWPGPL	7.348	140.230	c) MSEDCL Bilateral *	73.318	1229.234
6) Other IPP	41.353	723.149	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.858	501.825
C) 1) TPCL Thermal	12.511	116.034	Include PX	0.000	0.000
2) TPCL Hydro	3.902	70.698	Standby	0.013	0.400
3) TPCL Gas	0.000	30.587	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.549	164.838	1) MSEDCL	508.593	8515.355
D) STATE			2) Mumbai Discoms	65.869	969.782
1) Thermal	362.475	5818.692	3) Other Discoms	10.023	168.585
(A1+C1+C4+(B1-B6))			TOTAL STATE	584.485	9653.722
2) Hydro (A2+C2)	18.759	284.989			
3) Gas (A3+B7+C3)	3.229	116.278			
4) Wind	16.132	180.101			
6) SOLAR	16.877	266.274			
TOTAL STATE	417.472	6666.334			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6892	6157	6841	6142
MSPGCL Hydro	561	813	1667	334
MSPGCL Gas	134	123	132	140
MSPGCL Total Generation	7587	7093	8640	6616
Central Sector Receipt	7861	8167	6585	6267
WIND	1093	729	391	729
CPP / IPP Thermal	7691	7456	7674	7232
CPP / IPP Gas	0	0	0	0
SOLAR	2069	2273	0	0
Exchange with Mumbai	-1846	-2190	-1590	-1432
MSEDCL DEMAND MET	24010	23086	21224	19045
Load Shedding	0	0	0	0
MSEDCL DEMAND	24010	23086	21224	19045
TPCL GENERATION	916	680	978	436
AEML GENERATION	482	477	498	480
MUMBAI DEMAND	3244	3347	3066	2348
OTHER DISCOM DEMAND	445	442	476	367
STATE DEMAND MET	27699	26875	24766	21760
STATE DEMAND	27699	26875	24766	21760
Frequency (Hz)	50.03	50.00	50.01	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 06.02 Hrs	49.67 Hz at 22.09 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 17/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.76	69.65	195	0
Unit 8	14.04	232.76	641	533
Unit 9	13.32	225.27	599	515
Unit 10	12.64	202.34	565	505
Total	42.76	730.02		
Bhusawal				
Unit 3	3.58	55.72	165	115
Unit 4	10.20	172.95	470	295
Unit 5	9.86	169.02	460	275
Total	23.64	397.69		
Parli				
Unit 6	5.18	77.73	236	153
Unit 7	5.26	41.35	248	151
Unit 8	2.77	58.71	118	108
Total	13.21	177.80		
Chandrapur				
Unit 3	3.71	59.74	166	130
Unit 4	3.34	49.50	150	116
Unit 5	0.00	76.31	0	0
Unit 6	9.09	143.91	410	290
Unit 7	0.00	0.00	0	0
Unit 8	11.66	190.28	495	470
Unit 9	11.32	106.59	495	445
Total	39.11	626.33		
Paras				
Unit 3	4.77	83.40	231	177
Unit 4	5.77	97.68	245	234
Total	10.54	181.09		
Khaparkheda				
Unit 1	2.24	34.02	110	80
Unit 2	2.75	46.38	125	100
Unit 3	3.58	62.41	180	133
Unit 4	3.59	51.68	164	133
Unit 5	10.71	181.46	473	410
Total	22.87	375.96		
Nasik				
Unit 3	3.85	61.91	175	121
Unit 4	0.00	2.54	0	0
Unit 5	3.60	48.55	170	118
Total	7.45	113.00		
Uran				
All Units	3.23	85.69	143	121
Total	3.23	85.69		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.44	8.32	42	0
Total	0.44	8.32		
Koyna				
Stage 1-2	4.27	56.77	535	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	3.71	47.77	755	0
Stage 3	1.63	22.54	320	0
Total	9.61	127.09		
Hydro				
KDPH	0.86	13.11	36	36
VTRNA	1.00	9.24	61	0
TILLARI	0.46	6.63	58	0
BHIRA T.R.	0.12	4.42	40	0
SMLHY_PTN	2.36	40.85	102	89
GHATGHAR	0.00	4.64	0	0
Total	4.81	78.88		
Wind				
Total	16.13	180.10	0	0
Total	16.13	180.10		
CPP				
APML(Mus)	76.18	1234.86	0	0
JSWEL(Mus)	23.81	326.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.14	511.61	0	0
SWPGPL-Mus	7.35	140.23	0	0
Dhariwal	0.00	18.40	0	0
IEPL	5.62	86.04	264	195
Other(Mus)	35.73	618.71	0	0
Total	179.83	2935.94		
SOLAR				
Total	16.88	266.27	0	0
Total	16.88	266.27		
Tata				
Trombay 5	8.05	47.27	458	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	16.65	0	0
Trombay 7B	0.00	13.94	0	0
TATA Hydro	3.90	70.70	289	7
Trombay 8	4.46	68.76	238	131
Total	16.41	217.32		
AEML				
DTPS U-1&2	10.55	164.84	498	333
Total	10.55	164.84		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.58	2601.88	MSPGCL Total	177.67	2901.86
			MSPGCL Thml+Gas	162.81	2687.57	Koyna 1,2 & 4 Total	7.98	104.54
			MSPGCL Hydro	14.86	214.29	State Total	417.47	6666.33

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 17/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6142	334	140	6616	729	7232	0	0	6171	6267	-1432	19045	0	19045	2348	367	21760	49.94
2	6423	296	141	6860	678	7228	0	0	6343	6551	-1328	19646	0	19646	2175	343	22164	50.00
3	6532	179	143	6854	679	7251	0	0	6508	6376	-1255	19580	0	19580	2033	325	21938	50.01
4	6542	174	143	6859	667	7317	0	0	6484	6399	-1193	19738	0	19738	1949	311	21998	50.02
5	6593	296	142	7031	719	7412	0	0	6643	6468	-1182	20110	0	20110	1949	338	22397	50.00
6	6638	900	143	7681	717	7688	0	0	6326	6246	-1074	20899	0	20899	2091	359	23349	50.00
7	6685	1281	143	8109	772	7701	0	9	6432	6289	-988	21499	0	21499	2291	393	24183	50.00
8	6746	1830	142	8718	699	7687	0	298	6572	6659	-1124	22504	0	22504	2462	433	25399	49.96
9	6804	1174	142	8120	672	7711	0	986	6848	7037	-1343	22752	0	22752	2717	431	25900	50.06
10	6875	818	137	7830	842	7688	0	1593	7463	7382	-1569	23333	0	23333	3004	433	26770	50.01
11	6892	561	134	7587	1093	7691	0	2069	8196	7861	-1846	24010	0	24010	3244	445	27699	50.03
12	6436	615	130	7181	915	7584	0	2247	7922	8147	-2103	23522	0	23522	3372	449	27343	50.00
13	6157	813	123	7093	729	7456	0	2273	8049	8167	-2190	23086	0	23086	3347	442	26875	50.00
14	6333	441	121	6895	719	7213	0	2206	8271	8300	-2250	22648	0	22648	3129	435	26212	50.06
15	6683	304	126	7113	613	7226	0	2047	8681	8256	-2314	22497	0	22497	3148	444	26089	50.02
16	6727	353	125	7205	575	7202	0	1658	8397	8307	-2280	22214	0	22214	3183	453	25850	50.01
17	6812	399	124	7335	499	7481	0	1119	7686	7806	-2093	21685	0	21685	3197	462	25344	50.00
18	6844	288	123	7255	348	7597	0	363	7113	7174	-1941	20332	0	20332	3214	464	24010	50.02
19	6879	832	133	7844	314	7664	0	9	6418	6474	-1768	20061	0	20061	3117	476	23654	49.98
20	6841	1667	132	8640	391	7674	0	0	6234	6585	-1590	21224	0	21224	3066	476	24766	50.01
21	6819	502	135	7456	553	7631	0	0	6210	6213	-1465	19938	0	19938	2900	450	23288	50.01
22	6768	285	135	7188	722	7437	0	0	6182	6287	-1565	19625	0	19625	2751	444	22820	49.98
23	6738	244	136	7118	751	7463	0	0	5973	5866	-1498	19265	0	19265	2636	435	22336	49.91
24	6674	271	136	7081	736	7598	0	0	5871	5896	-1516	19396	0	19396	2546	399	22341	49.96
MUs	159.58	14.86	3.23	177.67	16.13	179.83	0.00	16.88	166.99	167.01	-38.91	508.61	0.00	508.61	65.87	10.00	584.49	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 17/Feb/2023

Position as on 6.30 Hrs of 18/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	22/02/2023
IPP	Dhariwal	300	05/02/2023	00:00		Continued.	Annual Overhaul	22/02/2023
IPP	SWPGPL U-2	135	08/02/2023	00:01		Continued.	Bag Filter replacement work	02/03/2023
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05		Continued.	Boiler validity work	27/02/2023
TPC-G	Bhira PSU	150	15/02/2023	04:30		Continued.	Tunnel 1 inspection, RM Trials, Calibration and testing work.	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	20/02/2023
MSPGCL	Nasik Unit 4	210	01/02/2023	19:24		Continued.	NASHIK TPS U#4 TOLLING FROM DATED 02.02.2023 at 03.43 A.M	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Koradi Unit 6	210	15/02/2023	02:30	17/02/2023	07:51	SUSPECED BTL	17/02/2023
MSPGCL	Uran Unit 6	108	15/02/2023	13:13		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	15/02/2023	16:54		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	15/02/2023	17:12	18/02/2023	17:34	Gas shortage	
TPC-G	Trombay 7A	120	18/02/2023	21:27		Continued.	Gas shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 18/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	17/02/2023	17:08	17/02/2023	22:42	EO	Emergency shutdown of HVDC Pole-1 Valve Hall (R-Ph Quadruple valve) to attend Water Leakage at R-Ph Quadruple valve
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	IntraState	15/02/2023	11:13	18/02/2023	20:22	PO	89A and 89B PG isolator overhauling work.
MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA	IntraState	17/02/2023	14:14	17/02/2023	19:05	PO	DCRM, Tandelta & routine maintenance work
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	17/02/2023	08:37	17/02/2023	18:53	PO	CVT testing work
DHULE - SSNNL CKT - 2	InterState	18/02/2023	08:57	18/02/2023	18:59	PO	CVT (Capacitance tan delta) testing work.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/02/2023	17:50	17/02/2023	03:10	T	TRIPPED ON SOTF WHILE RETURNING AFTER OUTAGE
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	17/02/2023	08:54	18/02/2023	14:50	HT	H/T due to Load Management
NEW KOYNA - DABHOL CKT - 2	IntraState	17/02/2023	10:36	17/02/2023	17:58	PO	Cold washing & string replacement work
DEEPNAGAR - THAPTI TANDA	IntraState	17/02/2023	11:55	17/02/2023	19:01	PO	For 400 kV Main Bus - 1 bus bar testing work, current injection through line CT is required. Bus isolator maintenance work.
MAIN BUS - 1 @ TAPTITANDA	IntraState	17/02/2023	12:26	17/02/2023	18:55	PO	Bus bar testing of entire scheme and maintenance of bus Isolator.
PADGHE - KALWA CKT - 2	IntraState	18/02/2023	00:10		Continued.	PO	Replacement of existing conductor/ hardware/ insulators by HTLS conductor/hardware/ insulators.
KORADI-NANDGAONPETH (RPL)	IntraState	18/02/2023	15:06	18/02/2023	18:09	EO	As 400KV Koradi- Nandgaonpeth RPL got A/R at 04:55 Hrs on dt 18.02.2023, Patrolling was carried out & Flashover Marks were observed on B Ph String Hardware at loc no 110 . Hence replacement of F/O String is needed to be carried out on urgent basis.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	18/02/2023	15:15	18/02/2023	23:25	HT	Emergency HT due to heavy sparking on Y PH PG isolator of main bus-A.
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	14/02/2023	09:52	18/02/2023	16:55	PO	FOR LV side CB REPLACEMENT WORK
400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	17/02/2023	10:17	17/02/2023	11:59	PO	Diagnostic Testing Work
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	17/02/2023	11:26	17/02/2023	17:24	PO	For PID testing work of Aux bus section-2
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	17/02/2023	11:37	17/02/2023	21:22	PO	Replacement of RET 670 Relay as existing reley is faulty 2) NIFPS Maint work 3) Bay maint work 4) MTAMC work
400 KV BR Outages/Trippings							
400 KV GT- 5 MAIN BAY (422)	IntraState	16/02/2023	10:12		Continued.	PO	For servicing & overhauling of 400kV AREVA make GT-V Main C.B. Mechanism
220 KV MAINBAY Outages/Trippings							
BUS @ VIRAJ	IntraState	17/02/2023	11:14	17/02/2023	17:00	PO	Annual 220 kV Bus Isolator maintenance and 220 kV Bus PT Tan Delta and IR. 50 MVA PTR 1 Bushing Tan Delta & PI

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 18/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TBC @ HINJEWADI-2	IntraState	18/02/2023	09:09	18/02/2023	11:15	PO	Half yearly maintenance
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work.
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
TROMBAY SALSETTE LINE-2	IntraState	16/02/2023	23:03	17/02/2023	04:33	PO	400KV KVPTL WORK
WAGHIVALI - DHARAVI 8	IntraState	17/02/2023	08:06			PO	Project work for shifting of conductor of Trombay Dharavi Salsette line.
KHAREPATAN -PAWAS LINE	IntraState	17/02/2023	09:19	17/02/2023	18:34	PO	For tree cutting work (trees which are in induction zone).
URAN - KHARGHAR 2	IntraState	17/02/2023	09:28	17/02/2023	18:03	PO	For disc insulator string replacement work & Diagnostic testing and bay maint's work.
BHIRA - KARANJADE 7	IntraState	17/02/2023	09:31	17/02/2023	16:47	PO	R/M AND TESTING AT BHIRA
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	17/02/2023	10:18	17/02/2023	23:28	HT	Due to Load Management.
KANDALGAON - POSCO	IntraState	17/02/2023	10:20	17/02/2023	19:35	PO	Diagnostic testing, Relay testing and Bay maintenance work at 220KV kandalgaon ss.
VERSOVA - GHODBUNDER	IntraState	17/02/2023	11:29	17/02/2023	13:11	T	Tripped on Differential Distance Protection.
SADAWAGHAPUR KARAD CKT 1	IntraState	17/02/2023	12:01	17/02/2023	15:13	T	Tripped on Distance Protection.
CHALISGAON -KOPARGAON	IntraState	17/02/2023	18:30	17/02/2023	19:50		For attending hotspot (on wavetrap)
TROMBAY - SALSETTE CKT - 1	IntraState	17/02/2023	19:55	17/02/2023	23:56	PO	Project work in vicinity for shifting of conductor of Trombay Dharavi Salsette line.
KHAREPATAN -PAWAS LINE	IntraState	18/02/2023	08:59	18/02/2023	18:55	PO	For tree cutting work (trees which are in induction zone).
SHEDYAL-JATH	IntraState	18/02/2023	09:53		Continued.	PO	Quarterly Maintenance Work
MHAISHAL - SHEDYAL	IntraState	18/02/2023	10:12		Continued.	PO	Quarterly Maintenance Work
NAGAR BELWANDI CKT 1	IntraState	18/02/2023	11:35	18/02/2023	17:05		Replacement of R ph flashover string at loc No. 102 (found during vertical patrolling)
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	17/02/2023	07:12	17/02/2023	12:16	PO	1)For oil top up 2)Oil leakage attending 3)OLTC overhauling 4) Y ph LA replacement

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 18/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 200 MVA ICT 2 @ BABHLESHWAR	IntraState	17/02/2023	10:17	17/02/2023	18:53		Diagnostic Testing of Bay equipments and attending red hot and oil leakage
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	17/02/2023	10:45	17/02/2023	17:25	PO	1. FOR ATTENDING PROBLEM OF CTR & FDR 2. CHECKING HEALTHYNESS OF CTR 3. TAKING TRIL OF WTI & OTI. 4. ATTENDING HOTSPOT
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ URAN	IntraState	17/02/2023	10:40	17/02/2023	18:20	PO	For MAIN BUS 1 insulator string replacement work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage