

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Mar/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.816	2642.221	1) Gujrat	-4.980	-117.467
2) Hydro	45.784	382.604	2) Madhya Pradesh	10.193	163.198
3) Gas	4.616	61.436	3) Chattisgarh	4.750	92.360
Total MSPGCL	213.216	3086.261	4) Maharashtra	177.360	2813.091
B) 1) APLM	60.743	1255.337	5) Goa (Amona)	-1.511	-21.399
2) JSWEL	18.032	341.820	Total	185.812	2929.783
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.891	482.233
4) RPL(AMT)	25.685	428.921	b) Mumbai Drawl	34.559	524.481
5) SWPGPL	6.395	99.409	c) MSEDCL Bilateral *	80.803	1685.246
6) Other IPP	40.031	679.389	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.877	482.100
C) 1) TPCL Thermal	14.740	223.243	Include PX	0.000	5.604
2) TPCL Hydro	8.720	86.165	Standby	0.014	0.133
3) TPCL Gas	2.834	19.686	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.147	150.851	1) MSEDCL	525.423	8426.957
D) STATE			2) Mumbai Discoms	67.000	1004.426
1) Thermal	334.589	5821.191	3) Other Discoms	8.892	148.822
(A1+C1+C4+(B1-B6))			TOTAL STATE	601.315	9580.205
2) Hydro	54.504	468.769			
(A2+C2)					
3) Gas	7.450	81.122			
(A3+B7+C3)					
4) Wind	10.118	146.069			
6) SOLAR	8.842	133.271			
TOTAL STATE	415.503	6650.422			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6709	6738	6697	6692
MSPGCL Hydro	2176	2106	1774	1883
MSPGCL Gas	223	211	217	170
MSPGCL Total Generation	9108	9055	8688	8745
Central Sector Receipt	9559	9331	7003	6728
WIND	386	349	577	456
CPP / IPP Thermal	6256	6285	6493	6265
CPP / IPP Gas	0	0	0	0
SOLAR	1172	1197	0	0
Exchange with Mumbai	-1867	-1891	-1499	-1463
MSEDCL DEMAND MET	24219	23933	20847	20354
Load Shedding	0	0	0	0
MSEDCL DEMAND	24219	23933	20847	20354
TPCL GENERATION	1192	1153	1139	948
AEML GENERATION	245	247	250	299
MUMBAI DEMAND	3304	3291	2888	2710
OTHER DISCOM DEMAND	395	393	415	377
STATE DEMAND MET	27918	27617	24150	23441
STATE DEMAND	27918	27617	24150	23441
Frequency (Hz)	49.90	49.95	49.98	49.91

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 18:01 Hrs	49.59 Hz at 22:10 Hrs	49.94	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 17/Mar/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.92	70.88	170	155
Unit 7	0.00	0.00	0	0
Unit 8	13.68	231.23	595	556
Unit 9	12.26	225.29	526	501
Unit 10	10.76	171.95	510	390
Total	40.62	699.34		
Bhusawal				
Unit 3	0.00	38.67	0	0
Unit 4	11.46	152.00	495	455
Unit 5	10.04	41.10	490	285
Total	21.50	231.78		
Parli				
Unit 6	4.51	77.60	233	150
Unit 7	0.00	66.38	0	0
Unit 8	3.57	56.26	152	145
Total	8.09	200.24		
Chandrapur				
Unit 3	0.00	44.44	0	0
Unit 4	4.10	67.14	178	166
Unit 5	8.74	126.74	380	330
Unit 6	9.90	78.51	430	378
Unit 7	8.33	152.06	400	292
Unit 8	10.90	132.96	478	415
Unit 9	10.87	175.45	461	442
Total	52.85	777.31		
Paras				
Unit 3	4.70	91.10	213	154
Unit 4	4.71	89.55	214	179
Total	9.41	180.65		
Khaparkheda				
Unit 1	3.66	57.58	160	140
Unit 2	3.81	60.10	165	150
Unit 3	0.02	59.24	25	0
Unit 4	4.29	68.17	194	150
Unit 5	11.02	180.12	495	410
Total	22.80	425.22		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.20	69.63	192	157
Unit 5	3.36	58.06	157	118
Total	7.56	127.69		
Uran				
All Units	4.62	61.44	243	139
Total	4.62	61.44		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	3.16	38	0
Total	0.15	3.16		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	10.24	85.07	520	95
Stage 4	21.34	130.29	1060	400
Stage 3	6.42	45.56	320	158
Total	38.01	260.93		
Hydro				
KDPH	0.63	11.67	36	18
VTRNA	0.00	0.00	0	0
TILLARI	0.23	1.68	58	0
BHIRA T.R.	0.48	4.82	80	0
SMLHY_PTN	6.28	100.34	284	238
GHATGHAR	0.00	0.00	0	0
Total	7.63	118.51		
Wind				
Total	10.12	146.07	0	0
Total	10.12	146.07		
CPP				
APML(Mus)	60.74	1255.34	0	0
JSWEL(Mus)	18.03	341.82	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.68	428.92	0	0
SWPGPL-Mus	6.40	99.41	0	0
Other(Mus)	40.03	679.39	0	0
Total	150.89	2804.88		
SOLAR				
Total	8.84	133.27	0	0
Total	8.84	133.27		
Tata				
Trombay 5	9.04	150.62	397	349
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.60	11.65	95	48
Trombay 7B	1.23	8.04	61	41
TATA Hydro	8.72	86.16	444	213
Trombay 8	5.70	72.62	245	219
Total	26.29	329.09		
AEML				
DTPS U-1&2	6.15	150.85	396	244
Total	6.15	150.85		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.82	2642.22	MSPGCL Total	213.22	3086.26
			MSPGCL Thml+Gas	167.43	2703.66	Koyna 1,2 & 4 Total	31.59	215.36
			MSPGCL Hydro	45.78	382.60	State Total	415.50	6650.42

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 17/Mar/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6876	2128	139	9143	453	6501	0	0	6380	6885	-1372	21312	0	21312	2680	298	24290	49.85
2	6892	2145	139	9176	364	6283	0	0	6844	6961	-1236	21271	0	21271	2514	277	24062	49.86
3	6855	2197	140	9192	365	6189	0	0	6724	6912	-990	21389	0	21389	2374	279	24042	49.92
4	6845	2139	151	9135	366	6161	0	0	6756	6869	-942	21307	0	21307	2252	282	23841	49.95
5	6862	2127	140	9129	372	6133	0	0	6897	7130	-1012	21461	0	21461	2179	291	23931	49.87
6	6938	2109	142	9189	464	6289	0	0	6974	7384	-919	22075	0	22075	2214	332	24621	49.84
7	6952	2223	160	9335	497	6452	0	12	6978	7130	-848	22225	0	22225	2269	353	24847	49.98
8	6916	1866	243	9025	491	6460	0	189	7545	7501	-1019	22268	0	22268	2342	379	24989	50.00
9	6902	1269	241	8412	369	6244	0	558	7863	8053	-1324	21904	0	21904	2599	408	24911	50.02
10	6845	1902	228	8975	382	6172	0	881	7856	8493	-1545	22950	0	22950	2915	408	26273	49.90
11	6798	2191	235	9224	427	6176	0	1116	8228	8904	-1748	23696	0	23696	3167	403	27266	49.89
12	6709	2176	223	9108	386	6256	0	1172	8783	9559	-1867	24219	0	24219	3304	395	27918	49.90
13	6738	2106	211	9055	349	6285	0	1197	9071	9331	-1891	23933	0	23933	3291	393	27617	49.95
14	6822	1933	223	8978	414	6064	0	1169	8950	8888	-1820	23296	0	23296	3215	397	26908	50.00
15	6794	1718	224	8736	450	6063	0	1030	9233	9104	-1859	23134	0	23134	3277	390	26801	49.97
16	6723	1906	214	8843	257	6176	0	796	8820	9205	-1914	22957	0	22957	3312	406	26675	49.94
17	6718	1958	214	8890	257	6324	0	532	8121	8761	-1835	22518	0	22518	3228	411	26157	50.00
18	6605	1885	226	8716	358	6426	0	184	7864	7706	-1665	21303	0	21303	3073	422	24798	50.01
19	6645	1534	227	8406	436	6469	0	6	7223	7108	-1503	20493	0	20493	2919	429	23841	49.98
20	6697	1774	217	8688	577	6493	0	0	7002	7003	-1499	20847	0	20847	2888	415	24150	49.98
21	6620	1138	170	7928	654	6499	0	0	6735	6585	-1425	19833	0	19833	2789	408	23030	50.00
22	6675	1412	160	8247	611	6274	0	0	6565	6589	-1438	19899	0	19899	2684	384	22967	50.00
23	6692	1883	170	8745	456	6265	0	0	6295	6728	-1463	20354	0	20354	2710	377	23441	49.91
24	6697	2065	179	8941	363	6232	0	0	6286	7023	-1425	20780	0	20780	2805	354	23939	49.86
MUs	162.82	45.78	4.62	213.22	10.12	150.89	0.00	8.84	179.99	185.81	-34.56	525.42	0.00	525.42	67.00	8.89	601.32	49.94

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 17/Mar/2022

Position as on 6.30 Hrs of 18/Mar/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
MSPGCL	Koyana Unit 6	80	18/03/2022	07:30		Continued.	Needle O/H and P.M.Work	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Uran Unit A0	120	21/02/2022	21:57	18/03/2022	13:39	Gas shortage	
IPP	SWPGPL U-4	135	25/02/2022	16:47		Continued.	Turbine Vibration	
IPP	RPL(AMT) U-1	270	07/03/2022	02:39		Continued.	Generator Protection operated. (from 15/03/2022 due to coal shortage)	
MSPGCL	Ghatghar Unit-2	125	11/03/2022	01:25		Continued.	TRIPPED ON SFC HEAVY FAULT WHILE TAKING ON PUMPING MODE.(PUMPING TRIAL CARRIED OUT SUCCESSFULLY FROM 20:35HRS TO 22:35HRS DT.10/03/22)	
MSPGCL	Chandrapur Unit 3	210	11/03/2022	08:43	18/03/2022	08:50	WITHDRAWN FOR ATTENDING HPCV-I STEAM LEAKAGE WORK	
MSPGCL	Uran Unit 5	108	14/03/2022	00:00		Continued.	Gas shortage	
AEML	AEML Unit 1	250	14/03/2022	12:32	17/03/2022	22:13	stuck up of barring gear	
MSPGCL	Khaparkheda Unit 3	210	15/03/2022	03:27	17/03/2022	23:21	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 3	210	15/03/2022	19:38	18/03/2022	12:07	Coal Shortage	
MSPGCL	Parli Unit 7	250	15/03/2022	23:10		Continued.	Furnace Pressure High	
IPP	Adani U-3	660	16/03/2022	11:54		Continued.	Primary Duct Leakage	
MSPGCL	Uran Unit 6	108	16/03/2022	21:00	17/03/2022	06:28	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Mar/2022

Position as on 6.30 Hrs of 18/Mar/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Bhusawal Unit 5	500	18/03/2022	01:26		Continued.	bottom ash clinker formation	
MSPGCL	Chandrapur Unit 3	210	18/03/2022	14:30	18/03/2022	17:37	HIGH PRESSURE HEATER LEVEL VERY HIGH	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Mar/2022

Statement-VII

Position as on 6.30 Hrs of 18/Mar/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	12/03/2022	15:01			T	Pole-2 tripped at Padghe end.Black smoke observed near pole 2, B phase converter transformer's 3A bushing - turret. Fire looked external and it was extinguished in 10-15 minjutes using fire tenders and fire hydrant
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	16/03/2022	23:24	17/03/2022	04:57	EO	Attending RED HOT at pole-1 base filter Z11- Z2 at jumper connecting to Capacitor bushing
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	17/03/2022	11:31	17/03/2022	15:58	T	Tripped on distance protection
CHANDRAPUR - BHADRAVATI CKT - 3	InterState	18/03/2022	16:13	18/03/2022	18:52	T	Tripped on distance protection
KORADI - KHADKA	IntraState	17/03/2022	14:57	17/03/2022	16:33	T	TRIPPED ON DIST. PROTN.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	18/03/2022	16:18	18/03/2022	19:38	T	Y-B ph 23 KA 9.9 Km from Chandrapur 2 end
400 KV ICT Outages/Trippings							
400/220/33 KV 315MVA ICT - 2 @ CHAKAN	IntraState	16/03/2022	22:28	17/03/2022	04:51	EO	To replace LV 220kV B ph CT due to oil leakage
400/220/33KV 500 MVA ICT - 1 @ KUDUS	IntraState	17/03/2022	16:22	17/03/2022	17:22	EO	The 400/220/33kV, 500MVA ICT-1 was tripped on dated 08.03.2022, is charged on 15.03.2022 at 23:03 hrs after all testing, oil top up and filtration and kept on humming for 24 hrs before taking on load. Therefore, we need to Hand-Trip 400/220/33kV ICT-1 for 1 hour (from 9:00 hrs to 10:00 hrs) on 17.03.2022 for Air Releasing
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	18/03/2022	10:04	18/03/2022	16:57	PO	1) Bph IV Bushing leakage attending work 2) Hot Spot on YPh ,Bph IV bushing 120,110deg resp 3) Hot Spot C bus Rph PG isolator and B bus YPh PH isolator 110,100deg resp.
400/220/33 KV 315MVA ICT - 1 @ CHAKAN	IntraState	18/03/2022	11:29	18/03/2022	17:25	EO	The 89A R ph Isolator Rotary Insulator is Damaged and Isolator Scissor Is contact Gap is Created So Heavy Sparking is occurred and due to Rotary Insulator is Damaged its operation is not possible So same will be opened through Hot Line Team , Rotary Replacement Work
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	18/03/2022	17:56	18/03/2022	21:07	PO	FOR REPLACEMENT OF MV SIDE "R" PH. LINE ISOLATOR JAW WITH ALIGNMENT WORK.
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	08/03/2022	06:06	18/03/2022	08:14	T	Distance Protection
KHAREPATAN -PAWAS LINE	IntraState	17/03/2022	01:13	17/03/2022	07:47	T	tripped on Dist prot
NIWALI - PAWAS LINE	IntraState	17/03/2022	01:13	17/03/2022	17:57	T	tripped on Dist prot
PEDHAMBE ONI LINE	IntraState	17/03/2022	01:13	17/03/2022	02:26	T	Breaker Problem at Pedambe

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Mar/2022

Statement-VII

Position as on 6.30 Hrs of 18/Mar/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY - SALSETTE CKT - 1	IntraState	17/03/2022	05:27	17/03/2022	07:09	EO	Ttree in vicinity of 220kV Trombay -Salsette-1 line in span 55-56, which required emergency trimming
ONGC URAN - JNPT	IntraState	17/03/2022	12:44	17/03/2022	17:03	T	Tripped on distance protection
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	17/03/2022	13:32	17/03/2022	16:50	T	TRIPPED ON DIST. PROTN.
KANDALGAON - BHIRA	IntraState	17/03/2022	13:52	17/03/2022	16:14	T	TRIPPED ON DIST. PROTN.
ONGC URAN - JNPT	IntraState	17/03/2022	14:24	17/03/2022	17:03	EO	Attending Red Hotspot Loc. No. 16, Top Phase
220KV MALEGAON - DHULE	IntraState	17/03/2022	14:59	17/03/2022	15:24	T	TRIPPED ON DIST. PROTN.
DAHANU - GHODBUNDER CKT - 2	IntraState	17/03/2022	16:24	17/03/2022	18:19	EO	Attending hotspot (120 deg) at LS 46A R-ph DHN side.
KHARGHAR - NERUL	IntraState	18/03/2022	00:22	18/03/2022	04:34	HT	Emergency outage
KHARGHAR - NERUL	IntraState	18/03/2022	00:22	18/03/2022	04:34	EO	Replacement of wavetrap
JEJURI - BARAMATI	IntraState	18/03/2022	06:09	18/03/2022	09:34	HT	HT for Load Management
LONAND-BARAMATI	IntraState	18/03/2022	06:09	18/03/2022	09:34	HT	HT for Load Management
ADLABS - PEDAMBE	IntraState	18/03/2022	06:15	18/03/2022	09:52	EO	For replacement of damaged insulator strings at loc no. 92
ADLABS - PEDAMBE	IntraState	18/03/2022	06:15	18/03/2022	09:52	EO	For replcement of damaged DSN middle phase string at loc no.92.
TROMBAY - ANTOP HILL CKT - 1	IntraState	18/03/2022	08:12	18/03/2022	08:39	EO	Coconut tree in vicinity of 220kV Trombay-Antop Hill#1 for tree trimming
COLOURCHEM - TEMGHAR	IntraState	18/03/2022	09:10	18/03/2022	11:35	EO	For Hot spot attending work on B-Phase CT
PEDHAMBE ONI LINE	IntraState	18/03/2022	10:48	18/03/2022	13:17	EO	For checking and attending Breaker Pole Discrepancy circuit .
BUS SECTION BREAKER	IntraState	18/03/2022	13:21	18/03/2022	13:43	EO	for raising Sf6 gas pressure in 220 KV bus coupler-3 due to low sf6 gas pressure
220KV MALEGAON - DHULE	IntraState	18/03/2022	14:50	18/03/2022	17:11	EO	Attending Heavy Red Hot at B-phase CT (line side)
GHODBUNDER - GORAI	IntraState	18/03/2022	16:40	18/03/2022	18:52	T	Differential protection R and Y ph
VILE BHAGAD - KANDHALGAON	IntraState	18/03/2022	18:12	18/03/2022	18:12	EO	A t loc n-01,R-ph conductor strands found partially opened near Jumper Cone To be attended.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220 / 110 / 22kV 250MVA ICT 1 @ BORIVALI (TATA)	IntraState	17/03/2022	12:30			PO	Shifting to new GIS
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	18/03/2022	11:28	18/03/2022	13:26	PO	Bay Maintenance work along with LV CT oil leakage checking & attend
220/22 KV 50 MVA PTR 1 @ TEMGHAR	IntraState	18/03/2022	11:58	18/03/2022	13:05	EO	For Hot spot attending work on 50MVA Tr.1 LV bus Isolator jaw (130deg. C)
132 KV MAINBAY Outages/Trippings							
MAIN BUS - 2 @ SONEWADI (KEDGAON)	IntraState	17/03/2022	14:04	17/03/2022	18:58	PO	Dismantling of line side jumpers directly connected to 132KV CT of 132KV Ckt-II & after Erection of 132KV line side Isolator & Earth switch for 132KV Kedgaon CKT-II .

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Mar/2022

Statement-VII

Position as on 6.30 Hrs of 18/Mar/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
BHIRA - KHOPOLI	IntraState	18/03/2022	08:27	18/03/2022	19:02	HT	emergency outage

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage