

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Apr/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	155.996	2748.294	1) Gujrat	-2.273	-67.532
2) Hydro	29.889	356.364	2) Madhya Pradesh	9.702	146.459
3) Gas	3.888	43.592	3) Chattisgarh	3.280	78.970
Total MSPGCL	189.773	3148.250	4) Maharashtra	183.767	3053.895
B) 1) APLM	73.745	1256.036	5) Goa (Amona)	-1.659	-25.829
2) JSWEL	27.568	420.762	Total	192.817	3185.963
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.791	564.384
4) RPL(AMT)	31.291	498.147	b) Mumbai Drawl	39.270	626.476
5) SWPGPL	12.408	193.581	c) MSEDCL Bilateral *	100.422	1626.989
6) Other IPP	18.985	367.540	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.791	564.384
C) 1) TPCL Thermal	13.445	201.087	Include PX	0.000	0.000
2) TPCL Hydro	5.034	91.588	Standby	0.000	0.000
3) TPCL Gas	4.100	49.770	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.302	167.147	1) MSEDCL	523.322	8729.922
D) STATE			2) Mumbai Discoms	73.151	1136.064
1) Thermal	344.740	5852.594	3) Other Discoms	10.441	172.756
(A1+C1+C4+(B1-B6))			TOTAL STATE	606.914	10038.742
2) Hydro	34.923	447.952			
(A2+C2)					
3) Gas	7.988	93.362			
(A3+B7+C3)					
4) Wind	10.856	204.834			
6) SOLAR	15.590	254.041			
TOTAL STATE	414.097	6852.783			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6659	6565	6680	6011
MSPGCL Hydro	206	1348	2042	1192
MSPGCL Gas	131	118	210	145
MSPGCL Total Generation	6996	8030	8932	7348
Central Sector Receipt	9951	10253	7436	6672
WIND	299	129	667	982
CPP / IPP Thermal	6295	6810	7048	7036
CPP / IPP Gas	0	0	0	0
SOLAR	2112	1317	0	0
Exchange with Mumbai	-2225	-2297	-1508	-1108
MSEDCL DEMAND MET	22958	23755	22092	20602
Load Shedding	0	0	0	0
MSEDCL DEMAND	22958	23755	22092	20602
TPCL GENERATION	835	890	1204	809
AEML GENERATION	468	469	486	455
MUMBAI DEMAND	3528	3656	3198	2372
OTHER DISCOM DEMAND	469	487	483	328
STATE DEMAND MET	26956	27898	25774	23302
STATE DEMAND	26956	27898	25774	23302
Frequency (Hz)	50.03	49.86	49.98	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 13.02 Hrs	49.51 Hz at 22.15 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 17/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.28	78.02	200	145
Unit 8	0.00	214.31	0	0
Unit 9	13.05	89.62	561	492
Unit 10	12.82	226.80	575	515
Total	30.14	608.76		
Bhusawal				
Unit 3	3.32	57.24	150	115
Unit 4	9.26	147.38	500	0
Unit 5	10.37	179.82	445	420
Total	22.96	384.44		
Parli				
Unit 6	5.88	86.13	250	233
Unit 7	5.31	79.43	245	140
Unit 8	0.00	57.99	0	0
Total	11.20	223.55		
Chandrapur				
Unit 3	3.93	64.20	168	153
Unit 4	3.87	41.38	169	125
Unit 5	9.78	154.04	415	380
Unit 6	9.71	150.95	418	395
Unit 7	0.00	126.27	0	0
Unit 8	11.71	190.64	494	468
Unit 9	11.10	139.50	485	446
Total	50.10	866.98		
Paras				
Unit 3	4.56	74.67	230	124
Unit 4	5.66	74.22	245	227
Total	10.22	148.90		
Khaparkheda				
Unit 1	2.04	44.60	135	0
Unit 2	2.75	40.20	135	64
Unit 3	4.34	66.01	190	175
Unit 4	4.18	72.23	188	155
Unit 5	10.78	160.50	455	439
Total	24.08	383.54		
Nasik				
Unit 3	3.11	67.03	155	0
Unit 4	4.19	36.80	183	160
Unit 5	0.00	28.30	0	0
Total	7.30	132.13		
Uran				
All Units	3.89	43.59	233	118
Total	3.89	43.59		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.01	1.72	7	0
Total	0.01	1.72		
Koyna				
Stage 1-2	6.91	89.37	565	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	13.97	144.24	1027	0
Stage 3	4.70	50.14	320	0
Total	25.58	283.75		
Hydro				
KDPH	0.80	14.28	34	34
VTRNA	1.43	20.17	60	59
TILLARI	0.00	1.82	0	0
BHIRA T.R.	0.21	5.15	77	0
SMLHY_PTN	1.86	29.47	80	73
GHATGHAR	0.00	0.00	0	0
Total	4.30	70.89		
Wind				
Total	10.86	204.83	0	0
Total	10.86	204.83		
CPP				
APML(Mus)	73.74	1256.04	0	0
JSWEL(Mus)	27.57	420.76	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.29	498.15	0	0
SWPGPL-Mus	12.41	193.58	0	0
Dhariwal	6.36	102.60	272	244
IEPL	5.72	89.66	270	197
Other(Mus)	6.91	175.28	0	0
Total	164.00	2736.07		
SOLAR				
Total	15.59	254.04	0	0
Total	15.59	254.04		
Tata				
Trombay 5	8.73	131.68	424	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.56	29.27	108	106
Trombay 7B	1.54	20.50	65	64
TATA Hydro	5.03	91.59	418	74
Trombay 8	4.72	69.41	240	137
Total	22.58	342.44		
AEML				
DTPS U-1&2	11.30	167.15	499	406
Total	11.30	167.15		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	156.00	2748.29	MSPGCL Total	189.77	3148.25
			MSPGCL Thml+Gas	159.88	2791.89	Koyna 1,2 & 4 Total	20.88	233.61
			MSPGCL Hydro	29.89	356.36	State Total	414.10	6852.78

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Transmission Constraint					
1	6545	2014	211	8770	659	7066	0	0	6257	6269	-1314	21063	0	0	21063	2871	386	24320	49.99
2	6180	2054	233	8466	800	7066	0	0	6190	6167	-1160	20989	0	0	20989	2670	351	24010	50.04
3	6119	1838	232	8188	937	7064	0	0	6093	6008	-1013	20868	0	0	20868	2493	317	23678	50.04
4	6011	1192	145	7348	982	7036	0	0	6687	6672	-1108	20602	0	0	20602	2372	328	23302	50.03
5	6144	1132	141	7416	921	7080	0	0	6823	6866	-1176	20774	0	0	20774	2312	334	23420	50.00
6	6344	1350	141	7834	795	7065	0	0	6845	7107	-1133	21300	0	0	21300	2391	368	24060	50.01
7	6405	1264	142	7810	705	7002	0	83	7457	7491	-1210	21461	0	0	21461	2442	421	24324	50.05
8	6472	620	144	7236	432	6752	0	499	8158	7844	-1480	20839	0	0	20839	2550	444	23834	50.12
9	6522	286	143	6952	344	6344	0	1042	8636	8483	-1747	20945	0	0	20945	2839	473	24256	50.00
10	6639	234	138	7010	324	6364	0	1538	9181	8808	-1860	21713	0	0	21713	3155	471	25340	49.98
11	6674	210	139	7024	359	6112	0	1962	9946	9791	-2080	22702	0	27	22702	3387	465	26554	50.01
12	6659	206	131	6996	299	6295	0	2112	10011	9951	-2225	22958	0	28	22958	3528	469	26956	50.03
13	6691	206	125	7022	185	6302	0	2131	9881	10082	-2239	23019	0	2	23019	3570	463	27052	50.02
14	6609	212	123	6944	113	6649	0	1968	9843	9966	-2175	22994	0	2	22994	3506	472	26972	50.06
15	6581	788	124	7492	121	6742	0	1695	10164	10307	-2306	23590	0	18	23590	3630	461	27682	49.96
16	6565	1348	118	8030	129	6810	0	1317	9874	10253	-2297	23755	0	18	23755	3656	487	27898	49.86
17	6563	2006	122	8690	227	6964	0	872	9212	9326	-2145	23433	0	1	23433	3580	501	27514	49.91
18	6606	1460	123	8188	249	6997	0	344	8921	8557	-1995	21843	0	0	21843	3430	497	25770	49.99
19	6636	1284	156	8076	404	7063	0	27	7866	7519	-1634	20957	0	0	20957	3237	499	24692	50.01
20	6680	2042	210	8932	667	7048	0	0	7330	7436	-1508	22092	0	0	22092	3198	483	25774	49.98
21	6710	2056	211	8976	289	7053	0	0	6633	6867	-1433	21295	0	0	21295	3133	457	24886	50.01
22	6587	2052	220	8858	331	7043	0	0	6539	7100	-1337	21554	0	0	21554	3057	442	25052	49.93
23	6534	2034	207	8774	264	7031	0	0	6566	7290	-1328	21598	470	0	22068	3059	433	25560	49.85
24	6520	2006	209	8736	320	7049	0	0	6655	6657	-1367	20977	864	0	21841	3085	418	25344	49.96
MUs	156.00	29.89	3.89	189.77	10.86	164.00	0.00	15.59	191.77	192.82	-39.27	523.32	1.33	0.10	524.66	73.15	10.44	608.25	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

1)DLS due to overloading of 220kv jejuri-Ionand line.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Apr/2023

Position as on 6.30 Hrs of 18/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	19/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 5	210	08/04/2023	20:20	18/04/2023	02:02	Boiler Tube Leakage(under tolling from 18.00Hrs DT. 13-04-2023)	
MSPGCL	Chandrapur Unit 7	500	14/04/2023	07:58	18/04/2023	00:19	HPT Top bottom casing Temperature difference	18/04/2023
MSPGCL	Khaparkheda Unit 1	210	15/04/2023	06:30	17/04/2023	06:39	Air heater problem	16/04/2023
MSPGCL	Uran Unit 6	108	15/04/2023	19:47	17/04/2023	00:00	No Schedule.	
MSPGCL	Parli Unit 8	250	15/04/2023	22:05	18/04/2023	07:18	Boiler Tube Leakage	18/04/2023
MSPGCL	Koradi Unit 8	660	16/04/2023	11:24		Continued.	Boiler Tube Leakage	19/04/2023
MSPGCL	Bhusawal Unit 4	500	17/04/2023	00:54	17/04/2023	04:15	Class A Protection Operated	
MSPGCL	Uran Unit 6	108	17/04/2023	03:10	17/04/2023	18:27	No Schedule	
MSPGCL	Nasik Unit 3	210	17/04/2023	21:27		Continued.	Boiler Tube Leakage	20/04/2023
MSPGCL	Koradi Unit 6	210	18/04/2023	10:25		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 18/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 1	IntraState	09/04/2023	22:22			T	Tripped on distance protection
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF KARAD LINE AND 400/220KV 315MVA ICT - 1 @ SOLAPUR (PG)	InterState	15/04/2023	09:39			PO	411-Bay Y.Ph CT Replacement due to oil seepage from porcelain and cementing joint
400 KV MAINBAY Outages/Trippings							
MAIN BAY-425 OF GT-8 @ KORADI-2	IntraState	17/04/2023	09:15	17/04/2023	17:05	PO	Diagnostic testing of Circuit Breaker
220KV AUXILLARY BUS @ KHAPARKHEDA	IntraState	17/04/2023	12:02	17/04/2023	15:50	PO	CONNECTION OF TWIN JUMPERS 220KV AUXILLARY ISOLATOR JUMPERS OF 220KV KANHAN CKT
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	11/04/2023	09:07			PO	Diagnostic testing and allied bay maintenance work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	IntraState	17/04/2023	09:39	17/04/2023	17:46	PO	For ICT Painting work
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	17/04/2023	10:30			PO	1. ICT-II IV Bay Circuit Breaker Pole Overhauling Work. 2. ICT-II IV will be charged through TBC.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	17/04/2023	16:44	18/04/2023	04:16	PO	1. SFRA Testing 2. 33kV IPS Tube and BPI insulation coating work to avoid NDR Tripping 3. OLTC oil filtration work 4. R ph Unit oil leakage attending work 5. Protection & Colling system Supervisory trials. 6. Diagnostic testing work
400/220/33 KV 500MVA ICT - 1 @ KORADI 2	IntraState	18/04/2023	11:18	18/04/2023	12:25	T	WTI METER ISSUE
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
KALWA - SALESETTE CKT - 5	IntraState	13/04/2023	10:10			PO	Normalization of 110 KV Kalwa Kalyan Salsette 2 section - 220 KV Kalwa Salsette 5 project work.
YEOTMAL- PUSAD	IntraState	17/04/2023	07:58	17/04/2023	15:40	T	DIST PROT OPTD.
TALOJA II - OCIL 1	IntraState	17/04/2023	09:22			PO	Isolator maintenance & Checking of busbar connections nut-blot tightness.
132 KV KAGZIPURA - DEOGAON RANGARI CKT	IntraState	17/04/2023	10:17	17/04/2023	16:30	PO	CT REPLACEMENT WORK AT KAZIPURA END.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 18/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NIWALI - PAWAS LINE	IntraState	17/04/2023	10:28	17/04/2023	18:54	PO	For cold washing of line insulator strings.
GHODBUNDER - GORAI	IntraState	17/04/2023	11:36	17/04/2023	12:58	PO	attending frequent Pole discrepancy alarm and sf6 gas pressure low alarm
NAGOTHANE - POSCO	IntraState	17/04/2023	12:03	17/04/2023	18:08	PO	Pre monsoon maintenance work
WANI-WARORA 1	IntraState	17/04/2023	14:10	17/04/2023	14:38	T	LINE AR SUCCESSFUL AT WARORA END AND TRIPPED AT WANI END.
MIRAJ - ICHALKARANJI	IntraState	17/04/2023	17:05	18/04/2023	03:18	PO	1)For proper load management at 220 kV Tilawani & 220 kV Miraj S/S as on dt. 17.04.2023 outage proposed on 220 kV Talandage-Ichalkaranji Ckt-2. & 220 kV Talandage- Ichalkaranji -1 2)220 kV Miraj- Ichalkaranji line needs to be kept off at 220 kV Ichalkaranji (Tilawani) S/S. 3) 220 kV Miraj - Ichalkaranji line will be in service from 220 kV Miraj S/S end.
URSE-CHINCHWAD	IntraState	17/04/2023	17:11	17/04/2023	19:25	T	Tripped due to heavy rain
TALANDGE - ICHALKARANJI 2	IntraState	17/04/2023	17:13	17/04/2023	18:51	PO	For attending hotspots at T.L No-45 B Phase
CHAKAN -BRIDGESTONE	IntraState	17/04/2023	17:45	17/04/2023	18:46	T	tripped due to heavy rain
TALANDGE - ICHALKARANJI 1	IntraState	17/04/2023	18:56	18/04/2023	03:15	PO	For attending hospot at T.L No 29 B phase & Repairement of damaged conductor in between T L no 33-34, B Phase
BHUGAON - WARDHA (PG)	IntraState	17/04/2023	22:10	18/04/2023	00:06	HT	To control OD
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	17/04/2023	22:34	18/04/2023	00:17	HT	To control OD
NIWALI - PAWAS LINE	IntraState	18/04/2023	09:03			PO	For cold washing of line insulator strings.
MHAISHAL- JATH	IntraState	18/04/2023	09:52			PO	For replacement of R, Y & B-Ph CTs due to higher Tan delta results
NAGOTHANE - ACCIL	IntraState	18/04/2023	11:56			PO	Pre monsoon maintenance and other R&M work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/110 KV 200 MVA ICT - 2 @ ICHALKARANJI - II	IntraState	17/04/2023	08:26	17/04/2023	21:00	PO	1)Quarterly bay maintenance work 2) HV Bushing replacement work due to leakage 3) Diagnostic testing work.
220/132 KV 100 MVA ICT 3 @ RANJANGAON	IntraState	17/04/2023	10:40	17/04/2023	16:02	PO	For replacement of Air Cell and general bay maintenance work.
220/132 KV, 100MVA ICT I	IntraState	17/04/2023	12:59	17/04/2023	19:42	PO	FOR SCADA INTEGRATION WORK DEMANDED BY ZIV ENGINEER AS PER INSTRUCTION OF TESTING UNIT AMRAVATI.
220 KV BUSBAR Outages/Trippings							
MAIN BUS @ SWARAJ CO GEN	IntraState	18/04/2023	10:35			PO	For annual maintenance, Switchyard equipment testing & 220 kV Bus bar testing work at 220 kV Swaraj Co-gen.
132 KV LINE Outages/Trippings							
MADGI-KAULEWADA CKT II	IntraState	17/04/2023	07:41	17/04/2023	08:48	EO	ATTENDING HOT SPOT ON R PH LINE ISOLATOR.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 18/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
132KV WASHIM MANGRULPIR CKT	IntraState	17/04/2023	07:53	17/04/2023	11:30	PO	DIAGNOSTIC TESTING AND ROUTINE MAINTENANCE.
PADEGAON-SILLOD	IntraState	17/04/2023	08:26	17/04/2023	18:29	PO	FOR REPLACEMENT OF ALL 3 PHASE R, Y, B CTS OF 132KV SILLOD LINE BAY AT 220KV PADEGAON SS.
AMALNER(220KV)-CHOPDA CKT - 2	IntraState	17/04/2023	09:01	17/04/2023	13:43	EO	TO ATTEND OIL LEAKAGE OF B PH CT.
TELGAON-PANGRI	IntraState	17/04/2023	11:05	17/04/2023	15:28	PO	COLD LINE WASHING WORK OF INSULATORS STRINGS.
BULDANA-MOTALA	IntraState	17/04/2023	14:41	17/04/2023	15:17	T	Tripped at Buldhana end.
CHIKHALI-BULDANA	IntraState	17/04/2023	14:41	17/04/2023	15:04	T	C-B PH ZONE2 DIST -18.67 KM ,IF -3.2KA B ..DIST KM IF--529 AMP,
PARLI-PANGRI	IntraState	17/04/2023	15:37	17/04/2023	19:05	PO	COLD LINE WASHING WORK.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
SALSETTE VIKHROLI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage