

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Jun/2024 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.103	2591.178	1) Gujrat	-3.375	-1.633
2) Hydro	9.321	157.053	2) Madhya Pradesh	0.198	16.846
3) Gas	7.428	115.584	3) Chattisgarh	1.580	36.630
Total MSPGCL	159.852	2863.815	4) Maharashtra	181.745	3262.017
B) 1) APML	62.750	943.994	5) Goa (Amona)	-1.528	-33.494
2) JSWEL	20.468	420.804	Total	178.620	3280.366
3) VIPL	0.000	0.000	a) Mumbai Schedule	41.538	739.827
4) RPL(AMT)	31.688	512.638	b) Mumbai Drawl	43.240	783.516
5) SWPGPL	12.430	207.089	c) MSEDCL Bilateral *	68.832	1401.020
6) Other IPP	8.760	244.971	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	41.538	739.775
C) 1) TPCL Thermal	14.695	221.113	Include PX	0.000	0.000
2) TPCL Hydro	5.374	93.759	Standby	0.000	0.053
3) TPCL Gas	4.134	69.105	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.657	145.872	1) MSEDCL	452.232	8100.761
D) STATE			2) Mumbai Discoms	73.100	1313.362
1) Thermal	299.551	5287.659	3) Other Discoms	11.698	197.834
(A1+C1+C4+(B1-B6))			TOTAL STATE	537.030	9611.957
2) Hydro	14.695	250.812			
(A2+C2)					
3) Gas	11.562	184.689			
(A3+B7+C3)					
4) Wind	16.523	346.660			
6) SOLAR	16.079	261.774			
TOTAL STATE	358.410	6331.594			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5600	6270	6090	5876
MSPGCL Hydro	118	123	719	166
MSPGCL Gas	281	286	473	290
MSPGCL Total Generation	5999	6679	7282	6332
Central Sector Receipt	8765	8261	6983	6485
WIND	406	541	1079	784
CPP / IPP Thermal	4621	5191	6280	5917
CPP / IPP Gas	0	0	0	0
SOLAR	2370	1588	0	0
Exchange with Mumbai	-2377	-2112	-1739	-1426
MSEDCL DEMAND MET	19227	19622	19374	17687
Load Shedding	0	0	0	0
MSEDCL DEMAND	19227	19622	19374	17687
TPCL GENERATION	782	1101	1176	1083
AEML GENERATION	238	250	203	225
MUMBAI DEMAND	3397	3463	3118	2734
OTHER DISCOM DEMAND	557	526	511	404
STATE DEMAND MET	23181	23611	23003	20826
STATE DEMAND	23181	23611	23003	20826
Frequency (Hz)	49.99	50.04	50.02	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.68 Hz at 16:53 Hrs	49.77 Hz at 09:11 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 17/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.28	70.23	191	150
Unit 8	13.84	232.23	615	520
Unit 9	12.28	200.82	609	355
Unit 10	13.27	216.72	582	530
Total	43.67	720.00		
Bhusawal				
Unit 3	0.10	20.60	60	0
Unit 4	0.00	151.03	0	0
Unit 5	10.53	161.34	485	305
Total	10.63	332.97		
Parli				
Unit 6	0.00	34.93	0	0
Unit 7	0.00	26.47	0	0
Unit 8	0.00	38.18	0	0
Total	0.00	99.58		
Chandrapur				
Unit 3	0.06	52.63	33	0
Unit 4	3.68	61.39	163	134
Unit 5	8.91	116.69	438	275
Unit 6	8.73	98.17	420	280
Unit 7	9.97	153.31	475	282
Unit 8	10.38	150.35	450	357
Unit 9	9.58	148.84	500	0
Total	51.30	781.40		
Paras				
Unit 3	5.20	78.52	232	191
Unit 4	0.00	7.43	0	0
Total	5.20	85.95		
Khaparkheda				
Unit 1	3.50	58.52	160	80
Unit 2	3.48	67.49	193	0
Unit 3	3.19	53.36	149	54
Unit 4	3.49	69.16	187	0
Unit 5	11.18	187.32	485	441
Total	24.83	435.84		
Nasik				
Unit 3	3.82	58.84	171	137
Unit 4	0.00	19.19	0	0
Unit 5	3.66	57.41	166	117
Total	7.48	135.45		
Uran				
All Units	7.43	115.58	474	281
Total	7.43	115.58		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.42	0	0
Total	0.00	1.42		
Koyna				
Stage 1-2	2.98	49.80	435	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.07	37.42	570	0
Stage 3	1.32	21.43	240	0
Total	6.37	108.64		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	0.78	11.86	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.30	0.78	40	0
SMLHY_PTN	1.79	28.60	85	65
GHATGHAR	0.08	4.21	75	0
Total	2.95	48.41		
Wind				
Total	16.52	346.66	0	0
Total	16.52	346.66		
CPP				
APML(Mus)	62.75	943.99	0	0
JSWEL(Mus)	20.47	420.80	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.69	512.64	0	0
SWPGPL-Mus	12.43	207.09	0	0
Dhariwal	0.00	0.00	0	0
IEPL	0.88	92.41	210	0
Other(Mus)	1.74	65.42	0	0
JPL	6.14	87.14	271	234
Total	136.10	2329.50		
SOLAR				
Total	16.08	261.77	0	0
Total	16.08	261.77		
Tata				
Trombay 5	9.61	146.68	456	291
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	43.28	108	108
Trombay 7B	1.54	25.83	65	64
TATA Hydro	5.37	93.76	368	82
Trombay 8	5.09	74.43	232	141
Total	24.20	383.98		
AEML				
DTPS U-1&2	5.66	145.87	340	176
Total	5.66	145.87		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.10	2591.18	MSPGCL Total	159.85	2863.82
			MSPGCL Thml+Gas	150.53	2706.76	Koyna 1,2 & 4 Total	5.05	87.22
			MSPGCL Hydro	9.32	157.05	State Total	358.41	6331.59

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5775	1072	289	7136	818	6129	0	0	6910	6583	-1638	18587	0	0	18587	3111	440	22139	50.00
2	5806	273	289	6368	830	6049	0	0	6927	6816	-1525	18138	0	0	18138	2902	400	21440	50.00
3	5876	166	290	6332	784	5917	0	0	6858	6485	-1426	17687	0	0	17687	2734	404	20826	49.98
4	6020	172	291	6483	707	5900	0	0	6743	6605	-1378	17922	0	0	17922	2597	395	20914	50.00
5	6084	128	292	6504	583	5773	0	0	6906	6960	-1345	18069	0	0	18069	2554	406	21029	50.01
6	6182	268	293	6743	445	6059	0	0	7263	7195	-1448	18571	0	0	18571	2570	423	21564	50.00
7	6164	881	289	7334	430	6203	0	116	6886	6805	-1306	19111	0	0	19111	2575	471	22157	50.01
8	6066	298	289	6653	398	6029	0	488	7431	7568	-1556	19095	0	0	19095	2608	485	22188	49.99
9	5810	239	290	6339	416	5434	0	1059	8239	8019	-1993	18769	0	0	18769	2855	504	22129	49.96
10	5749	233	285	6267	388	4840	0	1771	8685	8014	-2193	18567	0	0	18567	3157	519	22244	49.95
11	5465	153	283	5901	429	4604	0	2205	8886	8758	-2294	19093	0	0	19093	3327	511	22930	50.02
12	5600	118	281	5999	406	4621	0	2370	9007	8765	-2377	19227	0	36	19227	3397	557	23181	49.99
13	5874	113	281	6268	320	4660	0	2243	8822	8308	-2201	19058	0	18	19058	3410	540	23008	49.91
14	5739	212	284	6235	291	4639	0	1993	8671	8692	-2156	19162	0	3	19162	3350	531	23044	50.02
15	6270	123	286	6679	541	5191	0	1588	8643	8261	-2112	19622	0	81	19622	3463	526	23611	50.04
16	6328	117	289	6734	777	5636	0	1208	8451	7413	-1958	19291	0	9	19291	3380	519	23190	49.99
17	5838	188	288	6314	1207	5089	0	728	8210	8168	-1893	19099	0	0	19099	3266	514	22879	50.03
18	6131	362	288	6781	1138	5217	0	269	7745	7657	-1991	18530	0	0	18530	3175	540	22246	50.03
19	6388	224	334	6946	1104	6057	0	41	7329	6926	-1899	18633	0	0	18633	3110	542	22285	50.06
20	6090	719	473	7282	1079	6280	0	0	7235	6983	-1739	19374	0	0	19374	3118	511	23003	50.02
21	5955	675	474	7104	1164	6373	0	0	6943	6969	-1707	19402	0	0	19402	3081	502	22984	49.98
22	5961	623	381	6965	946	6439	0	0	6846	6860	-1682	19015	0	0	19015	3048	513	22576	49.95
23	5995	1022	294	7311	664	6439	0	0	6886	6990	-1689	19251	0	0	19251	3170	463	22885	49.94
24	5937	942	295	7174	658	6520	0	0	6997	6820	-1734	18959	0	0	18959	3142	479	22580	50.01
MUs	143.10	9.32	7.43	159.85	16.52	136.10	0.00	16.08	183.52	178.62	-43.24	452.23	0.00	0.15	452.23	73.10	11.70	537.03	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

BBLR-1 & 2 loading reaches upto 757Amp/272MW.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 17/Jun/2024

Position as on 6.30 Hrs of 18/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 2	70	15/06/2024	07:10		Continued.	Govrner renovation	10/07/2024
MSPGCL	Bhusawal Unit 4	500	16/06/2024	00:00		Continued.	Annual Overhaul	06/07/2024
Total Capacity MSPGCL		570						
Total Capacity PLANNED OUTAGE		570						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	19/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
MSPGCL	Chandrapur Unit 3	210	15/06/2024	22.16	17/06/2024	21:55	Boiler Tube Leakage	19/06/2024
MSPGCL	Khaparkheda Unit 4	210	16/06/2024	16:56	17/06/2024	02:24	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 3	210	16/06/2024	16:56	17/06/2024	00:50	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 1	210	16/06/2024	16:56	17/06/2024	00:08	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 2	210	16/06/2024	17:01	17/06/2024	03:15	AC Supply failure.	
MSPGCL	Chandrapur Unit 9	500	17/06/2024	19:31	18/06/2024	05:30	EXCITATION SYSTEM FAILURE	
Total Capacity MSPGCL		2255						
AEML								
AEML	AEML Unit 1	250	14/06/2024	10:16		Continued.	Boiler Tube Leakage	19/06/2024
Total Capacity AEML		250						
IPP								
IPP	JSW (J) U1	300	17/06/2024	07:25		Continued.	Condenser tube leakage.	
IPP	IEPL Unit 1	270	17/06/2024	2.31	17/06/2024	20:40	Critical Clinker Formation in the Boiler Furnace.	
Total Capacity IPP		570						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Jun/2024

Position as on 6.30 Hrs of 18/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity FORCED OUTAGE		3395						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00	17/06/2024	18:44	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40	17/06/2024	18:31	Zero Schedule given by MSEDCL.	
MSPGCL	Parli Unit 7	250	08/06/2024	21:00	18/06/2024	04:52	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 6	250	08/06/2024	21:13		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 8	250	09/06/2024	20:50		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	12/06/2024	16:15	17/06/2024	21:56	Zero schedule given by LM Cell Discom due to drop in demand	
MSPGCL	Uran Unit 6	108	17/06/2024	21:30		Continued.	Zero Schedule given by MSEDCL	
MSPGCL	Uran Unit 5	108	17/06/2024	21:44		Continued.	Zero Schedule given by MSEDCL	
Total Capacity MSPGCL		1392						
IPP								
IPP	Adani U-4	660	10/06/2024	16:16	17/06/2024	04:34	ZERO SCHEDULE BY MSEDCL	
Total Capacity IPP		660						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		2052						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted generataor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 18/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY (403) of 500 MVA ICT @ ALKUD	IntraState	17/06/2024	11:24	17/06/2024	22:54	PO	Diagnostic testing & Maintenance work
400 KV LINE Outages/Trippings							
DHULE - KHANDWA CKT - 2	InterState	17/06/2024	17:44	17/06/2024	18:24	T	Distance Protection
DHULE - KHANDWA CKT - 2	InterState	17/06/2024	17:44	17/06/2024	18:24	T	Distance protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
KHADKA-AURANGABAD (WALUJ)	IntraState	17/06/2024	14:43	17/06/2024	17:37	EO	For Urgent Re-Jointing and Termination work of CT bus-bar protection at waluj end.
MAIN BUS - 1 @ TALANDGE	IntraState	17/06/2024	20:36			PO	Insulator cleaning work. 400kV PG Isolator alignment and maintenance work.
NAGOTHANE - DABHOL CKT - 2	IntraState	18/06/2024	03:15			T	Tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	13/06/2024	10:11			PO	For work in vicinity for erection of scaffolding for installation of LA�s on 220KV Bays at KVTL Vikhroli (These Bays used for feeding 220/110kV, 250MVA, ICT-1 & ICT-2 of TPC Vikhroli).
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	17/06/2024	09:43	17/06/2024	16:46	PO	Routine maint. Work & Covering plastic Papar on PRV etc.
400/220 KV 500 MVA ICT @ ALKUD	IntraState	17/06/2024	11:24	17/06/2024	22:54	PO	Diagnostic testing & Maintenance work
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	18/06/2024	07:21			PO	Diagnostic testing and routine maintenance work
400 KV BR Outages/Trippings							
BUS REACTOR (125 MVar) - 2 @ KOLHAPUR (TALANDGE)	IntraState	17/06/2024	10:55	17/06/2024	18:03		To attend CB & Trip Circuit Supervision problems
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV TBC	IntraState	16/06/2024	07:12	17/06/2024	04:58	PO	29A and 220kV Bus-1 PT isolator alignment work with removing / Reconnecting 29A isolators jumpers by HLU, Nagpur
TBC @ PARVATI	IntraState	17/06/2024	09:40	17/06/2024	13:15	PO	For shifting position of 220 kV CT away from cable trench
220 KV LINE Outages/Trippings							
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 18/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
EKLAHARE (OCR) - PADGHE	IntraState	10/06/2024	08:42			HT	H/T for load management
TIFIL - KALWA	IntraState	13/06/2024	08:55	17/06/2024	00:29	PO	For making 220kV Pawane-TIFIL line LILO for M/s NXTRA Data Ltd for the proposed 220kV GIS S/stn.
TOPWORTH - KHANDESHWAR	IntraState	15/06/2024	14:24			PO	Making LILO of 220kV Khandeshwar - Topwarth line & 220kV Khandeshwar Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel
PANVEL TSS - KHANDESHWAR	IntraState	15/06/2024	14:30			PO	Making LILO of 220kV Khandeahwar Topwarth line & 220kV Khandeshwar - Panvel TSS line and commissioing of 220/33kV Timber Market GIS, Panvel
220 KV KAULEWADA-KORADI 2 CKT - I	IntraState	16/06/2024	16:54	17/06/2024	23:50	T	Distance protection
KHAPARKHEDA- SURYALAKSHMI	IntraState	17/06/2024	00:14	17/06/2024	03:29	EO	Attending visible hotspot on RPH WT clamp
BHUGAON- WARDHA	IntraState	17/06/2024	08:12	17/06/2024	12:01	PO	Measurement of Tan delta of CT CCS, Routine line maintenance and Diagnostic testing work.
VANKUSWADE - AJINKYATARA	IntraState	17/06/2024	09:10	17/06/2024	16:05	PO	Maintenance of 220kV Main Bus jumps & isolators at 220kV Vankusavde SSt.
VANKUSWADE - KDPH	IntraState	17/06/2024	09:20	17/06/2024	16:40	PO	Maintenance of 220kV Main Bus jumps & isolators at 220kV Vankusavde SSt.
KARAD - OGALEWADI CKT 1	IntraState	17/06/2024	09:24			PO	For Distance Relay Retrofitting and Relay Panel rewiring work.
NIWALI - PAWAS LINE	IntraState	17/06/2024	10:08	17/06/2024	15:56	PO	Line CT ratio changing work and Auxiliary bus side isolator maintenance work.
TALANDGE - MUDSHINGI CKT - 2	IntraState	17/06/2024	10:22	17/06/2024	21:16	PO	Diagnostic testing work of CT & LA and quarterly maintenance work.
VERSOVA - GHODBUNDER	IntraState	17/06/2024	12:24	17/06/2024	15:00	PO	Pre-Monsoon Activity of CB Covering
DAHANU - GHODBUNDER CKT - 1	IntraState	17/06/2024	15:16	17/06/2024	16:45	PO	Pre-Monsoon Activity of CB Covering
PARANDA - OSMANABAD	IntraState	17/06/2024	15:50	17/06/2024	16:10	T	At U E- AR Unsuccessful at Osmanabad
220KV HINGOLI -KURUNDA CKT	IntraState	17/06/2024	15:56	17/06/2024	18:32	T	Distance protection
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132 KV 200 MVA ICT 1 @ KALMESHWAR	IntraState	17/06/2024	09:48	17/06/2024	11:29	PO	Pre-monsoon maintenance work
220/33KV 25MVA PTR 1 @ HALKARNI	IntraState	17/06/2024	09:57	17/06/2024	13:31	PO	Quarterly Maintanance work
220/132 KV 200 MVA ICT 2	IntraState	17/06/2024	12:34	17/06/2024	14:59	PO	Pre-monsoon maintenance work
220/110kV 250MVA ICT-2 @ VIKHROLI(GIS)	IntraState	18/06/2024	00:47			PO	for LA replacement
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 18/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
KHOPOLI - KARANJADE	IntraState	17/06/2024	07:38	17/06/2024	09:46	EO	Bird nest removal at loc. 266,264

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage