

State Load Despatch Center,Airoli (MSETCL) Statement I
Daily system Report for 17/Jul/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	119.087	2301.742	1) Gujrat	3.721	23.156
2) Hydro	5.663	119.182	2) Madhya Pradesh	6.402	100.772
3) Gas	0.212	0.771	3) Chattisgarh	4.510	40.550
Total MSPGCL	124.962	2421.695	4) Maharashtra	165.580	2763.438
B) 1) APLM	51.398	1038.664	5) Goa (Amona)	-1.094	-17.949
2) JSWEL	19.710	334.615	Total	179.119	2909.967
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.782	605.597
4) RPL(AMT)	24.083	392.979	b) Mumbai Drawl	37.786	666.395
5) SWPGPL	9.008	150.079	c) MSEDCL Bilateral *	101.615	1539.193
6) Other IPP	6.513	109.622	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.782	604.746
C) 1) TPCL Thermal	10.739	124.325	Include PX	0.000	0.000
2) TPCL Hydro	4.267	81.636	Standby	0.000	0.851
3) TPCL Gas	3.014	60.133	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.405	151.650	1) MSEDCL	424.740	7405.307
D) STATE			2) Mumbai Discoms	64.211	1084.141
1) Thermal	248.943	4603.676	3) Other Discoms	10.177	167.167
(A1+C1+C4+(B1-B6))			TOTAL STATE	499.128	8656.615
2) Hydro (A2+C2)	9.930	200.818			
3) Gas (A3+B7+C3)	3.226	60.904			
4) Wind	49.127	700.831			
6) SOLAR	8.783	180.417			
TOTAL STATE	320.009	5746.646			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4753	4758	5479	4616
MSPGCL Hydro	267	146	543	147
MSPGCL Gas	0	0	34	0
MSPGCL Total Generation	5020	4904	6056	4763
Central Sector Receipt	9360	8341	7148	6171
WIND	1990	2060	2241	1881
CPP / IPP Thermal	4663	4301	4914	4407
CPP / IPP Gas	0	0	0	0
SOLAR	880	1080	0	0
Exchange with Mumbai	-2087	-2128	-1359	-1135
MSEDCL DEMAND MET	19379	18110	18534	15742
Load Shedding	0	0	0	0
MSEDCL DEMAND	19379	18110	18534	15742
TPCL GENERATION	613	650	1155	634
AEML GENERATION	317	360	406	305
MUMBAI DEMAND	3017	3138	2920	2074
OTHER DISCOM DEMAND	447	448	466	345
STATE DEMAND MET	22843	21696	21920	18161
STATE DEMAND	22843	21696	21920	18161
Frequency (Hz)	50.01	49.99	50.01	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 18.02 Hrs	49.72 Hz at 06.09 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 17/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.42	62.32	170	85
Unit 8	0.00	186.88	0	0
Unit 9	12.14	205.06	526	490
Unit 10	0.00	111.14	0	0
Total	15.56	565.40		
Bhusawal				
Unit 3	3.14	49.24	140	120
Unit 4	9.73	165.60	460	355
Unit 5	10.42	173.30	465	370
Total	23.30	388.14		
Parli				
Unit 6	3.14	26.16	206	112
Unit 7	4.33	17.78	241	147
Unit 8	3.61	6.60	181	137
Total	11.09	50.53		
Chandrapur				
Unit 3	1.47	51.31	80	45
Unit 4	1.56	50.09	82	50
Unit 5	0.00	0.00	0	0
Unit 6	7.47	132.26	331	270
Unit 7	7.52	135.20	342	278
Unit 8	10.18	168.72	436	413
Unit 9	11.14	178.70	482	450
Total	39.35	716.28		
Paras				
Unit 3	4.76	64.90	222	155
Unit 4	2.77	76.45	197	0
Total	7.53	141.34		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	3.04	44.39	136	118
Unit 3	3.92	65.34	182	145
Unit 4	4.42	59.68	196	143
Unit 5	3.54	149.78	425	0
Total	14.92	319.19		
Nasik				
Unit 3	3.66	48.80	172	125
Unit 4	3.68	59.74	169	125
Unit 5	0.00	12.33	0	0
Total	7.34	120.87		
Uran				
All Units	0.21	0.77	155	0
Total	0.21	0.77		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.16	0.77	23	0
Total	0.16	0.77		
Koyna				
Stage 1-2	1.59	36.68	190	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	6.91	0	0
Stage 3	0.59	15.32	116	0
Total	2.18	58.91		
Hydro				
KDPH	0.00	0.14	0	0
VTRNA	0.00	0.64	0	0
TILLARI	0.00	1.16	0	0
BHIRA T.R.	0.40	7.33	80	0
SMLHY_PTN	2.64	46.24	113	102
GHATGHAR	0.29	3.99	125	0
Total	3.33	59.51		
Wind				
Total	49.13	700.83	0	0
Total	49.13	700.83		
CPP				
APML(Mus)	51.40	1038.66	0	0
JSWEL(Mus)	19.71	334.62	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.08	392.98	0	0
SWPGPL-Mus	9.01	150.08	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.18	87.71	269	176
Other(Mus)	1.33	21.91	0	0
Total	110.71	2025.96		
SOLAR				
Total	8.78	180.42	0	0
Total	8.78	180.42		
Tata				
Trombay 5	7.13	59.23	448	222
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.80	36.78	108	40
Trombay 7B	1.22	23.35	65	35
TATA Hydro	4.27	81.64	394	30
Trombay 8	3.61	65.09	219	131
Total	18.02	266.09		
AEML				
DTPS U-1&2	8.40	151.65	474	289
Total	8.40	151.65		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	119.09	2301.74	MSPGCL Total	124.96	2421.70
			MSPGCL Thml+Gas	119.30	2302.51	Koyna 1,2 & 4 Total	1.59	43.59
			MSPGCL Hydro	5.66	119.18	State Total	320.01	5746.65

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	4786	146	0	4932	1755	4682	0	0	6505	5952	-1246	15707	0	0	15707	2367	368	18442	49.97
2	4763	147	0	4910	1833	4539	0	0	6472	6061	-1146	15834	0	0	15834	2210	363	18407	50.02
3	4616	147	0	4763	1881	4407	0	0	6369	6171	-1135	15742	0	0	15742	2074	345	18161	49.99
4	4646	146	0	4792	1858	4405	0	0	6378	6308	-1093	15941	0	0	15941	2001	328	18271	49.97
5	4715	167	0	4882	1716	4702	0	0	6726	6631	-1074	16519	0	0	16519	1981	337	18838	49.93
6	4760	157	0	4917	1643	4924	0	0	7843	7615	-1131	17585	0	0	17585	2098	383	20066	49.95
7	4780	231	0	5011	1671	4990	0	115	8892	8717	-1209	18897	0	0	18897	2227	398	21522	49.96
8	4722	381	0	5103	1595	4884	0	198	9363	9012	-1520	18846	0	0	18846	2426	426	21698	50.00
9	4768	282	0	5050	1622	4978	0	565	9500	9332	-1810	19284	0	0	19284	2735	453	22472	49.99
10	4753	267	0	5020	1990	4663	0	880	9922	9360	-2087	19379	0	0	19379	3017	447	22843	50.01
11	4606	169	0	4775	2152	4176	0	1035	9918	9722	-2315	19088	0	0	19088	3180	457	22725	50.00
12	4728	309	0	5037	2142	4351	0	1067	9108	8880	-2224	18797	0	0	18797	3216	455	22469	50.02
13	4758	146	0	4904	2060	4301	0	1080	8515	8341	-2128	18110	0	0	18110	3138	448	21696	49.99
14	4739	178	0	4917	2283	4064	0	1001	8185	7774	-2071	17512	0	0	17512	3032	456	21000	49.96
15	4822	251	0	5073	2289	4029	0	1056	8000	7669	-2042	17634	0	0	17634	2992	440	21066	49.97
16	5022	221	0	5243	2400	4175	0	767	7842	7962	-2014	18084	0	0	18084	2985	449	21518	49.97
17	5247	181	0	5428	2465	4301	0	656	7778	7845	-2008	18220	0	0	18220	2982	467	21669	50.05
18	5247	169	0	5416	2512	4257	0	314	7775	7684	-1964	17742	0	0	17742	2954	477	21173	50.01
19	5351	248	0	5599	2429	4567	0	49	7954	7700	-1755	18111	0	0	18111	2933	479	21522	50.07
20	5479	543	34	6056	2241	4914	0	0	7489	7148	-1359	18534	0	0	18534	2920	466	21920	50.01
21	5505	465	155	6125	2129	5197	0	0	6736	6324	-1194	18119	0	0	18119	2841	462	21422	50.02
22	5512	387	23	5922	2222	5239	0	0	6111	5813	-1115	17633	0	0	17633	2715	448	20796	50.03
23	5511	167	0	5678	2138	5215	0	0	5886	5290	-1034	16859	0	0	16859	2659	428	19946	50.04
24	5251	158	0	5409	2101	4753	0	0	6088	5808	-1112	16562	0	0	16562	2528	397	19487	50.04
MUs	119.09	5.66	0.21	124.96	49.13	110.71	0.00	8.78	185.35	179.12	-37.79	424.74	0.00	0.00	424.74	64.21	10.18	499.13	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 17/Jul/2023

Position as on 6.30 Hrs of 18/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	
MSPGCL	Uran Unit 6	108	15/07/2023	21:15	17/07/2023	19:23	No schedule	
MSPGCL	Uran Unit 7	108	15/07/2023	21:18	17/07/2023	20:00	No schedule	
IPP	Adani U-1	660	16/07/2023	00:00		Continued.	Annual Overhaul	07/08/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/07/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	25/07/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	25/07/2023
IPP	SWPGPL U-1	135	02/07/2023	02:54	17/07/2023	21:33	PA Fan problem	17/07/2023
MSPGCL	Nasik Unit 5	210	04/07/2023	18:00		Continued.	Generator Swapping : nashik Unit-3 sync 16:35 Hrs and tolling agreement with IEPL	
MSPGCL	Khaparkheda Unit 5	500	15/07/2023	14:28	17/07/2023	13:15	Boiler Tube Leakage	18/07/2023
MSPGCL	Koradi Unit 8	660	16/07/2023	10:25		Continued.	Boiler Tube Leakage	20/07/2023
MSPGCL	Paras Unit 4	250	16/07/2023	20:07	17/07/2023	07:45	On Coal Mill AB	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Jul/2023

Position as on 6.30 Hrs of 18/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							Pressurised	
MSPGCL	Uran Unit 6	108	17/07/2023	21:15		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	17/07/2023	21:26		Continued.	No Schedule	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 17/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 18/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (701) OF ICT @ TIRORA	IntraState	17/07/2023	10:27	17/07/2023	16:20	PO	For bay(701) equipment maintenance and testing work.
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20			PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR	IntraState	06/07/2023	08:38			PO	1. Maintenance and alignment work of Bus-1, Bus-2 Aus. Bus And HCB Isolator. 2. Maintenance of CB, CT and Synch CVT.
SPARE LINE-2 BAY (404) @ TAPTITANDA	IntraState	17/07/2023	12:09			PO	Circuit breaker mechanism overhauling work by M/s CGL service Engineer.
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	17/07/2023	12:12	17/07/2023	17:49	PO	Diagnostic testing of Spare ICT
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
LONIKAND I - TALEGAON (PGCIL)	InterState	16/07/2023	14:35	17/07/2023	00:34	PO	CT Replacement work
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	13/07/2023	08:03			HT	H/T Due to load management.
KHADKA-AURANGABAD (WALUJ)	IntraState	16/07/2023	22:45	17/07/2023	07:24	HT	TO CONTROL O/V
JAIGAD - KARAD CKT - 1	IntraState	17/07/2023	00:54	17/07/2023	10:36	HT	H/T on overvoltage
KHADKA-AURANGABAD (WALUJ)	IntraState	18/07/2023	00:26			HT	HT for Overvoltage
AKOLA-NANDGAONPETH (RPL-AMT)	IntraState	18/07/2023	09:50			PO	Routine Maintenance & Testing work
DABHOL - NEW KOYNA CKT - 1	IntraState	18/07/2023	10:07			PO	Diagnostic testing & Relay testing work , Routine maint. Work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	IntraState	16/07/2023	10:00			PO	ABB Circuit Breaker Pole & Mechanism overhauling;HV CB DCRM/timing
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	17/07/2023	13:04			PO	1.Replacement of HV CB under LES Scheme. 2.ICT will be in service through TBC.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 18/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - VERSOVA	IntraState	10/07/2023	10:24			PO	Shifting of Lines on Newly constructed Towers for NHRCL Project Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
BOISAR - VERSOVA	IntraState	10/07/2023	10:27			PO	Shifting of Lines on Newly constructed Towers for NHRCL Project. Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
GOREGAON - AAREY CKT - 2	IntraState	17/07/2023	03:01	17/07/2023	06:02	PO	Replacement of Cable Link box of 220kV Line.
GOREGAON - AAREY CKT - 1	IntraState	17/07/2023	06:19	17/07/2023	15:03	PO	Replacement of Cable Link boxes of 220kV Line.
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	17/07/2023	09:55	17/07/2023	12:00	PO	Replacement Of Disc String At Loc. No 345 Y&B Phase A.
HINJAWADI I- CHINCHWAD	IntraState	17/07/2023	10:45	17/07/2023	20:02	PO	1. Erection of monopole at Location 161 - 7 sections with 500 Ton crane
RANJANGAON-FIAT 1	IntraState	17/07/2023	12:20	17/07/2023	16:32	PO	EHV CB O/H work
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	17/07/2023	15:11	17/07/2023	19:35	PO	For carrying out the work of stringing of OPGW on dead portion of 220 kv Waghiwali Kharghar line, but while doing this in loc no 85 & 86 the 220 kv Khandeshwar Kharghar line is crossing (below
KHARGHAR - KHANDESHWAR CKT - 2	IntraState	17/07/2023	15:20	17/07/2023	19:36	PO	For carrying out the work of stringing of OPGW on dead portion of 220 kv Waghiwali Kharghar line, but while doing this in loc no 85 & 86 the 220 kv Khandeshwar Kharghar line is crossing (below).
PEDHAMBE ONI LINE	IntraState	18/07/2023	04:59	18/07/2023	06:06	T	Distance Protection
PALGHAR - NALASOPARA	IntraState	18/07/2023	05:16	18/07/2023	08:46	PO	For replacement of rusted old Disc insulator string at location no. 79,94,95,97,98 & 99.
TROMBAY - MULUND	IntraState	18/07/2023	05:21	18/07/2023	08:57	PO	Outage is required for safety purpose by M/s KVTL during stringing of 400KV Khargar-Vikhroli line between loc no. AP 59- AP 60 & 61-62 by M/s KVTL.
TROMBAY - KALWA	IntraState	18/07/2023	05:22	18/07/2023	09:01	PO	Outage is required for safety purpose by M/s KVTL during stringing of 400KV Khargar-Vikhroli line between loc no. AP 59- AP 60 & 61-62 by M/s KVTL.
URAN - APTA CKT - 1	IntraState	18/07/2023	06:58			HT	Tripped on distance protection.
KARAD - KADEGAON	IntraState	18/07/2023	09:00			PO	Cold line washing of insulator string from Loc No.1 to 85.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 18/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	15/07/2023	12:45			EO	Attending the SF6 Gas leakage . Present SF6 gas pressure is 5.7
250 MVA ICT-4 @ TROMBAY	IntraState	17/07/2023	09:59	17/07/2023	17:23	PO	R/M & Testing
220/132kV 100MVA ICT -1 @ LONI DEOKAR	IntraState	17/07/2023	10:05	17/07/2023	16:35	PO	OLTC Overhauling work.
220/33 KV 50 MVA CGL PTR 1 @ MUDSHINGI	IntraState	17/07/2023	10:17	17/07/2023	17:00	PO	For TAMS system wiring & testing work. Quarterly maintenance work
220 KV BUSBAR Outages/Trippings							
AUXILIARY BUS @ PHALTAN MIDC-220 KV	IntraState	16/07/2023	10:02			PO	For Gantry replacement from AH type to AF type
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	17/07/2023	16:30	17/07/2023	21:41	PO	Metro 4 work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage