

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Aug/2016 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	77.585	1155.621	1) Gujrat	9.128	73.711
2) Hydro	16.069	229.922	2) Madhya Pradesh	13.578	198.524
3) Gas	6.850	143.982	3) Chattisgarh	6.490	114.330
Total MSPGCL	100.504	1529.525	4) Maharashtra Net	73.430	1042.930
B) 1) APML	27.926	510.804	5) Goa (Amona)	-0.642	-11.375
2) JSWEL	21.874	348.727	6) TAPS 1&2 Injection	7.632	128.129
3) VIPL	13.524	161.099	7) RGPPL Injection	11.748	198.182
4) RPL(AMT)	0.000	0.000	8) Pench (MS)	0.194	4.218
5) WPCL	4.629	74.291	9) Pench (Excess)	-0.194	-4.218
6) PGPL	6.062	22.979	Total	121.170	1740.213
7) Other IPP	1.869	37.540	a) Mumbai Schedule	20.596	307.755
C) 1) TPCL Thermal	16.215	228.981	b) Mumbai Drawl	21.873	390.944
2) TPCL Hydro	5.854	98.581	c) MSEDCL Bilateral *	28.183	458.236
3) TPCL Gas	3.823	62.767	Include PX	-0.170	-28.856
4) R-INFRA Thermal	11.486	171.576	d) Mumbai Bilateral *	20.596	307.755
D) STATE			Include PX	1.642	33.266
1) Thermal	175.108	2688.639	Include Standby	0.000	0.000
(A1+C1+C4+(B1-B6))			H) ENERGY CATERED (MUs)		
2) Hydro	21.923	328.503	1) MSEDCL	318.775	4836.444
3) Gas	16.735	229.728	2) Mumbai Discoms	59.251	952.849
4) Wind	42.123	787.982	TOTAL STATE	378.026	5789.293
6) SOLAR	0.967	14.228			
TOTAL STATE	256.856	4049.080			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	3451	3373	3378	2868
MSPGCL Hydro	637	391	1611	86
MSPGCL Gas	284	293	281	281
MSPGCL Total Generation	4372	4057	5270	3235
Central Sector Receipt	5629	5462	5253	4621
WIND	2144	2327	1452	1934
CPP / IPP Thermal	2901	2920	2990	2768
CPP / IPP Gas	280	283	241	283
SOLAR	77	128	0	0
Exchange with Mumbai	-1336	-1211	-978	-726
MSEDCL DEMAND MET	14067	13966	14228	12115
Load Shedding	0	0	0	0
MSEDCL DEMAND	14067	13966	14228	12115
TPCL GENERATION	1187	1300	1269	627
R-INFRA GENERATION	504	506	506	403
MUMBAI DEMAND	3027	3017	2753	1756
STATE DEMAND MET	17094	16983	16981	13871
STATE DEMAND	17094	16983	16981	13871
Frequency (Hz)	49.98	49.98	49.97	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 06.00 Hrs	49.74 Hz at 22.16 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 17/Aug/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	8.18	132.18	490	0
Total	8.18	132.18		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	10.56	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	10.56		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.22	32.52	193	161
Unit 4	3.60	57.61	170	127
Unit 5	8.95	138.18	390	350
Unit 6	10.02	127.27	450	355
Unit 7	9.27	143.87	417	356
Unit 8	7.18	74.91	370	186
Total	43.24	574.36		
Paras				
Unit 3	0.00	33.73	0	0
Unit 4	5.70	83.91	250	190
Total	5.70	117.64		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	11.57	170.59	500	430
Total	11.57	170.59		
Nasik				
Unit 3	4.44	66.87	195	165
Unit 4	4.45	56.22	200	160
Unit 5	0.00	10.04	0	0
Total	8.90	133.14		
Uran				
All Units	6.85	143.98	295	275
Total	6.85	143.98		
PGPL				
Unit 1	4.19	14.18	190	95

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	1.87	8.80	101	4
Total	6.06	22.98		
PENCH (MS)				
Pench (MS)	0.19	4.22	26	0
Total	0.19	4.22		
Koyna				
Stage 1-2	4.28	65.80	535	40
Stage 4	6.86	58.44	945	0
Stage 3	2.56	40.44	238	0
Total	13.71	164.68		
Hydro				
KDPH	0.00	5.89	0	0
VTRNA	0.00	14.96	0	0
TILLARI	0.40	4.85	62	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.45	7.81	80	0
RNGR+BHTSA	0.00	4.33	0	0
BHANDARDRA	0.34	7.97	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.52	6.29	22	21
GHATGHAR	0.64	13.15	125	0
Total	2.36	65.24		
Wind				
Total	42.12	787.98	0	0
Total	42.12	787.98		
CPP				
APML(Mus)	27.93	510.80	0	0
JSWEL(Mus)	21.87	348.73	0	0
VIPL(Mus)	13.52	161.10	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	4.63	74.29	0	0
Other(Mus)	1.87	37.54	0	0
Total	69.82	1132.46		
SOLAR				
Total	0.97	14.23	0	0
Total	0.97	14.23		
Tata				
Trombay 5	10.58	142.90	488	313
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.36	38.57	115	59
Trombay 7B	1.47	24.20	67	48
Trombay 8	5.64	86.08	249	199
TATA Hydro	5.85	98.58	387	0
Total	25.89	390.33		
R-INFRA				
1-2	11.49	171.58	508	402
Total	11.49	171.58		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	0.00	17.16
Koradi 9	0.00	0.00
Koradi 10	0.00	0.00
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	77.58	1155.62
MSPGCL Thml+Gas	84.44	1299.60
MSPGCL Hydro	16.07	229.92

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	100.50	1529.52
Koyna 1,2 & 4 Total	11.14	124.24
State Total	256.86	4049.08

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Aug/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2874	291	290	3455	1975	2933	281	0	4298	4459	-847	12256	0	12256	2073	14329	49.94
2	2881	241	279	3401	1860	2908	283	0	4293	4470	-867	12055	0	12055	1918	13973	49.96
3	2779	236	279	3294	2016	2762	283	0	4379	4492	-791	12056	0	12056	1820	13876	49.96
4	2781	180	290	3251	1958	2737	283	0	4395	4631	-733	12127	0	12127	1756	13883	49.98
5	2868	86	281	3235	1934	2768	283	0	4415	4621	-726	12115	0	12115	1756	13871	49.99
6	3011	307	280	3598	1912	2787	283	0	4419	4867	-666	12781	0	12781	1838	14619	49.96
7	3165	419	290	3874	1636	2892	282	1	4888	5277	-536	13426	0	13426	1943	15369	49.96
8	3317	907	280	4504	1482	2924	283	32	5062	5395	-706	13914	0	13914	2167	16081	49.99
9	3376	1132	295	4803	1797	2921	281	83	5042	5512	-755	14642	0	14642	2448	17090	50.03
10	3394	950	293	4637	2029	2901	282	96	5287	5356	-976	14325	0	14325	2745	17070	49.95
11	3451	637	284	4372	2144	2901	280	77	5461	5629	-1336	14067	0	14067	3027	17094	49.98
12	3403	460	295	4158	2188	2908	282	128	5201	5526	-1252	13938	0	13938	3051	16989	49.94
13	3373	391	293	4057	2327	2920	283	128	5015	5462	-1211	13966	0	13966	3017	16983	49.98
14	3373	181	284	3838	1925	2955	281	128	4979	5219	-1078	13268	0	13268	2882	16150	49.99
15	3349	451	277	4077	1861	2940	266	113	5098	5327	-1083	13501	0	13501	2886	16387	49.96
16	3260	714	285	4259	1644	2952	163	91	5053	5635	-1051	13693	0	13693	2857	16550	49.97
17	3364	973	275	4612	1646	2941	193	62	4937	5087	-1019	13522	0	13522	2824	16346	49.96
18	3300	640	281	4221	1742	2870	239	25	4676	4696	-1037	12756	0	12756	2815	15571	49.98
19	3390	777	289	4456	1361	2913	248	3	4844	4893	-961	12913	0	12913	2741	15654	50.01
20	3378	1611	281	5270	1452	2990	241	0	4861	5253	-978	14228	0	14228	2753	16981	49.97
21	3332	1627	277	5236	1377	3017	243	0	4833	5033	-889	14017	0	14017	2696	16713	49.99
22	3415	948	294	4657	1228	3024	259	0	4782	4908	-764	13312	0	13312	2537	15849	49.95
23	3363	1080	284	4727	1342	2964	114	0	4391	4757	-779	13125	0	13125	2391	15516	49.92
24	3388	830	294	4512	1287	2993	146	0	4521	4665	-832	12771	0	12771	2310	15081	49.98
MUs	77.59	16.07	6.85	100.50	42.12	69.82	6.06	0.97	115.13	121.17	-21.87	318.78	0.00	318.78	59.25	378.03	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Aug/2016

Position as on 6.30 Hrs of 18/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Koyana Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 1	210	25/06/2016	23.45		Continued.	Zero Schedule by MSEDCL from 00.00Hrs Dt.19-7-16 and A.O.H from 25/06/2016 to 18/07/2016	
MSPGCL	Khaparkheda Unit 3	210	05/07/2016	23.52		Continued.	Zero Shedule By MSEDCL, converted for AOH from 00 Hrs Dt.25-7-16	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-2	270	18/06/2016	06.54		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	30/06/2016	10.11		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 5	200	01/07/2016	02.23		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Koradi Unit 7	210	01/07/2016	04.43		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-1	270	01/07/2016	18.40		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 5	500	01/07/2016	23.59		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkheda Unit 2	210	05/07/2016	23.46		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkheda Unit 4	210	08/07/2016	03.07		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	08/07/2016	23.57		Continued.	ID Fan Problem (Converted	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Aug/2016

Position as on 6.30 Hrs of 18/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							to Zero schedule by MSEDCL from 11-07-2016)	
IPP	Adani U-4	660	13/07/2016	02.22		Continued.	Zero Shedule By MSEDCL,Shedule Glven On 21/08/2016	
MSPGCL	Nasik Unit 5	210	03/08/2016	17.30		Continued.	Zero shedule	
IPP	Adani U-1	660	05/08/2016	11.44		Continued.	Zero Schedule from MSEDCL	
IPP	Adani U-5	660	06/08/2016	23.54		Continued.	Zero schedule given by MSDCL.	
MSPGCL	Paras Unit 3	250	08/08/2016	00.01	18/08/2016	06.00	Zero schedule given by MSDCL.	
MSPGCL	Chandrapur Unit 9	500	11/08/2016	22.11		Continued.	Oil Shortage.	
MSPGCL	Uran Unit B0	120	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Bhusawal Unit 4	500	14/08/2016	21.28		Continued.	Zero schedule given by MSEDCL	
RGPL	Dabhol 3A	230	16/08/2016	17.24		Continued.	Change Over	
MSPGCL	Koradi Unit-8	660	16/08/2016	18.32	17/08/2016	03.22	ID Fan Problem	
MSPGCL	Koyna Unit 6	75	17/08/2016	16.43	17/08/2016	21.25	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
MSPGCL	Koyna Unit 5	80	17/08/2016	16.43	17/08/2016	21.20	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
MSPGCL	Koyna Unit 7	80	17/08/2016	16.43	17/08/2016	21.45	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
MSPGCL	Koyna Unit 8	80	17/08/2016	16.43	18/08/2016	00.45	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
IPP	JSW (J) U3	300	17/08/2016	16.49	17/08/2016	18.50	Governor Valve Oil Leakage	
PGPL	PGPL U2	126	18/08/2016	00.15		Continued.	Gas shortage	
PGPL	PGPL U1	262	18/08/2016	00.23		Continued.	Gas shortage	
MSPGCL	Koyna Unit 8	80	18/08/2016	06.40	18/08/2016	10.20	TGB Oil level very Low	
MSPGCL	Paras Unit 4	250	18/08/2016	07.02	18/08/2016	16.11	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 18/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Kolhapur Solapur(PG) I	InterState	14/08/2016	00.42	17/08/2016	07.45	HT	Over Voltage
Dhule Khandwa II	InterState	16/08/2016	22.21	17/08/2016	07.15	HT	Over Voltage
Akola Aurangabad(PG) II	InterState	17/08/2016	12.10	17/08/2016	17.19	PO	To attend Tie Breaker
Dhule Khandwa II	InterState	17/08/2016	23.33	18/08/2016	06.56	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	27/07/2016	13.09		Continued.	HT	Over Voltage
Ektuni-Bableshwar ckt II	IntraState	01/08/2016	09.53		Continued.	HT	To control Padgha-BBLSR L/L
Padghe - Kharghar	IntraState	07/08/2016	17.07		Continued.	PO	Shifted on TBC at kharghar end
karad -kolhapur-I	IntraState	09/08/2016	14.48		Continued.	T	Over Voltage,Opportunity Outage from DT 16.08.2016.
Karad - Jaigad - II	IntraState	13/08/2016	13.02	18/08/2016	10.06	HT	Over Voltage
N.Koyna-Karad -Ckt II	IntraState	15/08/2016	16.49	18/08/2016	10.02	HT	Over Voltage
Lonikand2-Lonikand1 (Intrconector)	IntraState	18/08/2016	09.17	18/08/2016	15.15	PO	Half yearly maintenance work
Koradi-India Bulls	IntraState	18/08/2016	14.03		Continued.	T	Distance Protection
Karad - Jaigad - II	IntraState	18/08/2016	16.45		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	18/08/2016	11.25	18/08/2016	13.57	EO	Attending Hot Spot
Ict Spare Single Unit 167 Mva Ict @Jejuri	IntraState	18/08/2016	14.56	18/08/2016	18.58	PO	Testing Work
220 KV LINE Outages/Trippings							
Borivali - Tarapur	InterState	18/08/2016	14.20		Continued.	PO	shifted on TBC
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conducting of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Aurangabad (Waluj)-Bhenda	IntraState	22/06/2016	23.02	18/08/2016	05.01	HT	Hand Tripped.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Bableshwar- Alephata	IntraState	24/07/2016	07.57		Continued.	HT	Load Diversion.
Ghatghar - Bapgaon	IntraState	17/08/2016	04.30	17/08/2016	05.15	T	Distance Protection
Padghe - Kamba	IntraState	17/08/2016	05.30	17/08/2016	06.17	T	Distance Protection(Tripped at Kamba end only)
Pandharpur - Malinagar	IntraState	17/08/2016	06.03	17/08/2016	16.44	PO	LILO arrangement on Pandhar-Malinagar line for SVSSK Ltd
Lamboti-Vita	IntraState	17/08/2016	06.03	17/08/2016	16.57	PO	LILO arrangement on Pandhar-Malinagar line for SVSSK Ltd
Ghatghar - Bapgaon	IntraState	17/08/2016	06.30	17/08/2016	20.10	T	Distance Protection
Kandalgaon - Sona Alloys	IntraState	17/08/2016	09.05	18/08/2016	13.05	T	Distance Protection
Ambazari-Amravati	IntraState	17/08/2016	09.54	17/08/2016	14.50	PO	Tan Delta Measurment of CTs
Khaparkheda-Kalmeshwar	IntraState	17/08/2016	10.23	17/08/2016	14.14	PO	Replacement of LA
Theur-Jejuri	IntraState	17/08/2016	11.00	17/08/2016	13.57	PO	Line Maintenance work
Pophli Pedhmbe Line- 1	IntraState	17/08/2016	13.20	17/08/2016	18.35	PO	To attend Badly damaged conductor
Jejuri (400 Kv)-Jejuri- li	IntraState	17/08/2016	15.01	17/08/2016	17.38	PO	Line Maintenance work
Eklahare (Gcr) - Ghatghar	IntraState	17/08/2016	16.38	17/08/2016	19.18	PO	To attend problem of Bapgaon-Ghatghar line(on same Tower)
Bus Section II @ Pophali	IntraState	17/08/2016	16.40	17/08/2016	21.15	HT	Main Bus GOD B Phase Conductor Snapped of pedambe - II line

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 18/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Pophli Pedhmbe Line- 2	IntraState	17/08/2016	16.43	17/08/2016	21.10	HT	Main Bus GOD B Phase Conductor Snapped of pedambe - II line
Pophali - Nerale	IntraState	17/08/2016	16.43	17/08/2016	21.35	HT	Main Bus GOD B Phase Conductor Snapped of pedambe - II line
Pophali - New Koyna	IntraState	17/08/2016	16.43	17/08/2016	21.40	HT	Main Bus GOD B Phase Conductor Snapped of pedambe - II line
Bableshwar -Bhenda	IntraState	18/08/2016	04.34	18/08/2016	10.15	T	Distance Protection
Pedambe-Nerle	IntraState	18/08/2016	08.20	18/08/2016	16.20	PO	Attending Hot Spot
Jejuri-Phursungi 2	IntraState	18/08/2016	10.30	18/08/2016	19.09	PO	Annual Maintenance Work
Jejuri (400 Kv)- Baramati li	IntraState	18/08/2016	16.36	18/08/2016	21.40	PO	CT Ratio changing
Lonand-Baramati	IntraState	18/08/2016	17.57	18/08/2016	18.23	PO	Bus Bar Protection Operated
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
100 KV LINE Outages/Trippings							
Vasai-li - Vasai 2 Line	IntraState	13/08/2016	08.53		Continued.	HT	ICT Problem.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage