

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Aug/2017 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	163.147	2310.782	1) Gujrat	2.526	78.563
2) Hydro	4.060	138.410	2) Madhya Pradesh	11.177	292.794
3) Gas	8.936	168.678	3) Chattisgarh	4.640	101.460
Total MSPGCL	176.143	2617.870	4) Maharashtra Net	98.857	1690.151
B) 1) APML	42.314	824.986	5) Goa (Amona)	-0.462	-7.876
2) JSWEL	14.529	247.573	Total	116.738	2155.092
3) VIPL	7.462	109.747	a) Mumbai Schedule	20.866	374.981
4) RPL(AMT)	21.759	146.820	b) Mumbai Drawl	29.104	440.993
5) WPCL	2.621	52.902	c) MSEDCL Bilateral *	15.297	374.735
6) PGPL	0.000	0.000	Include PX	1.226	78.721
7) Other IPP	3.909	58.636	d) Mumbai Bilateral *	20.866	374.981
C) 1) TPCL Thermal	14.285	254.983	Include PX	6.031	116.617
2) TPCL Hydro	5.629	78.732	Include Standby	0.000	0.000
3) TPCL Gas	2.414	66.714	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	9.830	177.253	1) MSEDCL	381.206	6246.960
D) STATE			2) Mumbai Discoms	61.261	1018.670
1) Thermal	279.856	4183.682	TOTAL STATE	442.467	7265.630
(A1+C1+C4+(B1-B6))					
2) Hydro	9.689	217.142			
(A2+C2)					
3) Gas	11.350	235.392			
(A3+B6+C3)					
4) Wind	22.650	443.121			
6) SOLAR	2.185	31.206			
TOTAL STATE	325.730	5110.543			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6733	7051	7249	6109
MSPGCL Hydro	766	238	145	69
MSPGCL Gas	363	384	374	377
MSPGCL Total Generation	7862	7673	7768	6555
Central Sector Receipt	5500	5444	4182	4202
WIND	786	1127	1089	920
CPP / IPP Thermal	4034	4030	4063	3537
CPP / IPP Gas	0	0	0	0
SOLAR	309	229	0	0
Exchange with Mumbai	-1426	-1237	-1310	-863
MSEDCL DEMAND MET	17066	17266	15792	14351
Load Shedding	0	0	0	0
MSEDCL DEMAND	17066	17266	15792	14351
TPCL GENERATION	1215	1214	1129	602
R-INFRA GENERATION	497	504	399	375
MUMBAI DEMAND	3138	2955	2838	1840
STATE DEMAND MET	20204	20221	18630	16191
STATE DEMAND	20204	20221	18630	16191
Frequency (Hz)	49.99	49.97	49.90	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 18.01 Hrs	49.7 Hz at 19.24 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 17/Aug/2017

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	2.86	3.26	148	85
Unit 8	12.34	113.58	555	445
Unit 9	11.62	199.89	565	387
Unit 10	12.44	205.98	600	460
Total	39.26	522.72		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	4.24	24.78	190	165
Unit 4	10.60	185.23	500	360
Unit 5	3.84	8.51	460	0
Total	18.67	218.52		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	1.32	39.43	250	0
Unit 7	3.55	7.98	248	0
Unit 8	0.00	0.00	0	0
Total	4.88	47.41		
Chandrapur				
Unit 3	4.72	78.44	202	170
Unit 4	4.49	74.43	190	176
Unit 5	9.86	139.25	430	365
Unit 6	9.22	151.96	400	350
Unit 7	9.88	168.44	425	364
Unit 8	11.48	159.74	500	370
Unit 9	11.49	182.89	500	360
Total	61.13	955.16		
Paras				
Unit 3	5.54	94.27	256	190
Unit 4	5.56	94.64	255	191
Total	11.09	188.91		
Khaparkheda				
Unit 1	3.93	41.52	180	145
Unit 2	4.04	38.43	185	140
Unit 3	4.13	35.10	184	160
Unit 4	0.00	0.00	0	0
Unit 5	11.78	186.84	505	360
Total	23.89	301.89		
Nasik				
Unit 3	0.00	38.47	0	0
Unit 4	4.22	36.24	199	162
Unit 5	0.00	1.46	0	0
Total	4.22	76.17		
Uran				
All Units	8.94	168.68	386	361
Total	8.94	168.68		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.07	1.02	41	0
Total	0.07	1.02		
Koyna				
Stage 1-2	1.84	49.38	400	40
Stage 4	0.63	38.31	336	0
Stage 3	0.58	24.20	160	0
Total	3.04	111.89		
Hydro				
KDPH	0.00	1.25	0	0
VTRNA	0.00	5.18	0	0
TILLARI	0.18	0.79	61	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.40	6.75	80	0
RNGR+BHTSA	0.00	2.14	0	0
BHANDARDRA	0.34	5.82	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.09	4.59	4	3
GHATGHAR	0.00	0.00	0	0
Total	1.02	26.52		
Wind				
Total	22.65	443.12	0	0
Total	22.65	443.12		
CPP				
APML(Mus)	42.31	824.99	0	0
JSWEL(Mus)	14.53	247.57	0	0
VIPL(Mus)	7.46	109.75	0	0
RPLAMT(Mus)	21.76	146.82	0	0
WPCL(Mus)	2.62	52.90	0	0
Other(Mus)	3.91	58.64	0	0
Total	92.59	1440.66		
SOLAR				
Total	2.18	31.21	0	0
Total	2.18	31.21		
Tata				
Trombay 5	9.09	163.76	489	305
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.33	41.22	64	52
Trombay 7B	1.08	25.50	51	43
Trombay 8	5.20	91.22	246	196
TATA Hydro	5.63	78.73	387	2
Total	22.33	400.43		
R-INFRA				
DTPS U-1&2	9.83	177.25	505	372
Total	9.83	177.25		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	163.15	2310.78	MSPGCL Total	176.14	2617.87
			MSPGCL Thml+Gas	172.08	2479.46	Koyna 1,2 & 4 Total	2.46	87.70
			MSPGCL Hydro	4.06	138.41	State Total	325.73	5110.54

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 17/Aug/2017

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6988	68	376	7432	706	3815	0	0	4265	4207	-1227	14933	0	14933	2209	17142	49.96
2	6536	58	367	6961	816	3827	0	0	4175	3958	-1073	14489	0	14489	2051	16540	49.98
3	6484	58	376	6918	939	3632	0	0	4164	3831	-942	14378	0	14378	1922	16300	50.03
4	6109	69	377	6555	920	3537	0	0	4161	4202	-863	14351	0	14351	1840	16191	49.97
5	5970	74	377	6421	880	3542	0	0	4532	4658	-849	14653	0	14653	1829	16482	49.99
6	6479	59	367	6905	832	3601	0	0	4794	5124	-923	15539	0	15539	1901	17440	50.00
7	6886	59	377	7322	841	3784	0	5	5481	5473	-1012	16413	0	16413	1989	18402	49.97
8	6739	73	376	7188	815	3766	0	41	5568	5896	-1195	16511	0	16511	2239	18750	50.03
9	6768	155	375	7298	861	3935	0	120	5667	5940	-1338	16816	0	16816	2502	19318	50.01
10	6785	204	374	7363	789	4008	0	185	5568	5535	-1383	16497	0	16497	2893	19390	50.02
11	6709	199	362	7270	778	4044	0	268	5553	5758	-1435	16683	0	16683	3071	19754	50.00
12	6733	766	363	7862	786	4034	0	309	5590	5500	-1426	17066	0	17066	3138	20204	49.99
13	6855	634	382	7871	787	4048	0	318	5477	5339	-1405	16958	0	16958	3121	20079	49.98
14	6903	352	361	7616	903	4045	0	284	5417	5373	-1231	16990	0	16990	2946	19936	50.00
15	7051	238	384	7673	1127	4030	0	229	5432	5444	-1237	17266	0	17266	2955	20221	49.97
16	7151	125	363	7639	1199	3980	0	196	5432	5122	-1291	16845	0	16845	2937	19782	49.99
17	7009	63	365	7437	1185	3874	0	156	5149	5279	-1504	16427	0	16427	2901	19328	49.96
18	6818	158	383	7359	1231	3758	0	64	4935	5199	-1486	16125	0	16125	2863	18988	49.95
19	6830	58	364	7252	1139	3766	0	10	4920	4997	-1411	15754	0	15754	2789	18543	49.94
20	7249	145	374	7768	1089	4063	0	0	4546	4182	-1310	15792	0	15792	2838	18630	49.90
21	7255	143	376	7774	1048	4084	0	0	4220	3636	-1042	15501	0	15501	2768	18269	49.89
22	7199	86	365	7650	993	3860	0	0	4174	3912	-1106	15309	0	15309	2637	17946	49.90
23	6940	63	386	7389	1025	3790	0	0	3971	3994	-1228	14970	0	14970	2498	17468	49.90
24	6701	153	366	7220	961	3768	0	0	3830	4179	-1187	14940	0	14940	2425	17365	49.93
MUs	163.15	4.06	8.94	176.14	22.65	92.59	0.00	2.19	117.02	116.74	-29.10	381.21	0.00	381.21	61.26	442.47	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Aug/2017

Position as on 6.30 Hrs of 18/Aug/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown.	
CENT.SECTOR	TARAPUR 4	540	23/04/2017	19:55		Continued.	Annual Maintenance	
CENT.SECTOR	Tarapur 1	160	04/06/2017	19.09		Continued.	3 months outage for refuelling.	
CENT.SECTOR	TARAPUR-3	540	11/07/2017	16.30		Continued.	Reactor Inspection Work	
MSPGCL	Khaparkheda Unit 4	210	13/07/2017	03.36		Continued.	Drum level low. on Dated 14.07.2017 converted to zero schedule. Converted into COH from 00:00Hrs of 02.08.2017	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Shutdown	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	JSW (J) U2	300	31/05/2017	23.58		Continued.	NO SCHEDULE.	
IPP	Dhariwal	300	01/06/2017	00.01		Continued.	NO SCHEDULE.	
IPP	RPL(AMT) U-4	270	09/06/2017	00.20		Continued.	Zero Schedule by MSEDCL	
IPP	VIPL U-1	300	13/06/2017	08.30		Continued.	GT WORK	
MSPGCL	Parli Unit 8	250	17/06/2017	00.08		Continued.	Zero Schedule by MSEDCL, scheduled issued on 08.08.2017 but synchronization delayed.	
MSPGCL	Ghatghar Unit-2	125	28/07/2017	00.00		Continued.	due to common pressure shaft with unit 1.	
MSPGCL	Ghatghar Unit-1	125	28/07/2017	00.00		Continued.	rbtv leakage attending work.	
IPP	JSW (J) U4	300	05/08/2017	20.30		Continued.	Turbine shaft Vibration high.	
IPP	Adani U-1	660	07/08/2017	00.29		Continued.	AIR PREHEATER PROBLEM.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Aug/2017

Position as on 6.30 Hrs of 18/Aug/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Nasik Unit 5	210	09/08/2017	00.00		Continued.	ID Fan Problem converted to zero schedule from 19:00Hrs of 11.08.2017	
MSPGCL	Nasik Unit 3	210	10/08/2017	00.00		Continued.	Withdrawn for maintenance work.	
IPP	Adani U-2	660	11/08/2017	16.49		Continued.	Furnace Pressure High	
CPP	SWPGL U-4	135	11/08/2017	23.23		Continued.	Y ph ct of bhugaoan ckt burst.	
MSPGCL	Bhusawal Unit 5	500	16/08/2017	13.50	17/08/2017	11.43	Tube leakage near turbine.	
MSPGCL	Parli Unit 7	250	17/08/2017	06.32	17/08/2017	13.53	due to bus trip.	
MSPGCL	Parli Unit 6	250	17/08/2017	06.32	18/08/2017	22.06	bus trip.	
MSPGCL	Chandrapur Unit 9	500	18/08/2017	15.26		Continued.	Turbine sharp Vibration problem.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Aug/2017

Statement-VII

Position as on 6.30 Hrs of 18/Aug/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar II	InterState	16/08/2017	12.38	17/08/2017	06.34	T	Distance Protection
Dhule Sar'Sarovar II	InterState	17/08/2017	12.12	17/08/2017	23.10	T	Distance Protection
Akola Aurangabad(PG) I	InterState	18/08/2017	10.45	18/08/2017	14.54	PO	Routine Maintenance Work
Dhule Sar'Sarovar I	InterState	18/08/2017	19.08		Continued.	HT	Over Voltage
Ektuni-Bableswhar ckt I	IntraState	10/08/2017	06.43		Continued.	HT	Emergency outage on padghe bblsr ckt.
N.Koyna-Karad -Ckt I	IntraState	15/08/2017	04.42	17/08/2017	18.00	T	Distance Protection
karad -kolhapur-II	IntraState	16/08/2017	18.02	17/08/2017	08.27	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/08/2017	20.15	17/08/2017	09.33	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	16/08/2017	20.23	17/08/2017	06.23	HT	Over Voltage
Aurangabad - Aurangabad(PG) I	IntraState	17/08/2017	09.53	17/08/2017	13.21	PO	Line Maintenance work
Jejuri- Koynastage-IV	IntraState	17/08/2017	12.35	17/08/2017	18.56	PO	Attending Hot Spot
Chandrapur II - Chandrapur SW Ckt I	IntraState	17/08/2017	15.30	17/08/2017	16.13	PO	Attending Hot Spot
Bhusawal-Aurangabad	IntraState	17/08/2017	15.57	17/08/2017	16.48	PO	Corona ring fixing by hot line method.
karad -kolhapur-I	IntraState	17/08/2017	21.07		Continued.	HT	Over Voltage
Kalwa - Kharghar	IntraState	18/08/2017	09.26	18/08/2017	12.08	EO	Attending Hot Spot
Dhule - Bableswhar - li	IntraState	18/08/2017	09.28		Continued.	PO	Routine Maintenance Work
400 KV ICT Outages/Trippings							
400/220kv 315 Mva ICT I @Karad	IntraState	08/08/2017	06.15		Continued.	PO	REPLACEMENT OF Y PHASE UNIT(outage for 11 Days)
400/220KV 500MVA ICT1@koradi 2	IntraState	10/08/2017	11.39		Continued.	PO	Attend defects observed in OLTC of ICT 1.
400/220 Kv 500 MVA ICT II @Lamboti	IntraState	18/08/2017	17.43	18/08/2017	19.27	EO	Attending Hot Spot
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	NO SCHEDULE.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Vita - Mhaishal	IntraState	01/07/2017	14.19	18/08/2017	01.38	PO	Bunching Work
Vita - Miraj	IntraState	01/07/2017	14.53	18/08/2017	01.35	PO	bunching work.
Osmanabad - Solapur (Bale)	IntraState	16/08/2017	11.34	17/08/2017	06.49	HT	to control solapur ict o/l.
Parly-Parly Extn.-II	IntraState	17/08/2017	06.32	17/08/2017	08.11	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parly-Parly Extn-I	IntraState	17/08/2017	06.32	17/08/2017	08.05	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Harangul-Parly	IntraState	17/08/2017	06.32	17/08/2017	08.10	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli 3 (Old Gcr)-Girwali Ckt 2	IntraState	17/08/2017	06.32	17/08/2017	08.25	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli 3(Old Gcr)-Parli Newtps Ckt-2	IntraState	17/08/2017	06.32	17/08/2017	08.11	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli 3(Old Gcr)-Parli Newtps Ckt 1	IntraState	17/08/2017	06.32	17/08/2017	08.05	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli New Tps - Beed Ckt 1	IntraState	17/08/2017	06.32	17/08/2017	08.26	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli New Tps - Beed Ckt 2	IntraState	17/08/2017	06.32	17/08/2017	08.59	T	Wave trap burst of Harangul ckt.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Aug/2017

Statement-VII

Position as on 6.30 Hrs of 18/Aug/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							01. Bus 1 and Bus 2 tripped.
Parli 3 (Oldgcr)-Harangul Ckt 2	IntraState	17/08/2017	06.32	17/08/2017	08.10	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli 3 (Oldgcr)-Harangul Ckt I	IntraState	17/08/2017	06.32	17/08/2017	14.43	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli 3 (Old Gcr)-Osmanabad	IntraState	17/08/2017	06.32	17/08/2017	08.35	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	17/08/2017	06.32	17/08/2017	08.00	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	17/08/2017	06.32	17/08/2017	08.00	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Parli(U-VIII) GCR CKT	IntraState	17/08/2017	06.32	17/08/2017	09.03	T	Wave trap burst of Harangul ckt. 01. Bus 1 and Bus 2 tripped.
Interconnector Breaker @ pophali	IntraState	17/08/2017	08.30	17/08/2017	10.35	PO	Line Maintenance work
Talandge-Mudshingi Ckt-I	IntraState	17/08/2017	10.09		Continued.	PO	Taken on TBC
Kathapur-Ranjangaon	IntraState	17/08/2017	11.10	17/08/2017	18.20	PO	Bay Maintainance Work.
Virur - Gadchiroli	IntraState	17/08/2017	11.26	17/08/2017	17.15	PO	Tan Delta Measurment of CTs
Bombay Dyeing - Sahara	IntraState	17/08/2017	12.50		Continued.	T	Distance Protection
Chinchwad-Hinjewadi I	IntraState	17/08/2017	14.46	17/08/2017	19.15	HT	Over Voltage
Bhosari 2 - Telco	IntraState	17/08/2017	16.23	18/08/2017	01.27	PO	Breaker overhauling work.
Eklahare (Gcr) - Airoli Know Park	IntraState	18/08/2017	09.02	18/08/2017	14.41	PO	Isolator maintenance work.
Ghodbunder - Versova	IntraState	18/08/2017	12.33	18/08/2017	13.33	PO	Routine Maintenance Work
Kalwa - Airoli Knowledge Park	IntraState	18/08/2017	14.48	18/08/2017	17.17	PO	Isolator maintenance work.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 Kv 100 Mva Ict 1 @Bhokardan	IntraState	17/08/2017	10.40	17/08/2017	19.27	PO	Tan Delta Measurment of CTs
220/132kv 100mva Ptr 1 @Kharepatan	IntraState	18/08/2017	10.11	18/08/2017	18.02	PO	Attending Oil Leakage
132 KV LINE Outages/Trippings							
Kanhan Pench	InterState	15/08/2017	16.45	17/08/2017	19.28	T	Distance Protection
Parli 2(Girwali) - Latur Midc	IntraState	17/08/2017	08.07	17/08/2017	16.44	T	Distance Protection
100 KV LINE Outages/Trippings							
Kalwa-Kalyan	IntraState	18/08/2017	10.46		Continued.	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage