

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 17/Aug/2019 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 89.073         | 1349.864        | 1) Gujrat                      | 13.446         | 82.692          |
| 2) Hydro            | 8.732          | 137.039         | 2) Madhya Pradesh              | 7.815          | 120.786         |
| 3) Gas              | 6.481          | 144.514         | 3) Chattisgarh                 | 1.670          | 43.470          |
| <b>Total MSPGCL</b> | <b>104.286</b> | <b>1631.417</b> | 4) Maharashtra                 | 107.485        | 1545.459        |
| B) 1) APLM          | 58.321         | 932.126         | 5) Goa (Amona)                 | -0.550         | -9.240          |
| 2) JSWEL            | 24.277         | 381.593         | <b>Total</b>                   | <b>129.866</b> | <b>1783.167</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 25.675         | 378.814         |
| 4) RPL(AMT)         | 17.424         | 66.803          | b) Mumbai Drawl                | 29.308         | 477.007         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 14.851         | 200.954         |
| 6) Other IPP        | 2.385          | 40.282          | Include PX                     | -0.189         | -51.630         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 25.675         | 377.120         |
| C) 1) TPCL Thermal  | 11.610         | 172.864         | Include PX                     | 10.583         | 85.032          |
| 2) TPCL Hydro       | 6.669          | 106.106         | Standby                        | 0.000          | 1.694           |
| 3) TPCL Gas         | 0.000          | 51.125          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 10.670         | 165.972         | 1) MSEDCL                      | 341.624        | 5293.346        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 58.257         | 973.073         |
| 1) Thermal          | 213.760        | 3109.504        | <b>TOTAL STATE</b>             | <b>399.881</b> | <b>6266.419</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 15.401         | 243.145         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 6.481          | 195.639         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 29.158         | 872.038         |                                |                |                 |
| 6) SOLAR            | 5.215          | 62.927          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>270.015</b> | <b>4483.253</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 3562                      | 3791                  | 3784                      | 3736                      |
| MSPGCL Hydro             | 238                       | 158                   | 1300                      | 159                       |
| MSPGCL Gas               | 273                       | 269                   | 273                       | 274                       |
| MSPGCL Total Generation  | 4073                      | 4218                  | 5357                      | 4169                      |
| Central Sector Receipt   | 6088                      | 5877                  | 5961                      | 4479                      |
| WIND                     | 1501                      | 1321                  | 863                       | 1406                      |
| CPP / IPP Thermal        | 4460                      | 4168                  | 4638                      | 3546                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 485                       | 622                   | 0                         | 0                         |
| Exchange with Mumbai     | -1397                     | -1611                 | -1223                     | -829                      |
| <b>MSEDCL DEMAND MET</b> | <b>15210</b>              | <b>14595</b>          | <b>15596</b>              | <b>12771</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 15210                     | 14595                 | 15596                     | 12771                     |
| TPCL GENERATION          | 743                       | 784                   | 989                       | 637                       |
| AEML GENERATION          | 498                       | 373                   | 496                       | 375                       |
| <b>MUMBAI DEMAND</b>     | <b>2638</b>               | <b>2768</b>           | <b>2708</b>               | <b>1841</b>               |
| STATE DEMAND MET         | 17848                     | 17363                 | 18304                     | 14612                     |
| <b>STATE DEMAND</b>      | <b>17848</b>              | <b>17363</b>          | <b>18304</b>              | <b>14612</b>              |
| Frequency (Hz)           | 50.01                     | 49.97                 | 49.98                     | 49.95                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.13 Hz at 11.06 Hrs | 49.84 Hz at 05.13 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 17/Aug/2019

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 7.02         | 50.40         | 351      | 250      |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| Unit 10            | 5.52         | 79.85         | 250      | 150      |
| <b>Total</b>       | <b>12.54</b> | <b>130.25</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 8.54         | 150.05        | 420      | 295      |
| Unit 5             | 8.59         | 149.05        | 390      | 330      |
| <b>Total</b>       | <b>17.14</b> | <b>299.10</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.94         | 35.23         | 134      | 119      |
| Unit 4             | 2.75         | 38.24         | 121      | 111      |
| Unit 5             | 6.88         | 99.75         | 330      | 220      |
| Unit 6             | 7.09         | 109.60        | 335      | 190      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 80.74         | 0        | 0        |
| Unit 9             | 8.84         | 109.12        | 410      | 311      |
| <b>Total</b>       | <b>28.50</b> | <b>472.69</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.26         | 68.51         | 254      | 172      |
| Unit 4             | 4.01         | 59.76         | 205      | 125      |
| <b>Total</b>       | <b>9.27</b>  | <b>128.28</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.68         | 35.91         | 135      | 90       |
| Unit 2             | 0.00         | 34.18         | 0        | 0        |
| Unit 3             | 3.43         | 53.48         | 155      | 130      |
| Unit 4             | 3.63         | 19.38         | 160      | 145      |
| Unit 5             | 7.97         | 136.20        | 365      | 295      |
| <b>Total</b>       | <b>17.71</b> | <b>279.15</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 8.18          | 0        | 0        |
| Unit 4             | 3.92         | 30.11         | 183      | 145      |
| Unit 5             | 0.00         | 2.11          | 0        | 0        |
| <b>Total</b>       | <b>3.92</b>  | <b>40.40</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.48         | 144.51        | 277      | 259      |
| <b>Total</b>       | <b>6.48</b>  | <b>144.51</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.00         | 0.00          | 3        | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>   | <b>0.00</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 2.06          | 34.30          | 385      | 40       |
| Stage 4         | 2.50          | 15.01          | 631      | 0        |
| Stage 3         | 1.15          | 31.81          | 80       | 0        |
| <b>Total</b>    | <b>5.71</b>   | <b>81.13</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.89          | 13.17          | 37       | 37       |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.33          | 13.64          | 40       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.34          | 7.22           | 40       | 0        |
| RNGR+BHTSA      | 0.00          | 0.00           | 0        | 0        |
| BHANDARDRA      | 0.34          | 6.68           | 15       | 14       |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.65          | 9.33           | 28       | 27       |
| GHATGHAR        | 0.47          | 5.88           | 125      | 0        |
| <b>Total</b>    | <b>3.03</b>   | <b>55.91</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 29.16         | 872.04         | 0        | 0        |
| <b>Total</b>    | <b>29.16</b>  | <b>872.04</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 58.32         | 932.13         | 0        | 0        |
| JSWEL(Mus)      | 24.28         | 381.59         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 17.42         | 66.80          | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 2.38          | 40.28          | 0        | 0        |
| <b>Total</b>    | <b>102.41</b> | <b>1420.80</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 5.22          | 62.93          | 0        | 0        |
| <b>Total</b>    | <b>5.22</b>   | <b>62.93</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 6.58          | 92.75          | 311      | 216      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 0.00          | 30.99          | 0        | 0        |
| Trombay 7B      | 0.00          | 20.13          | 0        | 0        |
| Trombay 8       | 5.03          | 80.11          | 219      | 198      |
| TATA Hydro      | 6.67          | 106.11         | 462      | 159      |
| <b>Total</b>    | <b>18.28</b>  | <b>330.10</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 10.67         | 165.97         | 498      | 373      |
| <b>Total</b>    | <b>10.67</b>  | <b>165.97</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 89.07       | 1349.86       | MSPGCL Total        | 104.29      | 1631.42       |
|                |             |         | MSPGCL Thml+Gas | 95.55       | 1494.38       | Koyna 1,2 & 4 Total | 4.56        | 49.32         |
|                |             |         | MSPGCL Hydro    | 8.73        | 137.04        | State Total         | 270.02      | 4483.25       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 17/Aug/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 3718        | 159  | 274  | 4151   | 1417  | 3824      | 0    | 0     | 5015        | 4806        | -1131                | 13067                 | 0                    | 13067                     | 2181             | 15248           | 50.00         |
| 2                  | 3733        | 159  | 265  | 4157   | 1353  | 3601      | 0    | 0     | 4745        | 4748        | -971                 | 12888                 | 0                    | 12888                     | 2016             | 14904           | 50.00         |
| 3                  | 3714        | 174  | 275  | 4163   | 1295  | 3517      | 0    | 0     | 4420        | 4676        | -879                 | 12772                 | 0                    | 12772                     | 1906             | 14678           | 50.00         |
| 4                  | 3736        | 159  | 274  | 4169   | 1406  | 3546      | 0    | 0     | 4442        | 4479        | -829                 | 12771                 | 0                    | 12771                     | 1841             | 14612           | 49.95         |
| 5                  | 3703        | 164  | 277  | 4144   | 1402  | 3604      | 0    | 0     | 4660        | 4834        | -854                 | 13130                 | 0                    | 13130                     | 1826             | 14956           | 49.97         |
| 6                  | 3673        | 164  | 274  | 4111   | 1419  | 4192      | 0    | 0     | 4957        | 4975        | -869                 | 13828                 | 0                    | 13828                     | 1898             | 15726           | 49.96         |
| 7                  | 3678        | 609  | 274  | 4561   | 1400  | 4426      | 0    | 23    | 5180        | 5348        | -833                 | 14925                 | 0                    | 14925                     | 1974             | 16899           | 49.96         |
| 8                  | 3647        | 305  | 264  | 4216   | 1385  | 4449      | 0    | 179   | 5594        | 5709        | -953                 | 14985                 | 0                    | 14985                     | 2096             | 17081           | 49.96         |
| 9                  | 3632        | 254  | 274  | 4160   | 1396  | 4460      | 0    | 338   | 5717        | 5894        | -1173                | 15075                 | 0                    | 15075                     | 2345             | 17420           | 49.97         |
| 10                 | 3562        | 238  | 273  | 4073   | 1501  | 4460      | 0    | 485   | 5991        | 6088        | -1397                | 15210                 | 0                    | 15210                     | 2638             | 17848           | 50.01         |
| 11                 | 3492        | 311  | 273  | 4076   | 1405  | 4462      | 0    | 570   | 5766        | 5936        | -1582                | 14867                 | 0                    | 14867                     | 2851             | 17718           | 50.04         |
| 12                 | 3592        | 273  | 261  | 4126   | 1296  | 4366      | 0    | 678   | 6099        | 5973        | -1670                | 14769                 | 0                    | 14769                     | 2925             | 17694           | 50.03         |
| 13                 | 3631        | 208  | 269  | 4108   | 1345  | 4120      | 0    | 670   | 5911        | 5830        | -1703                | 14370                 | 0                    | 14370                     | 2875             | 17245           | 49.98         |
| 14                 | 3699        | 258  | 259  | 4216   | 1255  | 4140      | 0    | 583   | 5507        | 5581        | -1635                | 14140                 | 0                    | 14140                     | 2758             | 16898           | 50.00         |
| 15                 | 3791        | 158  | 269  | 4218   | 1321  | 4168      | 0    | 622   | 5860        | 5877        | -1611                | 14595                 | 0                    | 14595                     | 2768             | 17363           | 49.97         |
| 16                 | 3725        | 180  | 259  | 4164   | 1103  | 4365      | 0    | 538   | 5724        | 5702        | -1607                | 14265                 | 0                    | 14265                     | 2753             | 17018           | 49.95         |
| 17                 | 3694        | 268  | 269  | 4231   | 1172  | 4483      | 0    | 338   | 5611        | 5779        | -1460                | 14543                 | 0                    | 14543                     | 2724             | 17267           | 49.93         |
| 18                 | 3711        | 203  | 271  | 4185   | 1033  | 4541      | 0    | 165   | 5628        | 5648        | -1383                | 14189                 | 0                    | 14189                     | 2696             | 16885           | 50.01         |
| 19                 | 3792        | 289  | 262  | 4343   | 840   | 4551      | 0    | 26    | 5764        | 5603        | -1283                | 14080                 | 0                    | 14080                     | 2651             | 16731           | 49.96         |
| 20                 | 3784        | 1300 | 273  | 5357   | 863   | 4638      | 0    | 0     | 5650        | 5961        | -1223                | 15596                 | 0                    | 15596                     | 2708             | 18304           | 49.98         |
| 21                 | 3845        | 874  | 275  | 4994   | 878   | 4644      | 0    | 0     | 5376        | 5576        | -1139                | 14953                 | 0                    | 14953                     | 2617             | 17570           | 50.04         |
| 22                 | 3813        | 788  | 276  | 4877   | 871   | 4636      | 0    | 0     | 5100        | 5176        | -1057                | 14503                 | 0                    | 14503                     | 2496             | 16999           | 50.03         |
| 23                 | 3836        | 718  | 275  | 4829   | 867   | 4643      | 0    | 0     | 4846        | 5033        | -1027                | 14345                 | 0                    | 14345                     | 2386             | 16731           | 50.03         |
| 24                 | 3872        | 519  | 266  | 4657   | 935   | 4571      | 0    | 0     | 4527        | 4634        | -1039                | 13758                 | 0                    | 13758                     | 2328             | 16086           | 50.02         |
| MUs                | 89.07       | 8.73 | 6.48 | 104.29 | 29.16 | 102.41    | 0.00 | 5.22  | 128.09      | 129.87      | -29.31               | 341.62                | 0.00                 | 341.62                    | 58.26            | 399.88          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 17/Aug/2019**

**Position as on 6.30 Hrs of 18/Aug/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                            |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                                                            |               |
| MSPGCL                | Parli Unit 8            | 250      | 04/06/2019   | 00.00        |            | Continued. | Zero Schedule (converted to AOH from 25/06/2019)                                           |               |
| MSPGCL                | Koyana STG- IV Unit - 1 | 250      | 18/07/2019   | 14.30        |            | Continued. | Breaker Air Pressure Problem(Converted for Capital Overhaul from DT.24-07-2019 for 60Days) |               |
| MSPGCL                | Koradi Unit 9           | 660      | 19/07/2019   | 17.35        |            | Continued. | Annual Overhaul                                                                            |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 27/07/2019   | 00.00        |            | Continued. | Annual Overhaul                                                                            |               |
| IPP                   | Adani U-2               | 660      | 05/08/2019   | 00.13        |            | Continued. | Annual Overhaul                                                                            |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                            |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                                                          |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                    |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                          |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.                                                        |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Coal Shortage                                                                              |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                                                               |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.(water shortage from 25/06/2019)                                             |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                                                                |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                                              |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                                              |               |
| MSPGCL                | Parli Unit 7            | 250      | 25/06/2019   | 09.45        |            | Continued. | Water Shortage                                                                             |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 28/06/2019   | 18.35        |            | Continued. | Zero schedule.                                                                             |               |
| IPP                   | Dhariwal                | 300      | 01/07/2019   | 00.01        |            | Continued. | NO SCHEDULE                                                                                |               |
| IPP                   | RPL(AMT) U-2            | 270      | 25/07/2019   | 02.00        |            | Continued. | Zero Schedule                                                                              |               |
| IPP                   | RPL(AMT) U-1            | 270      | 25/07/2019   | 08.00        | 18/08/2019 | 16.55      | Zero schedule.                                                                             |               |
| MSPGCL                | Koradi Unit 6           | 210      | 27/07/2019   | 15.32        |            | Continued. | Zero Schedule.                                                                             |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/07/2019   | 15:47        |            | Continued. | Zero Schedule.                                                                             |               |
| MSPGCL                | Nasik Unit 5            | 210      | 01/08/2019   | 22.45        |            | Continued. | Zero Schedule.                                                                             |               |
| MSPGCL                | Nasik Unit 3            | 210      | 05/08/2019   | 09.15        |            | Continued. | Zero Schedule.                                                                             |               |
| MSPGCL                | Koyana Unit 10          | 80       | 05/08/2019   | 20.05        |            | Continued. | Stator Earth Fault                                                                         |               |
| MSPGCL                | Khaparkheda Unit 2      | 210      | 13/08/2019   | 15.01        |            | Continued. | Flame Failure                                                                              |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 14/08/2019   | 22.06        |            | Continued. | Boiler Tube Leakage                                                                        |               |
| TPC-G                 | Trombay 7B              | 60       | 15/08/2019   | 18.55        |            | Continued. | Gas pressure Low                                                                           |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 17/Aug/2019**

**Position as on 6.30 Hrs of 18/Aug/2019**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                        | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------|---------------|
| TPC-G              | Trombay 7A              | 120      | 15/08/2019   | 22.57        |           | Continued. | Gas pressure Low                                        |               |
| MSPGCL             | Uran Unit B0            | 120      | 16/08/2019   | 23.17        |           | Continued. | Gas shortage                                            |               |
| MSPGCL             | Uran Unit 8             | 108      | 16/08/2019   | 23.17        |           | Continued. | Gas shortage                                            |               |
| IPP                | RPL(AMT) U-5            | 270      | 18/08/2019   | 13.50        |           | Continued. | Electrical Fault Rotor Earth Fault Protection Operated. |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 17/Aug/2019**

**Statement-VII**

Position as on 6.30 Hrs of 18/Aug/2019

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                     |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                      |
| Chandrapur - Padghe Hvdc Pole 2                   | IntraState                | 17/08/2019   | 13.04        | 17/08/2019 | 18.28      | EO          | To Attend The Relief Vent Alarm of OLTC In Pole-2 B-Phase Con. T/F.  |
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                      |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403             |
| Dhule Khandwa I                                   | InterState                | 10/08/2019   | 01.22        | 17/08/2019 | 07.05      | HT          | Over Voltage                                                         |
| Boisar (PG)- Aurangabad (PG)-I                    | InterState                | 10/08/2019   | 01.30        | 18/08/2019 | 08.31      | HT          | Over Voltage                                                         |
| Dhule Khandwa II                                  | InterState                | 17/08/2019   | 08.04        |            | Continued. | HT          | Over Voltage                                                         |
| Dhule Sar'Sarovar II                              | InterState                | 18/08/2019   | 14.48        | 18/08/2019 | 15.41      | T           | Distance Protection, Y-PH.3.8KA.90KM From Dhule.                     |
| Dhule Sar'Sarovar II                              | InterState                | 18/08/2019   | 15.46        |            | Continued. | T           | Distance Protection, Y-PH.3.8KA.90KM From Dhule.                     |
| Chandrapur-II - Nanded ckt II                     | IntraState                | 30/07/2019   | 23.38        | 18/08/2019 | 07.11      | T           | Over Voltage(RFC 18.54 DT.17-8-2019)                                 |
| Bhusawal-Aurangabad                               | IntraState                | 16/08/2019   | 17.42        | 17/08/2019 | 07.16      | HT          | Over Voltage                                                         |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 17/08/2019   | 17.54        | 18/08/2019 | 09.22      | HT          | Over Voltage                                                         |
| Lonikand I - Koyna stage-IV                       | IntraState                | 17/08/2019   | 22.02        | 17/08/2019 | 08.07      | HT          | Over Voltage                                                         |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 18/08/2019   | 16.50        |            | Continued. | HT          | Over Voltage                                                         |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                      |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe               | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                            |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2        | IntraState                | 12/04/2019   | 17.10        |            | Continued. | HT          | Due To CVT Porcelain Collars Of The ICT-1 are Damaged.               |
| 400/220/33 Kv 600 MVA ICT 4 @Padghe               | IntraState                | 12/08/2019   | 04.52        |            | Continued. | T           | LV Side Y-Ph LA Burst.                                               |
| 400/220/33 Kv 500 Mva ICT III @Aurangabad (Waluj) | IntraState                | 17/08/2019   | 08.52        | 17/08/2019 | 09.56      | PO          | Attend Isolator Problem                                              |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                      |
| Talandage - Chikodi                               | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                          |
| Mudshingi - Chikodi                               | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                         |
| Solapur(PG)- Jeur                                 | InterState                | 17/08/2019   | 10.53        | 17/08/2019 | 18.25      | PO          | Work of Conversion of SSN To DSN.                                    |
| BOISAR BORIVALI                                   | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                         |
| Miraj - Tilwani                                   | IntraState                | 09/08/2019   | 05.27        |            | Continued. | T           | Distance Protection                                                  |
| Padgha-Temghar-II                                 | IntraState                | 12/08/2019   | 11.12        |            | Continued. | HT          | To Divert The Load of Padgha ICT.                                    |
| Padgha - Temghar I                                | IntraState                | 14/08/2019   | 18.03        |            | Continued. | HT          | Control Padgha ICT Loading.                                          |
| Roma-Bhavegar                                     | IntraState                | 17/08/2019   | 07.00        | 17/08/2019 | 11.00      | PO          | Extension of Bus Bar For Proposed 02 Nos On 220KV T/F Bays At 220KV. |
| Kolshet-Roma                                      | IntraState                | 17/08/2019   | 07.31        | 18/08/2019 | 19.46      | PO          | Extension of Bus Bar For Proposed 02 Nos On 220KV T/F Bays At 220KV. |
| Roma-Bhavegar                                     | IntraState                | 17/08/2019   | 08.06        | 18/08/2019 | 20.1       | PO          | BUS BAR Extension Work.                                              |
| Vankuswade - Kdph                                 | IntraState                | 17/08/2019   | 09.10        | 17/08/2019 | 12.50      | EO          | Replacement of Conductor Between Breaker & Ct of Y Phase.            |
| New Koyna - Loteparshuram                         | IntraState                | 17/08/2019   | 10.15        | 17/08/2019 | 17.29      | EO          | Attending Hot Spot Y-Phase Wavetrap Bottom Jumper.                   |
| Nanded - Parli Ext. Ckt II                        | IntraState                | 17/08/2019   | 16.02        | 17/08/2019 | 17.30      | PO          | Removing Bird Nest Below CT Secondary Box.                           |
| Badnera-Akola I                                   | IntraState                | 17/08/2019   | 16.25        | 17/08/2019 | 17.20      | HT          | Sparking Observed On Isolator Jaw.                                   |
| Karad(400kv) -Mudshingi Ckt 2-Tak                 | IntraState                | 17/08/2019   | 19.05        | 17/08/2019 | 19.22      | T           | Distance Protection                                                  |
| Trombay-Chembur Line 2                            | IntraState                | 18/08/2019   | 09.16        | 18/08/2019 | 16.00      | T           | BUS 2 Protection OPTD Due To R-PH PT Blast. Load Affected Nil.       |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 17/Aug/2019**

**Statement-VII**

Position as on 6.30 Hrs of 18/Aug/2019

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                               |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------|
| Trombay - Kalwa                        | IntraState                | 18/08/2019   | 09.16        | 18/08/2019 | 17.29      | T           | BUS 2 Protection OPTD Due To R-PH PT Blast. Load Affected Nil. |
| Trombay MSETCL Tie 2                   | IntraState                | 18/08/2019   | 09.16        | 18/08/2019 | 16.27      | T           | BUS 2 Protection OPTD Due To R-PH PT Blast. Load Affected Nil. |
| Uran - Apta IV                         | IntraState                | 18/08/2019   | 11.17        | 18/08/2019 | 18.47      | EO          | Attending TCS Faulty Problem.                                  |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                |
| 220/132Kv 200MVA ICT-I @ Akola         | IntraState                | 17/08/2019   | 09.08        | 18/08/2019 | 12.13      | PO          | Replacement of Y & B Phase LV Bushings.                        |
| 220/132-110kv 100mva Imp Ptr 1 @Wathar | IntraState                | 18/08/2019   | 02.45        | 18/08/2019 | 06.25      | T           | Trip On OSR Relay.                                             |