

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 17/Aug/2021 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 148.777        | 2311.964        | 1) Gujrat                      | -9.419         | -136.925        |
| 2) Hydro            | 9.911          | 195.291         | 2) Madhya Pradesh              | -0.774         | 78.552          |
| 3) Gas              | 3.786          | 70.702          | 3) Chattisgarh                 | 2.160          | 63.450          |
| <b>Total MSPGCL</b> | <b>162.474</b> | <b>2577.957</b> | 4) Maharashtra                 | 150.654        | 2583.304        |
| B) 1) APML          | 66.006         | 1019.477        | 5) Goa (Amona)                 | -0.496         | -19.104         |
| 2) JSWEL            | 20.446         | 350.832         | <b>Total</b>                   | <b>142.125</b> | <b>2569.277</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 19.260         | 392.343         |
| 4) RPL(AMT)         | 25.347         | 416.385         | b) Mumbai Drawl                | 25.764         | 434.662         |
| 5) SWPGPL           | 5.990          | 90.424          | c) MSEDCL Bilateral *          | 37.817         | 722.468         |
| 6) Other IPP        | 6.223          | 107.412         | Include PX                     | 8.120          | 208.254         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 19.260         | 392.343         |
| C) 1) TPCL Thermal  | 11.964         | 223.468         | Include PX                     | 5.288          | 168.317         |
| 2) TPCL Hydro       | 7.178          | 90.296          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 0.000          | 12.476          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 8.728          | 171.039         | 1) MSEDCL                      | 421.118        | 7364.226        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 53.634         | 931.941         |
| 1) Thermal          | 293.481        | 4691.001        | <b>TOTAL STATE</b>             | <b>474.752</b> | <b>8296.167</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 17.089         | 285.587         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 3.786          | 83.178          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 15.673         | 570.291         |                                |                |                 |
| 6) SOLAR            | 2.598          | 96.833          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>332.627</b> | <b>5726.890</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 24 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal           | 6733                      | 5997                  | 6547                      | 5676                       |
| MSPGCL Hydro             | 389                       | 441                   | 638                       | 415                        |
| MSPGCL Gas               | 127                       | 125                   | 224                       | 279                        |
| MSPGCL Total Generation  | 7249                      | 6563                  | 7409                      | 6370                       |
| Central Sector Receipt   | 7587                      | 7401                  | 5123                      | 4671                       |
| WIND                     | 630                       | 404                   | 625                       | 700                        |
| CPP / IPP Thermal        | 5159                      | 5146                  | 5434                      | 4534                       |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                          |
| SOLAR                    | 248                       | 354                   | 2                         | 0                          |
| Exchange with Mumbai     | -1259                     | -1374                 | -853                      | -1123                      |
| <b>MSEDCL DEMAND MET</b> | <b>19614</b>              | <b>18494</b>          | <b>17740</b>              | <b>15152</b>               |
| Load Shedding            | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND            | 19614                     | 18494                 | 17740                     | 15152                      |
| TPCL GENERATION          | 809                       | 1029                  | 1119                      | 633                        |
| AEML GENERATION          | 500                       | 285                   | 501                       | 285                        |
| <b>MUMBAI DEMAND</b>     | <b>2568</b>               | <b>2688</b>           | <b>2473</b>               | <b>2041</b>                |
| STATE DEMAND MET         | 22182                     | 21182                 | 20213                     | 17193                      |
| <b>STATE DEMAND</b>      | <b>22182</b>              | <b>21182</b>          | <b>20213</b>              | <b>17193</b>               |
| Frequency (Hz)           | 49.96                     | 49.99                 | 49.95                     | 50.01                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.11 Hz at 11.59 Hrs | 49.64 Hz at 06.34 Hrs | 49.96         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 17/Aug/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.34         | 35.27         | 170      | 120      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 12.40        | 169.46        | 529      | 446      |
| Unit 9             | 10.77        | 182.09        | 498      | 390      |
| Unit 10            | 12.30        | 162.52        | 570      | 385      |
| <b>Total</b>       | <b>38.81</b> | <b>549.34</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 25.75         | 0        | 0        |
| Unit 4             | 10.00        | 170.60        | 500      | 280      |
| Unit 5             | 10.08        | 169.06        | 495      | 280      |
| <b>Total</b>       | <b>20.09</b> | <b>365.40</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.79         | 46.96         | 240      | 110      |
| Unit 7             | 5.00         | 53.18         | 245      | 194      |
| Unit 8             | 4.95         | 61.39         | 210      | 199      |
| <b>Total</b>       | <b>14.73</b> | <b>161.52</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.93         | 55.55         | 133      | 116      |
| Unit 4             | 3.46         | 61.23         | 165      | 115      |
| Unit 5             | 8.17         | 139.60        | 380      | 275      |
| Unit 6             | 7.82         | 138.24        | 378      | 271      |
| Unit 7             | 7.71         | 116.15        | 355      | 280      |
| Unit 8             | 10.54        | 175.76        | 462      | 410      |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>40.64</b> | <b>686.54</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.59         | 80.42         | 244      | 154      |
| <b>Total</b>       | <b>4.59</b>  | <b>80.42</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.57         | 40.03         | 130      | 80       |
| Unit 2             | 3.03         | 46.75         | 150      | 110      |
| Unit 3             | 3.70         | 54.74         | 190      | 130      |
| Unit 4             | 3.60         | 54.76         | 187      | 130      |
| Unit 5             | 10.20        | 178.06        | 460      | 370      |
| <b>Total</b>       | <b>23.10</b> | <b>374.35</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.41         | 32.97         | 190      | 126      |
| Unit 4             | 3.42         | 35.70         | 198      | 123      |
| Unit 5             | 0.00         | 25.72         | 0        | 0        |
| <b>Total</b>       | <b>6.82</b>  | <b>94.40</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 3.79         | 70.70         | 279      | 80       |
| <b>Total</b>       | <b>3.79</b>  | <b>70.70</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.59         | 7.59          | 26       | 23       |
| <b>Total</b>       | <b>0.59</b>  | <b>7.59</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 1.64          | 42.11          | 280      | 40       |
| Stage 4         | 0.00          | 0.49           | 0        | 0        |
| Stage 3         | 0.53          | 15.00          | 80       | 0        |
| <b>Total</b>    | <b>2.17</b>   | <b>57.61</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.86          | 14.34          | 36       | 36       |
| VTRNA           | 0.00          | 0.29           | 0        | 0        |
| TILLARI         | 0.00          | 6.17           | 0        | 0        |
| BHIRA T.R.      | 0.50          | 7.60           | 40       | 0        |
| SMLHY_PTN       | 6.11          | 100.31         | 265      | 235      |
| GHATGHAR        | 0.26          | 8.97           | 208      | 0        |
| <b>Total</b>    | <b>7.74</b>   | <b>137.68</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 15.67         | 570.29         | 0        | 0        |
| <b>Total</b>    | <b>15.67</b>  | <b>570.29</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 66.01         | 1019.48        | 0        | 0        |
| JSWEL(Mus)      | 20.45         | 350.83         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 25.35         | 416.38         | 0        | 0        |
| SWPGPL-Mus      | 5.99          | 90.42          | 0        | 0        |
| Other(Mus)      | 6.22          | 107.41         | 0        | 0        |
| <b>Total</b>    | <b>124.01</b> | <b>1984.53</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 2.60          | 96.83          | 0        | 0        |
| <b>Total</b>    | <b>2.60</b>   | <b>96.83</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 7.78          | 149.08         | 469      | 278      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 0.00          | 6.95           | 0        | 0        |
| Trombay 7B      | 0.00          | 5.53           | 0        | 0        |
| Trombay 8       | 4.18          | 74.39          | 226      | 136      |
| TATA Hydro      | 7.18          | 90.30          | 459      | 90       |
| <b>Total</b>    | <b>19.14</b>  | <b>326.24</b>  |          |          |
| <b>AEMIL</b>    |               |                |          |          |
| DTPS U-1&2      | 8.73          | 171.04         | 502      | 285      |
| <b>Total</b>    | <b>8.73</b>   | <b>171.04</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 148.78      | 2311.96       | MSPGCL Total        | 162.47      | 2577.96       |
|                |             |         | MSPGCL Thml+Gas | 152.56      | 2382.67       | Koyna 1,2 & 4 Total | 1.64        | 42.60         |
|                |             |         | MSPGCL Hydro    | 9.91        | 195.29        | State Total         | 332.63      | 5726.89       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 17/Aug/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 6542        | 351  | 80   | 6973   | 727   | 5125      | 0    | 0     | 4864        | 4937        | -970                 | 16792                 | 0                    | 16792                     | 1926             | 18718           | 49.88         |
| 2                  | 6410        | 334  | 100  | 6844   | 739   | 5171      | 0    | 0     | 4829        | 4499        | -938                 | 16315                 | 0                    | 16315                     | 1797             | 18112           | 49.96         |
| 3                  | 6298        | 340  | 100  | 6738   | 790   | 5107      | 0    | 0     | 4964        | 4664        | -876                 | 16423                 | 0                    | 16423                     | 1713             | 18136           | 50.00         |
| 4                  | 6173        | 338  | 100  | 6611   | 871   | 5030      | 0    | 0     | 4706        | 4773        | -826                 | 16459                 | 0                    | 16459                     | 1648             | 18107           | 50.00         |
| 5                  | 6157        | 336  | 100  | 6593   | 849   | 5039      | 0    | 0     | 5062        | 5069        | -847                 | 16703                 | 0                    | 16703                     | 1642             | 18345           | 49.96         |
| 6                  | 5974        | 344  | 100  | 6418   | 867   | 5045      | 0    | 0     | 5867        | 6012        | -909                 | 17433                 | 0                    | 17433                     | 1710             | 19143           | 50.00         |
| 7                  | 6121        | 420  | 96   | 6637   | 823   | 5064      | 0    | 15    | 6667        | 6913        | -968                 | 18484                 | 0                    | 18484                     | 1802             | 20286           | 49.91         |
| 8                  | 6372        | 384  | 113  | 6869   | 786   | 5155      | 0    | 74    | 6955        | 7191        | -1086                | 18989                 | 0                    | 18989                     | 1991             | 20980           | 49.90         |
| 9                  | 6524        | 531  | 120  | 7175   | 728   | 5153      | 0    | 155   | 6838        | 7144        | -1240                | 19115                 | 0                    | 19115                     | 2292             | 21407           | 49.99         |
| 10                 | 6733        | 389  | 127  | 7249   | 630   | 5159      | 0    | 248   | 7297        | 7587        | -1259                | 19614                 | 0                    | 19614                     | 2568             | 22182           | 49.96         |
| 11                 | 6742        | 411  | 125  | 7278   | 408   | 5204      | 0    | 294   | 7590        | 7381        | -1316                | 19249                 | 0                    | 19249                     | 2722             | 21971           | 49.99         |
| 12                 | 6379        | 459  | 113  | 6951   | 354   | 5188      | 0    | 372   | 7852        | 7394        | -1467                | 18792                 | 0                    | 18792                     | 2731             | 21523           | 49.99         |
| 13                 | 5997        | 441  | 125  | 6563   | 404   | 5146      | 0    | 354   | 7443        | 7401        | -1374                | 18494                 | 0                    | 18494                     | 2688             | 21182           | 49.99         |
| 14                 | 5979        | 444  | 154  | 6577   | 482   | 5177      | 0    | 404   | 6697        | 6683        | -1446                | 17877                 | 0                    | 17877                     | 2556             | 20433           | 49.96         |
| 15                 | 5681        | 342  | 174  | 6197   | 437   | 5248      | 0    | 333   | 6674        | 7022        | -1065                | 18172                 | 0                    | 18172                     | 2556             | 20728           | 49.91         |
| 16                 | 5545        | 337  | 224  | 6106   | 423   | 5252      | 0    | 179   | 6819        | 6798        | -1031                | 17727                 | 0                    | 17727                     | 2567             | 20294           | 50.02         |
| 17                 | 5729        | 345  | 213  | 6287   | 484   | 5307      | 0    | 117   | 6402        | 6544        | -975                 | 17764                 | 0                    | 17764                     | 2534             | 20298           | 49.93         |
| 18                 | 6444        | 427  | 234  | 7105   | 514   | 5432      | 0    | 51    | 5393        | 5606        | -929                 | 17779                 | 0                    | 17779                     | 2503             | 20282           | 49.97         |
| 19                 | 6547        | 638  | 224  | 7409   | 625   | 5434      | 0    | 2     | 5107        | 5123        | -853                 | 17740                 | 0                    | 17740                     | 2473             | 20213           | 49.95         |
| 20                 | 6541        | 580  | 226  | 7347   | 762   | 5425      | 0    | 0     | 5176        | 4984        | -835                 | 17683                 | 0                    | 17683                     | 2469             | 20152           | 49.88         |
| 21                 | 6220        | 391  | 178  | 6789   | 743   | 5364      | 0    | 0     | 4956        | 4951        | -1115                | 16732                 | 0                    | 16732                     | 2347             | 19079           | 49.92         |
| 22                 | 6114        | 452  | 214  | 6780   | 754   | 5345      | 0    | 0     | 4748        | 4452        | -1179                | 16152                 | 0                    | 16152                     | 2236             | 18388           | 49.99         |
| 23                 | 5879        | 462  | 267  | 6608   | 773   | 4908      | 0    | 0     | 4612        | 4326        | -1137                | 15478                 | 0                    | 15478                     | 2122             | 17600           | 49.99         |
| 24                 | 5676        | 415  | 279  | 6370   | 700   | 4534      | 0    | 0     | 4469        | 4671        | -1123                | 15152                 | 0                    | 15152                     | 2041             | 17193           | 50.01         |
| MUs                | 148.78      | 9.91 | 3.79 | 162.47 | 15.67 | 124.01    | 0.00 | 2.60  | 141.99      | 142.12      | -25.76               | 421.12                | 0.00                 | 421.12                    | 53.63            | 474.75          | 49.96         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 17/Aug/2021**

**Position as on 6.30 Hrs of 18/Aug/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                            |               |
| IPP                   | RPL(AMT) U-3            | 270      | 15/07/2021   | 00.00        |            | Continued. | Annual Overhaul                                            |               |
| MSPGCL                | Chandrapur Unit 9       | 500      | 15/07/2021   | 02.00        |            | Continued. | Annual Overhaul                                            |               |
| MSPGCL                | Paras Unit 3            | 250      | 20/07/2021   | 00.35        |            | Continued. | Annual Overhaul                                            |               |
| TPC-G                 | Trombay 7B              | 60       | 05/08/2021   | 22.19        |            | Continued. | Gas Shortage(Converted to AOH 00.00Hrs from Dt.09/08/2021) |               |
| TPC-G                 | Trombay 7A              | 120      | 05/08/2021   | 22.39        |            | Continued. | Gas Shortage(Converted to AOH 00.00Hrs from Dt.09/08/2021) |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                            |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                    |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                       |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                       |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                     |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                    |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                     |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                      |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                              |               |
| IPP                   | JSW (J) U4              | 300      | 16/07/2021   | 17.44        |            | Continued. | Air Preheater problem.                                     |               |
| IPP                   | SWPGPL U-4              | 135      | 05/08/2021   | 03.04        |            | Continued. | Turbine Vibration High.                                    |               |
| MSPGCL                | Nasik Unit 5            | 210      | 07/08/2021   | 20.45        |            | Continued. | Boiler Tube Leakage                                        |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 15/08/2021   | 09.00        |            | Continued. | Zero Schedule By MSEDCL                                    |               |
| MSPGCL                | Uran Unit A0            | 120      | 16/08/2021   | 11.47        | 17/08/2021 | 14.42      | Attending control valve oil leakage work.                  |               |
| MSPGCL                | Uran Unit 5             | 108      | 16/08/2021   | 19.49        | 17/08/2021 | 19.52      | Tripped on REF Protection.                                 |               |
| MSPGCL                | Uran Unit 8             | 108      | 17/08/2021   | 20.06        |            | Continued. | Gas shortage                                               |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 17/Aug/2021**

**Statement-VII**

Position as on 6.30 Hrs of 18/Aug/2021

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                             |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                                              |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                                                     |
| Dabhol New koyna I                                | InterState                | 14/08/2021   | 13.03        |            | Continued. | T           | Distance Protection                                                                                                                                                          |
| Lamboti - Solapur (PG)                            | InterState                | 17/08/2021   | 01.19        | 17/08/2021 | 14.42      | T           | Distance Protection                                                                                                                                                          |
| Dhule Sar'Sarovar II                              | InterState                | 17/08/2021   | 09.12        | 17/08/2021 | 18.08      | PO          | Replacement of Damaged Earth wire                                                                                                                                            |
| Dhule Sar'Sarovar I                               | InterState                | 17/08/2021   | 15.17        |            | Continued. | T           | Distance Protection                                                                                                                                                          |
| Dabhol Nagothane I                                | InterState                | 18/08/2021   | 06.19        |            | Continued. | T           | Tripped at Dabhol end only                                                                                                                                                   |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 16/08/2021   | 20.03        | 17/08/2021 | 06.14      | HT          | Over Voltage                                                                                                                                                                 |
| Deepnagar - Aurangabad                            | IntraState                | 17/08/2021   | 02.07        | 17/08/2021 | 15.08      | T           | Distance Protection                                                                                                                                                          |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 17/08/2021   | 23.10        |            | Continued. | HT          | Over Voltage                                                                                                                                                                 |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                                                              |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.(FTC DT 16/08/2021 At 14.42)                                                                                            |
| 400/220kv 315 Mva ICT III @Karad                  | IntraState                | 17/08/2021   | 09.58        | 17/08/2021 | 17.54      | PO          | Relay Retrofitting Work by Testing                                                                                                                                           |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                                              |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                                                                                  |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                                                                       |
| Kharghar-Borivali ckt II                          | IntraState                | 23/07/2021   | 08.43        |            | Continued. | PO          | To Carry out bunching work.                                                                                                                                                  |
| Kalwa-TIFIL                                       | IntraState                | 23/07/2021   | 11.12        |            | Continued. | PO          | For Complete Tower erection work at loc no. 75A & 76 (behind M/s Siemens).                                                                                                   |
| Kharghar-Borivali ckt I                           | IntraState                | 24/07/2021   | 08.46        |            | Continued. | PO          | Tower Erection & Bunching work                                                                                                                                               |
| Kalwa - Siemens                                   | IntraState                | 24/07/2021   | 18.16        |            | Continued. | PO          | Tower Erection & Bunching work                                                                                                                                               |
| Miraj - ICHALKARANJI - II (TILWANI)               | IntraState                | 28/07/2021   | 08.19        |            | Continued. | T           | Tower collapsed at loc no.27.                                                                                                                                                |
| Wadkhal(GIS)-JSW(GIS) II                          | IntraState                | 04/08/2021   | 09.26        |            | Continued. | PO          | Outage required for replacement of existing 1200/1A GIS Metering CTs with New 1600/1A GIS CTs.(CB Opened At JSW End On 02/04/2021 At 10:18).                                 |
| Kolshet-Roma                                      | IntraState                | 13/08/2021   | 11.21        | 17/08/2021 | 18.13      | PO          | Outage required for safety purpose for : Pilling work by Rig machine between pilling points no. P117 and P118 near Patlipada flyover under MMRDA project (Reliance Astaldi). |
| Badnera Tss-Ii                                    | IntraState                | 16/08/2021   | 18.16        |            | Continued. | T           | R-Ph string decap from gantry at badnera end.                                                                                                                                |
| Kandalgaon - Pirangut                             | IntraState                | 17/08/2021   | 00.10        | 17/08/2021 | 17.30      | T           | Distance Protection                                                                                                                                                          |
| Lonand-Bothe                                      | IntraState                | 17/08/2021   | 09.03        | 17/08/2021 | 15.00      | PO          | Conductor Re-stringing work                                                                                                                                                  |
| Nanded-Ghatodi                                    | IntraState                | 17/08/2021   | 10.29        | 17/08/2021 | 13.28      | PO          | Replacement of R&Y Phase Flashover String                                                                                                                                    |
| ACCIL - Apta                                      | IntraState                | 17/08/2021   | 12.03        | 17/08/2021 | 12.28      | T           | LBB operated                                                                                                                                                                 |
| Nagothane - ACCIL                                 | IntraState                | 17/08/2021   | 12.03        | 17/08/2021 | 12.26      | T           | LBB operated                                                                                                                                                                 |
| KORADI 2 - KAULEWADA CKT - II                     | IntraState                | 17/08/2021   | 16.31        |            | Continued. | T           | Distance Protection                                                                                                                                                          |
| Koradi-Ambazari-I                                 | IntraState                | 17/08/2021   | 17.51        | 17/08/2021 | 18.59      | T           | Distance Protection                                                                                                                                                          |
| Midc Chandrapur-Gadchandur                        | IntraState                | 17/08/2021   | 19.43        | 17/08/2021 | 20.14      | T           | Distance Protection                                                                                                                                                          |
| <b>220 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                                                              |
| 220/132 KV 150MVA ICT I @ Boisar                  | IntraState                | 15/08/2021   | 01.30        |            | Continued. | PO          | Oil Filtration.                                                                                                                                                              |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 17/Aug/2021**

**Statement-VII**

**Position as on 6.30 Hrs of 18/Aug/2021**

| Name of Line                                       | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage   |
|----------------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|--------------------|
| 220/132KV 100MVA ICT-II@Shivajinagar               | IntraState                   | 17/08/2021      | 09.05           | 17/08/2021 | 13.05         | PO             | Testing Work       |
| 220/132/11 Kv 200 Mva Trans & Rect Ict 1 @Amravati | IntraState                   | 17/08/2021      | 14.45           |            | Continued.    | PO             | Replacement of MOG |