

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Aug/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	93.712	1773.837	1) Gujrat	12.413	136.860
2) Hydro	16.091	226.694	2) Madhya Pradesh	8.259	82.323
3) Gas	3.316	83.992	3) Chattisgarh	3.340	48.760
Total MSPGCL	113.119	2084.523	4) Maharashtra	128.016	2396.798
B) 1) APML	49.978	803.930	5) Goa (Amona)	-2.274	-26.461
2) JSWEL	15.046	239.917	Total	149.754	2638.280
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.484	515.348
4) RPL(AMT)	24.894	339.110	b) Mumbai Drawl	29.387	560.935
5) SWPGPL	4.366	108.557	c) MSEDCL Bilateral *	77.375	1284.360
6) Other IPP	5.434	103.699	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.484	515.134
C) 1) TPCL Thermal	10.201	175.313	Include PX	0.000	0.000
2) TPCL Hydro	7.758	95.334	Standby	0.000	0.214
3) TPCL Gas	2.216	30.713	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.650	160.804	1) MSEDCL	377.578	6422.859
D) STATE			2) Mumbai Discoms	60.212	1023.099
1) Thermal	214.281	3705.167	3) Other Discoms	8.439	146.944
(A1+C1+C4+(B1-B6))			TOTAL STATE	446.229	7592.902
2) Hydro	23.849	322.028			
(A2+C2)					
3) Gas	5.532	114.705			
(A3+B7+C3)					
4) Wind	43.135	685.545			
6) SOLAR	9.678	127.177			
TOTAL STATE	296.475	4954.622			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4227	4037	3584	3811
MSPGCL Hydro	485	380	1858	259
MSPGCL Gas	141	139	139	139
MSPGCL Total Generation	4853	4556	5581	4209
Central Sector Receipt	6848	7139	7621	4977
WIND	2039	1616	1369	1778
CPP / IPP Thermal	4307	4413	4626	3927
CPP / IPP Gas	0	0	0	0
SOLAR	844	269	0	0
Exchange with Mumbai	-1323	-1572	-1154	-608
MSEDCL DEMAND MET	17197	16025	17655	14026
Load Shedding	0	0	0	0
MSEDCL DEMAND	17197	16025	17655	14026
TPCL GENERATION	842	868	1155	737
AEML GENERATION	458	376	485	494
MUMBAI DEMAND	2623	2816	2794	1839
OTHER DISCOM DEMAND	371	396	388	257
STATE DEMAND MET	20191	19237	20837	16122
STATE DEMAND	20191	19237	20837	16122
Frequency (Hz)	50.02	49.97	49.93	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 18.02 Hrs	49.64 Hz at 11.37 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 17/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.53	42.76	115	90
Unit 7	0.00	0.00	0	0
Unit 8	9.48	71.02	442	342
Unit 9	0.00	46.51	0	0
Unit 10	10.45	175.34	470	390
Total	22.45	335.62		
Bhusawal				
Unit 3	0.00	7.23	0	0
Unit 4	6.89	136.09	375	210
Unit 5	0.00	55.81	0	0
Total	6.89	199.12		
Parli				
Unit 6	4.42	69.13	200	170
Unit 7	3.87	59.98	187	140
Unit 8	3.76	62.59	173	145
Total	12.04	191.70		
Chandrapur				
Unit 3	0.00	32.41	0	0
Unit 4	0.00	12.42	0	0
Unit 5	3.88	86.33	185	140
Unit 6	4.77	81.39	250	140
Unit 7	5.02	20.28	238	158
Unit 8	6.41	148.94	386	0
Unit 9	9.12	155.41	432	291
Total	29.19	537.18		
Paras				
Unit 3	2.78	55.57	157	0
Unit 4	2.91	60.78	163	100
Total	5.69	116.35		
Khaparkheda				
Unit 1	0.00	37.40	0	0
Unit 2	1.79	42.22	90	60
Unit 3	3.29	57.00	143	130
Unit 4	0.00	35.99	0	0
Unit 5	6.92	121.11	330	275
Total	12.00	293.72		
Nasik				
Unit 3	2.66	50.74	127	45
Unit 4	0.00	0.00	0	0
Unit 5	2.79	49.40	129	90
Total	5.44	100.14		
Uran				
All Units	3.32	83.99	141	133
Total	3.32	83.99		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	10.15	27	23
Total	0.60	10.15		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.40	44.38	470	35
Stage 4	3.11	32.29	740	0
Stage 3	1.75	26.28	240	0
Total	8.26	102.95		
Hydro				
KDPH	0.86	5.50	36	36
VTRNA	0.82	9.99	61	0
TILLARI	0.70	9.08	58	0
BHIRA T.R.	0.50	7.80	80	0
SMLHY_PTN	4.04	78.11	182	159
GHATGHAR	0.32	3.10	120	0
Total	7.23	113.59		
Wind				
Total	43.14	685.54	0	0
Total	43.14	685.54		
CPP				
APML(Mus)	49.98	803.93	0	0
JSWEL(Mus)	15.05	239.92	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.89	339.11	0	0
SWPGPL-Mus	4.37	108.56	0	0
Other(Mus)	5.43	103.70	0	0
Total	99.72	1595.21		
SOLAR				
Total	9.68	127.18	0	0
Total	9.68	127.18		
Tata				
Trombay 5	6.84	116.87	446	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.21	18.12	78	41
Trombay 7B	1.00	12.60	54	35
TATA Hydro	7.76	95.33	446	184
Trombay 8	3.36	58.44	214	131
Total	20.18	301.36		
AEML				
DTPS U-1&2	10.65	160.80	499	360
Total	10.65	160.80		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	93.71	1773.84	MSPGCL Total	113.12	2084.52
			MSPGCL Thml+Gas	97.03	1857.83	Koyna 1,2 & 4 Total	6.51	76.68
			MSPGCL Hydro	16.09	226.69	State Total	296.48	4954.62

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 17/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	3714	388	138	4240	1890	4071	0	0	4889	4878	-770	13982	0	13982	2082	327	16391	49.99
2	3810	259	138	4207	1835	4282	0	0	4812	4700	-666	14054	0	14054	1936	304	16294	50.00
3	3811	259	139	4209	1778	3927	0	0	4807	4977	-608	14026	0	14026	1839	257	16122	50.00
4	3884	263	137	4284	1842	3877	0	0	4899	5121	-600	14258	0	14258	1781	266	16305	50.00
5	3965	261	139	4365	1874	4386	0	0	5154	4918	-669	14599	0	14599	1773	275	16647	49.99
6	4042	474	138	4654	1865	4610	0	0	5216	5469	-718	15580	0	15580	1902	300	17782	50.01
7	4126	1310	140	5576	1702	4589	0	68	5982	6219	-825	16984	0	16984	2092	345	19421	50.02
8	4206	780	141	5127	1858	4517	0	395	7112	6964	-1020	17476	0	17476	2297	365	20138	50.04
9	4227	485	141	4853	2039	4307	0	844	7155	6848	-1323	17197	0	17197	2623	371	20191	50.02
10	4178	437	133	4748	2117	3838	0	1204	6948	6711	-1609	16623	0	16623	2911	386	19920	49.92
11	3884	492	137	4513	2078	3670	0	1152	6783	6799	-1832	15997	0	15997	3103	383	19483	49.94
12	3794	787	136	4717	2100	3415	0	1211	6499	6646	-1870	15854	0	15854	3099	365	19318	49.90
13	3891	831	135	4857	2050	3502	0	1155	5931	5984	-1881	15296	0	15296	3034	371	18701	49.91
14	3973	517	135	4625	2004	3587	0	1085	5844	5902	-1762	15099	0	15099	2906	342	18347	50.00
15	3851	378	137	4366	1935	3539	0	933	6383	6550	-1737	15225	0	15225	2904	361	18490	49.97
16	3979	384	138	4501	1817	3639	0	795	6520	6479	-1643	15224	0	15224	2898	364	18486	50.00
17	4052	381	139	4572	1841	3920	0	521	6857	6907	-1622	15755	0	15755	2861	384	19000	50.02
18	4037	380	139	4556	1616	4413	0	269	7232	7139	-1572	16025	0	16025	2816	396	19237	49.97
19	3741	737	139	4617	1529	4425	0	46	7783	7776	-1467	16520	0	16520	2791	406	19717	50.02
20	3584	1858	139	5581	1369	4626	0	0	6766	7621	-1154	17655	0	17655	2794	388	20837	49.93
21	3690	1812	139	5641	1423	4629	0	0	6740	6764	-987	17094	0	17094	2660	376	20130	50.01
22	3745	1106	139	4990	1533	4640	0	0	6626	6533	-1071	16242	0	16242	2499	383	19124	50.02
23	3764	881	140	4785	1426	4652	0	0	6210	6239	-1039	15694	0	15694	2364	369	18427	49.99
24	3764	631	140	4535	1614	4657	0	0	5669	5610	-942	15121	0	15121	2247	353	17721	50.01
MUs	93.71	16.09	3.32	113.12	43.14	99.72	0.00	9.68	148.82	149.75	-29.39	377.58	0.00	377.58	60.21	8.44	446.23	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 17/Aug/2022

Position as on 6.30 Hrs of 18/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
IPP	Adani U-3	660	27/07/2022	00:05		Continued.	Annual Overhaul	19/08/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Koyna STG-IV Unit-4	250	13/08/2022	10:06		Continued.	Commissioning and installation of new TSLG Governor	22/08/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	24/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 4	210	09/08/2022	20:25		Continued.	FURNACE DRAFT VERY HIGH/ poor coal receipt & wet coal.	
MSPGCL	Khaparkheda Unit 4	210	10/08/2022	23:58		Continued.	UNIT IS READY FROM 13.08.2022 (DELAY TO LIGHT UP DUE TO WET COAL).	
MSPGCL	Uran Unit A0	120	14/08/2022	09:24		Continued.	Gas shortage	19/08/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Aug/2022

Position as on 6.30 Hrs of 18/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Paras Unit 3	250	15/08/2022	08:50	17/08/2022	01:32	CHP coal feeding problem	16/08/2022
MSPGCL	Chandrapur Unit 3	210	15/08/2022	12:50		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit 5	108	15/08/2022	19:41		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	16/08/2022	03:44		Continued.	Wet coal problem.	
MSPGCL	Khaparkheda Unit 1	210	16/08/2022	04:28		Continued.	DUE TO WET STEAM PROTECTION/ poor coal receipt & wet coal.	
MSPGCL	Uran Unit 6	108	16/08/2022	08:30		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 8	500	17/08/2022	18:30	18/08/2022	01:26	Low Vaccum	
MSPGCL	Koyana Unit 1	70	18/08/2022	06:50		Continued.	D.C.supply fail	
MSPGCL	Koyana Unit 2	70	18/08/2022	06:50	18/08/2022	18:30	D.C.supply fail	
MSPGCL	Koyana Unit 3	70	18/08/2022	06:50		Continued.	D.C.supply fail	
MSPGCL	Koyana Unit 6	80	18/08/2022	06:50	18/08/2022	20:50	D.C.supply fail	
MSPGCL	Koyana Unit 7	80	18/08/2022	06:50	18/08/2022	19:50	D.C.supply fail	
MSPGCL	Koyana Unit 8	80	18/08/2022	06:50		Continued.	D.C.supply fail	
MSPGCL	Koyana Unit 5	80	18/08/2022	06:50	18/08/2022	21:05	D.C.supply fail	
MSPGCL	Chandrapur Unit 7	500	18/08/2022	07:58		Continued.	MAIN TURBINE TRIM BALANCING IN VIEW OF POOR COAL RECIEPT (PCR)	
AEML	AEML Unit 1	250	18/08/2022	10:04		Continued.	UAT T/F Buchholz relay tripped	22/08/2022
MSPGCL	Koradi Unit 6	210	18/08/2022	17:58		Continued.	Flame Failure	20/08/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 17/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 18/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Tripping							
MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2	IntraState	18/08/2022	11:16	18/08/2022	16:39	PO	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
500 KV LR Outages/Tripping							
Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	16/08/2022	15:11			HT	This breaker put in lock out at 15:06hrs dt.15.08.2022 and this filter is under breakdown and expert service are required for
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	17/08/2022	01:19	17/08/2022	05:14	EO	For attending water leakages in B phase thyristor valve inside Pole 1 Valve hall.
400 KV TIEBAY Outages/Tripping							
TIE BAY - 411 OF PARLI (GIRWALI) CKT-1 @ NANDED	IntraState	18/08/2022	11:42	18/08/2022	16:34	PO	CB DCRM and Bay maintenance works.
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Tripping							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	05/08/2022	00:06		Continued.	HT	For load management
KHADKA-AURANGABAD (WALUJ)	IntraState	12/08/2022	20:36	18/08/2022	06:54	HT	HT due to overvoltage
JAIGAD - KARAD CKT - 2	IntraState	15/08/2022	01:25	17/08/2022	10:50	HT	H/T to Control Over Voltages.
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	17/08/2022	08:21	17/08/2022	18:36	PO	Retrofitting of Main-I & Main-2 line differential relay work
KORADI-NANDGAONPETH (RPL)	IntraState	17/08/2022	09:40	17/08/2022	16:12	PO	400KV RPL line Reactor DFRA testing work
TBC @ KHADKA	IntraState	17/08/2022	10:45	17/08/2022	18:13	PO	FOR MTAMC WORK.
JAIGAD - KARAD CKT - 1	IntraState	17/08/2022	21:00	18/08/2022	06:56	HT	To control overvoltage
PADGHE - NAGOTHANE CKT - 1	IntraState	17/08/2022	23:00	18/08/2022	07:09	HT	H/T DUE TO O/V
LONIKAND I - CHAKAN	IntraState	18/08/2022	02:09	18/08/2022	05:01	HT	FOR ATTENDING HOT SPOT AT 400KV CHAKAN END
JAIGAD - KARAD CKT - 2	IntraState	18/08/2022	08:17	18/08/2022	13:31	PO	For CVT testing works under JSWEL bay maintenance
KARAD - LONIKAND I	IntraState	18/08/2022	15:24	18/08/2022	20:42	PO	Replacement of R ph CT to line jump due to damages. Also replacement of burned PG Isolator blade of Y ph 29 B Isolator.
KHADKA-AURANGABAD (WALUJ)	IntraState	18/08/2022	21:29		Continued.	HT	H/T DUE TO O/V
JAIGAD - KARAD CKT - 2	IntraState	18/08/2022	23:12		Continued.	HT	H/T DUE TO O/V
400 KV ICT Outages/Tripping							
400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	IntraState	17/08/2022	10:33	17/08/2022	18:18	PO	Tan Delta & Capacitance of Line CTs, Main CTs & IR values of LA
500 MVA 400/220 KV ICT - I @ CHANDRAPUR 2	IntraState	17/08/2022	16:50	18/08/2022	23:24	T	Tripped on Bucholz
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	18/08/2022	10:27	18/08/2022	21:18	PO	DT & Bay Maintenance
220 KV TBC Outages/Tripping							
BUS COUPLER @ KARANJADE	IntraState	17/08/2022	12:17	17/08/2022	14:17	PO	Protection testing
220 KV LINE Outages/Tripping							
NARANGWADI - SOLAPUR PG CKT - 1	InterState	18/08/2022	08:33	18/08/2022	18:55	PO	Line side equipments AMP
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	18/08/2022	19:40	18/08/2022	22:31	HT	To control overdrawal

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 18/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
INFOSYS - HINJAWADI 1	IntraState	17/08/2022	07:43	17/08/2022	19:19	PO	A) Tower Erection - 72MT MCTT Tower Main Body Erection B) Erection of one side Cross Arm (Road Side) C) Tower Tightneing
AEML BORIVALI -MSETCL BORIVALI CKT -1	IntraState	17/08/2022	09:39	17/08/2022	16:33	PO	Annual maintenance of Bay equipments.
MHAISAL - ALKUD	IntraState	17/08/2022	09:55	17/08/2022	17:58	PO	PID testing work
BORIVALI - TARAPUR	IntraState	17/08/2022	12:27	17/08/2022	12:47	T	A/R successful at Borvali end . Tripped at Tarapur end
TBC @ SOUTH SOLAPUR	IntraState	17/08/2022	13:12	17/08/2022	14:06	PO	Outage is required for Quarterly Maintenance
OSMANABAD - BARSHI	IntraState	17/08/2022	14:25	17/08/2022	16:54	PO	Quarterly Maintenance and CB CRM & Timing test
MAHALAXMI - AMONA	IntraState	17/08/2022	15:43	17/08/2022	17:07	T	Tripped on Distance protection
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	IntraState	17/08/2022	19:27	17/08/2022	20:07	HT	To control overdrawal
BHUGAON- WARDHA	IntraState	17/08/2022	19:28	17/08/2022	20:50	HT	To control Overdrawal
WARDHA - WARDHA (PG)	IntraState	17/08/2022	19:29	17/08/2022	20:51	HT	To control overdrawal
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 2	IntraState	17/08/2022	19:38	17/08/2022	21:01	HT	To control overdrawal
WARDHA (PG) - BADNERA	IntraState	17/08/2022	19:41	17/08/2022	20:52	HT	To control overdrawal
WARDHA-YEOTMAL	IntraState	17/08/2022	19:41	17/08/2022	20:15	HT	To control overdrawal
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	18/08/2022	00:42	18/08/2022	00:58	T	CKT TRIPPED FROM NASIK END AND A/R SUCCESSFUL FROM AKP END
ALEPHATA-PARGAON(KATHAPUR)	IntraState	18/08/2022	09:05	18/08/2022	21:53	HT	To control line loading
MHAISAL - ALKUD	IntraState	18/08/2022	10:00	18/08/2022	18:24	PO	PID testing work
AEML BORIVALI -MSETCL BORIVALI CKT -2	IntraState	18/08/2022	10:12	18/08/2022	15:04	PO	Annual Maintenance of Bay equipments.
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	18/08/2022	10:37	18/08/2022	17:30	EO	OPGW pulling & tightening work from Loc. No. 735 to 735/1 in BARC area.
MAHAPE - RELIANCE GIS	IntraState	18/08/2022	12:16	18/08/2022	15:26	EO	For closing the 29A isolator in proper manner since hotspot is seen on R-Ph Isolator Jaw towards breaker side.
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	18/08/2022	12:39	18/08/2022	15:31	EO	To attend the hot spot on Yph & B ph CT stud towards line side
LAMBOTI - PANDHARPUR	IntraState	18/08/2022	16:48	18/08/2022	19:11	EO	For Attending Hot spot on R ph wave trap
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	18/08/2022	19:15	18/08/2022	22:40	HT	To control overdrawal
OSMANABAD - PARLY (PG)	IntraState	18/08/2022	19:37	18/08/2022	22:24	HT	To control overdrawal
220 KV ICT Outages/Trippings							
220 / 110 / 22KV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33 KV 125MVA TF-3 @ BORIVALI (AEML)	IntraState	31/03/2021	05:38	18/08/2022	06:56	EO	1) Attaining minor oil leakage. 2) Venting of Trap Air and taking load thereafter.
220/33 KV 25MVA PTR NO 2 @ BHIGWAN	IntraState	18/08/2022	10:15	18/08/2022	16:20	PO	Maintenance work
220/132 KV 200 MVA ICT 1@ RANJANGAON	IntraState	18/08/2022	10:31	18/08/2022	19:50	PO	For Diagnostic testing work & Isolator Alignment work.
220/132KV 200MVA PTR 2 @ LONAND	IntraState	18/08/2022	20:49		Continued.	EO	To attend emrgency hotspot of 220KV Bus isolator B-ph bus side
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 18/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30		Continued.	PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30		Continued.	PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage