

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Sep/2016 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	92.955	1960.167	1) Gujrat	-9.855	25.600
2) Hydro	8.936	134.456	2) Madhya Pradesh	2.808	141.987
3) Gas	9.636	115.745	3) Chattisgarh	5.950	85.800
Total MSPGCL	111.527	2210.368	4) Maharashtra Net	58.459	1391.109
B) 1) APML	56.261	979.242	5) Goa (Amona)	-0.436	-9.290
2) JSWEL	19.579	336.136	6) TAPS 1&2 Injection	7.663	130.324
3) VIPL	10.061	194.157	7) RGPPL Injection	11.740	203.564
4) RPL(AMT)	0.000	65.208	8) Pench (MS)	0.873	15.984
5) WPCL	4.232	74.818	9) Pench (Excess)	-0.873	-15.984
6) PGPL	0.000	80.445	Total	75.456	1953.110
7) Other IPP	2.372	43.230	a) Mumbai Schedule	17.063	321.006
C) 1) TPCL Thermal	12.382	203.826	b) Mumbai Drawl	27.618	430.383
2) TPCL Hydro	1.333	83.937	c) MSEDCL Bilateral *	25.257	456.933
3) TPCL Gas	4.362	72.015	Include PX	0.000	-28.720
4) R-INFRA Thermal	9.743	175.433	d) Mumbai Bilateral *	17.063	320.492
D) STATE			Include PX	0.486	24.162
1) Thermal	207.585	4032.217	Include Standby	0.000	0.514
(A1+C1+C4+(B1-B6))			H) ENERGY CATERED (MUs)		
2) Hydro (A2+C2)	10.269	218.393	1) MSEDCL	281.101	5840.952
3) Gas (A3+B6+C3)	13.998	268.205	2) Mumbai Discoms	55.438	965.596
4) Wind	28.682	319.137	TOTAL STATE	336.539	6806.548
6) SOLAR	0.549	15.484			
TOTAL STATE	261.083	4853.436			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4207	3534	3553	4253
MSPGCL Hydro	751	651	1115	102
MSPGCL Gas	399	401	400	420
MSPGCL Total Generation	5357	4586	5068	4775
Central Sector Receipt	2962	3677	4380	1427
WIND	1318	1367	1259	950
CPP / IPP Thermal	3764	3765	4296	3809
CPP / IPP Gas	0	0	0	0
SOLAR	70	5	0	0
Exchange with Mumbai	-1348	-1317	-1380	-582
MSEDCL DEMAND MET	12123	12083	13623	10379
Load Shedding	0	0	0	0
MSEDCL DEMAND	12123	12083	13623	10379
TPCL GENERATION	739	829	880	705
R-INFRA GENERATION	402	402	402	403
MUMBAI DEMAND	2489	2548	2662	1690
STATE DEMAND MET	14612	14631	16285	12069
STATE DEMAND	14612	14631	16285	12069
Frequency (Hz)	50.00	49.95	50.00	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 18.01 Hrs	49.79 Hz at 14.13 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 17/Sep/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	10.83	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	51.03	0	0
Unit 8	8.74	180.48	464	325
Total	8.74	242.34		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	6.80	0	0
Unit 4	0.00	93.04	0	0
Unit 5	5.25	136.14	380	0
Total	5.25	235.98		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.97	71.34	173	163
Unit 4	3.94	51.21	169	161
Unit 5	8.43	150.22	370	315
Unit 6	8.71	159.78	370	349
Unit 7	8.61	154.87	375	340
Unit 8	7.73	134.86	369	0
Total	41.38	722.27		
Paras				
Unit 3	4.68	89.33	205	189
Unit 4	4.68	87.78	202	190
Total	9.36	177.10		
Khaparkheda				
Unit 1	2.16	45.01	165	0
Unit 2	2.18	62.12	170	0
Unit 3	3.36	70.68	165	0
Unit 4	3.37	68.43	171	0
Unit 5	9.46	175.14	400	390
Total	20.52	421.38		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.68	70.30	168	130
Unit 5	4.01	70.02	175	160
Total	7.69	140.32		
Uran				
All Units	9.64	115.74	423	386
Total	9.64	115.74		
PGPL				
Unit 1	0.00	51.09	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	0.00	29.35	0	0
Total	0.00	80.44		
PENCH (MS)				
Pench (MS)	0.87	15.98	53	21
Total	0.87	15.98		
Koyna				
Stage 1-2	3.10	48.00	425	40
Stage 4	0.87	20.30	266	0
Stage 3	1.87	18.59	160	0
Total	5.83	86.89		
Hydro				
KDPH	0.87	6.93	37	36
VTRNA	0.18	0.92	57	0
TILLARI	0.38	4.62	61	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.36	7.49	80	0
RNGR+BHTSA	0.04	0.61	2	1
BHANDARDRA	0.26	5.06	11	10
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.38	4.52	23	13
GHATGHAR	0.64	17.42	164	0
Total	3.11	47.57		
Wind				
Total	28.68	319.14	0	0
Total	28.68	319.14		
CPP				
APML(Mus)	56.26	979.24	0	0
JSWEL(Mus)	19.58	336.14	0	0
VIPL(Mus)	10.06	194.16	0	0
RPLAMT(Mus)	0.00	65.21	0	0
WPCL(Mus)	4.23	74.82	0	0
Other(Mus)	2.37	43.23	0	0
Total	92.50	1692.79		
SOLAR				
Total	0.55	15.48	0	0
Total	0.55	15.48		
Tata				
Trombay 5	7.55	116.41	319	312
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.76	45.30	115	115
Trombay 7B	1.60	26.71	68	66
Trombay 8	4.84	87.42	223	191
TATA Hydro	1.33	83.94	185	4
Total	18.08	359.78		
R-INFRA				
1-2	9.74	175.43	467	401
Total	9.74	175.43		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	0.00	20.78
Koradi 9	0.00	0.00
Koradi 10	0.00	0.00
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	92.96	1960.17
MSPGCL Thml+Gas	102.59	2075.91
MSPGCL Hydro	8.94	134.46

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	111.53	2210.37
Koyna 1,2 & 4 Total	3.96	68.30
State Total	261.08	4853.44

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Sep/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4022	113	423	4558	822	3793	0	0	3315	3073	-962	11284	0	11284	2060	13344	49.97
2	4014	103	415	4532	861	3793	0	0	2606	2355	-766	10775	0	10775	1864	12639	49.98
3	4134	107	412	4653	1009	3788	0	0	1762	1675	-638	10487	0	10487	1740	12227	49.94
4	4253	102	420	4775	950	3809	0	0	1185	1427	-582	10379	0	10379	1690	12069	49.97
5	4325	102	409	4836	955	3790	0	0	1262	1490	-588	10484	0	10484	1688	12172	49.95
6	4304	232	405	4941	1066	3782	0	0	1567	2109	-656	11242	0	11242	1762	13004	49.98
7	4303	284	410	4997	1070	3759	0	3	3077	2265	-793	11301	0	11301	1889	13190	50.02
8	4264	267	406	4937	1266	3784	0	19	3385	2974	-903	12077	0	12077	2001	14078	50.03
9	4219	282	388	4889	1228	3767	0	49	2577	2899	-1188	11644	0	11644	2287	13931	50.01
10	4207	751	399	5357	1318	3764	0	70	2517	2962	-1348	12123	0	12123	2489	14612	50.00
11	4193	524	407	5124	1360	3758	0	81	3153	2954	-1563	11714	0	11714	2765	14479	49.97
12	4201	347	400	4948	1430	3756	0	71	3484	3144	-1578	11771	0	11771	2805	14576	50.00
13	4173	297	388	4858	1446	3743	0	73	3318	3028	-1592	11556	0	11556	2796	14352	49.99
14	3980	297	394	4671	1368	3728	0	65	2973	2981	-1460	11353	0	11353	2679	14032	49.97
15	3513	581	394	4488	1170	3767	0	68	2939	3192	-1367	11318	0	11318	2657	13975	49.95
16	3539	447	390	4376	1252	3752	0	30	3142	3370	-1431	11349	0	11349	2599	13948	49.95
17	3567	333	386	4286	1275	3771	0	15	3170	3626	-1376	11597	0	11597	2563	14160	49.97
18	3534	651	401	4586	1367	3765	0	5	3190	3677	-1317	12083	0	12083	2548	14631	49.95
19	3512	873	396	4781	1357	3990	0	0	4104	4449	-1427	13150	0	13150	2612	15762	49.97
20	3553	1115	400	5068	1259	4296	0	0	4251	4380	-1380	13623	0	13623	2662	16285	50.00
21	3436	656	403	4495	1144	4306	0	0	4680	4761	-1299	13407	0	13407	2522	15929	49.98
22	3242	135	401	3778	1161	4259	0	0	4639	4940	-1266	12872	0	12872	2400	15272	49.99
23	3203	106	387	3696	1227	4018	0	0	4582	4146	-1120	11967	0	11967	2226	14193	49.99
24	3264	231	402	3897	1321	3761	0	0	3193	3582	-1018	11543	0	11543	2134	13677	50.00
MUs	92.96	8.94	9.64	111.53	28.68	92.51	0.00	0.55	74.07	75.46	-27.62	281.10	0.00	281.10	55.44	336.54	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Sep/2016

Position as on 6.30 Hrs of 18/Sep/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
MSPGCL	Uran Unit 6	108	18/09/2016	23.42		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No consent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Koyna Unit 8	80	19/08/2016	11.00		Continued.	High Vibration On LGB & UGB.	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Nasik Unit 3	210	28/08/2016	21.45		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan Problem	
IPP	RPL(AMT) U-2	270	12/09/2016	00.03		Continued.	Zero Shedule By MSEDCL.	
PGPL	PGPL U2	126	14/09/2016	00.16		Continued.	Due To No Shedule.	
PGPL	PGPL U1	262	14/09/2016	00.20		Continued.	Due To No Shedule.	
IPP	RPL(AMT) U-1	270	14/09/2016	23.55		Continued.	Zero Shedule.	
IPP	RPL(AMT) U-4	270	15/09/2016	18.09		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 4	500	15/09/2016	23.59		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 3	210	16/09/2016	00.02		Continued.	Zero Schedule By MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Sep/2016

Position as on 6.30 Hrs of 18/Sep/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 7	210	16/09/2016	00.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit-8	500	16/09/2016	19.08	17/09/2016	01.21	Flame Failure	
MSPGCL	Khaparkheda Unit 1	210	17/09/2016	13.39		Continued.	Withdrawn for Zero Schedule.	
MSPGCL	Khaparkheda Unit 2	210	17/09/2016	13.43		Continued.	Withdrawn for Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	17/09/2016	13.51		Continued.	Withdrawn for Zero Schedule.	
MSPGCL	Khaparkheda Unit 3	210	17/09/2016	20.40		Continued.	Withdrawn for Zero Schedule.	
MSPGCL	Khaparkheda Unit 4	210	17/09/2016	20.48		Continued.	Withdrawn for Zero Schedule.	
IPP	VIPL U-1	300	18/09/2016	14.52	18/09/2016	17.52	Fault on 6.6kv board.	
MSPGCL	Paras Unit 3	250	18/09/2016	14.58		Continued.	Air heater problem	
MSPGCL	Chandrapur Unit 7	500	18/09/2016	20.29		Continued.	Reserve Shutdown.	
MSPGCL	Koyna Unit 7	80	18/09/2016	23.10		Continued.	CPU protection not in service.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Sep/2016

Statement-VII

Position as on 6.30 Hrs of 18/Sep/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	18/09/2016	10.26	18/09/2016	17.13	PO	Electrode work at padgha.
400 KV LINE Outages/Trippings							
Dhule Sar'Sarovar II	InterState	14/09/2016	21.50	17/09/2016	09.44	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	16/09/2016	22.52		Continued.	HT	Over Voltage
Kolhapur(M)-Kolhapur(GIS) cktII	InterState	17/09/2016	03.43	17/09/2016	07.47	PO	Code 986.
Kolhapur(M)-Kolhapur(GIS) ckt1	InterState	17/09/2016	03.43	17/09/2016	05.11	PO	code 976.
Kolhapur Solapur(PG) I	InterState	17/09/2016	03.43	17/09/2016	06.56	T	Over Voltage
Dhule Khandwa I	InterState	17/09/2016	10.14	17/09/2016	14.26	PO	Attending Hot Spot
Dhule Khandwa I	InterState	17/09/2016	10.24	17/09/2016	14.33	PO	Routine Maintenance Work
Kolhapur(M)-Kolhapur(GIS) cktII	InterState	17/09/2016	11.22	17/09/2016	17.29	PO	Routine Maintenance Work
Chakan Talegaon(Pg)	InterState	18/09/2016	01.33	18/09/2016	02.06	T	Breaker Trip @ Chakan End.
Dhule Sar'Sarovar I	InterState	18/09/2016	17.15		Continued.	HT	Over Voltage
Chakan Talegaon(Pg)	InterState	18/09/2016	18.53		Continued.	PO	Insulator Replacement Work
Ektuni-Bableswhar ckt II	IntraState	01/08/2016	09.53		Continued.	HT	To control Padgha-BBLSR L/L
Khadka-Aurangabad (Waluj)	IntraState	14/09/2016	21.44		Continued.	HT	Over Voltage
Girwali-Solapur (Lamboti)	IntraState	15/09/2016	06.29	17/09/2016	17.58	EO	Insulator Replacement Work
N.Koyna-Karad - Ckt I	IntraState	15/09/2016	15.03		Continued.	T	Distance Protection
Lonikand I - Koyna stage-IV	IntraState	15/09/2016	21.22	17/09/2016	09.03	HT	Over Voltage
Babhaleshwar - Padghe-II	IntraState	16/09/2016	03.46		Continued.	T	Over Voltage
Karad-Jaigad - I	IntraState	16/09/2016	11.27		Continued.	EO	Attending Hot Spot, Line RFC @ 14.19 Hrs.
Girwali-Solapur (Lamboti)	IntraState	16/09/2016	14.42		Continued.	T	Distance Protection,R Phase to Earth Fault.
karad -kolhapur-II	IntraState	16/09/2016	22.01	17/09/2016	12.08	HT	Over Voltage
Koradi-Bhusawal	IntraState	17/09/2016	01.02	17/09/2016	16.36	T	Over Voltage
Chandrapur-II - Nanded	IntraState	17/09/2016	01.21	17/09/2016	18.44	T	Over Voltage
karad -kolhapur-I	IntraState	17/09/2016	03.43		Continued.	T	Over Voltage,B Pole of Breaker Burst.
Dhule - Bableswhar - li	IntraState	17/09/2016	11.36	17/09/2016	18.19	T	Distance Protection
Solapur - Parli(PG) I	IntraState	17/09/2016	14.42	17/09/2016	17.58	T	Distance Protection
Lonikand I - Koyna stage-IV	IntraState	18/09/2016	00.45	18/09/2016	09.15	HT	Over Voltage
Koradi-Khaperkheda I	IntraState	18/09/2016	09.26	18/09/2016	12.16	PO	For line signature
Dhule- Bableswhar - I	IntraState	18/09/2016	12.43		Continued.	T	Distance Protection (RFC at 19:20hrs)
Lonikand 1 - Chakan	IntraState	18/09/2016	14.09	18/09/2016	18.34	PO	Insulator Replacement Work
karad -kolhapur-II	IntraState	18/09/2016	18.07		Continued.	HT	Over Voltage
Ektuni - Taptitanda Ckt I	IntraState	18/09/2016	18.24	18/09/2016	20.51	HT	Sparking at ektuni end.
400 KV ICT Outages/Trippings							
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	20/08/2016	11.06		Continued.	PO	Shifted on TBC, by hot line jumper open for construction of kudus bay ektuni CKT-2 will remain off during this outage period.
400/220 Kv 500 MVA ICT 3 @Kolhapur	IntraState	17/09/2016	03.43	17/09/2016	04.01	T	Backup Protection
400/220kv 315MVA ICT 2 @ Kolhapur	IntraState	17/09/2016	03.43	17/09/2016	04.44	T	Backup Protection
400/220kv 315 MVA ICT I @ Kolhapur	IntraState	17/09/2016	03.43	17/09/2016	04.44	T	Backup Protection
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	17/09/2016	06.56	17/09/2016	17.20	T	PRV.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Sep/2016

Statement-VII

Position as on 6.30 Hrs of 18/Sep/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 500MVA ICT 2@koradi 2	IntraState	17/09/2016	10.25		Continued.	PO	Installation of online DGA kit and SCADA testing.
220 KV LINE Outages/Trippings							
Mudshingi - Chikodi	InterState	01/09/2016	00.00		Continued.	HT	No schedule from Karnataka(H/T from Chikodi end)
Talandage - Chikodi	InterState	01/09/2016	00.00		Continued.	HT	No schedule from Karnataka(H/T from Talandage end)
Boisar(MS) - Boisar (PG) - I	InterState	17/09/2016	03.53		Continued.	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Bableshwar- Alephata	IntraState	26/08/2016	20.54		Continued.	HT	Hand tripped.
Khadaka-Chaligaon III	IntraState	15/09/2016	19.27	17/09/2016	13.21	T	Distance Protection
Telco- Chinchwad	IntraState	17/09/2016	00.13	17/09/2016	05.25	PO	Tower Erection.
Chakan-Chinchwad	IntraState	17/09/2016	00.23	17/09/2016	05.58	PO	Tower Erection.
Mumewadi-Belewadi	IntraState	17/09/2016	03.44	17/09/2016	04.41	T	Backup Protection
Talandge(400)- Mudshingi 2 Line	IntraState	17/09/2016	03.44	17/09/2016	04.38	T	Backup Protection
Kandalgaon - Pirangut	IntraState	17/09/2016	09.05	17/09/2016	13.15	PO	Insulator Replacement Work
Kandalgaon - Koyna	IntraState	17/09/2016	09.15	17/09/2016	17.21	PO	Replacement of Wavetrap Jumper
Chaligaon - Deepnagar	IntraState	17/09/2016	10.14	17/09/2016	14.26	PO	Attending Hot Spot
Versova Gorai Line	IntraState	17/09/2016	15.43	17/09/2016	17.50	T	Distance Protection
Ghodbunder - Gorai	IntraState	17/09/2016	15.43	17/09/2016	17.50	T	Distance Protection
Chaligaon-Malegaon	IntraState	17/09/2016	16.50	17/09/2016	19.19	PO	At loc.51 R-PH string flashover.
Urse-Chinchwad	IntraState	18/09/2016	05.55	18/09/2016	06.14	T	Distance Protection
Kalwa - Borivali	IntraState	18/09/2016	06.21	18/09/2016	18.52	HT	Construction work.
Parli New Tps - Beed Ckt 1	IntraState	18/09/2016	10.23	18/09/2016	13.42	PO	Replacement of flashover Disc.
Kalwa - Taloja	IntraState	18/09/2016	11.37	18/09/2016	14.37	T	Distance Protection
Chakan-Chinchwad	IntraState	18/09/2016	21.20		Continued.	HT	Construction work.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
132 KV LINE Outages/Trippings							
Girwali-Renapur-Ahamadpur	IntraState	16/09/2016	15.37		Continued.	T	Distance Protection,Trial Failed.
Chitegaon - RI Steel	IntraState	17/09/2016	09.50	17/09/2016	10.28	T	Tripped on 33kv feeder fault.
Shahada-Taloda	IntraState	17/09/2016	15.25	17/09/2016	15.38	T	Distance Protection
100 KV LINE Outages/Trippings							
Vasai-li - Vasai 2 Line	IntraState	13/08/2016	08.53		Continued.	HT	ICT Problem.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage