

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Sep/2024 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	132.397	2167.243	1) Gujrat	11.605	170.353
2) Hydro	8.894	200.756	2) Madhya Pradesh	4.679	-22.810
3) Gas	7.047	121.318	3) Chattisgarh	4.050	22.130
Total MSPGCL	148.338	2489.317	4) Maharashtra	152.003	2673.297
B) 1) APLM	64.506	929.953	5) Goa (Amona)	-1.829	-33.731
2) JSWEL	26.462	372.841	Total	170.508	2809.239
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.872	628.077
4) RPL(AMT)	18.974	340.817	b) Mumbai Drawl	37.874	681.454
5) SWPGPL	10.304	172.403	c) MSEDCL Bilateral *	80.524	1464.857
6) Other IPP	9.814	161.637	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.872	628.077
C) 1) TPCL Thermal	11.067	189.888	Include PX	0.000	0.000
2) TPCL Hydro	3.985	73.873	Standby	0.000	0.000
3) TPCL Gas	4.137	69.749	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.096	142.971	1) MSEDCL	437.415	7238.762
D) STATE			2) Mumbai Discoms	65.159	1157.935
1) Thermal	281.620	4477.753	3) Other Discoms	12.110	202.107
(A1+C1+C4+(B1-B6))			TOTAL STATE	514.684	8598.804
2) Hydro (A2+C2)	12.879	274.629			
3) Gas (A3+B7+C3)	11.184	191.067			
4) Wind	18.334	580.042			
6) SOLAR	20.159	266.074			
TOTAL STATE	344.176	5789.565			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4674	4914	6011	5533
MSPGCL Hydro	376	241	806	210
MSPGCL Gas	288	282	323	296
MSPGCL Total Generation	5338	5437	7140	6039
Central Sector Receipt	8868	8327	6410	6013
WIND	467	484	1278	680
CPP / IPP Thermal	4578	4471	5972	5996
CPP / IPP Gas	0	0	0	0
SOLAR	2638	2620	0	0
Exchange with Mumbai	-2164	-2142	-1392	-1144
MSEDCL DEMAND MET	19201	18676	18863	17169
Load Shedding	0	0	0	0
MSEDCL DEMAND	19201	18676	18863	17169
TPCL GENERATION	792	781	1028	707
AEML GENERATION	288	285	365	332
MUMBAI DEMAND	3244	3208	2785	2183
OTHER DISCOM DEMAND	525	521	545	415
STATE DEMAND MET	22969	22406	22193	19767
STATE DEMAND	22969	22406	22193	19767
Frequency (Hz)	49.97	49.94	50.04	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 08.01 Hrs	49.79 Hz at 06.23 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 17/Sep/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.09	42.87	187	151
Unit 8	0.00	133.11	0	0
Unit 9	12.62	194.78	570	412
Unit 10	11.82	190.86	520	440
Total	28.54	561.62		
Bhusawal				
Unit 3	3.11	40.66	165	115
Unit 4	10.10	136.72	495	290
Unit 5	1.38	95.47	335	0
Total	14.59	272.86		
Parli				
Unit 6	4.06	36.16	224	143
Unit 7	3.85	59.19	205	133
Unit 8	3.95	71.54	204	146
Total	11.86	166.89		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	3.43	51.67	153	127
Unit 5	6.13	91.78	325	0
Unit 6	7.43	111.10	355	272
Unit 7	7.82	114.78	380	269
Unit 8	9.64	153.44	458	354
Unit 9	0.00	0.00	0	0
Total	34.45	522.76		
Paras				
Unit 3	4.66	73.91	229	137
Unit 4	4.74	71.11	227	151
Total	9.40	145.02		
Khaparkheda				
Unit 1	3.76	45.73	185	110
Unit 2	3.96	46.11	186	127
Unit 3	3.84	57.65	178	132
Unit 4	4.22	61.49	191	129
Unit 5	11.42	177.22	490	460
Total	27.19	388.20		
Nasik				
Unit 3	3.26	55.46	154	120
Unit 4	3.10	54.44	153	113
Unit 5	0.00	0.00	0	0
Total	6.37	109.89		
Uran				
All Units	7.05	121.32	323	282
Total	7.05	121.32		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.05	16.98	44	43
Total	1.05	16.98		
Koyna				
Stage 1-2	2.08	41.22	255	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.58	36.99	586	0
Stage 3	0.83	21.42	218	0
Total	4.48	99.63		
Hydro				
KDPH	0.86	14.69	36	36
VTRNA	0.00	0.46	0	0
TILLARI	0.37	8.62	62	0
BHIRA T.R.	0.28	5.04	40	0
SMLHY_PTN	2.90	65.71	126	113
GHATGHAR	0.00	6.61	0	0
Total	4.41	101.13		
Wind				
Total	18.33	580.04	0	0
Total	18.33	580.04		
CPP				
APML(Mus)	64.51	929.95	0	0
JSWEL(Mus)	26.46	372.84	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.97	340.82	0	0
SWPGPL-Mus	10.30	172.40	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.62	78.54	266	222
Other(Mus)	0.85	13.60	0	0
JPL	3.35	69.49	262	106
Total	130.06	1977.65		
SOLAR				
Total	20.16	266.07	0	0
Total	20.16	266.07		
Tata				
Trombay 5	7.40	126.76	398	255
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.60	43.68	109	108
Trombay 7B	1.54	26.07	65	64
TATA Hydro	3.98	73.87	350	70
Trombay 8	3.66	63.12	218	131
Total	19.19	333.51		
AEML				
DTPS U-1&2	8.10	142.97	493	285
Total	8.10	142.97		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	132.40	2167.24	MSPGCL Total	148.34	2489.32
			MSPGCL Thml+Gas	139.44	2288.56	Koyna 1,2 & 4 Total	3.66	78.21
			MSPGCL Hydro	8.89	200.76	State Total	344.18	5789.56

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Sep/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5572	331	296	6199	778	5991	0	0	6336	6506	-1553	17436	0	0	17436	2583	485	20504	49.96
2	5662	206	296	6164	786	6009	0	0	6198	6259	-1440	17342	0	0	17342	2410	437	20188	49.97
3	5615	207	296	6118	712	5993	0	0	6084	6347	-1302	17442	0	0	17442	2277	426	20145	49.99
4	5533	210	296	6039	680	5996	0	0	6058	6013	-1144	17169	0	0	17169	2183	415	19767	50.00
5	5702	193	298	6193	687	5985	0	0	6263	6223	-842	17833	0	0	17833	2174	414	20420	50.00
6	5859	628	298	6785	689	5967	0	0	6439	6369	-948	18412	0	0	18412	2226	450	21088	49.97
7	5922	1145	299	7366	619	5939	0	102	6768	6744	-927	19381	0	0	19381	2297	462	22140	49.95
8	5926	1042	299	7267	517	5785	0	647	6911	7089	-1191	19635	0	0	19635	2473	479	22587	50.04
9	5546	347	297	6190	553	5666	0	1505	7561	7765	-1710	19444	0	0	19444	2752	525	22721	50.05
10	5139	264	290	5693	543	4827	0	2194	8257	8538	-1932	19321	0	0	19321	3023	542	22885	49.99
11	4906	268	290	5464	423	4359	0	2561	8633	8880	-2097	19062	0	0	19062	3178	527	22768	49.96
12	4674	376	288	5338	467	4578	0	2638	8453	8868	-2164	19201	0	0	19201	3244	525	22969	49.97
13	4914	241	282	5437	484	4471	0	2620	8114	8327	-2142	18676	0	0	18676	3208	521	22406	49.94
14	4570	201	284	5055	483	4336	0	2479	8307	8605	-2019	18413	0	0	18413	3085	525	22023	50.00
15	4804	201	284	5289	493	4317	0	2131	8670	8725	-1965	18474	0	0	18474	3065	517	22055	50.01
16	5326	200	284	5810	568	4795	0	1756	8206	8084	-1956	18515	0	0	18515	3044	542	22101	50.02
17	5671	203	283	6157	764	5309	0	1077	7812	7256	-1885	18123	0	0	18123	2935	554	21613	49.99
18	5702	201	283	6186	849	5547	0	408	7375	6995	-1742	17681	0	0	17681	2813	562	21056	50.01
19	6008	440	323	6771	1066	5889	0	42	6743	6764	-1635	18332	0	0	18332	2774	565	21671	49.99
20	6011	806	323	7140	1278	5972	0	0	6228	6410	-1392	18863	0	0	18863	2785	545	22193	50.04
21	5825	385	288	6498	1314	5769	0	0	6342	6043	-1486	17607	0	0	17607	2700	531	20838	49.99
22	5762	406	287	6455	1239	5531	0	0	5922	6027	-1439	17269	0	0	17269	2664	544	20477	49.98
23	5883	201	292	6376	1208	5609	0	0	5957	5860	-1493	17038	0	0	17038	2638	522	20198	49.96
24	5865	192	291	6348	1134	5420	0	0	5909	5811	-1470	16746	0	0	16746	2628	497	19871	49.96
MUs	132.40	8.89	7.05	148.34	18.33	130.06	0.00	20.16	169.55	170.51	-37.87	437.41	0.00	0.00	437.41	65.16	12.11	514.68	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Sep/2024

Position as on 6.30 Hrs of 18/Sep/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Chandrapur Unit 3	210	15/08/2024	17:45		Continued.	Converted into AOH at 12:42 hrs dt.17.08.2024.	20/09/2024
MSPGCL	Nasik Unit 5	210	27/08/2024	23:55		Continued.	On Tolling(Under COH from 00.00 Hrs DT.05.09.2024)	30/09/2024
MSPGCL	Chandrapur Unit 9	500	31/08/2024	23:45		Continued.	Capital overhaul (COH) works.	01/10/2024
MSPGCL	Koyna Unit 6	80	12/09/2024	15:10		Continued.	Refurbishment of governing system & Upgradation of PLC system & Excitation system.	22/10/2024
Total Capacity MSPGCL		1000						
Total Capacity PLANNED OUTAGE		1000						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/09/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/09/2024
MSPGCL	Koyna Unit 5	80	18/08/2024	18:00		Continued.	UGB Temperature High	22/09/2024
MSPGCL	Koradi Unit 8	660	13/09/2024	08:20		Continued.	Boiler Tube Leakage	21/09/2024
MSPGCL	Bhusawal Unit 5	500	14/09/2024	21:54	17/09/2024	17:41	Boiler Tube Leakage	18/09/2024
MSPGCL	Chandrapur Unit 5	500	17/09/2024	11:04	17/09/2024	13.20	Furnace Pressure High	
Total Capacity MSPGCL		1985						
IPP								
IPP	RPL(AMT) U-3	270	23/07/2024	00:47		Continued.	Turbine Vibration High	31/10/2024
IPP	RPL(AMT) U-5	270	15/09/2024	15:21		Continued.	Bottom Ash Evacuation Problem	19/09/2024
Total Capacity IPP		540						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2845						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	16/09/2024	08:00	17/09/2024	18:28	No schedule from MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Sep/2024

Position as on 6.30 Hrs of 18/Sep/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	16/09/2024	08:15		Continued.	No schedule from MSEDCL.	
MSPGCL	Uran Unit 5	108	17/09/2024	19:30		Continued.	No schedule from MSEDCL.	
Total Capacity MSPGCL		324						
IPP								
IPP	JPL Unit 1	150	15/09/2024	00:25	17/09/2024	17:07	No Schedule.	
Total Capacity IPP		150						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		474						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Sep/2024

Statement-VII

Position as on 6.30 Hrs of 18/Sep/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (408) OF STN T/F-2 & KORADI 3 CKT-1 @ KORADI 2	IntraState	18/09/2024	10:11			PO	Diagnostic Testing of CB
400 KV MAINBAY Outages/Trippings							
TBC @ KARAD	IntraState	18/09/2024	10:13			PO	For Auto reclose testing with TBC Bay of newly commissioned relay panel for Jejuri Line
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	27/08/2024	10:11			EO	* Rectification of DC Leakage in 220V DC Source-1 of Trip Circuit-1 of 400KV NTPP-1 line. * Replacement of Air pressure Return valve of the Y-phase C.B of Circuit-1 of 400KV NTPP-1 line.
220kV Koradi-2 - Uppalwadi ckt 2	IntraState	28/08/2024	00:14			T	Distance protection
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	03/09/2024	15:06			PO	(1) Bay equipments replacement work (CB, CT,CVT,LA,WT, PG & HCB isolators) under LES. (2)Distance M1 & M2 relays retrofitting work.3) Hardware tightening & fitting work
KHADKA-AURANGABAD (WALUJ)	IntraState	10/09/2024	23:27	18/09/2024	09:03	HT	overvoltage
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	14/09/2024	00:05			HT	H/T For load management.
KHARGHAR - VIKHROLI GIS CKT - 2	IntraState	15/09/2024	06:59			PO	Outage proposed by M/s MUMIL for switching of 400KV Kharghar-Vikhroli ckt-2 to 400KV Padghe(PG) -Kharghar line, 400KV Padghe(PG)-Navimumbai line and 400KV Navi Mumbai-Vikhroli line.
KHADKA-AURANGABAD (WALUJ)	IntraState	16/09/2024	08:45	17/09/2024	17:03	PO	FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK BY AGENCY.
JAIGAD - KARAD CKT - 2	IntraState	16/09/2024	20:44	17/09/2024	10:48	HT	Hand tripped for Voltage Management.
PADGHE - KALWA CKT - 1	IntraState	17/09/2024	04:15	17/09/2024	07:09	EO	"Hot spot attending work 1)Y ph 29 D ISO cb side IPS clamp(195) 2)B ph 29 D ISO IPS clamp, cb side(164) 3)R ph 29 D ISO CB side (95)"
JAIGAD - KARAD CKT - 1	IntraState	17/09/2024	23:03	18/09/2024	09:55	HT	Overvoltage
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	18/09/2024	00:29	18/09/2024	04:39	T	Tripped on distance protection
PARLI-SOLAPUR (LAMBOTI)	IntraState	18/09/2024	10:13			PO	Hardware tighten and cold washing
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	12/09/2024	13:26	17/09/2024	13:00	PO	Oil filtration/degassing and internal inspection of STATION - 8A
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	15/09/2024	06:11			HT	H/T for planned outage on 400kv Vikroli-Kharghar Ckt-1 & 2.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Sep/2024

Statement-VII

Position as on 6.30 Hrs of 18/Sep/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	18/09/2024	10:13			PO	FOR AUTRECLOSE RELAY TESTING WITH TBC BAY
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
APTA - BOMBAY DYEING	IntraState	18/04/2024	00:00	18/09/2024	08:50	EO	Replacement of 245 kV R & Y phase CT due to heavy leakages and diagnostic testing
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale- PGCIL arrangement will be changed from 220 kV PG- Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
GHODBUNDER - GORAI	IntraState	29/07/2024	12:14			PO	Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.
EKLAHARE (OCR) - PADGHE	IntraState	21/08/2024	08:03			HT	load management
SHENDRA - SHENDRA GIS	IntraState	15/09/2024	17:00			T	Sparking was observed on LA
NAGOTHANE - POSCO	IntraState	17/09/2024	09:24	17/09/2024	19:20	PO	OPGW earthwire installation Work
PARAS-BALAPUR IV	IntraState	17/09/2024	10:12	17/09/2024	13:39	EO	To attend Hot Spot
BUTIBORI-ABHIJEET	IntraState	17/09/2024	10:54	17/09/2024	13:17	EO	To attend Hot Spot
BUTIBORI 3 - WARDHA	IntraState	17/09/2024	13:34	17/09/2024	14:56	EO	To attend Hot Spot
EKLAHARE (GCR) - GHATGHAR	IntraState	18/09/2024	03:16	18/09/2024	05:40	T	Distance protection
SAHARA-URSE	IntraState	18/09/2024	09:28			PO	Line shutdown will be required for OPGW installation work at earthwire missing & damage section.
TALOJA - PANCHANAND	IntraState	18/09/2024	09:46			PO	For replacing old rusted D ₂ shackles of R, Y & B ph insulators at TL No. 641, 642, 643, 645, 646 & 647.
NAGOTHANE - POSCO	IntraState	18/09/2024	10:14			PO	OPGW earthwire installation Work
220 KV ICT Outages/Trippings							
220/132 KV 100 MVA ICT 1@ BABHALESHWAR	IntraState	12/07/2024	13:35			PO	Augmentation of 220/132kV 100MVA to 220/132kV 200MVA at Babheshwar.
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	15/07/2024	05:28			T	Differential Protection
220/22KV 50MVA PTR 3 @ BHOSARI 2	IntraState	24/07/2024	23:02			T	Tripped due to caught fire.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Sep/2024

Statement-VII

Position as on 6.30 Hrs of 18/Sep/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100 MVA ICT I @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/132 KV 100 MVA ICT II @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/33 KV 25 MVA TF - I @ PURTI	IntraState	28/08/2024	23:05			T	33kV PT Burst and LA Burst, Bucholz protection operated
220/132 KV 100 MVA ICT 1	IntraState	17/09/2024	15:18	17/09/2024	15:58	HT	Heavy sparking observed on Isolator LV side
220/132-110KV 100MVA PTR 2 @ WATHAR	IntraState	18/09/2024	09:31			PO	CB OVERHAULING WORK BY AGENCY
220/33 KV 25 MVA PTR 2 @ BIDRI	IntraState	18/09/2024	10:17			PO	PAIPAINING WORK & QUARTERLY MAINT WORK
110 KV LINE Outages/Trippings							
BHIVPURI - AMBERNATH CKT - 1	IntraState	18/09/2024	09:10			PO	110 KV TBS GOD Arm replacement

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage