

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Oct/2019 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	105.302	2015.830	1) Gujrat	11.836	249.362
2) Hydro	12.358	111.540	2) Madhya Pradesh	12.297	160.906
3) Gas	10.697	158.137	3) Chattisgarh	4.340	53.560
Total MSPGCL	128.357	2285.507	4) Maharashtra	140.654	2221.294
B) 1) APML	60.777	621.118	5) Goa (Amona)	-0.484	-8.272
2) JSWEL	24.367	326.846	Total	168.643	2676.850
3) VIPL	0.000	0.000	a) Mumbai Schedule	37.907	541.182
4) RPL(AMT)	24.655	361.522	b) Mumbai Drawl	38.575	604.886
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	20.632	398.820
6) Other IPP	9.424	145.836	Include PX	1.389	83.632
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	37.907	541.182
C) 1) TPCL Thermal	14.617	223.082	Include PX	9.016	228.487
2) TPCL Hydro	5.392	67.126	Standby	0.000	0.000
3) TPCL Gas	4.360	60.250	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.547	120.814	1) MSEDCL	394.240	6036.850
D) STATE			2) Mumbai Discoms	68.491	1076.154
1) Thermal	244.689	3815.048	TOTAL STATE	462.731	7113.004
(A1+C1+C4+(B1-B6))					
2) Hydro	17.750	178.666			
(A2+C2)					
3) Gas	15.057	218.387			
(A3+B7+C3)					
4) Wind	10.339	119.055			
6) SOLAR	6.253	105.002			
TOTAL STATE	294.088	4436.158			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4404	4410	4385	4301
MSPGCL Hydro	350	285	1325	157
MSPGCL Gas	425	405	432	445
MSPGCL Total Generation	5179	5100	6142	4903
Central Sector Receipt	8199	8326	6867	5775
WIND	417	367	361	541
CPP / IPP Thermal	4794	5045	5228	4935
CPP / IPP Gas	0	0	0	0
SOLAR	908	677	0	0
Exchange with Mumbai	-1961	-1929	-1735	-1341
MSEDCL DEMAND MET	17536	17586	16863	14813
Load Shedding	0	0	0	0
MSEDCL DEMAND	17536	17586	16863	14813
TPCL GENERATION	1145	1155	1271	696
AEML GENERATION	250	250	250	191
MUMBAI DEMAND	3356	3334	3256	2228
STATE DEMAND MET	20892	20920	20119	17041
STATE DEMAND	20892	20920	20119	17041
Frequency (Hz)	49.94	50.00	50.02	49.93

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 17.30 Hrs	49.77 Hz at 11.14 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 17/Oct/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	34.05	0	0
Unit 9	11.72	181.22	540	425
Unit 10	10.56	175.26	478	420
Total	22.28	390.53		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.68	157.36	370	350
Unit 5	0.00	73.64	0	0
Total	8.68	231.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.27	40.35	221	46
Unit 7	4.82	82.73	248	166
Unit 8	0.00	71.04	0	0
Total	9.09	194.12		
Chandrapur				
Unit 3	4.45	50.67	190	180
Unit 4	3.40	60.58	168	120
Unit 5	8.76	138.25	379	360
Unit 6	9.75	140.92	445	345
Unit 7	0.00	0.00	0	0
Unit 8	10.03	151.15	480	340
Unit 9	9.52	147.31	470	345
Total	45.91	688.88		
Paras				
Unit 3	4.27	64.61	237	144
Unit 4	0.00	0.00	0	0
Total	4.27	64.61		
Khaparkheda				
Unit 1	0.00	30.23	0	0
Unit 2	0.00	35.13	0	0
Unit 3	0.00	44.89	0	0
Unit 4	0.00	53.98	0	0
Unit 5	10.99	163.99	500	400
Total	10.99	328.22		
Nasik				
Unit 3	0.00	24.52	0	0
Unit 4	0.00	31.55	0	0
Unit 5	4.08	62.40	185	153
Total	4.08	118.47		
Uran				
All Units	10.70	158.14	555	405
Total	10.70	158.14		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.20	12.70	37	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.20	12.70		
Koyna				
Stage 1-2	4.55	49.36	470	40
Stage 4	4.94	25.82	750	0
Stage 3	2.10	17.67	160	0
Total	11.59	92.86		
Hydro				
KDPH	0.00	4.03	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	2.67	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.37	4.74	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.00	0.97	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.00	3.37	0	0
GHATGHAR	0.40	2.90	125	0
Total	0.77	18.68		
Wind				
Total	10.34	119.06	0	0
Total	10.34	119.06		
CPP				
APML(Mus)	60.78	621.12	0	0
JSWEL(Mus)	24.37	326.85	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	24.66	361.52	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	9.42	145.84	0	0
Total	119.22	1455.32		
SOLAR				
Total	6.25	105.00	0	0
Total	6.25	105.00		
Tata				
Trombay 5	9.72	141.40	464	314
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.77	37.14	116	113
Trombay 7B	1.59	23.11	67	66
Trombay 8	4.90	81.69	209	197
TATA Hydro	5.39	67.13	459	0
Total	24.37	350.46		
AEML				
DTPS U-1&2	5.55	120.81	251	191
Total	5.55	120.81		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	105.30	2015.83	MSPGCL Total	128.36	2285.51
			MSPGCL Thml+Gas	116.00	2173.97	Koyna 1,2 & 4 Total	9.49	75.19
			MSPGCL Hydro	12.36	111.54	State Total	294.09	4436.16

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Oct/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4450	201	463	5114	525	4969	0	0	5948	6138	-1669	15077	0	15077	2623	17700	49.95
2	4280	271	435	4986	535	4971	0	0	5890	5883	-1499	14876	0	14876	2395	17271	49.97
3	4301	157	445	4903	541	4935	0	0	5988	5775	-1341	14813	0	14813	2228	17041	49.93
4	4302	45	445	4792	581	4897	0	0	5871	5938	-1231	14977	0	14977	2119	17096	49.98
5	4281	110	436	4827	557	4944	0	0	5853	6130	-1179	15279	0	15279	2070	17349	49.98
6	4323	632	437	5392	480	4916	0	0	6461	6508	-1103	16194	0	16194	2143	18336	49.94
7	4466	994	437	5897	529	4871	0	17	7140	7131	-1134	17311	0	17311	2233	19544	49.99
8	4441	1034	446	5921	472	4867	0	182	7178	7200	-1231	17411	0	17411	2390	19801	50.00
9	4376	575	429	5380	415	4910	0	453	7231	7452	-1382	17228	0	17228	2672	19900	49.98
10	4482	220	414	5116	410	4993	0	686	7490	7791	-1663	17333	0	17333	2996	20329	49.94
11	4494	113	422	5029	461	4898	0	856	7981	7908	-1893	17258	0	17258	3222	20480	49.99
12	4404	350	425	5179	417	4794	0	908	8272	8199	-1961	17536	0	17536	3356	20892	49.94
13	4417	120	451	4988	435	4832	0	885	8398	8131	-1919	17352	0	17352	3337	20688	50.00
14	4412	80	457	4949	379	4975	0	808	7896	8037	-1854	17294	0	17294	3259	20553	50.04
15	4410	285	405	5100	367	5045	0	677	8001	8326	-1929	17586	0	17586	3334	20920	50.00
16	4366	940	415	5721	346	5082	0	471	7776	7742	-1978	17384	0	17384	3397	20780	50.01
17	4444	974	405	5823	308	5104	0	256	7448	7433	-1894	17030	0	17030	3344	20374	49.99
18	4342	1226	420	5988	316	5185	0	54	6762	6748	-1747	16544	0	16544	3274	19818	50.02
19	4385	1325	432	6142	361	5228	0	0	6716	6867	-1735	16863	0	16863	3256	20119	50.02
20	4374	1370	416	6160	320	5216	0	0	6644	6646	-1650	16692	0	16692	3169	19862	50.08
21	4415	321	473	5209	345	5093	0	0	6836	6591	-1510	15728	0	15728	2995	18723	50.03
22	4428	235	493	5156	394	4819	0	0	6652	6630	-1626	15373	0	15373	2932	18305	50.00
23	4367	370	555	5292	401	4910	0	0	6386	6843	-1701	15744	0	15744	2864	18608	49.96
24	4342	410	541	5293	444	4770	0	0	6424	6596	-1746	15357	0	15357	2883	18240	49.99
MUs	105.30	12.36	10.70	128.36	10.34	119.22	0.00	6.25	167.24	168.64	-38.58	394.24	0.00	394.24	68.49	462.73	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 17/Oct/2019

Position as on 6.30 Hrs of 18/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn on shaft seal water leakage. Converted to AOH from 1 Nov 2019.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koyana Unit 10	80	05/08/2019	20.05		Continued.	Stator Earth Fault	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-1	660	19/09/2019	01.43		Continued.	Due to Low Coal Stock.	
AEML	AEML Unit 2	250	07/10/2019	21.18		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Nasik Unit 4	210	09/10/2019	23.59		Continued.	Zero schedule.	
MSPGCL	Koradi Unit-8	660	11/10/2019	22.36		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
RGPL	Dabhol 3X	290	13/10/2019	01.20	17/10/2019	06.21	Unit changeover.	
RGPL	Dabhol 3B	230	13/10/2019	01.20	17/10/2019	04.26	Unit changeover.	
MSPGCL	Khaparkheda Unit 3	210	13/10/2019	19.57		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 4	210	14/10/2019	23.51		Continued.	Zero Schedule	
MSPGCL	Parli Unit 8	250	16/10/2019	01.36		Continued.	Flame Failure (Converted To Zero Schedule DT.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Oct/2019

Position as on 6.30 Hrs of 18/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							23.10.2019 18.00.hrs)	
MSPGCL	Bhusawal Unit 5	500	16/10/2019	10.02		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit 8	108	17/10/2019	00.24	17/10/2019	11.40	Fuel gas shutoff valve problem.	
IPP	RPL(AMT) U-4	270	17/10/2019	10.41	17/10/2019	12.33	Low Vaccum Turbine trip.	
MSPGCL	Uran Unit 8	108	17/10/2019	13.47	17/10/2019	19.54	High Vibration Compressor Bearing.	
MSPGCL	Parli Unit 6	250	17/10/2019	23.25		Continued.	Poor Coal Receipt.	
MSPGCL	Uran Unit 8	108	18/10/2019	04.18		Continued.	Generator Vibration High.	
MSPGCL	Koyana Unit 11	80	18/10/2019	08.10	18/10/2019	14.30	BUS OUTAGE FOR HOT SPOT & ALLINGEMENT WORK.	
MSPGCL	Nasik Unit 5	210	18/10/2019	08.45	18/10/2019	14.45	DUE TO BOILAR BOARD TRIPEED.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 18/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Akola Aurangabad(PG) I	InterState	17/10/2019	10.11	17/10/2019	19.31	PO	Stringing Of Conductor.
Akola Aurangabad(PG) II	InterState	17/10/2019	10.30	17/10/2019	19.31	PO	Stringing Of Conductor.
Dabhol Nagothane II	InterState	17/10/2019	16.48	17/10/2019	17.29	T	Tripped At Dabhol End.
Akola Aurangabad(PG) I	InterState	18/10/2019	08.21	18/10/2019	19.56	PO	CONSTRUCTION WORK.
Akola Aurangabad(PG) II	InterState	18/10/2019	08.47	18/10/2019	19.57	PO	CONSTRUCTION WORK.
Babhaleshwar - Padghe-II	IntraState	17/10/2019	07.56	17/10/2019	18.55	PO	Auto Recloser Out.
Girwali - Lonikand 1	IntraState	17/10/2019	11.27	17/10/2019	15.51	PO	Line Maintenance work
Main Bus 1 @ New Koyana	IntraState	17/10/2019	12:26	18/10/2019	22:25	PO	Cold Washing.
Khadka-Aurangabad (Waluj)	IntraState	17/10/2019	19.37	18/10/2019	08.17	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	18/10/2019	20.05		Continued.	HT	Over Voltage
Dhule- Bableswhar - I	IntraState	18/10/2019	21.43		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali)	IntraState	18/10/2019	10.31	18/10/2019	19.35	PO	TESTING WORK.
400/220 KV 300 MVA ICT- I @Koradi	IntraState	18/10/2019	10.42	18/10/2019	18.13	PO	TESTING WORK.
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	18/10/2019	23.15		Continued.	PO	BUS BAR TESTING WORK.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
PARLY (PG) - OSMANABAD	InterState	15/10/2019	08.04		Continued.	PO	Tower Shifting Work of NH Crossing
Borivali - Tarapur	InterState	17/10/2019	06.00	17/10/2019	09.20	EO	Attending Hot Spot
Solapur (Pg) South Solapur I	InterState	17/10/2019	10.40	17/10/2019	19.00	PO	bay AMC Work.
Tillari Amona	InterState	18/10/2019	12.05	18/10/2019	17.37	PO	FLASH OVER ATTENDING WORK LOC 361, 334 Y-PHASE JUMPER REPLACEMENT.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Lonand-Baramati	IntraState	17/09/2019	11.13		Continued.	HT	To Control Overloading of Lonand -Jejuri Line.
Nanded-Ghatodi	IntraState	16/10/2019	04.04	17/10/2019	09.07	T	Distance Protection
Badnera-Akola li	IntraState	16/10/2019	08.07		Continued.	PO	Erection Of inline 220Kv Towers.
Badnera-Akola I	IntraState	16/10/2019	08.07		Continued.	PO	Erection Of inline 220Kv Towers.
Trombay - Kalwa	IntraState	16/10/2019	20.03	17/10/2019	07.13	PO	Tower Pilling Work.
Ambazari-Amravati	IntraState	17/10/2019	09.14	17/10/2019	17.55	PO	Conversion Of SSN IN To DSN.
karad - Dasgaon	IntraState	17/10/2019	09.44	17/10/2019	19.13	PO	Line Maintenance work
Kharghar-Borivali ckt II	IntraState	17/10/2019	09.51	17/10/2019	17.41	PO	Bus Isolator maintenance Work by Hot Line.
Gadchandur - Grace	IntraState	17/10/2019	10.01	17/10/2019	14.07	PO	Fixing Of Side Plate Of suspension Clamp of Pilot String At LOc No.151 (RPH).Fixing Of Suspension Clamp U Bolt At loc.no. 144(Y-PH).
Chandrapur GCR - Sicom II	IntraState	17/10/2019	10.14	17/10/2019	17.14	PO	Tree Cutting & Trimming Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 18/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Walchandnagar-Bhigwan	IntraState	17/10/2019	10.35	17/10/2019	17.30	PO	Diagnostic Work.
Koradi-Khaperkheda	IntraState	17/10/2019	10.56	17/10/2019	18.17	PO	Line Signature Test.
OSMANABAD PARANDA	IntraState	17/10/2019	18.37	17/10/2019	21.01	HT	To Remove the T & P Of Hot Line.
Midc Chandrapur-Gadchandur	IntraState	17/10/2019	20.20	17/10/2019	20.40	T	Distance Protection
Bappaon - Kalwa	IntraState	18/10/2019	04.44	18/10/2019	14.52	T	Distance Protection
Kharghar-Borivali ckt II	IntraState	18/10/2019	06:50	18/10/2019	12:58	PO	Replacement of B-Phase CT to line isolator Jumper since it is damaged and have hot spot.
Pophali - Pedambe II	IntraState	18/10/2019	08:10	18/10/2019	15:10	PO	Bus outage for Hot Spot & Alignment work.
Pedhambe - Oni	IntraState	18/10/2019	08:15	18/10/2019	15:00	PO	Bus Outage for Hot Spot & Alignment work.
Adlabs - Pedambe	IntraState	18/10/2019	08:35	18/10/2019	14:42	PO	Bus outage for Hot Spot & Alignment work.
Pedambe-Nerle	IntraState	18/10/2019	08:45	18/10/2019	15:18	PO	Bus outage for Hot Spot & Alignment work.
Main bus section-II @ Pedambe	IntraState	18/10/2019	08:50	18/10/2019	14:30	PO	Bus outage for Hot spot & Alignment work.
Chitegaon-Shendra Ckt-II	IntraState	18/10/2019	09.34	18/10/2019	19.03	EO	DUE BOARD CHANGE WORK.
Gadchandur-Ultratech I	IntraState	18/10/2019	10.03	18/10/2019	23.57	PO	DIAGNOSTIC TESTING WORK.
Gadchandur-Ultratech II	IntraState	18/10/2019	10.03	18/10/2019	18.18	PO	DIAGNOSTIC TESTING WORK.
Apta - Kalwa1	IntraState	18/10/2019	10.09	18/10/2019	15.02	PO	Line Maintenance work
TOPWORTH VILEBHAGAD	IntraState	18/10/2019	10.45	18/10/2019	21.15	PO	TESTING WORK.
Butibori - Khaperkheda	IntraState	18/10/2019	11.50	18/10/2019	19.09	PO	TESTING OF DISTANCE RELAY AND MAINTENANCE OF ISOLATOR.
Karad -Mudshingi Ckt- IV	IntraState	18/10/2019	14:35	18/10/2019	17:17	EO	Maintenance work.
PAL DOMBIVALI - PALAVA	IntraState	18/10/2019	15.45		Continued.	T	Distance Protection
Uran - Apta IV	IntraState	18/10/2019	15:21	18/10/2019	17:53	PO	Trip CKT Faulty indication,Apta -4 TBC Isolator problem, hence couldn't shifted on TBC.
Trombay MSETCL Tie 1	IntraState	18/10/2019	18.21	18/10/2019	22.55	T	Differential protection
Trombay - Mulund	IntraState	18/10/2019	18.32	18/10/2019	22.49	HT	FOR AVAILING BUS OUTAGE AT TROMBAY.
Trombay - Kalwa	IntraState	18/10/2019	23.15		Continued.	PO	TOWER PILLING WORK.
220 KV ICT Outages/Trippings							
220/110KV, 200MVA T/F-III at Mudshingi	InterState	18/10/2019	10.00	18/10/2019	13.50	PO	AMC WOEk.
220/132kv 200mva Emco ICT-1 @Kurkumbh	IntraState	15/10/2019	10.00		Continued.	PO	Oil Leakage Work.
220/132 KV ICT II @ Kopergaon	IntraState	17/10/2019	08.05	17/10/2019	12.00	PO	Routine Maintenance Work
220/100 kV 200 MVA ICT II @Padghe	IntraState	17/10/2019	09.02	17/10/2019	17.45	PO	Routine Maintenance Work
220/132kv 100 Mva Imp Ict 1 @Limbala Midc Hingoli	IntraState	17/10/2019	10.21	17/10/2019	18.51	PO	Quarterly Maintainance Work
220/132KV 100MVA -1@Alephata	IntraState	17/10/2019	11.16	17/10/2019	19.13	PO	For Removing Bird Nest.
220/66 Kv 150 Mva Ngef Ict 1 @Gadchandur	IntraState	17/10/2019	13.25	17/10/2019	17.50	PO	For Attending Of Oil Leakages From top & Diagnostic Testing.
220/132 KV 150MVA ICT I @ Boisar	IntraState	18/10/2019	09.32	18/10/2019	14.08	PO	ISOLATOR MAINTENANCE WORK.
220/100 Kv 200 Mva ICT III @Kalwa	IntraState	18/10/2019	09.38	18/10/2019	17.53	PO	OLTC OVERHAULING WORK.
220/100 Kv 200 MVA ICT I @Pal-Dombivali	IntraState	18/10/2019	17.30	18/10/2019	22.07	T	Differential protection
110 KV LINE Outages/Trippings							
Pedhambe Arawali Line	IntraState	18/10/2019	08:12	18/10/2019	15:45	PO	Bus Outage for Hot Spot & Alignment work.
100 KV LINE Outages/Trippings							
Kalwa-Kalyan	IntraState	18/10/2019	07:50	18/10/2019	16:48	PO	Tree Trimming.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage