

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 17/Oct/2024 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 151.239        | 2454.183        | 1) Gujrat                      | 9.970          | 138.853         |
| 2) Hydro            | 6.835          | 139.491         | 2) Madhya Pradesh              | 3.559          | 64.594          |
| 3) Gas              | 6.826          | 107.760         | 3) Chattisgarh                 | 3.060          | 57.620          |
| <b>Total MSPGCL</b> | <b>164.900</b> | <b>2701.434</b> | 4) Maharashtra                 | 207.625        | 3362.408        |
| B) 1) APLM          | 55.848         | 1032.241        | 5) Goa (Amona)                 | -2.746         | -34.803         |
| 2) JSWEL            | 26.040         | 416.130         | <b>Total</b>                   | <b>221.468</b> | <b>3588.672</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 52.880         | 824.548         |
| 4) RPL(AMT)         | 18.070         | 306.770         | b) Mumbai Drawl                | 55.676         | 873.571         |
| 5) SWPGPL           | 8.720          | 154.682         | c) MSEDCL Bilateral *          | 98.706         | 1533.970        |
| 6) Other IPP        | 10.997         | 187.918         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 52.739         | 820.407         |
| C) 1) TPCL Thermal  | 4.061          | 75.769          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 3.774          | 68.731          | Standby                        | 0.141          | 4.141           |
| 3) TPCL Gas         | 4.207          | 71.158          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 8.365          | 144.960         | 1) MSEDCL                      | 467.341        | 7766.679        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 76.083         | 1234.177        |
| 1) Thermal          | 283.340        | 4772.653        | 3) Other Discoms               | 12.262         | 207.159         |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>555.686</b> | <b>9208.015</b> |
| 2) Hydro            | 10.609         | 208.222         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.033         | 178.918         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 12.552         | 146.432         |                                |                |                 |
| 6) SOLAR            | 16.684         | 313.130         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>334.218</b> | <b>5619.355</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 5718                      | 6907                  | 6989                      | 6125                      |
| MSPGCL Hydro               | 246                       | 287                   | 514                       | 211                       |
| MSPGCL Gas                 | 286                       | 281                   | 277                       | 290                       |
| MSPGCL Total Generation    | 6250                      | 7475                  | 7780                      | 6626                      |
| Central Sector Receipt     | 9990                      | 9438                  | 9832                      | 8314                      |
| WIND                       | 442                       | 609                   | 763                       | 241                       |
| CPP / IPP Thermal          | 4155                      | 5256                  | 6045                      | 5035                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2161                      | 145                   | 6                         | 0                         |
| Exchange with Mumbai       | -2786                     | -2424                 | -2285                     | -1667                     |
| <b>MSEDCL DEMAND MET</b>   | <b>19666</b>              | <b>19929</b>          | <b>21574</b>              | <b>18143</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 19666                     | 19929                 | 21574                     | 18143                     |
| TPCL GENERATION            | 477                       | 689                   | 823                       | 387                       |
| AEML GENERATION            | 315                       | 476                   | 471                       | 309                       |
| <b>MUMBAI DEMAND</b>       | <b>3578</b>               | <b>3589</b>           | <b>3579</b>               | <b>2363</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>546</b>                | <b>570</b>            | <b>567</b>                | <b>406</b>                |
| STATE DEMAND MET           | 23790                     | 24088                 | 25720                     | 20912                     |
| <b>STATE DEMAND</b>        | <b>23790</b>              | <b>24088</b>          | <b>25720</b>              | <b>20912</b>              |
| Frequency (Hz)             | 49.99                     | 49.98                 | 49.97                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 06.01 Hrs | 49.59 Hz at 20.33 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 17/Oct/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.34         | 64.44         | 183      | 56       |
| Unit 8             | 11.74        | 207.79        | 552      | 374      |
| Unit 9             | 11.80        | 199.60        | 565      | 376      |
| Unit 10            | 11.32        | 196.41        | 526      | 370      |
| <b>Total</b>       | <b>38.19</b> | <b>668.24</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.08         | 43.20         | 155      | 115      |
| Unit 4             | 8.33         | 123.26        | 465      | 280      |
| Unit 5             | 8.20         | 147.20        | 435      | 280      |
| <b>Total</b>       | <b>19.60</b> | <b>313.67</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 3.76         | 64.66         | 222      | 139      |
| Unit 7             | 3.43         | 58.38         | 198      | 115      |
| Unit 8             | 3.82         | 66.14         | 223      | 146      |
| <b>Total</b>       | <b>11.01</b> | <b>189.18</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.95         | 57.14         | 192      | 114      |
| Unit 4             | 3.45         | 51.48         | 154      | 120      |
| Unit 5             | 8.37         | 130.15        | 387      | 280      |
| Unit 6             | 3.46         | 67.98         | 170      | 0        |
| Unit 7             | 8.76         | 123.71        | 443      | 278      |
| Unit 8             | 9.08         | 169.03        | 410      | 290      |
| Unit 9             | 2.81         | 10.26         | 327      | 0        |
| <b>Total</b>       | <b>39.88</b> | <b>609.76</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 3.89         | 76.64         | 229      | 136      |
| Unit 4             | 3.95         | 69.66         | 237      | 127      |
| <b>Total</b>       | <b>7.84</b>  | <b>146.29</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 4.02         | 60.99         | 185      | 115      |
| Unit 2             | 4.00         | 67.39         | 191      | 116      |
| Unit 3             | 3.91         | 58.24         | 172      | 133      |
| Unit 4             | 4.04         | 68.81         | 183      | 130      |
| Unit 5             | 10.39        | 159.53        | 480      | 300      |
| <b>Total</b>       | <b>26.35</b> | <b>414.97</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.32         | 56.54         | 151      | 122      |
| Unit 4             | 3.33         | 53.81         | 171      | 113      |
| Unit 5             | 1.72         | 1.72          | 127      | 0        |
| <b>Total</b>       | <b>8.36</b>  | <b>112.07</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.83         | 107.76        | 290      | 277      |
| <b>Total</b>       | <b>6.83</b>  | <b>107.76</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 1.03         | 13.19         | 44       | 42       |
| <b>Total</b>       | <b>1.03</b>  | <b>13.19</b>  |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 1.52         | 31.98         | 190      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 0.00          | 16.21          | 0        | 0        |
| Stage 3         | 0.17          | 11.25          | 94       | 0        |
| <b>Total</b>    | <b>1.69</b>   | <b>59.44</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.43          | 7.00           | 18       | 18       |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.49          | 3.51           | 62       | 0        |
| BHIRA T.R.      | 0.28          | 4.90           | 40       | 0        |
| SMLHY_PTN       | 3.82          | 59.09          | 180      | 147      |
| GHATGHAR        | 0.12          | 5.55           | 90       | 0        |
| <b>Total</b>    | <b>5.15</b>   | <b>80.06</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 12.55         | 146.43         | 0        | 0        |
| <b>Total</b>    | <b>12.55</b>  | <b>146.43</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 55.85         | 1032.24        | 0        | 0        |
| JSWEL(Mus)      | 26.04         | 416.13         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 18.07         | 306.77         | 0        | 0        |
| SWPGPL-Mus      | 8.72          | 154.68         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.60          | 97.89          | 269      | 185      |
| Other(Mus)      | 0.28          | 8.14           | 0        | 0        |
| JPL             | 5.12          | 81.89          | 227      | 209      |
| <b>Total</b>    | <b>119.68</b> | <b>2097.74</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 16.68         | 313.13         | 0        | 0        |
| <b>Total</b>    | <b>16.68</b>  | <b>313.13</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 0.00          | 0.00           | 0        | 0        |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.67          | 44.98          | 112      | 111      |
| Trombay 7B      | 1.54          | 26.18          | 65       | 63       |
| TATA Hydro      | 3.77          | 68.73          | 427      | 42       |
| Trombay 8       | 4.06          | 75.77          | 220      | 131      |
| <b>Total</b>    | <b>12.04</b>  | <b>215.66</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 8.36          | 144.96         | 491      | 282      |
| <b>Total</b>    | <b>8.36</b>   | <b>144.96</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 151.24      | 2454.18       | MSPGCL Total        | 164.90      | 2701.43       |
|                |             |         | MSPGCL Thml+Gas | 158.06      | 2561.94       | Koyna 1,2 & 4 Total | 1.52        | 48.19         |
|                |             |         | MSPGCL Hydro    | 6.84        | 139.49        | State Total         | 334.22      | 5619.36       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 17/Oct/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 6476        | 206  | 288  | 6970   | 145   | 5998      | 0    | 0     | 8618        | 8213        | -2158                | 18698                  | 0                | 0                           | 18698                         | 2922             | 470                       | 22090           | 50.00         |
| 2                  | 6216        | 205  | 289  | 6710   | 193   | 5462      | 0    | 0     | 8487        | 8670        | -1997                | 18593                  | 0                | 0                           | 18593                         | 2670             | 444                       | 21708           | 49.99         |
| 3                  | 6212        | 205  | 290  | 6707   | 173   | 5188      | 0    | 0     | 8294        | 8372        | -1791                | 18236                  | 0                | 0                           | 18236                         | 2480             | 413                       | 21129           | 49.99         |
| 4                  | 6125        | 211  | 290  | 6626   | 241   | 5035      | 0    | 0     | 8263        | 8314        | -1667                | 18143                  | 0                | 0                           | 18143                         | 2363             | 406                       | 20912           | 49.99         |
| 5                  | 6301        | 208  | 290  | 6799   | 295   | 5173      | 0    | 0     | 8274        | 8346        | -1611                | 18598                  | 0                | 0                           | 18598                         | 2307             | 404                       | 21309           | 50.02         |
| 6                  | 6429        | 215  | 289  | 6933   | 262   | 5384      | 0    | 0     | 8930        | 9085        | -1704                | 19501                  | 0                | 0                           | 19501                         | 2384             | 459                       | 22344           | 50.01         |
| 7                  | 6507        | 268  | 289  | 7064   | 257   | 5533      | 0    | 52    | 9695        | 9703        | -1843                | 20268                  | 0                | 0                           | 20268                         | 2535             | 498                       | 23301           | 50.02         |
| 8                  | 6546        | 437  | 290  | 7273   | 230   | 5264      | 0    | 433   | 9272        | 9374        | -1947                | 20101                  | 0                | 0                           | 20101                         | 2732             | 527                       | 23359           | 49.95         |
| 9                  | 6430        | 317  | 289  | 7036   | 213   | 4954      | 0    | 1117  | 9452        | 9640        | -2307                | 20107                  | 0                | 0                           | 20107                         | 3052             | 546                       | 23705           | 50.00         |
| 10                 | 6232        | 320  | 284  | 6836   | 299   | 4700      | 0    | 1649  | 9918        | 9481        | -2605                | 19822                  | 0                | 0                           | 19822                         | 3369             | 538                       | 23729           | 50.01         |
| 11                 | 5718        | 246  | 286  | 6250   | 442   | 4155      | 0    | 2161  | 10335       | 9990        | -2786                | 19666                  | 0                | 0                           | 19666                         | 3578             | 546                       | 23790           | 49.99         |
| 12                 | 5102        | 218  | 283  | 5603   | 470   | 4241      | 0    | 2492  | 10018       | 10130       | -2863                | 19536                  | 0                | 0                           | 19536                         | 3664             | 537                       | 23737           | 49.96         |
| 13                 | 5100        | 219  | 280  | 5599   | 639   | 3902      | 0    | 2473  | 9988        | 9583        | -2856                | 18806                  | 0                | 0                           | 18806                         | 3655             | 534                       | 22995           | 50.01         |
| 14                 | 5238        | 229  | 280  | 5747   | 815   | 3850      | 0    | 2177  | 9370        | 9223        | -2755                | 18540                  | 0                | 0                           | 18540                         | 3575             | 517                       | 22632           | 50.01         |
| 15                 | 5531        | 259  | 281  | 6071   | 710   | 4086      | 0    | 1880  | 9451        | 9548        | -2732                | 19048                  | 0                | 0                           | 19048                         | 3665             | 515                       | 23228           | 49.94         |
| 16                 | 5924        | 219  | 277  | 6420   | 674   | 4314      | 0    | 1397  | 9632        | 9787        | -2703                | 19356                  | 0                | 0                           | 19356                         | 3712             | 533                       | 23601           | 49.97         |
| 17                 | 6423        | 254  | 280  | 6957   | 543   | 4624      | 0    | 702   | 9635        | 9678        | -2610                | 19331                  | 0                | 0                           | 19331                         | 3667             | 563                       | 23561           | 49.97         |
| 18                 | 6907        | 287  | 281  | 7475   | 609   | 5256      | 0    | 145   | 9556        | 9438        | -2424                | 19929                  | 0                | 0                           | 19929                         | 3589             | 570                       | 24088           | 49.98         |
| 19                 | 6989        | 514  | 277  | 7780   | 763   | 6045      | 0    | 6     | 9749        | 9832        | -2285                | 21574                  | 0                | 0                           | 21574                         | 3579             | 567                       | 25720           | 49.97         |
| 20                 | 7078        | 445  | 282  | 7805   | 857   | 6017      | 0    | 0     | 9630        | 9430        | -2235                | 21314                  | 0                | 0                           | 21314                         | 3493             | 560                       | 25367           | 50.00         |
| 21                 | 6981        | 474  | 280  | 7735   | 1036  | 5536      | 0    | 0     | 8980        | 8879        | -2412                | 20221                  | 0                | 0                           | 20221                         | 3358             | 553                       | 24132           | 49.84         |
| 22                 | 7009        | 363  | 281  | 7653   | 830   | 5235      | 0    | 0     | 8825        | 9394        | -2493                | 20081                  | 0                | 0                           | 20081                         | 3273             | 538                       | 23892           | 50.02         |
| 23                 | 6866        | 268  | 284  | 7418   | 943   | 4954      | 0    | 0     | 8918        | 8880        | -2463                | 19213                  | 0                | 0                           | 19213                         | 3235             | 519                       | 22967           | 49.99         |
| 24                 | 6899        | 248  | 286  | 7433   | 913   | 4769      | 0    | 0     | 9030        | 8477        | -2429                | 18659                  | 0                | 0                           | 18659                         | 3226             | 504                       | 22389           | 50.01         |
| MUs                | 151.24      | 6.83 | 6.83 | 164.90 | 12.55 | 119.68    | 0.00 | 16.68 | 222.32      | 221.47      | -55.68               | 467.34                 | 0.00             | 0.00                        | 467.34                        | 76.08            | 12.26                     | 555.69          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

| Maximum Demand scenario for the date 17/Oct/2024 |                                  |                                   |
|--------------------------------------------------|----------------------------------|-----------------------------------|
| State Demand                                     | MSEDC Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 25720 MW                                         | 21574 MW                         | 3712 MW                           |
| 19 Hrs                                           | 19 Hrs                           | 16 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW               | --                                |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 17/Oct/2024**

Position as on 6.30 Hrs of 18/Oct/2024

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Nasik Unit 5            | 210      | 27/08/2024   | 23:55        | 17/10/2024 | 04:46      | On Tolling(Under COH from 00.00 Hrs DT.05.09.2024)                                                                                                      | 16/10/2024    |
| Total Capacity MSPGCL         |                         | 210      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | SWPGPL U-3              | 135      | 09/10/2024   | 01:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 26/10/2024    |
| Total Capacity IPP            |                         | 135      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE |                         | 345      |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/10/2024    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 26/11/2024    |
| MSPGCL                        | Koyna Unit 5            | 80       | 18/08/2024   | 18:00        |            | Continued. | UGB Temperature High                                                                                                                                    | 21/10/2024    |
| MSPGCL                        | Uran Unit 6             | 108      | 24/09/2024   | 10:30        | 17/10/2024 | 22:00      | Generator exciter end abnormal sound.                                                                                                                   | 18/10/2024    |
| MSPGCL                        | Chandrapur Unit 9       | 500      | 17/10/2024   | 00:51        | 17/10/2024 | 11:07      | Rotor Balancing Work                                                                                                                                    | 17/10/2024    |
| MSPGCL                        | Chandrapur Unit 6       | 500      | 17/10/2024   | 11:56        | 17/10/2024 | 13:22      | DUE TO LOW MS TEMPERATURE.                                                                                                                              |               |
| MSPGCL                        | Chandrapur Unit 9       | 500      | 17/10/2024   | 17:47        | 17/10/2024 | 19:52      | Drum level very high                                                                                                                                    |               |
| MSPGCL                        | Khaparkheda Unit 1      | 210      | 18/10/2024   | 17:41        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 22/10/2024    |
| Total Capacity MSPGCL         |                         | 2143     |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         | Trombay 5               | 500      | 22/09/2024   | 16:14        |            | Continued. | Emergency withdrwan due to fire in cable vault.                                                                                                         |               |
| Total Capacity TPC-G          |                         | 500      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                                                                  | 31/10/2024    |
| IPP                           | RPL(AMT) U-5            | 270      | 15/09/2024   | 15:21        |            | Continued. | Bottom Ash Evacuation Problem                                                                                                                           | 21/10/2024    |
| IPP                           | JPL Unit 2              | 150      | 18/10/2024   | 11:37        | 18/10/2024 | 13:55      | Turbine Lube oil Hdr, Pressure Low.                                                                                                                     |               |
| Total Capacity IPP            |                         | 690      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 30/12/2024    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/11/2024    |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 17/Oct/2024**

Position as on 6.30 Hrs of 18/Oct/2024

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                        | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-----------------------------------------|---------------|
| Total Capacity CENT.SECTOR                    |                         | 320      |              |              |           |            |                                         |               |
| Total Capacity FORCED OUTAGE                  |                         | 3653     |              |              |           |            |                                         |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |           |            |                                         |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                         |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 14/10/2024   | 16:49        |           | Continued. | Zero Schedule By MSEDCL.                |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 17/10/2024   | 22:00        |           | Continued. | Due to no schedule by MSEDCL            |               |
| Total Capacity MSPGCL                         |                         | 216      |              |              |           |            |                                         |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 216      |              |              |           |            |                                         |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |           |            |                                         |               |
| IPP                                           |                         |          |              |              |           |            |                                         |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                    |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                    |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019) |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)  |               |
| Total Capacity IPP                            |                         | 988      |              |              |           |            |                                         |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |           |            |                                         |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 17/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 18/Oct/2024

| Name of Line                                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                    |
|------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV BUSBAR Outages/Trippings</b>                     |                           |              |              |            |            |             |                                                                                                                                                                                                                                     |
| MAIN BUS - 2 @ KORADI 3                                    | IntraState                | 18/10/2024   | 09:33        | 18/10/2024 | 18:09      | PO          | Annual Maintenance of Bus Equipment at Koradi-III SS.                                                                                                                                                                               |
| <b>400 KV TIEBAY Outages/Trippings</b>                     |                           |              |              |            |            |             |                                                                                                                                                                                                                                     |
| 400KV TIE BAY 435 OF 500MVA 400/220KV ICT 2 @ CHANDRAPUR 2 | InterState                | 17/10/2024   | 10:00        | 17/10/2024 | 14:42      | PO          | Diagnostic testing and allied bay maintenance work                                                                                                                                                                                  |
| 220 KV TBC                                                 | IntraState                | 18/10/2024   | 10:45        | 18/10/2024 | 15:13      | PO          | CT Tan delta testing & Isolator routine maintenance work                                                                                                                                                                            |
| <b>400 KV TBC Outages/Trippings</b>                        |                           |              |              |            |            |             |                                                                                                                                                                                                                                     |
| 220KV TBC @ 400KV WARORA S/S                               | IntraState                | 18/10/2024   | 09:40        | 18/10/2024 | 16:20      | PO          | Routine maintenance , IR values, CB CRM, Timing, maintenance of bay equipment etc.                                                                                                                                                  |
| <b>400 KV MAINBAY Outages/Trippings</b>                    |                           |              |              |            |            |             |                                                                                                                                                                                                                                     |
| MAIN BAY - 412 OF WARDHA PGCIL @ KORADI 2                  | IntraState                | 16/10/2024   | 10:19        |            |            | PO          | Overhauling of CB by Agency                                                                                                                                                                                                         |
| MAIN BAY (410) KALWA - VIKHROLI GIS CKT - 1                | IntraState                | 17/10/2024   | 04:09        | 17/10/2024 | 05:55      | T           | Tripped on differential protection from Vikroli end only.                                                                                                                                                                           |
| MAIN BAY (413) OF 500MVA ICT - 2 @ TAPTITANDA              | IntraState                | 17/10/2024   | 12:00        | 17/10/2024 | 17:17      | PO          | Routine maintenance work and CB, CT diagnostic testing work                                                                                                                                                                         |
| MAIN BAY (409) OF AKOLA-1 CKT-1 @ AKOLA 2                  | IntraState                | 18/10/2024   | 09:23        | 18/10/2024 | 18:37      | PO          | Annual Maintenance of Bay Equipment at Akola-II SS.                                                                                                                                                                                 |
| <b>400 KV LINE Outages/Trippings</b>                       |                           |              |              |            |            |             |                                                                                                                                                                                                                                     |
| TALANDGE - KOLHAPUR (PG) CKT - 2                           | InterState                | 17/10/2024   | 20:40        | 18/10/2024 | 01:42      | EO          | Finger of B -phase, D isolator female contact bend down                                                                                                                                                                             |
| BUS REACTOR (50MVAR) @ PARLI                               | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.                                                                                                                                                                 |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                        | IntraState                | 04/10/2024   | 08:31        |            |            | HT          | H/T for load management.                                                                                                                                                                                                            |
| PADGHE - KALWA CKT - 1                                     | IntraState                | 16/10/2024   | 06:36        |            | Continued. | PO          | 1) Replacement of 29A bus PG isolator under LES scheme<br>2) A & B bus PG Isolator maint work<br>3) line will be in service through TBC . If required/ any emergency line will be charged on B bus .<br>4) Diagnostic Testing of CB |
| KALWA - VIKHROLI GIS                                       | IntraState                | 17/10/2024   | 04:09        | 17/10/2024 | 05:55      | T           | Differential protection at Vikhroli end only.                                                                                                                                                                                       |
| PARLI-SOLAPUR (LAMBOTI)                                    | IntraState                | 17/10/2024   | 09:52        | 18/10/2024 | 00:02      | PO          | 1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3) Hardware tightening & fitting work                                                                                                                       |
| KHADKA-AURANGABAD (WALUJ)                                  | IntraState                | 18/10/2024   | 01:54        |            | Continued. | HT          | Overvoltage Control                                                                                                                                                                                                                 |
| PARLI-SOLAPUR (LAMBOTI)                                    | IntraState                | 18/10/2024   | 12:05        | 18/10/2024 | 16:55      | PO          | Distance M1 & M2 relays retrofitting work, Bay maintenance work, Hardware tightening & fitting work.                                                                                                                                |
| <b>400 KV ICT Outages/Trippings</b>                        |                           |              |              |            |            |             |                                                                                                                                                                                                                                     |
| STATION TF No 3 @ CHANDRAPUR GCR                           | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                      |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA                        | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                             |
| 400/220/33 KV 315MVA ICT - 1 @ AKOLA                       | IntraState                | 17/10/2024   | 09:28        | 17/10/2024 | 22:14      | PO          | 1)Quarterly maintenance work of ICT and bay equipment<br>2)Diagnostic testing work                                                                                                                                                  |
| 400/220/33 KV 315 MVA ICT - 1 @ WALUJ                      | IntraState                | 17/10/2024   | 10:01        | 17/10/2024 | 18:54      | PO          | Diagnostic Testing, Relay Testing and routine maintenance work                                                                                                                                                                      |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 17/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 18/Oct/2024

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                   |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 400/220/33 KV 500 MVA ICT - 3 @ JEJURI    | IntraState                | 18/10/2024   | 08:45        | 18/10/2024 | 19:03      | PO          | Taking B-Ph unit of ICT-III in service in place of Spare ICT unit( which was taken in service through RRS on 20.06.2024)                                                                                                                                                                                                                                                                           |
| <b>400 KV BUSBAR Outages/Tripping</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| MAIN BUS - 1 @ PADGHE                     | IntraState                | 18/10/2024   | 09:38        |            | Continued. | PO          | 400kV Kalwa -1 A bus PG isolator Hanger Assembly replacement by Hot line method.<br>2) All feeders on A bus will be in service .                                                                                                                                                                                                                                                                   |
| <b>400 KV BR Outages/Tripping</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BUS REACTOR (80 MVar) - 1 @ BABHALESHWAR  | IntraState                | 07/10/2024   | 09:40        |            |            | PO          | The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order |
| BUS REACTOR (80 MVar) - 2 @ TIRORA        | IntraState                | 17/10/2024   | 09:52        | 18/10/2024 | 17:00      | PO          | Annual Maintenance of BR & Dia Equipment's                                                                                                                                                                                                                                                                                                                                                         |
| KARAD - 400KV 80 MVAR B/R 2               | IntraState                | 18/10/2024   | 08:26        | 18/10/2024 | 17:00      | PO          | Diagnostic testing work in respect of charging of 400KV Karad-solapur line. As reactor will work as line reactor.                                                                                                                                                                                                                                                                                  |
| <b>220 KV MAINBAY Outages/Tripping</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| 220KV BUS SECTION BAY @ PEDAMBE           | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                                                                                                                                       |
| <b>220 KV LINE Outages/Tripping</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BALE - SOLAPUR (PG)                       | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                   |
| OSMANABAD - SOLAPUR (BALE)                | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                      |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2     | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                                                                                                                                                |
| GHODBUNDER - GORAI                        | IntraState                | 29/07/2024   | 12:14        |            |            | PO          | Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.                                                                                                                                                                                                                                                                |
| 220kV Koradi-2 - Uppalwadi ckt 2          | IntraState                | 28/08/2024   | 00:14        |            |            | T           | Distance Protection                                                                                                                                                                                                                                                                                                                                                                                |
| EKLAHARE (OCR) - PADGHE                   | IntraState                | 24/09/2024   | 07:48        |            |            | HT          | For load mgmt                                                                                                                                                                                                                                                                                                                                                                                      |
| 220KV KORADI II (400KV)- BUTIBORI 3 CKT I | IntraState                | 01/10/2024   | 13:10        |            |            | HT          | H/T From Butibori 3 end                                                                                                                                                                                                                                                                                                                                                                            |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 17/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 18/Oct/2024

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                    |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II    | IntraState                | 01/10/2024   | 13:11        |            |            | HT          | H/T From Koradi 2 end                                                                                                                                                                                                                                                               |
| EKLAHARE (OCR) - NAVASARI CKT - 1             | IntraState                | 07/10/2024   | 15:10        |            |            | HT          | H/T For load management.                                                                                                                                                                                                                                                            |
| EKLAHARE (OCR) - NAVASARI CKT - 2             | IntraState                | 09/10/2024   | 12:00        |            |            | PO          | 1) PLCC, CVT, WT Foundation , Erection, Testing & Commissioning work at 220kV Navsari substation 2) PLCC, CVT, WT Erection, Testing & Commissioning work at 220kV Eklahare (OCR) substation                                                                                         |
| KARAD - DASGAON                               | IntraState                | 14/10/2024   | 15:46        |            |            | PO          | i)Dismantling of Exst. S/C Tower Loc. No. 160 of 220 KV KaradDasgaon (Pedambe) line. ii) Foundation of In-Line M/C Narrow Base Tower (MCN+3). iii) Erection of Tower & stringing of 220 KV Karad - Dasgaon & 220 Karad Koyana line                                                  |
| ALEPHATA-PARGAON(KATHAPUR)                    | IntraState                | 15/10/2024   | 07:31        |            |            | HT          | For Load Management                                                                                                                                                                                                                                                                 |
| TALOJA - PANCHANAND                           | IntraState                | 15/10/2024   | 16:03        | 17/10/2024 | 11:56      | HT          | Line charged from panchanand end only , kept off from taloja end for load management.                                                                                                                                                                                               |
| KALWA - PRINT HOUSE LINE                      | IntraState                | 15/10/2024   | 16:31        |            |            | HT          | Hand tripped at Kalwa end for load management.                                                                                                                                                                                                                                      |
| EKLAHARE (GCR) - AIROLI KNOW PARK             | IntraState                | 15/10/2024   | 22:33        | 18/10/2024 | 05:46      | HT          | H/T for load management.                                                                                                                                                                                                                                                            |
| TALEGAON (AMBI)-GENERAL MOTORS                | IntraState                | 16/10/2024   | 08:45        | 17/10/2024 | 17:35      | PO          | For Maintenance work at GM end by consumer .                                                                                                                                                                                                                                        |
| GHATGHAR - JINDAL                             | IntraState                | 16/10/2024   | 11:04        | 17/10/2024 | 00:25      | HT          | Load management.                                                                                                                                                                                                                                                                    |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1 | IntraState                | 16/10/2024   | 16:01        |            |            | HT          | Line Hand tripped for load management on 220kV Ulve - Waghivali ckt no 1.                                                                                                                                                                                                           |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2 | IntraState                | 17/10/2024   | 06:26        |            |            | HT          | H/T for controlling load of 220kV Ulve-Waghivali ckt-1                                                                                                                                                                                                                              |
| HINJAWADI I- CHINCHWAD                        | IntraState                | 17/10/2024   | 07:30        | 17/10/2024 | 20:30      | HT          | Load management.                                                                                                                                                                                                                                                                    |
| BHOSARI 2 - TELCO                             | IntraState                | 17/10/2024   | 08:33        | 17/10/2024 | 13:33      | PO          | 1. HYM work of 220KV Main Bus -2<br>2. Tan D & C measurement of EHV CTs of 220 kV Telco Line bay                                                                                                                                                                                    |
| VITA - MIRAJ                                  | IntraState                | 17/10/2024   | 08:35        | 17/10/2024 | 18:47      | PO          | Restranging of the conductor from Loc STN 576 - DTN 84                                                                                                                                                                                                                              |
| MAIN BUS - 2 @ BHOSARI 2                      | IntraState                | 17/10/2024   | 09:02        | 17/10/2024 | 13:24      | PO          | 1. HYM work of 220KV Main Bus -2<br>2. Tan D & C measurement of TF No 2 Bushing and Winding<br>3. Tan D & C measurement of EHV CTs of 220 kV Telco Line bay & 50 MVA TF 2 bay                                                                                                       |
| TALANDGE - MUDSHINGI CKT - 2                  | IntraState                | 17/10/2024   | 09:40        | 17/10/2024 | 18:08      | PO          | For double jump arrangement using C type, Wedge connector at tower cut point locations.                                                                                                                                                                                             |
| CHANDRAPUR MIDC - BALLARSHAH CKT II           | IntraState                | 17/10/2024   | 10:00        | 17/10/2024 | 14:02      | HT          | 1) for diagnostic testing work. 2) replacement of flashover insulator disc at loc no.41 r ph by addl.ee, l.m. s/dn-ii ballarshah being in opportunity outage period. 3) diagnostic testing work will be carried out by dy.ee, 220 kv midc s/stn being in opportunity outage period. |
| KHAPARKHEDA- BUTIBORI                         | IntraState                | 17/10/2024   | 10:46        | 17/10/2024 | 17:03      | HT          | 220 kv cts tan delta ,capacitance , ir & cb crm and timing , ir measurements works to be carried out.                                                                                                                                                                               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 17/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 18/Oct/2024

| Name of Line                          | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                              |
|---------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| GHATODI-NANDED                        | IntraState                | 17/10/2024   | 11:16        | 17/10/2024 | 17:34      | HT          | Risagging of loc.no. 132 -138 to mainten clearance as per ie act.                                                                                                                             |
| KALWA - PANCHANAND                    | IntraState                | 17/10/2024   | 12:10        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Talaja.                                                                         |
| KALWA - PRINT HOUSE LINE              | IntraState                | 17/10/2024   | 12:23        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Talaja.                                                                         |
| LONIKAND (400 KV)-THEUR II            | IntraState                | 17/10/2024   | 15:57        | 17/10/2024 | 22:53      | PO          | IR Measurement of LA                                                                                                                                                                          |
| MAHAD - KANDALGAON                    | IntraState                | 17/10/2024   | 17:08        | 17/10/2024 | 18:59      | EO          | Emergency outage on 220 KV Mahad-Kandalgaon line at Mahad S/S for Hot-Spot attending work at R-ph Wave Trap palm .                                                                            |
| PHURSUNGI-PARVATI                     | IntraState                | 17/10/2024   | 23:32        | 18/10/2024 | 02:54      | PO          | 1) Conversion of STN to DTN at L. N. - 18, 17, ( R,Y B ) Both are C/P.<br>2) Cold washing of Disc string at Loc. No.2A,7,8,10,11,12,(1 to 18 Parvati end) 13,15,16,17 (1 to 23 Kachara depo.) |
| POPHLI PEDHMBE LINE- 1                | IntraState                | 17/10/2024   | 23:44        | 18/10/2024 | 01:48      | T           | Distance Protection                                                                                                                                                                           |
| EKLAHARE (GCR) - GHATGHAR             | IntraState                | 18/10/2024   | 05:51        | 18/10/2024 | 13:26      |             | For replacement of Flashover string at Loc no. 183 , 173, 175.                                                                                                                                |
| WARDHA-YEOTMAL                        | IntraState                | 18/10/2024   | 08:03        | 18/10/2024 | 15:04      | PO          | Fixing of medium voltage conductor cover tape between Loc no.174(03)-174(04)                                                                                                                  |
| GADCHANDUR - VIRUR-II                 | IntraState                | 18/10/2024   | 08:15        | 18/10/2024 | 00:41      | PO          | De stringing work                                                                                                                                                                             |
| GADCHANDUR - VIRUR-II                 | IntraState                | 18/10/2024   | 08:15        | 18/10/2024 | 00:41      | PO          | Destringing work from location no.38 to 40, Stringing work from location no.38 to AP4 & AP4 to 40.                                                                                            |
| MAHAD - KANDALGAON                    | IntraState                | 18/10/2024   | 08:38        | 18/10/2024 | 18:32      | PO          | OPGW earthwire installation work.                                                                                                                                                             |
| GHATODI-NANDED                        | IntraState                | 18/10/2024   | 10:04        | 18/10/2024 | 20:22      | PO          | Risagging of Loc no.132-138 to mainten clearance                                                                                                                                              |
| BABLESHWAR AHAMADNAGAR-II             | IntraState                | 18/10/2024   | 10:09        | 18/10/2024 | 13:29      | PO          | 5 (i) Nature of work to be carried out. : Distance relay retrofitting work under PAC A'nagar Division                                                                                         |
| BHAVEGHAR - ROMA                      | IntraState                | 18/10/2024   | 10:14        | 18/10/2024 | 18:04      | PO          | Replacement of Insulator identified in PID.                                                                                                                                                   |
| SADAWAGHAPUR KARAD CKT 2              | IntraState                | 18/10/2024   | 10:24        |            | Continued. | PO          | Jump Nut Bolt tightening work at Loc No.1 to 34                                                                                                                                               |
| LOTEPARSHURAM- DASTURI LINE           | IntraState                | 18/10/2024   | 10:45        |            | Continued. | T           | Tripped on distance protection                                                                                                                                                                |
| LAMBOTI - TULJAPUR CKT - 2            | IntraState                | 18/10/2024   | 10:51        | 18/10/2024 | 17:37      | PO          | Outage is required for Replacement/ Tightening of Jump at Loc. No. 26 & cold washing of Insulator String and Jumper Tighteneing at Cut Point Locations.                                       |
| 132 KV PUSAD (220 KV ) - JAMBAZAR CKT | IntraState                | 18/10/2024   | 11:40        | 18/10/2024 | 19:37      | HT          | Safety work.                                                                                                                                                                                  |
| SHIVAJINAGAR-MALEGAON                 | IntraState                | 18/10/2024   | 13:16        |            | Continued. | PO          | For Bay Maintenance & Distance Relay Replacement work                                                                                                                                         |
| GHATGHAR - JINDAL                     | IntraState                | 18/10/2024   | 14:50        | 18/10/2024 | 19:49      | PO          | Replacement of Flashover polymer Loc 183,189.                                                                                                                                                 |
| KANDALGAON - KOYNA (POPHALI)          | IntraState                | 18/10/2024   | 15:48        |            | Continued. | EO          | For replacement of cross arm at loc no. 99.                                                                                                                                                   |
| KARAD -MUDSHINGI CKT 2-TAK            | IntraState                | 18/10/2024   | 15:51        | 18/10/2024 | 17:40      | EO          | Removal of the R-phase LA jumper at the 220kV Takari LIS Substation due to a major hissing noise.                                                                                             |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 17/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 18/Oct/2024

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| TALOJA - PANCHANAND                      | IntraState                | 18/10/2024   | 22:58        | 18/10/2024 | 23:42      | EO          | for red hot spot B ph CT P1 160 degree                                                                              |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                     |
| 220/132 KV 100 MVA ICT 1@ BABHALESHWAR   | IntraState                | 12/07/2024   | 13:35        |            |            | PO          | Augmentation of 220/132kV 100MVA to 220/132kV 200MVA at Babheshwar.                                                 |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2         | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                         |
| 220/132 KV 100 MVA ICT I @ UPPALWADI     | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                         |
| 220/132 KV 100 MVA ICT II @ UPPALWADI    | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                         |
| 220/33KV 50MVA PTR 1 @ KURKUMBH          | IntraState                | 17/10/2024   | 09:52        | 17/10/2024 | 17:28      | PO          | To attend oil leakage and t/f oil top up work                                                                       |
| 220/110 kV 200 MVA ICT 3 @ MUDSHINGI     | IntraState                | 17/10/2024   | 10:05        | 17/10/2024 | 15:25      | PO          | Differential relay retrofitting work and Quarterly maint. Work                                                      |
| 220/132 KV 200 MVA ICT 1 @ CHALISGAON    | IntraState                | 17/10/2024   | 10:34        | 17/10/2024 | 18:11      | HT          | Replacement of differential relay with the help of pac unit, dhule.                                                 |
| 220/132 KV 100 MVA ICT 1                 | IntraState                | 17/10/2024   | 11:00        | 17/10/2024 | 17:27      | HT          | Bus, line and auxiliary isolator maintenance work.                                                                  |
| 220/33KV 25MVA PTR - 1 @ ONI             | IntraState                | 17/10/2024   | 11:21        |            | Continued. | PO          | HV CB overhauling                                                                                                   |
| 220/132-110/11KV 200MVA ICT 3 @ MIRAJ    | IntraState                | 17/10/2024   | 11:27        | 17/10/2024 | 18:26      | PO          | 1. Diagnostic Testing Work<br>2. Annual Testing Work<br>3.Quarterly Maintenance Work                                |
| 220/132kV 100MVA ICT - 2 @ KALWAN        | IntraState                | 17/10/2024   | 11:32        | 17/10/2024 | 12:57      | PO          | Quarterly maintenance work                                                                                          |
| 220/132 KV 200 MVA ICT 2 @ PARBHANI      | IntraState                | 17/10/2024   | 14:28        | 17/10/2024 | 16:32      | HT          | LA replacement work and diagnostic test.                                                                            |
| MAIN BUS- A PT @ BAPGAON                 | IntraState                | 17/10/2024   | 16:30        | 17/10/2024 | 17:28      | PO          | For 220KV A-Bus B-ph PT oil leakage arresting work at 220KV Bapgaon SS.                                             |
| 220/132 KV 200 MVA ICT 1 @ AMALNER       | IntraState                | 18/10/2024   | 00:29        |            |            | HT          | Hot Spot on HV Y Ph CT                                                                                              |
| 220/132/11 KV 200 MVA ICT 1 @ AMRAVATI   | IntraState                | 18/10/2024   | 07:52        | 18/10/2024 | 18:10      | PO          | For In-Tank OLTC Overhauling work                                                                                   |
| 220/100 KV 200 MVA ICT 4 @ APTA          | IntraState                | 18/10/2024   | 10:10        | 18/10/2024 | 18:25      | PO          | 1. Replacement work of Differential Relay.<br>2. Replacement work of Back up Relay.<br>3. Routine Maintenance Work. |
| 220/132 KV 200 MVA ICT 2 @ CHALISGAON    | IntraState                | 18/10/2024   | 10:33        | 18/10/2024 | 19:00      | PO          | Replacement of differential relay with the help of PAC unit, Dhule                                                  |
| 220/22-22 KV 100 MVA PTR 2 @ PARVATI     | IntraState                | 18/10/2024   | 18:25        | 18/10/2024 | 18:25      | PO          | Half Yearly Maintenance & Annul Testing of Transformer                                                              |
| <b>220 KV BUSBAR Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                     |
| BUS SECTION @ BHOSARI II                 | IntraState                | 17/10/2024   | 09:02        | 17/10/2024 | 13:24      | PO          | 1. HYM work of 220KV Main Bus -2                                                                                    |
| <b>132 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                     |
| MANSAR-PENCH                             | InterState                | 26/09/2024   | 14:40        |            |            | HT          | H/T at 132KV Pench end                                                                                              |
| CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP | IntraState                | 16/10/2024   | 07:02        |            |            | HT          | For Load Management                                                                                                 |
| <b>110 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                     |
| KALWA KALYAN                             | IntraState                | 18/10/2024   | 13:04        | 18/10/2024 | 16:29      | EO          | loop connection closing at loc. 174 A Phase RHS side                                                                |
| <b>110 KV BUSBAR Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                     |
| BUS-2 @ KARANJADE                        | IntraState                | 16/10/2024   | 22:40        | 17/10/2024 | 08:06      | PO          | Project work new bay extended work                                                                                  |
| BUS-1 @ KARANJADE                        | IntraState                | 17/10/2024   | 22:36        | 18/10/2024 | 08:58      | PO          | Project work. New extended bay work.                                                                                |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage