

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Nov/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	135.678	2460.270	1) Gujrat	-7.674	-141.943
2) Hydro	7.245	142.530	2) Madhya Pradesh	-0.432	-32.238
3) Gas	2.087	31.362	3) Chattisgarh	6.300	103.240
Total MSPGCL	145.010	2634.162	4) Maharashtra	184.036	2875.661
B) 1) APLM	74.638	1080.876	5) Goa (Amona)	-1.194	-23.945
2) JSWEL	11.991	214.455	Total	181.036	2780.775
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.915	548.387
4) RPL(AMT)	29.722	438.291	b) Mumbai Drawl	40.019	619.804
5) SWPGPL	8.248	118.892			
6) Other IPP	39.589	544.886	c) MSEDCL Bilateral *	74.672	1196.654
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	10.105	183.983	d) Mumbai Bilateral *	34.913	548.385
2) TPCL Hydro	3.470	64.803	Include PX	0.000	0.000
3) TPCL Gas	0.000	6.990	Standby	0.002	0.002
4) AEML Thermal	8.236	149.077			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	318.207	5190.730	1) MSEDCL	462.493	7475.621
2) Hydro (A2+C2)	10.715	207.333	2) Mumbai Discoms	61.830	1024.657
3) Gas (A3+B7+C3)	2.087	38.352	3) Other Discoms	9.415	158.929
4) Wind	9.437	239.148			
6) SOLAR	12.256	202.869	TOTAL STATE	533.738	8659.207
TOTAL STATE	352.702	5878.432			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6082	5406	6070	5110
MSPGCL Hydro	200	185	1353	137
MSPGCL Gas	49	90	90	93
MSPGCL Total Generation	6331	5681	7513	5340
Central Sector Receipt	9066	8885	7130	5958
WIND	349	318	467	670
CPP / IPP Thermal	6961	6938	6994	6727
CPP / IPP Gas	0	0	0	0
SOLAR	1608	1783	0	0
Exchange with Mumbai	-1885	-2143	-1605	-1580
MSEDCL DEMAND MET	21995	21040	20065	16732
Load Shedding	0	0	0	0
MSEDCL DEMAND	21995	21040	20065	16732
TPCL GENERATION	719	531	943	511
AEML GENERATION	493	382	448	284
MUMBAI DEMAND	3097	3056	2996	2375
OTHER DISCOM DEMAND	435	422	434	383
STATE DEMAND MET	25527	24518	23495	19490
STATE DEMAND	25527	24518	23495	19490
Frequency (Hz)	50.04	50.00	50.00	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 14.03 Hrs	49.78 Hz at 16.44 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 17/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.70	78.92	215	165
Unit 7	0.00	0.00	0	0
Unit 8	13.24	217.21	613	479
Unit 9	13.20	216.31	585	500
Unit 10	0.00	91.74	0	0
Total	31.14	604.18		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.21	156.26	460	280
Unit 5	8.98	159.34	440	285
Total	18.18	315.60		
Parli				
Unit 6	4.07	67.60	227	145
Unit 7	4.03	63.79	216	144
Unit 8	3.74	55.48	182	138
Total	11.84	186.87		
Chandrapur				
Unit 3	3.24	53.32	165	122
Unit 4	3.20	49.89	157	116
Unit 5	7.03	109.08	325	249
Unit 6	0.00	107.25	0	0
Unit 7	6.40	123.36	322	239
Unit 8	8.72	166.58	460	275
Unit 9	8.94	159.48	443	293
Total	37.53	768.97		
Paras				
Unit 3	5.15	82.14	226	200
Unit 4	4.83	36.36	224	178
Total	9.98	118.51		
Khaparkheda				
Unit 1	2.66	46.14	125	95
Unit 2	3.10	45.74	150	115
Unit 3	3.55	51.66	180	96
Unit 4	3.50	58.59	173	126
Unit 5	7.34	165.26	370	273
Total	20.15	367.39		
Nasik				
Unit 3	0.00	1.31	0	0
Unit 4	3.60	44.56	175	115
Unit 5	3.26	52.89	163	110
Total	6.86	98.76		
Uran				
All Units	2.09	31.36	94	30
Total	2.09	31.36		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	11.00	24	0
Total	0.14	11.00		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.86	39.08	340	40
Stage 4	1.70	32.77	647	0
Stage 3	0.67	15.78	240	0
Total	4.24	87.64		
Hydro				
KDPH	0.43	5.49	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.46	3.07	58	0
BHIRA T.R.	0.18	3.24	70	0
SMLHY_PTN	1.60	27.44	73	62
GHATGHAR	0.19	4.64	125	0
Total	2.87	43.88		
Wind				
Total	9.44	239.15	0	0
Total	9.44	239.15		
CPP				
APML(Mus)	74.64	1080.88	0	0
JSWEL(Mus)	11.99	214.46	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	29.72	438.29	0	0
SWPGPL-Mus	8.25	118.89	0	0
Other(Mus)	39.59	544.89	0	0
Total	164.19	2397.40		
SOLAR				
Total	12.26	202.87	0	0
Total	12.26	202.87		
Tata				
Trombay 5	6.85	124.73	380	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.91	0	0
Trombay 7B	0.00	3.08	0	0
TATA Hydro	3.47	64.80	434	12
Trombay 8	3.26	59.25	170	129
Total	13.58	255.78		
AEMIL				
DTPS U-1&2	8.24	149.08	496	283
Total	8.24	149.08		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	135.68	2460.27	MSPGCL Total	145.01	2634.16
			MSPGCL Thml+Gas	137.76	2491.63	Koyna 1,2 & 4 Total	3.57	71.86
			MSPGCL Hydro	7.24	142.53	State Total	352.70	5878.43

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 17/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5105	131	92	5328	437	6412	0	0	6696	6581	-1474	16928	0	16928	2252	356	19536	50.01
2	5250	124	92	5466	498	6520	0	0	6617	6586	-1373	17361	0	17361	2094	336	19791	50.01
3	5209	123	92	5424	442	6595	0	0	6435	6408	-1277	17290	0	17290	1969	302	19561	49.99
4	5174	124	92	5390	421	6652	0	0	6438	6557	-1202	17518	0	17518	1898	300	19716	50.00
5	5569	124	92	5785	368	6771	0	0	6513	6856	-1195	18274	0	18274	1887	311	20472	50.02
6	5912	143	92	6147	364	6806	0	0	7371	7368	-1293	19045	0	19045	1994	347	21386	50.00
7	6041	313	94	6448	338	6849	0	27	7833	7895	-1406	19763	0	19763	2135	388	22286	49.97
8	6162	936	94	7192	294	6894	0	343	7512	8049	-1455	20909	0	20909	2337	408	23654	50.02
9	6054	263	93	6410	173	6983	0	846	8005	8460	-1707	20732	0	20732	2580	433	23745	50.04
10	5787	163	92	6042	238	6965	0	1282	8619	8805	-1891	21008	0	21008	2893	433	24334	50.00
11	6082	200	49	6331	349	6961	0	1608	8971	9066	-1885	21995	0	21995	3097	435	25527	50.04
12	5774	181	30	5985	382	6990	0	1793	9070	8684	-1942	21469	0	21469	3149	423	25041	50.04
13	5406	185	90	5681	318	6938	0	1783	8838	8885	-2143	21040	0	21040	3056	422	24518	50.00
14	5529	182	89	5800	248	6890	0	1685	8508	8699	-2073	20860	0	20860	2914	389	24163	50.03
15	5526	182	87	5795	227	6893	0	1373	9055	9010	-2102	20797	0	20797	2955	399	24151	50.03
16	5818	182	88	6088	244	6923	0	989	9036	8687	-2089	20421	0	20421	2996	421	23838	50.04
17	5985	215	88	6288	219	7014	0	468	8833	8531	-2026	20058	0	20058	2975	436	23469	49.95
18	6131	725	88	6944	298	7033	0	59	7446	7238	-1714	19428	0	19428	2964	430	22822	49.93
19	6070	1353	90	7513	467	6994	0	0	6776	7130	-1605	20065	0	20065	2996	434	23495	50.00
20	6067	574	91	6732	503	6997	0	0	7106	6850	-1695	18954	0	18954	2862	433	22249	50.02
21	5587	302	92	5981	580	6944	0	0	6557	6394	-1717	17764	0	17764	2660	418	20842	49.99
22	5239	222	93	5554	683	6917	0	0	6180	6062	-1674	17140	0	17140	2514	402	20056	50.01
23	5110	137	93	5340	670	6727	0	0	6119	5958	-1580	16732	0	16732	2375	383	19490	49.99
24	5091	161	94	5346	676	6521	0	0	6054	6277	-1501	16943	0	16943	2278	376	19597	49.98
MUs	135.68	7.24	2.09	145.01	9.44	164.19	0.00	12.26	180.59	181.04	-40.02	462.49	0.00	462.49	61.83	9.42	533.74	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Nov/2022

Position as on 6.30 Hrs of 18/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33	17/11/2022	04:48	Furnace Pressure High(converted into coal shortage from 15-10-2022)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	19/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	19/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	
CENT.SECTOR	Tarapur 3	540	07/11/2022	02:00		Continued.	For maintenance on reactor side	19/11/2022
IPP	JSW (J) U3	300	09/11/2022	08:08	18/11/2022	09:47	Generator Elect. Fault	16/11/2022
MSPGCL	Uran Unit 6	108	10/11/2022	10:44		Continued.	Gas shortage	
MSPGCL	Koradi Unit-10	660	10/11/2022	22:13		Continued.	Boiler Tube Leakage	19/11/2022
MSPGCL	Nasik Unit 3	210	11/11/2022	03:16		Continued.	Boiler Tube Leakage (under tolling from 06:33 hrs dtd-13/11/2022)	20/11/2022
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.	18/11/2022
MSPGCL	Chandrapur Unit 6	500	16/11/2022	14:06		Continued.	ID Fan Problem	20/11/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 18/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY - 702 OF BUS REACTOR AND 765/400kV 1500MVA ICT @ AKOLA 2	IntraState	18/11/2022	09:18			PO	Annual Maintenance of Bay Equipment
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	18/11/2022	00:36			PO	For Pole 1 Scheduled Annual Outage and Pole1 Y Phase Converter Transformer replacement work.
400 KV TIEBAY Outages/Trippings							
TIE BAY- 402 OF 400/220/33 KV 500 MVA ICT - 1 AND PARLI @ LAMBOTI	IntraState	14/11/2022	10:43			PO	Overhauling of 402-52 CB
TIE BAY (415) OF CHANDRAPUR-2 & ADANI - 2 @ WARORA	IntraState	17/11/2022	09:41	17/11/2022	12:56	PO	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN Bay - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	17/11/2022	10:11	17/11/2022	11:43	PO	Diagnostic testing and Maintenance
MAIN BAY (416) OF CHANDRAPUR ckt-2 @ WARORA	IntraState	18/11/2022	09:52			PO	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
400 KV LINE Outages/Trippings							
KALWA - TALEGAON (PG)	InterState	16/11/2022	22:35	17/11/2022	07:39	EO	To apply repair sleeve on broken conductor strand near vibration damper at, 178, 179, 159,162.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
GT-10 @ KORADI-2	IntraState	12/11/2022	11:44				1) Routine maintenance of isolator. 2) Health check up of CB 402-Q52 by M/S Siemens(OEM) 3) Routine Bay maintenance work. 4) Erection, testing and commissioning of dedicated metering CT and IVT for the metering arrangement for GT-10 bay at 400 kV Koradi II S/s.
KARAD - TALANDGE CKT - 1	IntraState	15/11/2022	17:03			PO	Overhauling of A bus, B Bus PG isolators.
LONIKAND I - KOYNA STAGE-IV	IntraState	17/11/2022	10:42	17/11/2022	17:44	EO	Y phase WaveTrap jumper conductor found cut in stage4 pothead s/y
EKTUNI - TAPTITANDA CKT - 2	IntraState	17/11/2022	12:03	17/11/2022	18:40	PO	Relay Testing and Routine Maintenance
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	17/11/2022	13:21	17/11/2022	20:07	T	TRIPPED ON DIST. PROTECTION
DEEPNAGAR - THAPTI TANDA	IntraState	18/11/2022	02:39	18/11/2022	04:18	T	Distance Protection
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	18/11/2022	06:01			PO	1) String Disc Replacement Work 2) Maintenance Work
220 KV DHULE(400KV) - MALEGAON CKT	IntraState	18/11/2022	10:17			PO	For routine testing and maintenance work
400 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 18/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	17/11/2022	07:09	17/11/2022	15:16	PO	Dismantling of 400 kV bushing is required for internal inspection of ICT-I R ph unit. So while dismantling of 400 kV bushing,for safety from induction zone of R ph CT to 400 kV gantry jump which is now in live condition.For this outage is required on ICT-I
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	17/11/2022	09:10	17/11/2022	17:22	EO	17/11/2022 , low oil level indication is appeared on control panel of ICT-1. During inspection, oil level in conservator is found low. It is very necessary to top up the oil in ICT-1 unit. Window indication is attached herewith proposal.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	17/11/2022	17:16	17/11/2022	19:54	EO	Hotspot observed at 220kV B ph line isolator and Bph B bus isolator at 400 kV Talandge.
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	18/11/2022	09:43			PO	Diagnostic testing work of CB and other routine maint.work.
400 KV BR Outages/Trippings							
80 MVAr Bus reactor @ Talandge	IntraState	17/11/2022	09:40	17/11/2022	22:48	PO	AMP and relay testing works.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/11/2022	08:24			HT	For Load Management
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARA(OCR)-RAYMOND	IntraState	14/11/2022	10:00	17/11/2022	19:23	PO	CB Mechanism overhauling & CB pole overhauling work due to SF6 Gas purity of CB is below the acceptable limit
EKLAHARE (OCR) - PADGHE	IntraState	15/11/2022	08:45			HT	For Load Management
TROMBAY SALSETTE LINE-2	IntraState	17/11/2022	03:43	17/11/2022	04:26	PO	Project work in Vicinity of line to Close loop of 110 KV Dharavi - Vikhroli and Dharavi Powai line of A Phase at Loc. 58.
URAN - APTA 2	IntraState	17/11/2022	08:58	17/11/2022	18:50	PO	"1) For Insulator string replacement work. 2) Bay Maintaince Work and Diagnostic Testing Work."
KANDALGAON - PIRANGUT	IntraState	17/11/2022	10:26	17/11/2022	16:25	PO	1)Replacement of polymer insulators by longrod porcelain at location no. -34 2)Emergency Tree Cutting
WALCHANDNAGAR-LONI DEOKAR	IntraState	17/11/2022	11:40	17/11/2022	15:00	EO	REPLACEMENT OF FLASHOVER STRING AT LOC NO.64 & 74

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 18/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VITA WAIPHALE	IntraState	17/11/2022	12:09	17/11/2022	18:28	PO	Distance protection relay replacement work
HALKARNI-MAHALAXMI LINE	IntraState	17/11/2022	12:27	17/11/2022	19:26	PO	Quarterly Maintainance, Diagnostic Testing work.
VARKUTI- HIWARWADI	IntraState	17/11/2022	12:42	17/11/2022	15:55	PO	Cold washing work at Loc No.166 to 233
URAN - KHARGHAR 2	IntraState	18/11/2022	09:14			PO	1) For Insulator string replacement work. 2) Bay Maintainance Work and Diagnostic Testing Work.
TALANDGE - HAMIDWADA	IntraState	18/11/2022	09:30			PO	Quarterly Maintainance Work, Diagnostic testing. Attending Hot spot.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	18/11/2022	09:34			PO	Routine bay maintenance & Line maintenance
MALEGAON-SATANA	IntraState	18/11/2022	10:05			HT	H/T TO CONTROL LINE LOADING
JAMBHUL - ANANDNAGAR	IntraState	18/11/2022	10:14			PO	1) For attending hot spot 2) CB CRM, Timing and IR 3) Bay R&M work
BUS COUPLER @ AAREY	IntraState	18/11/2022	10:25			PO	Annual Maint of Bus Coupler.facilitating outage of 220kV Main Bus 1
MAIN BUS - 1 @ AAREY	IntraState	18/11/2022	10:25			PO	Annual Maintenance of Main Bus-1 and Bus Side Isolators
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/110 kV 200 MVA ICT 2 @ MUDSHINGI	IntraState	16/11/2022	09:43	17/11/2022	18:35	PO	HV CB overhauling in presence of Siemens Engineer, TF oil filtration work & QM work
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	17/11/2022	08:40	17/11/2022	13:55	PO	Diagnosis of testing work
220/132 KV 100MVA ICT 2 @ BARAMATI	IntraState	17/11/2022	15:05	17/11/2022	17:58	PO	DIAGNOSTIC TESTING & RELAY TESTING WORK
250 MVA ICT-5 @ TROMBAY	IntraState	18/11/2022	08:24			PO	110 KV RING BUS 2 & 3 OUTAGE FOR GOD REPLACEMENT
220/132KV 200MVA ICT 6 @ EKLAHARE (GCR)	IntraState	18/11/2022	09:02			PO	diagnostic testing work
220/132 KV 200 MVA ICT 1 @ BOISAR-II	IntraState	18/11/2022	09:26			PO	Bay Maintenance Works
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	IntraState	18/11/2022	10:07			PO	TF oil filtration & QM work
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	17/11/2022	09:36	17/11/2022	18:01	PO	1) For MAIN BUS 2 insulator string replacement work.
MAIN BUS - 2 @ URAN	IntraState	18/11/2022	09:37			PO	1) For MAIN BUS 2 insulator string replacement work.
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 18/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03	17/11/2022	06:20	PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03	17/11/2022	05:30	PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
AMBERNATH - KALYAN CKT - 1	IntraState	17/11/2022	08:35	17/11/2022	14:02	PO	Project work for installation of New 110 KV breaker at OFA.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage