

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Jan/2019 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.573	2588.999	1) Gujrat	3.187	39.813
2) Hydro	6.627	120.612	2) Madhya Pradesh	10.169	146.543
3) Gas	7.193	120.989	3) Chattisgarh	3.480	68.020
Total MSPGCL	150.393	2830.600	4) Maharashtra	109.121	1678.781
B) 1) APLM	66.197	1231.332	5) Goa (Amona)	-0.242	-3.916
2) JSWEL	22.519	408.109	Total	125.715	1929.241
3) VIPL	0.000	81.108	a) Mumbai Schedule	28.382	353.176
4) RPL(AMT)	4.194	23.204	b) Mumbai Drawl	30.175	423.672
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	7.143	187.291
6) Other IPP	12.538	260.353	Include PX	-5.437	-90.059
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.382	353.026
C) 1) TPCL Thermal	5.284	177.604	Include PX	15.325	73.924
2) TPCL Hydro	5.524	70.272	Standby	0.000	0.150
3) TPCL Gas	4.394	78.636	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.750	85.980	1) MSEDCL	363.607	6552.917
D) STATE			2) Mumbai Discoms	50.123	836.162
1) Thermal	252.055	4856.689	TOTAL STATE	413.730	7389.079
(A1+C1+C4+(B1-B6))					
2) Hydro	12.151	190.884			
(A2+C2)					
3) Gas	11.587	199.625			
(A3+B7+C3)					
4) Wind	6.197	109.607			
6) SOLAR	6.029	103.035			
TOTAL STATE	288.019	5459.840			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6198	5918	5709	5288
MSPGCL Hydro	481	232	269	83
MSPGCL Gas	288	287	294	313
MSPGCL Total Generation	6967	6437	6272	5684
Central Sector Receipt	6087	5895	5420	4064
WIND	348	207	157	299
CPP / IPP Thermal	4979	4954	4410	3820
CPP / IPP Gas	0	0	0	0
SOLAR	838	1100	0	0
Exchange with Mumbai	-1611	-1586	-1453	-769
MSEDCL DEMAND MET	17608	17007	14806	13098
Load Shedding	0	0	0	0
MSEDCL DEMAND	17608	17007	14806	13098
TPCL GENERATION	846	839	836	387
AEML GENERATION	190	190	191	190
MUMBAI DEMAND	2647	2615	2480	1346
STATE DEMAND MET	20255	19622	17286	14444
STATE DEMAND	20255	19622	17286	14444
Frequency (Hz)	49.93	49.94	49.93	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.11 Hz at 02.26 Hrs	49.73 Hz at 05.42 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 18/Jan/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.54	40.42	165	120
Unit 7	3.22	61.81	150	108
Unit 8	8.42	108.98	360	343
Unit 9	11.76	152.69	660	400
Unit 10	0.00	149.01	0	0
Total	26.95	512.91		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.16	174.08	475	350
Unit 5	9.20	174.14	480	350
Total	18.36	348.23		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	56.43	0	0
Total	0.00	56.43		
Chandrapur				
Unit 3	4.25	76.22	188	163
Unit 4	4.07	70.84	185	160
Unit 5	8.99	166.35	395	355
Unit 6	10.01	174.84	455	361
Unit 7	9.45	170.10	413	370
Unit 8	10.42	188.69	490	365
Unit 9	10.31	188.54	483	360
Total	57.50	1035.58		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	5.04	96.50	256	155
Total	5.04	96.50		
Khaparkheda				
Unit 1	3.63	65.96	160	135
Unit 2	3.66	64.92	160	120
Unit 3	3.70	67.09	160	145
Unit 4	3.81	66.22	170	155
Unit 5	9.76	178.24	450	375
Total	24.55	442.42		
Nasik				
Unit 3	0.00	22.11	0	0
Unit 4	4.17	74.81	204	162
Unit 5	0.00	0.00	0	0
Total	4.17	96.92		
Uran				
All Units	7.19	120.99	316	273
Total	7.19	120.99		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.82	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.82		
Koyna				
Stage 1-2	1.62	33.24	185	40
Stage 4	0.00	8.32	0	0
Stage 3	0.68	9.61	130	0
Total	2.30	51.18		
Hydro				
KDPH	0.44	6.40	19	18
VTRNA	0.59	9.16	60	0
TILLARI	0.42	7.88	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.33	3.52	80	0
RNGR+BHTSA	0.30	5.28	13	5
BHANDARDRA	0.00	0.06	0	0
ELDARY	0.00	2.78	0	0
SMLHY_PTN	0.53	7.07	30	20
GHATGHAR	1.72	27.29	250	0
Total	4.32	69.44		
Wind				
Total	6.20	109.61	0	0
Total	6.20	109.61		
CPP				
APML(Mus)	66.20	1231.33	0	0
JSWEL(Mus)	22.52	408.11	0	0
VIPL(Mus)	0.00	81.11	0	0
RPLAMT(Mus)	4.19	23.20	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	12.54	260.35	0	0
Total	105.45	2004.11		
SOLAR				
Total	6.03	103.04	0	0
Total	6.03	103.04		
Tata				
Trombay 5	0.00	83.46	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	49.78	117	116
Trombay 7B	1.61	28.86	68	66
Trombay 8	5.28	94.15	238	204
TATA Hydro	5.52	70.27	437	0
Total	15.20	326.51		
AEML				
DTPS U-1&2	4.75	85.98	253	189
Total	4.75	85.98		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.57	2589.00	MSPGCL Total	150.39	2830.60
			MSPGCL Thml+Gas	143.77	2709.99	Koyna 1,2 & 4 Total	1.62	41.56
			MSPGCL Hydro	6.63	120.61	State Total	288.02	5459.84

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 18/Jan/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5328	111	300	5739	132	3854	0	0	4586	4544	-962	13307	0	13307	1590	14897	49.94
2	5270	91	312	5673	269	3828	0	0	4468	4442	-886	13326	0	13326	1464	14790	49.98
3	5259	91	301	5651	308	3811	0	0	4347	4173	-816	13127	0	13127	1392	14519	50.04
4	5288	83	313	5684	299	3820	0	0	4317	4064	-769	13098	0	13098	1346	14444	49.95
5	5250	95	315	5660	322	3796	0	0	4656	4828	-784	13822	0	13822	1360	15182	49.96
6	5442	247	303	5992	306	3910	0	0	5265	5270	-899	14579	0	14579	1495	16074	49.83
7	6030	351	314	6695	341	4730	0	4	5723	5430	-1067	16133	0	16133	1715	17848	49.93
8	6136	339	316	6791	229	5113	0	57	5951	5753	-1168	16775	0	16775	1903	18678	49.92
9	6268	479	315	7062	201	5178	0	290	6132	6176	-1317	17590	0	17590	2178	19768	49.94
10	6290	586	300	7176	237	5177	0	524	6257	5985	-1489	17610	0	17610	2423	20033	49.98
11	6285	561	293	7139	247	5116	0	722	6352	5847	-1567	17504	0	17504	2591	20095	49.93
12	6198	481	288	6967	348	4979	0	838	6312	6087	-1611	17608	0	17608	2647	20255	49.93
13	5918	232	287	6437	207	4954	0	1100	5963	5895	-1586	17007	0	17007	2615	19622	49.94
14	5863	227	273	6363	237	4518	0	851	5892	5841	-1482	16328	0	16328	2481	18809	50.00
15	5893	272	283	6448	212	4313	0	727	5889	5819	-1514	16005	0	16005	2478	18483	49.94
16	5826	297	286	6409	180	4271	0	565	5910	5762	-1509	15678	0	15678	2495	18173	49.90
17	5797	297	286	6380	117	4480	0	288	5524	5442	-1481	15226	0	15226	2486	17712	49.95
18	5711	205	289	6205	111	4534	0	63	5154	5248	-1461	14700	0	14700	2454	17154	49.94
19	5709	269	294	6272	157	4410	0	0	5267	5420	-1453	14806	0	14806	2480	17286	49.93
20	5681	372	306	6359	302	4351	0	0	5228	5260	-1440	14832	0	14832	2454	17286	50.00
21	5315	372	296	5983	304	4210	0	0	4901	4939	-1362	14074	0	14074	2281	16355	49.92
22	5291	247	310	5848	388	4117	0	0	4621	4750	-1282	13821	0	13821	2108	15929	50.00
23	5255	230	301	5786	360	4028	0	0	4400	4445	-1198	13421	0	13421	1935	15356	49.99
24	5270	92	312	5674	383	3950	0	0	4418	4295	-1072	13230	0	13230	1756	14986	50.02
MUs	136.57	6.63	7.19	150.39	6.20	105.45	0.00	6.03	127.53	125.71	-30.18	363.61	0.00	363.61	50.13	413.73	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Jan/2019

Position as on 6.30 Hrs of 19/Jan/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 5	210	22/11/2018	03.50		Continued.	Boiler Tube Leakage Work Completed On 24/11/2018. Available Against Case 4 From 25/11/2018.Converted To COH From 00:00 Hrs of 05/12/2018 (Converted COH to Zero sch by MSEDCL from 29.01.2019)	
AEML	AEML Unit 1	250	23/12/2018	06.06		Continued.	For COH.	
TPC-G	Trombay 5	500	11/01/2019	23.56		Continued.	Annual Overhaul	
MSPGCL	Koyana STG-IV Unit-2	250	14/01/2019	09:40		Continued.	Routine Maintenance work.	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
MSPGCL	Koyana Unit 1	70	26/11/2018	00.00		Continued.	Oil Cooler Leakage.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	14/12/2018	16.30		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	RPL(AMT) U-2	270	27/12/2018	19.30		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/01/2019	19.30		Continued.	Zero Schedule	
IPP	Dhariwal	300	12/01/2019	10.15		Continued.	Coal Shortage	
MSPGCL	Parli Unit 8	250	12/01/2019	12.00		Continued.	Zero Schedule by MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Jan/2019

Position as on 6.30 Hrs of 19/Jan/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 10	660	15/01/2019	23.25		Continued.	Condenser Tube Cleaning Work & PCR.	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
IPP	RPL(AMT) U-1	270	18/01/2019	19.30		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit 7	210	19/01/2019	18.21		Continued.	Poor Coal Receipt	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 19/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	17/01/2019	20.24	18/01/2019	03.11	EO	To attend Pole-2 Conversion T/F OLTC oil Leakage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	10/01/2019	16.32		Continued.	HT	Over Voltage
Dabhol Nagothane I	InterState	18/01/2019	11.52		Continued.	PO	String Replacement of Insulator Strings.
Bhusawal-Aurangabad	IntraState	17/01/2019	16.13	18/01/2019	07.42	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	18/01/2019	00.01	18/01/2019	07.34	HT	Over Voltage
Warora -IEPL	IntraState	18/01/2019	10.38	18/01/2019	18.18	PO	Tightening of Nut Bolts.
Girwali - Lonikand 1	IntraState	18/01/2019	14.12	18/01/2019	16.52	EO	Attending Hot Spot on R PH CT Stud.
Khadka-Aurangabad (Waluj)	IntraState	18/01/2019	17.31		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	19/01/2019	00.06	19/01/2019	07.39	HT	Over Voltage
Girwali- Lonikand 2	IntraState	19/01/2019	11.35	19/01/2019	13.24	EO	To attend Hot Spot at Base Joint of 29B Isolator(Taken on TBC)
Main Bus-II @ Koradi	IntraState	19/01/2019	12.38	19/01/2019	17.11	PO	Tan Delta Measurement of Bus CVT
Lonikand I - Koyna stage-IV	IntraState	19/01/2019	23.30		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220kv, 500 Mva ICT-1 @Deepnagar	IntraState	18/01/2019	15.45	18/01/2019	16.41	EO	Tightning of Tubes Connecting R & Y Phase For Delta Formation of Tertiary Winding.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Nasik Navsari I	InterState	19/01/2019	15.56	19/01/2019	18.52	T	Distance Protection Zone-II
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.
Nanded - Parli Ext. Ckt I	IntraState	06/12/2018	07.02		Continued.	HT	Waghala-Kumbhargaoon CKT O/L.
Kalwa - Colourchem	IntraState	17/01/2019	19.56	18/01/2019	07.27	T	Tripped at Kalwa Zone 1, R & Y Phase to ground
Kalwa - Borivali	IntraState	18/01/2019	07.30	18/01/2019	10.10	EO	Attending Hot Spot
Washala - Ghatghar	IntraState	18/01/2019	08.52	18/01/2019	18.34	PO	Earthwire Replacement Work.
Nanded-Parbhani	IntraState	18/01/2019	09.21	18/01/2019	21.52	T	In View of Outage of Bus Section At Yavatmal.
Ghatghar - Jindal	IntraState	18/01/2019	09.25	18/01/2019	19.06	PO	Earthwire Replacement Work.
Pusad - Hingoli	IntraState	18/01/2019	09.35	18/01/2019	21.50	T	In View of Outage of Bus Section At Yavatmal.
Pusad-Ghatodi	IntraState	18/01/2019	09.35	18/01/2019	21.52	T	In View of Outage of Bus Section At Yavatmal.
220KV Chalisagaon-Kopergaon	IntraState	18/01/2019	10.01	18/01/2019	17.25	PO	Replacement of CT.
Pusad-Ghatodi	IntraState	18/01/2019	10.10	18/01/2019	18.09	PO	Diagnostic Testing Work,

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jan/2019

Statement-VII

Position as on 6.30 Hrs of 19/Jan/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Measurement of Tan Delta of CT.
Nalasopara-Boisar	IntraState	18/01/2019	10.41	18/01/2019	17.25	PO	Routine Maintenance Work
Half Bus section-I @ Yavatmal	IntraState	18/01/2019	10.56	18/01/2019	21.16	PO	Jumper Replacement work.
Kanhan-Bhandara I	IntraState	18/01/2019	11.22	18/01/2019	17.37	PO	Diagnostic Testing Work.
Chakan-Chinchwad	IntraState	18/01/2019	13.41	18/01/2019	15.09	T	Distance Protection, Zone1, R&Y PH, 12KA.
Topworth - Kharghar	IntraState	18/01/2019	23.05	18/01/2019	23.16	HT	Hand tripped Due To AR Successful But Unbalance Load RYB Phase.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	19/01/2019	06.51	19/01/2019	07.08	T	Distance Protection R Phase
Loteparshuram- Dasturi Line	IntraState	19/01/2019	08.40	19/01/2019	16.30	PO	Changing of Insulator String
Dhule-Chalisagaon	IntraState	19/01/2019	09.04	19/01/2019	13.09	PO	Replacement of Line Isolators
Apta - Kalwa	IntraState	19/01/2019	09.53	19/01/2019	18.34	PO	Replacement of Old Disc Insulator
Ghatghar - Jindal	IntraState	19/01/2019	09.56	19/01/2019	20.30	PO	E/W replacement work
Hinjawadi I- Chinchwad	IntraState	19/01/2019	10.13	19/01/2019	17.38	PO	Line Maintenance work
Washala - Ghatghar	IntraState	19/01/2019	11.00	19/01/2019	19.55	PO	E/W Replacement work
Ambazari-Abhijeet	IntraState	19/01/2019	12.54	19/01/2019	15.25	PO	For connecting New PT supply
Ambazari-Amravati	IntraState	19/01/2019	15.45	19/01/2019	16.43	PO	PT Supply extension
220 KV ICT Outages/Trippings							
220/110KV, 200MVA T/F-III at Mudshingi	InterState	18/01/2019	10.30	18/01/2019	13.25	PO	Quarterly Maintenance Work
220/33 Kv 50 Mva Apex Ptr 1 @Boisar-Ii	IntraState	18/01/2019	07.15	18/01/2019	10.00	PO	Diagnostic Testing Work.
220/22 Kv 50 Mva Bhel Ptr 1 @Padghe	IntraState	18/01/2019	10.07	18/01/2019	18.26	PO	Diagnostic Testing Work.
220/22 Kv 50 Mva Cgl Ptr 1 @Kalwa	IntraState	18/01/2019	11.34	18/01/2019	16.04	PO	Maintenance Work of Isolators.
220/33kv 100 MVA ICT-II @ Boisar	IntraState	18/01/2019	15.10	18/01/2019	20.07	PO	Diagnostic Testing Work.
220/132KV 100MVA ICT-II@Shivajinagar	IntraState	19/01/2019	07.06	19/01/2019	11.04	PO	Quarterly Maintainance Work
220/33 Kv 100 Mva Areva Ptr 1 @Jamde	IntraState	19/01/2019	09.25	19/01/2019	12.42	PO	Testing Work
220/132 KV 200MVA ict 1@Nasik GCR	IntraState	19/01/2019	09.52		Continued.	PO	Dismantling of existing main and aux Bus Isolator and commissioning of new Isolator
220/100 Kv 125 Mva Hel Ict 2 @Jambhul	IntraState	19/01/2019	10.05	19/01/2019	20.47	PO	Testing Work
220/33 Kv 100 Mva Alstom Ptr 2 @Jamde	IntraState	19/01/2019	12.44	19/01/2019	15.38	PO	Testing Work
132 KV LINE Outages/Trippings							
Pusad-Jambazar	IntraState	18/01/2019	09.06	18/01/2019	21.53	T	In View of Outage of Bus Section At Yavatmal.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage