

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Jan/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	146.571	2623.260	1) Gujrat	-9.157	-118.368
2) Hydro	16.564	204.191	2) Madhya Pradesh	2.737	88.156
3) Gas	5.775	81.979	3) Chattisgarh	5.040	103.100
Total MSPGCL	168.910	2909.430	4) Maharashtra	136.000	2320.786
B) 1) APLM	69.103	1227.378	5) Goa (Amona)	-1.555	-25.521
2) JSWEL	14.421	252.250	Total	133.065	2368.153
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.756	386.031
4) RPL(AMT)	21.560	461.759	b) Mumbai Drawl	23.765	414.641
5) SWPGPL	8.144	99.255	c) MSEDCL Bilateral *	59.687	1011.950
6) Other IPP	39.581	681.579	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.756	385.908
C) 1) TPCL Thermal	11.990	183.062	Include PX	0.000	0.000
2) TPCL Hydro	4.074	70.341	Standby	0.000	0.123
3) TPCL Gas	0.000	9.340	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.639	163.551	1) MSEDCL	435.614	7687.318
D) STATE			2) Mumbai Discoms	49.468	840.934
1) Thermal	321.009	5692.094	3) Other Discoms	8.115	165.561
(A1+C1+C4+(B1-B6))			TOTAL STATE	493.197	8693.813
2) Hydro	20.638	274.532			
3) Gas	5.775	91.319			
4) Wind	5.595	157.288			
6) SOLAR	7.115	110.428			
TOTAL STATE	360.132	6325.661			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6197	6288	6427	5637
MSPGCL Hydro	1954	983	672	294
MSPGCL Gas	246	232	235	243
MSPGCL Total Generation	8397	7503	7334	6174
Central Sector Receipt	6751	7085	5202	4372
WIND	126	77	189	379
CPP / IPP Thermal	6821	6718	6839	5644
CPP / IPP Gas	0	0	0	0
SOLAR	898	1030	0	0
Exchange with Mumbai	-1067	-1409	-836	-875
MSEDCL DEMAND MET	18379	17473	14793	12560
Load Shedding	0	0	0	0
MSEDCL DEMAND	18379	17473	14793	12560
TPCL GENERATION	999	726	1085	412
AEML GENERATION	500	422	501	352
MUMBAI DEMAND	2566	2557	2422	1639
OTHER DISCOM DEMAND	355	353	393	313
STATE DEMAND MET	24492	23561	21150	17333
STATE DEMAND	24492	23561	21150	17333
Frequency (Hz)	49.98	50.00	49.98	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 13.02 Hrs	49.82 Hz at 22.09 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Jan/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.42	51.72	160	115
Unit 7	0.00	0.00	0	0
Unit 8	13.78	239.90	594	488
Unit 9	13.03	202.83	584	430
Unit 10	11.99	207.90	525	485
Total	42.23	702.34		
Bhusawal				
Unit 3	3.42	48.06	170	115
Unit 4	0.00	100.73	0	0
Unit 5	9.72	152.32	460	280
Total	13.14	301.10		
Parli				
Unit 6	4.91	69.39	250	147
Unit 7	4.28	68.75	216	140
Unit 8	4.13	71.27	200	144
Total	13.32	209.41		
Chandrapur				
Unit 3	3.04	49.03	161	120
Unit 4	2.79	58.23	130	85
Unit 5	7.24	137.80	340	285
Unit 6	7.27	150.50	355	285
Unit 7	7.29	86.27	355	280
Unit 8	7.15	171.80	443	0
Unit 9	8.39	168.72	450	281
Total	43.17	822.34		
Paras				
Unit 3	4.93	78.02	250	138
Unit 4	4.87	69.99	247	141
Total	9.80	148.01		
Khaparkheda				
Unit 1	3.37	44.88	155	120
Unit 2	0.00	0.00	0	0
Unit 3	3.94	63.09	187	130
Unit 4	0.00	54.04	0	0
Unit 5	10.50	173.96	480	310
Total	17.82	335.97		
Nasik				
Unit 3	3.56	52.07	173	122
Unit 4	0.00	18.28	0	0
Unit 5	3.54	33.74	177	117
Total	7.10	104.08		
Uran				
All Units	5.78	81.98	253	229
Total	5.78	81.98		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.25	5.29	27	0
Total	0.25	5.29		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.68	41.99	450	35
Stage 4	3.19	21.74	764	0
Stage 3	1.65	14.38	320	0
Total	8.52	78.11		
Hydro				
KDPH	0.43	4.68	18	18
VTRNA	0.65	9.60	60	0
TILLARI	0.52	9.40	58	0
BHIRA T.R.	0.22	4.22	40	0
SMLHY_PTN	5.56	97.14	248	222
GHATGHAR	0.65	1.05	125	0
Total	8.04	126.08		
Wind				
Total	5.60	157.29	0	0
Total	5.60	157.29		
CPP				
APML(Mus)	69.10	1227.38	0	0
JSWEL(Mus)	14.42	252.25	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	21.56	461.76	0	0
SWPGPL-Mus	8.14	99.26	0	0
Other(Mus)	39.58	681.58	0	0
Total	152.81	2722.22		
SOLAR				
Total	7.12	110.43	0	0
Total	7.12	110.43		
Tata				
Trombay 5	7.71	119.96	471	256
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	5.17	0	0
Trombay 7B	0.00	4.17	0	0
Trombay 8	4.28	63.10	221	133
TATA Hydro	4.07	70.34	420	0
Total	16.06	262.74		
AEML				
DTPS U-1&2	9.64	163.55	501	307
Total	9.64	163.55		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	146.57	2623.26	MSPGCL Total	168.91	2909.43
			MSPGCL Thml+Gas	152.35	2705.24	Koyna 1,2 & 4 Total	6.87	63.73
			MSPGCL Hydro	16.56	204.19	State Total	360.13	6325.66

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Jan/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5637	294	243	6174	379	5644	0	0	4759	4372	-875	15381	0	15381	1639	313	17333	49.99
2	5576	292	241	6109	473	5481	0	0	4710	4544	-782	15556	0	15556	1526	269	17351	49.98
3	5721	297	253	6271	545	5510	0	0	4751	4499	-741	15824	0	15824	1457	260	17541	49.99
4	5688	288	241	6217	491	5332	0	0	4792	4587	-718	15653	0	15653	1426	256	17335	49.99
5	5796	298	243	6337	368	5571	0	0	4827	4739	-737	16008	0	16008	1439	270	17717	49.98
6	6161	366	252	6779	332	5958	0	0	4867	4948	-815	16901	0	16901	1531	301	18733	49.94
7	6557	486	242	7285	333	6534	0	3	5032	5035	-825	18047	0	18047	1654	318	20019	49.96
8	6767	886	251	7904	359	6765	0	68	5272	5165	-757	19168	0	19168	1859	336	21363	49.99
9	6650	1422	240	8312	265	6829	0	376	5614	5649	-947	20130	0	20130	2155	354	22639	50.02
10	6377	1860	239	8476	202	6804	0	682	6201	6488	-1103	21187	0	21187	2401	362	23950	49.95
11	6197	1954	246	8397	126	6821	0	898	6818	6751	-1067	21571	0	21571	2566	355	24492	49.98
12	6223	1745	232	8200	111	6763	0	1032	7004	7005	-1241	21510	0	21510	2600	360	24470	50.02
13	6288	983	232	7503	77	6718	0	1030	7117	7085	-1409	20651	0	20651	2557	353	23561	50.00
14	6251	752	229	7232	82	6651	0	969	7062	6749	-1390	19945	0	19945	2415	348	22708	50.03
15	6114	405	239	6758	92	6560	0	909	7148	7058	-1198	19821	0	19821	2409	358	22588	50.00
16	6232	405	230	6867	150	6676	0	649	6993	6930	-1233	19664	0	19664	2412	375	22451	49.97
17	6330	573	230	7133	146	6697	0	405	6151	5847	-1079	18782	0	18782	2410	367	21559	49.99
18	6358	395	241	6994	180	6843	0	94	5488	5513	-904	18347	0	18347	2390	373	21110	49.99
19	6427	672	235	7334	189	6839	0	0	5134	5202	-836	18335	0	18335	2422	393	21150	49.98
20	6388	966	237	7591	169	6866	0	0	5010	4926	-842	18322	0	18322	2375	388	21085	49.97
21	6110	328	248	6686	121	6786	0	0	4854	4903	-989	17131	0	17131	2211	376	19718	49.96
22	5710	329	239	6278	128	6280	0	0	5116	5264	-1174	16421	0	16421	2032	355	18808	49.96
23	5636	277	242	6155	141	6050	0	0	5109	4882	-1094	15794	0	15794	1853	340	17987	49.96
24	5377	291	250	5918	136	5831	0	0	5090	4924	-1009	15465	0	15465	1729	335	17529	49.97
MUs	146.57	16.56	5.77	168.91	5.60	152.81	0.00	7.12	134.92	133.06	-23.76	435.61	0.00	435.61	49.47	8.12	493.20	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 18/Jan/2022

Position as on 6.30 Hrs of 19/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 4	210	16/01/2022	23:52		Continued.	Extension of Boiler Steaming Validity.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vibration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/01/2022	19:40		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/01/2022	20:00		Continued.	Gas shortage	
MSPGCL	Nasik Unit 4	210	07/01/2022	22:00		Continued.	CONDENSER TUBE LEAKAGE	
IPP	JSW (J) U3	300	15/01/2022	07:46		Continued.	non availability of load schedule.	
IPP	RPL(AMT) U-4	270	17/01/2022	10:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 8	500	18/01/2022	22:06	19/01/2022	01:30	Generator Protection operated	
MSPGCL	Chandrapur Unit 4	210	18/01/2022	23:47		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 3	210	19/01/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 3	210	19/01/2022	06:11		Continued.	Furnace Pressure High	
MSPGCL	Paras Unit 4	250	19/01/2022	11:16		Continued.	electrical fault	
MSPGCL	Ghatghar Unit-2	125	19/01/2022	12:05		Continued.	AVR Heavy fault.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 18/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	17/01/2022	21:00	18/01/2022	01:20	EO	Attending RED HOT at pole-1 base filter Z11- Z1 at jumper connecting to Capacitor bushing.
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	19/01/2022	07:16	19/01/2022	08:17	T	Card Failure at HVDC Chandrapur
400 KV LR Outages/Tripping							
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	17/01/2022	10:56	19/01/2022	06:33	PO	Retrofitting of Distance Relay I & II under MTAMC Project
400 KV LINE Outages/Tripping							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/12/2021	12:35			HT	HAND TRIPPED TO CONTROL LINE LOADING OF 400KV TALEGAON-KALWA AND 400KV TALEGAON - KHARGHAR CKT
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	04/01/2022	15:46			PO	Height raising work of 400kV Waluj-Babhleshwar line at Loc No. 239 to 240 crossing to Samruddhi Highway i.e. 1. Dismantling of loc No. 239,240,241 (all DA+01) 2. Erection of new towers at loc No.239, 240,241 (All DD+9) 3. Restraining between Loc No. 237 to 242
BUS - 1 @ NEW KOYNA	IntraState	17/01/2022	12:25	18/01/2022	14:55	PO	Bus conductor replacement Work & Bus Isolator replacement work
JAIGAD - KARAD CKT - 2	IntraState	17/01/2022	22:30	18/01/2022	09:43	HT	H/T for o/v.
NAGOTHANE - DABHOL CKT - 2	IntraState	18/01/2022	02:50	18/01/2022	13:53	T	DP
BABHALESHWAR - PADGHE CKT-1	IntraState	19/01/2022	03:21	19/01/2022	06:32	HT	DP trip.
AKOLA - KHADKA (BHUSAWAL)	IntraState	19/01/2022	09:44	19/01/2022	15:21	PO	Routine maintenance & testing work
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	19/01/2022	10:08	19/01/2022	18:58	PO	For Conductor & Earthwire H/W tightening work & replacement of broken E/W in span 59-61
400 KV ICT Outages/Tripping							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	18/01/2022	10:30	18/01/2022	19:35	PO	Post monsoon maint work
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	19/01/2022	11:18	19/01/2022	18:40	PO	Post monsoon maint work
220 KV LINE Outages/Tripping							
132 KV KANHAN (220 KV) - PENCH CKT	InterState	19/01/2022	09:48	19/01/2022	14:06	PO	For Black Start Mock Drill
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
PADGHE - TEMGHAR - 2	IntraState	02/01/2022	23:25			HT	conductor replacement work
BOISAR II - BOISAR (PG) CKT - 1	IntraState	10/01/2022	09:51		Continued.	PO	REPLACEMENT OF old CONDUCTOR by HTLS CONDUCTOR

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TEMGHAR - KALWA	IntraState	13/01/2022	23:10				As safety precaution for the replacement of CB pole of 220/22 kV, 50MVA PTR-2
SALSETTE BORIVLI - 2	IntraState	16/01/2022	16:34	19/01/2022	23:28	PO	For shifting to new 220KV GIS
JEJURI-PHURSUNGI 1	IntraState	18/01/2022	10:00	18/01/2022	14:48	PO	Replacement of R and B Ph wave trap jump and half yearly maintenance
NAGOTHANE - ACCIL	IntraState	18/01/2022	10:13	18/01/2022	18:40	PO	1) Damaged/Flashover insulator string replacement at Loc.No.20A,22A,23A,29A and other line maintenance work.
DASTURI-KANDALGAON LINE	IntraState	18/01/2022	12:45	18/01/2022	14:58	T	R,Z1,19.2 KM,3.83 KA
KANDALGAON - KOYNA (POPHALI)	IntraState	18/01/2022	13:35	18/01/2022	14:05	T	B,Z1,32.1 KM,2.53 KA
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	18/01/2022	14:55	18/01/2022	18:32	T	TRIPPED ON DIST PROT
TALANDGE - BIDRI	IntraState	19/01/2022	09:27	19/01/2022	13:15	PO	For relay testing work
BHALVANI - VARKUTI	IntraState	19/01/2022	10:53	19/01/2022	15:47	PO	Outage is required for Quarterly Maintenance
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 2	IntraState	19/01/2022	11:21	19/01/2022	15:47	PO	Outage is required for Quarterly Maintenance
FLAGSHIP-CHINCHWAD	IntraState	19/01/2022	12:27	19/01/2022	15:53	EO	To attend oil leakage of R ph CT of 220KV Chinchwad line Bay
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	19/01/2022	12:44	19/01/2022	15:32	EO	Hot spot attending work on B-ph CB
BIDRI - SAWANTWADI	IntraState	19/01/2022	13:20	19/01/2022	18:43	PO	conversion of SSN to DSN & Conversion of STN To DTN
SALSETTE - SAHAR CKT	IntraState	19/01/2022	13:36	19/01/2022	13:14		Loc no 28, hanging object in B ph.
LAMBOTI - KARKAMB	IntraState	19/01/2022	15:13	19/01/2022	16:38	EO	An outage is required for Broken disc replacement work at loc no. 82 R-ph
NERLE - PEDAMBE	IntraState	19/01/2022	20:05		Continued.	HT	B-PH,LINE ISOLATOR,HEAVY SPARKING OBSERVED.
TROMBAY - SALSETTE CKT - 1	IntraState	19/01/2022	23:06		Continued.	PO	FOR METRO-4 WORK
TROMBAY SALSETTE LINE-2	IntraState	19/01/2022	23:13		Continued.	PO	FOR METRO -4 WORK
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220 / 110 / 33kV 250MVA ICT 8 @ DHARAVI	IntraState	16/01/2022	08:59			PO	For disconnecting 33KV for NGT replacement
220/132KV 100 MVA ICT 2@ PETH	IntraState	16/01/2022	09:25	18/01/2022	13:40	PO	Oil filtration & oil leakage attending work by replacement of gaskets of bushing, PRV & inspection window
220 / 110 / 22kv 250MVA ICT 1 @ SAKI	IntraState	16/01/2022	09:39			PO	Only breakers to be kept open (220/110/33 Kv)
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	17/01/2022	20:45	18/01/2022	22:53	EO	SF6 gas top up in ICT-2 LV breaker to avoid any untoward incidence & failure of ICT.
220/100 KV 200 MVA ICT 3 @ TROMBAY	IntraState	18/01/2022	09:58	18/01/2022	19:03	PO	1). Diagnostic test of ICT 2) CT Tan Delta 3) R&M work.
220/33 KV 50 MVA PTR 1 @ KHARGHAR	IntraState	19/01/2022	09:16	19/01/2022	18:43	PO	For Winding Resistance measurement test and replacement of Bucholz relay along with Gas collecting device
220/33-22 KV 50 MVA PTR 4 @ NERUL	IntraState	19/01/2022	09:57	19/01/2022	19:25	PO	Diagnostic Testing and for attending Oil Leakage of B phase CT on EHV Side

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 200 MVA ICT 2 @ TALOJA	IntraState	19/01/2022	10:09	19/01/2022	14:06	PO	Dignostic test ICT & CT HV, LV & R/M work
220/100 KV 200 MVA ICT 1 @ APTA	IntraState	19/01/2022	15:21	19/01/2022	16:53	PO	Diagnostic testing work(CT,winding,bushing C & Tan delta testing, IR testing) & maintenance work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage