

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Jan/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.943	2595.235	1) Gujrat	-6.126	-87.638
2) Hydro	10.033	241.077	2) Madhya Pradesh	-0.721	52.797
3) Gas	5.629	88.104	3) Chattisgarh	4.390	99.700
Total MSPGCL	159.605	2924.416	4) Maharashtra	176.918	3197.715
B) 1) APML	67.155	946.328	5) Goa (Amona)	-1.101	-27.611
2) JSWEL	20.177	348.799	Total	173.360	3234.963
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.897	397.338
4) RPL(AMT)	31.210	434.040	b) Mumbai Drawl	27.949	466.627
5) SWPGPL	9.909	147.689	c) MSEDCL Bilateral *	67.562	1286.302
6) Other IPP	46.873	827.294	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.887	397.328
C) 1) TPCL Thermal	4.416	198.615	Include PX	0.000	0.000
2) TPCL Hydro	5.656	60.406	Standby	0.010	0.010
3) TPCL Gas	2.475	42.525	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.050	161.122	1) MSEDCL	487.903	8577.611
D) STATE			2) Mumbai Discoms	50.545	929.293
1) Thermal	333.733	5659.122	3) Other Discoms	9.866	173.588
(A1+C1+C4+(B1-B6))			TOTAL STATE	548.314	9680.492
2) Hydro (A2+C2)	15.689	301.483			
3) Gas (A3+B7+C3)	8.104	130.629			
4) Wind	3.866	127.674			
6) SOLAR	13.563	226.623			
TOTAL STATE	374.955	6445.531			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6445	6129	6448	5159
MSPGCL Hydro	482	459	798	118
MSPGCL Gas	237	229	232	239
MSPGCL Total Generation	7164	6817	7478	5516
Central Sector Receipt	9331	8712	6206	6727
WIND	134	113	85	265
CPP / IPP Thermal	8009	7088	8027	6322
CPP / IPP Gas	0	0	0	0
SOLAR	1727	2022	0	0
Exchange with Mumbai	-1508	-1562	-1187	-849
MSEDCL DEMAND MET	24401	22765	20143	17659
Load Shedding	0	0	0	0
MSEDCL DEMAND	24401	22765	20143	17659
TPCL GENERATION	610	516	839	237
AEML GENERATION	495	501	499	292
MUMBAI DEMAND	2613	2579	2525	1378
OTHER DISCOM DEMAND	456	425	466	322
STATE DEMAND MET	27470	25769	23134	19359
STATE DEMAND	27470	25769	23134	19359
Frequency (Hz)	49.95	49.91	50.01	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.38 Hz at 17:02 Hrs	49.77 Hz at 14:28 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Jan/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.38	86.28	210	130
Unit 7	0.00	0.00	0	0
Unit 8	14.67	240.68	643	527
Unit 9	13.70	136.45	605	536
Unit 10	13.00	230.02	612	440
Total	45.75	693.43		
Bhusawal				
Unit 3	3.32	33.01	165	115
Unit 4	9.19	181.12	490	280
Unit 5	8.54	136.03	435	280
Total	21.06	350.16		
Parli				
Unit 6	4.42	71.08	235	152
Unit 7	0.00	13.70	0	0
Unit 8	0.00	52.59	0	0
Total	4.42	137.37		
Chandrapur				
Unit 3	3.24	60.63	165	120
Unit 4	2.99	44.04	136	117
Unit 5	7.08	111.66	305	285
Unit 6	0.00	139.72	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.05	192.80	486	282
Unit 9	10.13	195.13	483	325
Total	33.49	743.98		
Paras				
Unit 3	4.37	88.04	192	167
Unit 4	5.02	74.30	244	186
Total	9.39	162.34		
Khaparkheda				
Unit 1	2.90	48.88	135	110
Unit 2	2.88	49.31	133	104
Unit 3	3.53	61.27	174	131
Unit 4	3.48	52.28	186	125
Unit 5	10.26	179.40	490	280
Total	23.06	391.14		
Nasik				
Unit 3	3.41	8.28	172	115
Unit 4	3.37	60.55	165	120
Unit 5	0.00	47.98	0	0
Total	6.78	116.82		
Uran				
All Units	5.63	88.10	241	227
Total	5.63	88.10		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.52	7.05	49	0
Total	0.52	7.05		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.48	72.08	485	35
Stage 4	3.06	80.56	643	0
Stage 3	1.29	32.99	240	0
Total	6.82	185.62		
Hydro				
KDPH	0.00	3.13	0	0
VTRNA	0.00	0.04	0	0
TILLARI	0.00	4.41	0	0
BHIRA T.R.	0.18	3.50	40	0
SMLHY_PTN	1.75	25.64	78	69
GHATGHAR	0.76	11.70	125	0
Total	2.69	48.41		
Wind				
Total	3.87	127.67	0	0
Total	3.87	127.67		
CPP				
APML(Mus)	67.16	946.33	0	0
JSWEL(Mus)	20.18	348.80	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.21	434.04	0	0
SWPGPL-Mus	9.91	147.69	0	0
Other(Mus)	46.87	827.29	0	0
Total	175.32	2704.15		
SOLAR				
Total	13.56	226.62	0	0
Total	13.56	226.62		
Tata				
Trombay 5	0.21	128.60	185	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.40	24.27	108	43
Trombay 7B	1.08	18.25	65	38
TATA Hydro	5.66	60.41	440	10
Trombay 8	4.20	70.01	227	132
Total	12.55	301.55		
AEMIL				
DTPS U-1&2	10.05	161.12	502	292
Total	10.05	161.12		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.94	2595.24	MSPGCL Total	159.60	2924.42
			MSPGCL Thml+Gas	149.57	2683.34	Koyna 1,2 & 4 Total	5.54	152.63
			MSPGCL Hydro	10.03	241.08	State Total	374.96	6445.53

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Jan/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5092	111	235	5438	185	6497	0	0	6770	6686	-818	17626	0	17626	1578	362	19566	50.01
2	5153	111	237	5501	230	6271	0	0	7078	7069	-885	17846	0	17846	1445	340	19631	50.03
3	5159	118	239	5516	265	6322	0	0	6868	6727	-849	17659	0	17659	1378	322	19359	50.01
4	5212	112	238	5562	249	6299	0	0	6888	6935	-809	17913	0	17913	1338	323	19574	49.99
5	5212	112	238	5562	177	6629	0	0	7131	7260	-831	18463	0	18463	1361	334	20158	49.95
6	5908	112	238	6258	227	7008	0	0	7228	7343	-983	19473	0	19473	1530	380	21383	49.94
7	6366	470	237	7073	179	7611	0	1	7082	7067	-1052	20481	0	20481	1758	398	22637	49.97
8	6387	839	236	7462	203	7980	0	147	7404	7113	-995	21503	0	21503	1954	407	23864	49.95
9	6443	1414	238	8095	158	8057	0	633	7001	7144	-1154	22493	0	22493	2238	440	25171	50.05
10	6412	1470	235	8117	124	8064	0	1292	7659	8108	-1286	23962	0	23962	2472	457	26891	50.01
11	6445	482	237	7164	134	8009	0	1727	9043	9331	-1508	24401	0	24401	2613	456	27470	49.95
12	6287	393	234	6914	129	7543	0	1975	8966	8864	-1589	23394	0	23394	2632	442	26468	49.95
13	6129	459	229	6817	113	7088	0	2022	8625	8712	-1562	22765	0	22765	2579	425	25769	49.91
14	5955	455	228	6638	75	6960	0	1929	8451	8504	-1479	22203	0	22203	2456	424	25083	49.97
15	6179	426	228	6833	70	7020	0	1699	8532	8532	-1451	22266	0	22266	2475	437	25178	49.89
16	6450	186	230	6866	84	7489	0	1273	8226	7954	-1359	21861	0	21861	2495	446	24802	49.94
17	6494	296	227	7017	98	7826	0	695	7287	7314	-1289	21210	0	21210	2499	451	24160	49.97
18	6389	387	229	7005	77	7807	0	170	6612	6499	-1182	19915	0	19915	2477	461	22853	50.09
19	6448	798	232	7478	85	8027	0	0	6171	6206	-1187	20143	0	20143	2525	466	23134	50.01
20	6472	685	234	7391	105	8005	0	0	6191	6191	-1151	20097	0	20097	2473	444	23014	50.03
21	6293	266	235	6794	144	7889	0	0	5685	5421	-1118	18696	0	18696	2339	434	21469	50.05
22	5787	116	235	6138	179	7145	0	0	6106	6190	-1032	18202	0	18202	2165	418	20785	50.06
23	5755	107	241	6103	194	6916	0	0	6319	6268	-1197	17869	0	17869	1981	415	20265	50.01
24	5516	108	239	5863	382	6862	0	0	6349	5922	-1183	17461	0	17461	1785	385	19631	49.94
MUs	143.94	10.03	5.63	159.61	3.87	175.32	0.00	13.56	173.67	173.36	-27.95	487.90	0.00	487.90	50.55	9.87	548.32	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Jan/2023

Position as on 6.30 Hrs of 19/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
TPC-G	Trombay 5	500	18/01/2023	01:10		Continued.	Annual Overhaul	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	20/01/2023
MSPGCL	Parli Unit 8	250	14/01/2023	08:51		Continued.	Lube oil system problem	18/01/2023
MSPGCL	Nasik Unit 5	210	15/01/2023	21:18		Continued.	ID Fan Problem	24/01/2023
MSPGCL	Koyna Unit 6	80	16/01/2023	11:00		Continued.	Preventive Maintenance Work	19/01/2023
MSPGCL	Chandrapur Unit 6	500	17/01/2023	10:17		Continued.	Boiler Tube Leakage	20/01/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 19/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LR Outages/Trippings							
709 LR (AKOLA CKT - 1) REACTOR @ KORADI 3	IntraState	17/01/2023	13:05			PO	For Reactor changeover Activity as per CEA guideline B- Ph reactor taken into service in place of Spare Reactor.
400 KV TBC Outages/Trippings							
TBC @ KHARGHAR	IntraState	16/01/2023	08:25			PO	400kV CB mechanism Overhauling work
400 KV MAINBAY Outages/Trippings							
MAIN BAY (418) OF PADGHE PG CKT - 2 @ KUDUS	InterState	18/01/2023	15:09	18/01/2023	19:02	HT	testing and maintenance work
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
TBC @ KORADI-1	IntraState	16/01/2023	11:14	18/01/2023	21:20	PO	For 400KV TBC CB mechanism overhauling work by M/s Royal Corporation,Mumbai.During outage 400kV Bus reactor remain out of service as bus reactor charged through TBC
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
JAIGAD - KARAD CKT - 1	IntraState	17/01/2023	23:39	18/01/2023	09:13	HT	H/T Due to Over Voltage.
LONIKAND I - KOYNA STAGE-IV	IntraState	18/01/2023	02:08	18/01/2023	09:24	HT	H/T Due to Over Voltage.
DHULE- - BABLESHWAR - I	IntraState	18/01/2023	08:46	18/01/2023	19:02	PO	cold line washing of insulator string and routine Line maintenance work
BUS REACTOR 50MVAR @ PARLI	IntraState	18/01/2023	09:53	18/01/2023	17:30	PO	Reactor Bushings and winding C & tan D measurement.
400 KV ICT Outages/Trippings							
400/220 KV 315MVA ICT - 2 @ KARAD	IntraState	16/01/2023	08:49			PO	Oil filtration work of ICT-II Y ph 105 MVA Unit having abnormal DGA reports & partial Discharge.SE,TCC Karad recommended to carry out filtration of oil for monitoring
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	16/01/2023	12:55	18/01/2023	17:10	PO	Overhauling and servicing of 29A & 29B PGI replacement of their mechanism box
400/220 KV 3X105 MVA ICT - 1 @ PADGHE	IntraState	18/01/2023	09:25	18/01/2023	18:44	PO	1) DCRM of CB 2) MTAMC work 3) A & B Bus PG isolator maint work ICT 1 in service through TBC on HV side
500 MVA 400/220 KV ICT - I @ CHANDRAPUR 2	IntraState	18/01/2023	09:38			PO	Diagnostic testing and allied maintenance work
400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	IntraState	18/01/2023	09:41	18/01/2023	19:23	PO	For ICT Painting work.
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	18/01/2023	12:02	18/01/2023	18:20	T	B-ph. NDR protection
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	19/01/2023	06:30			T	Tripped on Bucholz relay
400 KV BUSBAR Outages/Trippings							
BUSBAR PROTECTION @ BABHALESHWAR	IntraState	18/01/2023	10:57	18/01/2023	16:31	PO	ZIV BUS BAR Testing
400 KV BR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 19/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS REACTOR - 1 @ TIRORA	IntraState	18/01/2023	11:54	18/01/2023	20:10	PO	For bay equipment maintenance and testing work
220 KV MAINBAY Outages/Trippings							
MAIN BUS SECTION-2 @ VSNL	IntraState	16/01/2023	12:02			PO	Metering CT Replacement activity at 220 KV STT GIS end
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILO line.
EKLAHARE (OCR) - PADGHE	IntraState	16/01/2023	11:11	18/01/2023	00:47	HT	For load management
VSNL - STT GIS CKT - 2	IntraState	16/01/2023	12:02			PO	Metering CT Replacement activity at 220 KV STT GIS end
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	17/01/2023	10:16			PO	Erection and Stringing of 8nos of monopole, out of which of 6nos of In-line monopole loc.no.118, 118A,119A,122, 123, 123A.
EKLAHARE (GCR) - GHATGHAR	IntraState	17/01/2023	10:37			PO	Erection and Stringing of 8nos of monopole, out of which of 6nos of In-line monopole loc.no.118, 118A,119A,122, 123, 123A.
CHIKHALI-JALNA I	IntraState	18/01/2023	07:28	18/01/2023	21:06	HT	IN VIEW OF CONTROL OVERLOADING OF AKOLA ICT
CHIKHALI-JALNA II	IntraState	18/01/2023	07:30	18/01/2023	21:06	HT	IN VIEW OF CONTROL OVERLOADING OF AKOLA ICT
NEW KOYNA - NIWALI	IntraState	18/01/2023	09:19	18/01/2023	18:04	PO	Diagnostic & relay testing work.
BUS @ BARSHI	IntraState	18/01/2023	09:36	18/01/2023	16:45	PO	Outage is required for Quarterly Maintenance
GOREGAON - AAREY CKT - 1	IntraState	18/01/2023	10:02	18/01/2023	13:53	EO	Hotspot to be attended on R-Phase Jumper (Goregaon Side) at tower no. VAB 33. (Temp > 150 deg.)
ONGC PANVEL - TSS PANVEL	IntraState	18/01/2023	10:22	18/01/2023	17:44	PO	1.For stringing of new 1 Nos. conductors & 1 No. OPGW earthwire from new Monopole to Monopole of 220kV ONGC-Panvel -TSS line bet.loc no. 2&3 for Height rising work of proposed DFCCIL Railway track . Also destringing of 2 No. old existing conductors. 2. Stringing of 3 Nos. conductor from new MDN+12 Mtr tower to loc. No.3A for MRVCL line shifting work.
SADAWAGHAPUR KARAD CKT 1	IntraState	18/01/2023	10:23	18/01/2023	21:17	PO	220 kV New PT bay for Bus-I & Bus-II is taken into service since 18.03.2021 & all bay PT extension is completed on new PT bay. Also outage on 220 KV SADAWAGHAPUR KARAD CKT 1 required for opening of Bus Section to avoid phase to phase fault while opening with the help of Hot Line Unit. 220 kV Sadawaghapur Ckt-I kept OFF. Also alignment of Bus-II isolator of Sadawaghapur Ckt-I will be carried out.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 19/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	18/01/2023	10:31	18/01/2023	13:12	PO	Outage is required for CT tan delta & maintenance work
TROMBAY - KALWA	IntraState	18/01/2023	13:07			EO	For attending SF6 gas leakage in main CB of 220KV Trombay Bay by shifting the 220KV Kalwa-Trombay line on TBC.
PIRANGUT - HINJAWADI 2	IntraState	18/01/2023	16:10	18/01/2023	20:17	HT	Load management
PEDAMBE-KALAMBANI(TSS)	IntraState	18/01/2023	16:40	18/01/2023	17:55	EO	B Phase CT oil top up work
KARAD -MUDSHINGI CKT 2-TAK	IntraState	18/01/2023	17:31	18/01/2023	21:39	T	Y ph LA burst at Tembu LIS ss tap
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 200 MVA ICT 4 @ APTA	IntraState	16/01/2023	09:26			PO	Bushing Gasket Replacement work & Schedule maintenance work.
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	18/01/2023	08:27	18/01/2023	17:40	PO	For the work of anticorrosive painting with chemical to 125 MVA 220/100 KV ICT -1
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	18/01/2023	10:35			PO	"1. For attending oil leakage from Intank OLTC. (Oil is flowing through OLTC breather) 2. For Oil filtration of complete ICT (Recent DGA report shows higher Water ppm Content)"
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	18/01/2023	10:47	18/01/2023	13:44	PO	Diagnostic testing work
220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR	IntraState	18/01/2023	11:10	18/01/2023	13:55	PO	Outage is required for Quarterly Maintenance
220/132KV 100MVA ICT 2 @ JEUR	IntraState	18/01/2023	11:30	18/01/2023	16:55	PO	Outage is required for Quarterly Maintenance
220/132 KV 100 MVA ICT 2 @ BELWANDI	IntraState	18/01/2023	14:20	18/01/2023	16:44	PO	Diagnostic testing work
220/100 KV 200 MVA ICT 3 @ TROMBAY	IntraState	18/01/2023	15:15	18/01/2023	20:34	T	No abnormalities found
220 KV BUSBAR Outages/Trippings							
220 KV BUS-2 @ KARAD I-220 KV	IntraState	18/01/2023	10:20	18/01/2023	21:17	PO	Dismantling of old 03 nos of 220 KV Bus-II PTs which are now out of service due to completion of working life & oil leakages with help of Hot Line Unit, Ogalewadi by opening Bus-II jump in ICT-II bay as Bus PT are commissioned exact below the Bus by isolating bus section for 220 kV Sadawaghapur Ckt-I & II. PTs are to be dismantled by crane after isolating Bus PT.
110 KV LINE Outages/Trippings							
WAGHIVALI - MANKHURD	IntraState	18/01/2023	00:47	18/01/2023	05:36	PO	Movement of jack up barge in vicinity of line in vashi creek for new tower foundation work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage