

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Mar/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.811	2881.426	1) Gujrat	2.513	52.428
2) Hydro	7.927	205.145	2) Madhya Pradesh	4.041	90.727
3) Gas	3.416	76.222	3) Chattisgarh	5.230	73.960
Total MSPGCL	152.154	3162.793	4) Maharashtra	155.269	2985.538
B) 1) APMIL	73.425	1198.368	5) Goa (Amona)	-1.294	-29.803
2) JSWEL	23.897	456.902	Total	165.759	3172.850
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.398	565.801
4) RPL(AMT)	30.635	544.185	b) Mumbai Drawl	36.986	665.185
5) SWPGPL	9.750	182.851	c) MSEDCL Bilateral *	85.860	1531.438
6) Other IPP	34.647	726.817	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.398	565.801
C) 1) TPCL Thermal	10.237	194.519	Include PX	0.000	0.000
2) TPCL Hydro	3.324	54.335	Standby	0.000	0.000
3) TPCL Gas	3.301	50.457	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.533	196.640	1) MSEDCL	465.634	9027.342
D) STATE			2) Mumbai Discoms	63.381	1161.136
1) Thermal	332.935	6381.708	3) Other Discoms	10.165	181.899
(A1+C1+C4+(B1-B6))			TOTAL STATE	539.180	10370.377
2) Hydro (A2+C2)	11.251	259.480			
3) Gas (A3+B7+C3)	6.717	126.679			
4) Wind	9.643	196.604			
6) SOLAR	12.875	233.056			
TOTAL STATE	373.421	7197.527			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5990	5707	6447	5344
MSPGCL Hydro	221	186	615	268
MSPGCL Gas	154	161	112	212
MSPGCL Total Generation	6365	6054	7174	5824
Central Sector Receipt	8453	8186	6533	6052
WIND	96	92	663	426
CPP / IPP Thermal	7185	7139	7196	7094
CPP / IPP Gas	0	0	0	0
SOLAR	1999	1921	0	0
Exchange with Mumbai	-1906	-1867	-1589	-1247
MSEDCL DEMAND MET	21735	21071	19514	17821
Load Shedding	0	0	0	0
MSEDCL DEMAND	21735	21071	19514	17821
TPCL GENERATION	732	746	868	484
AEML GENERATION	483	465	418	371
MUMBAI DEMAND	3121	3078	2875	2102
OTHER DISCOM DEMAND	457	454	463	328
STATE DEMAND MET	25313	24603	22852	20251
STATE DEMAND	25313	24603	22852	20251
Frequency (Hz)	50.05	50.10	50.00	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.35 Hz at 13:02 Hrs	49.73 Hz at 08:35 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.50	81.46	200	170
Unit 8	0.00	183.93	0	0
Unit 9	13.60	242.41	612	502
Unit 10	13.04	127.59	591	460
Total	31.14	635.38		
Bhusawal				
Unit 3	2.99	59.54	140	120
Unit 4	7.92	173.65	490	275
Unit 5	7.70	183.96	475	270
Total	18.61	417.14		
Parli				
Unit 6	3.60	84.87	160	146
Unit 7	3.55	83.20	162	142
Unit 8	3.45	63.35	152	136
Total	10.59	231.42		
Chandrapur				
Unit 3	2.97	64.06	155	115
Unit 4	2.99	58.23	138	100
Unit 5	6.80	86.88	340	265
Unit 6	8.35	154.55	360	310
Unit 7	7.13	151.74	365	283
Unit 8	9.02	193.61	493	276
Unit 9	9.15	162.00	490	300
Total	46.39	871.07		
Paras				
Unit 3	0.84	83.93	202	0
Unit 4	5.00	94.71	232	169
Total	5.84	178.64		
Khaparkheda				
Unit 1	2.46	49.42	120	85
Unit 2	2.90	54.99	140	110
Unit 3	3.39	64.21	175	130
Unit 4	2.94	70.23	185	0
Unit 5	9.68	189.25	480	285
Total	21.36	428.10		
Nasik				
Unit 3	0.00	0.97	0	0
Unit 4	3.50	55.36	175	123
Unit 5	3.38	63.33	180	110
Total	6.87	119.66		
Uran				
All Units	3.42	76.22	212	109
Total	3.42	76.22		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.08	2.21	23	0
Total	0.08	2.21		
Koyna				
Stage 1-2	2.04	49.70	255	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	50.79	0	0
Stage 3	0.31	21.53	80	0
Total	2.35	122.03		
Hydro				
KDPH	0.86	15.10	36	36
VTRNA	1.15	19.41	61	0
TILLARI	0.46	4.52	58	0
BHIRA T.R.	0.18	2.45	40	0
SMLHY_PTN	2.85	39.43	127	110
GHATGHAR	0.00	0.00	0	0
Total	5.50	80.91		
Wind				
Total	9.64	196.60	0	0
Total	9.64	196.60		
CPP				
APML(Mus)	73.42	1198.37	0	0
JSWEL(Mus)	23.90	456.90	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.64	544.18	0	0
SWPGPL-Mus	9.75	182.85	0	0
Dhariwal	5.86	108.13	264	235
IEPL	4.73	90.46	224	174
Other(Mus)	24.06	528.23	0	0
Total	172.35	3109.12		
SOLAR				
Total	12.88	233.06	0	0
Total	12.88	233.06		
Tata				
Trombay 5	6.80	128.88	369	262
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.98	29.80	108	43
Trombay 7B	1.32	20.66	65	39
TATA Hydro	3.32	54.34	300	4
Trombay 8	3.44	65.64	204	131
Total	16.86	299.31		
AEML				
DTPS U-1&2	9.53	196.64	486	315
Total	9.53	196.64		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.81	2881.43	MSPGCL Total	152.15	3162.79
			MSPGCL Thml+Gas	144.23	2957.65	Koyna 1,2 & 4 Total	2.04	100.50
			MSPGCL Hydro	7.93	205.14	State Total	373.42	7197.53

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5654	263	209	6126	416	7213	0	0	6559	6023	-1531	17861	0	17861	2553	386	20800	49.99
2	5487	259	209	5955	311	7189	0	0	6467	6299	-1417	17996	0	17996	2361	341	20698	49.97
3	5682	262	209	6153	399	7203	0	0	6410	5766	-1343	17847	0	17847	2207	331	20385	49.99
4	5344	268	212	5824	426	7094	0	0	6366	6052	-1247	17821	0	17821	2102	328	20251	49.99
5	5406	352	210	5968	331	7228	0	0	6131	6009	-1197	17994	0	17994	2071	345	20410	49.94
6	5893	495	211	6599	408	7201	0	0	6212	6220	-1152	18908	0	18908	2125	368	21401	50.00
7	6517	435	153	7105	423	7303	0	13	6408	6425	-1015	19864	0	19864	2181	390	22435	49.98
8	6735	450	113	7298	358	7222	0	282	6356	6364	-1064	20035	0	20035	2280	425	22740	50.01
9	6268	623	110	7001	245	7185	0	750	6867	7224	-1354	20612	0	20612	2504	439	23555	49.96
10	6243	486	110	6839	187	7205	0	1334	7330	7238	-1610	20748	0	20748	2792	445	23985	49.99
11	6500	254	122	6876	125	7200	0	1839	7981	7578	-1744	21416	0	21416	3038	458	24912	50.19
12	5990	221	154	6365	96	7185	0	1999	8580	8453	-1906	21735	0	21735	3121	457	25313	50.05
13	5707	186	161	6054	92	7139	0	1921	8608	8186	-1867	21071	0	21071	3078	454	24603	50.10
14	5362	189	112	5663	99	7115	0	1755	8388	8597	-1845	20934	0	20934	2928	450	24312	50.06
15	5561	195	112	5868	276	7133	0	1308	8788	8690	-2030	20792	0	20792	2966	453	24211	49.96
16	6117	199	118	6434	538	7158	0	974	8697	8099	-1977	20774	0	20774	2986	452	24212	49.92
17	5819	262	112	6193	602	7073	0	504	7834	7307	-1784	19439	0	19439	2958	456	22853	49.97
18	5617	312	114	6043	712	7088	0	192	7137	7191	-1774	18985	0	18985	2881	467	22333	49.96
19	5787	495	112	6394	641	7243	0	4	6463	6845	-1635	19029	0	19029	2845	463	22337	49.99
20	6447	615	112	7174	663	7196	0	0	6622	6533	-1589	19514	0	19514	2875	463	22852	50.00
21	5888	297	111	6296	801	7146	0	0	6543	6390	-1510	18666	0	18666	2790	457	21913	49.93
22	5455	283	109	5847	713	7190	0	0	6180	6117	-1364	18049	0	18049	2656	454	21159	49.93
23	5590	262	111	5963	425	7308	0	0	6135	6113	-1484	17869	0	17869	2567	456	20892	50.02
24	5742	264	110	6116	356	7137	0	0	6430	6040	-1547	17674	0	17674	2516	428	20618	50.04
MUs	140.81	7.93	3.42	152.15	9.64	172.35	0.00	12.88	169.49	165.76	-36.99	465.63	0.00	465.63	63.38	10.16	539.18	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Mar/2023

Position as on 6.30 Hrs of 19/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	SWPGPL U-2	135	19/03/2023	00:17	19/03/2023	14:25	TURBINE CONTROL VALVE RECTIFICATION WORK	
IPP	JSW (J) U1	300	19/03/2023	17:29		Continued.	Zero Schedule	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Nasik Unit 3	210	10/03/2023	15:22		Continued.	Axial shift high	23/03/2023
MSPGCL	Koradi Unit 8	660	15/03/2023	02:06		Continued.	Boiler Tube Leakage	21/03/2023
MSPGCL	Paras Unit 3	250	18/03/2023	04:35	19/03/2023	14:10	Tripped on EHTC Fault	20/03/2023
MSPGCL	Uran Unit 6	108	18/03/2023	06:30	18/03/2023	10:25	Generator protection	
MSPGCL	Khaparkheda Unit 4	210	18/03/2023	11:13	18/03/2023	14:28	SUSPECTED MALFUNCTION OF PROCESSOR CARDS	
MSPGCL	Uran Unit 6	108	18/03/2023	12:44		Continued.	ZERO SCHEDULE.	
MSPGCL	Chandrapur Unit 5	500	19/03/2023	11:15		Continued.	Drum Door Leakage Attending work	21/03/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 19/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 1	IntraState	18/03/2023	16:10	18/03/2023	19:31	PO	Testing of Metering CT
400 KV LINE Outages/Trippings							
SOLAPUR PG - ALKUD	InterState	19/03/2023	18:39		Continued.	PO	Quarterly maintenance & diagnostic testing work.
MAIN BUS - 1 @ TALANDGE	IntraState	17/03/2023	13:33	18/03/2023	00:37	PO	1. AM work 2. Bus CVT replacement work 3. PID faulty strings replacement work.
LONIKAND I - CHAKAN	IntraState	18/03/2023	11:00	18/03/2023	18:45	PO	For Overhauling of Bus A 89A & BUS B 89 B Rph, Yph, Bph PG Isolators. Cold washing/chemical cleaning of insulator strings Diagnostic Testing, Relay Testing
BABHALESHWAR - RPL(NSK) CKT - 2	IntraState	18/03/2023	14:45	18/03/2023	17:49	T	Distance Protection
DABHOL - NEW KOYNA CKT - 2	IntraState	19/03/2023	02:28	19/03/2023	18:29	T	Tripped on distance protection in Zone 3
NAGOTHANE - DABHOL CKT - 1	IntraState	19/03/2023	02:29	19/03/2023	07:51	T	Tripped on distance protection from Dhabhol end
KORADI II - IEPL	IntraState	19/03/2023	08:37	19/03/2023	20:40	PO	Routine Line Maintainance work
BABHALESHWAR - PADGHE CKT - 2	IntraState	19/03/2023	11:45	19/03/2023	18:57	PO	TO ATTEND DEFECTS IDENTIFIED IN MONKEY PATROLLING UNDER PADGHE AND JUNNER S-DN:-1. To FIX REPAIR SLEEVE AT BROKEN CONDUCTOR STRANDS.2. REPLACEMENT OF BROKEN AND FLASHOVER DISC INSULATORS STRINGS.3. CHEMICAL AND COLD WASHING OF DUST/BIRD SHIT POLLUTED INSULATOR STRING.4. FIX OF BIRD GUARD AT INSULATORS STRING AT BIRD SHIT LOCATIONS.5. FIXING OF MISSING/DAMAGED HARDWARE.6. TIGHTENING LOOSE OF NUT BOLTS OF CONDUCTOR JUMPER AND EARTHWIRE HARDWARE. works at 400kv Padghe 1) Bay maint work 2) diagnostic testing work 3) MTAMC work 4) Replacement of LA under LES scheme. 5) Replacement of 29C bus PG isolator under LES scheme.
LONIKAND 2 - KARJAT CKT - 2	IntraState	19/03/2023	15:49	19/03/2023	16:19	T	Tripped on Distance Protection.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	18/03/2023	08:12	18/03/2023	13:15	PO	For SFRA testing and Relay testing and bay maint work
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	18/03/2023	08:12	18/03/2023	13:15	PO	SFRA Testing and Relay testing work.
400/6.6 KV 60 MVA STATION TRANSFORMER-1 @ DHARIWAL (STU)	IntraState	18/03/2023	09:04	18/03/2023	21:40	PO	CTU & STU Bus connection
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	18/03/2023	10:37	18/03/2023	18:13	PO	1. MOG replacement work. 2. Diagnostic Testing Work. 3. CTR Sensors & control cable replacement work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 19/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315MVA ICT - 3 @ KHADKA	IntraState	18/03/2023	14:13	18/03/2023	18:14	EO	E/O required on 400/220 KV 315 MVA ICT-3 HV for attending the red hot on R Phase CT jumper Clamp by replacing damaged bolts if required
400 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ DHARIWAL	IntraState	18/03/2023	10:28			PO	STU CTU bus connection as per CERC order
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ SONKAR	IntraState	19/03/2023	14:37	19/03/2023	19:02	EO	1) Outage is required on 220KV Bus-2 (220 KV bus coupler,220 kv sonkhar �Trombay line,50 mva T/f no 3) at 220KV Sonkhar S/stn. 2) 220KV Trombay-Sonkhar Outage is already proposed by Trombay S/stn. 3) During the outage following work is proposed: i)Servicing & overhauling of 220 kV main bus isolators ii)Replacement of moving blade,jaw & isolator gearbox of 29A main bus isolator of 220kV Sonkhar-Trombay line iii)Tightening of nutbolts & RM work of 220kV main bus-2 iv)Painting of bus PT-2
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
CTRLS - NET MAGIC GIS	IntraState	07/03/2023	12:43			T	Distance Protection.
MIRAJ - ICHALKARANJI	IntraState	17/03/2023	16:57	18/03/2023	01:33	PO	Erection of Loc. No. 27A (MAN + 9) at crossing point of 132 KV Jaysingpur-Kurundwad link line near rever crossing.
APTA - TALOJA	IntraState	18/03/2023	06:15	18/03/2023	09:55	PO	Bay maint's work & RM work at Apta end.
MALHARPETH SATARA MIDC	IntraState	18/03/2023	09:01	18/03/2023	19:09	PO	Cold washing of insulator
ADLABS - PEDAMBE	IntraState	18/03/2023	11:08	18/03/2023	14:47	EO	Replacement of flashover double suspension polymer insulator at Loc no. 466 (Middle phase) by new longrod porcelian insulator
TOPWORTH - Vile - bhagad	IntraState	19/03/2023	08:55	19/03/2023	14:50	PO	Cold washing of insulator string, Outage tree cutting work and other line maintenance work.
BHAVEGHAR - ROMA	IntraState	19/03/2023	10:57	19/03/2023	17:50	PO	Shifting of existing line to ERS towers between loc no113to116 for the Work of Shifting / Height raising of various EHV (220/100KV) transmission lines infringing in Mumbai - Ahmadabad High Speed Rail Corporation Ltd.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	19/03/2023	11:37	19/03/2023	23:10	HT	For load management

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 19/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
THEUR- MAGAR PATTI CITY	IntraState	19/03/2023	13:27	19/03/2023	15:31	EO	Replacement of flashover SSN string at L. N -28, R Phase
SONKHAR - TROMBAY	IntraState	19/03/2023	14:12	19/03/2023	19:31	EO	For: 1) Testing of Coupling Capacitor 2) Faulty LMU replacement & Commissioning work 3) Reconnecting of jumper of Coupling Capacitor
KANDALGAON - KOYNA (POPHALI)	IntraState	19/03/2023	15:33	19/03/2023	20:45	PO	For cold washing of line insulators.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220 / 110 / 33kV 250MVA ICT 3 @ BORIVALI (TATA)	IntraState	18/03/2023	09:51	18/03/2023	14:33	PO	Attending OLTC oil Leakage.
220/132 KV 200MVA ICT 2	IntraState	18/03/2023	12:16	18/03/2023	16:43	PO	Red-Hot Attending & Oil Leakage Attending Work of ICT 2
220 / 110 / 33kV 250MVA ICT 9 @ DHARAVI	IntraState	19/03/2023	09:15		Continued.	EO	for reconnecting jumpers at ICT side between bushing and cable sealing end.
220 KV BUSBAR Outages/Trippings							
GIS BUS - 1 @ SALSETTE	IntraState	17/03/2023	09:33			PO	KS # 5 New Bay connection to GIS BUS.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	18/03/2023	05:22	18/03/2023	06:44	T	Tripped on distance protection
110 KV BUSBAR Outages/Trippings							
ZONE 2 (BUS SECTION 3+4+5+6) @ BHIVPURI	IntraState	19/03/2023	06:35	19/03/2023	17:10	PO	R/M

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage