

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Apr/2015 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	122.619	2186.572	1) Gujrat	-3.583	-20.205
2) Hydro	28.625	410.660	2) Madhya Pradesh	15.204	290.512
3) Gas	6.686	93.940	3) Chattisgarh	5.160	96.430
Total MSPGCL	157.930	2691.172	4) Maharashtra Net	89.135	1572.012
B) 1) APMIL	51.530	823.190	5) Goa	-7.657	-126.282
2) JSWEL	21.556	396.191	6) TAPS 1&2 Injection	3.530	64.712
3) VIPL	11.380	203.800	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	5.410	123.379	8) Pench (MS)	0.104	1.074
5) WPCL	2.370	47.442	9) Pench (Excess)	-0.104	-1.074
6) Other IPP	7.445	148.982	Total	101.685	1876.105
C) 1) TPCL Thermal	16.870	319.670	a) Mumbai Schedule	27.261	406.925
2) TPCL Hydro	4.809	69.942	b) Mumbai Drawl	31.839	438.348
3) TPCL Gas	2.383	41.898	c) MSEDCL Bilateral *	20.733	397.141
4) R-INFRA Thermal	6.230	197.991	Include PX	0.066	-25.556
D) STATE			d) Mumbai Bilateral *	26.028	401.476
1) Thermal	245.410	4447.217	Include PX	1.443	7.081
(A1+C1+C4+(B1-B6))			Include Standby	1.233	5.449
2) Hydro	33.434	480.602	H) ENERGY CATERED (MUs)		
3) Gas	9.069	135.838	1) MSEDCL	338.449	6059.065
4) Wind	9.471	163.510	2) Mumbai Discoms	62.129	1067.839
6) SOLAR	1.511	22.568	TOTAL STATE	400.578	7126.904
TOTAL STATE	298.895	5249.735			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5345	5178	4783	5200
MSPGCL Hydro	1763	1450	1576	581
MSPGCL Gas	278	275	276	283
MSPGCL Total Generation	7386	6903	6635	6064
Central Sector Receipt	4144	4567	4644	3658
WIND	440	554	338	313
CPP / IPP	4435	4142	4257	3913
SOLAR	184	142	0	0
Exchange with Mumbai	-1529	-1575	-1422	-965
MSEDCL DEMAND MET	15060	14733	14452	12983
Load Shedding	59	42	42	45
MSEDCL DEMAND	15119	14775	14494	13028
TPCL GENERATION	1136	1201	1164	801
R-INFRA GENERATION	253	260	260	261
MUMBAI DEMAND	2918	3061	2871	2027
STATE DEMAND MET	17978	17794	17323	15010
STATE DEMAND	18037	17836	17365	15055
Frequency (Hz)	50.00	49.89	49.97	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.21 Hz at 07.03 Hrs	49.76 Hz at 18.41 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 18/Apr/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	3.39	40.83	155	125
Unit 6	0.00	0.00	0	0
Unit 7	3.82	69.50	170	150
Total	7.21	110.32		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	4.24	73.32	190	165
Unit 4	10.78	180.56	510	375
Unit 5	7.68	163.20	350	300
Total	22.70	417.07		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	25.46	0	0
Unit 5	3.49	61.96	157	129
Unit 6	0.00	66.86	0	0
Unit 7	5.28	83.04	241	180
Total	8.77	237.33		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	3.16	57.54	135	127
Unit 3	4.44	82.02	200	163
Unit 4	4.34	74.80	194	162
Unit 5	9.67	153.52	425	372
Unit 6	9.50	172.50	431	355
Unit 7	9.86	169.72	445	374
Total	40.97	710.10		
Paras				
Unit 3	4.99	72.10	220	192
Unit 4	5.07	55.41	227	190
Total	10.06	127.50		
Khaparkheda				
Unit 1	4.24	75.86	190	165
Unit 2	0.00	0.44	0	0
Unit 3	0.00	11.38	0	0
Unit 4	4.46	58.52	196	176
Unit 5	10.74	200.49	500	409
Total	19.44	346.69		
Nasik				
Unit 3	4.58	83.16	200	175
Unit 4	4.46	80.89	193	177
Unit 5	4.44	73.51	193	171
Total	13.48	237.55		
Uran				
All Units	6.69	93.94	283	274
Total	6.69	93.94		
PENCH (MS)				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.10	1.07	25	0
Total	0.10	1.07		
Koyna				
Stage 1-2	4.57	103.88	410	35
Stage 4	16.06	164.66	1040	200
Stage 3	4.78	58.17	258	90
Total	25.41	326.72		
Hydro				
KDPH	0.43	10.28	18	17
VTRNA	0.94	18.87	61	0
TILLARI	0.37	6.42	63	0
BHTGR/VEER	0.05	0.98	2	2
BHIRA T.R.	0.26	3.78	80	0
RNGR+BHTSA	0.24	4.40	11	10
BHANDARDRA	0.00	7.28	0	0
ELDARY	0.00	0.72	0	0
SMLHY_PTN	0.90	17.40	44	34
GHATGHAR	0.02	13.81	20	0
Total	3.22	83.94		
Wind				
Total	9.47	163.51	0	0
Total	9.47	163.51		
CPP				
APML(Mus)	51.53	823.19	0	0
JSWEL(Mus)	21.56	396.19	0	0
VIPL(Mus)	11.38	203.80	0	0
RPLAMT(Mus)	5.41	123.38	0	0
WPCL(Mus)	2.37	47.44	0	0
Other(Mus)	7.44	148.98	0	0
Total	99.69	1742.98		
SOLAR				
Total	1.51	22.57	0	0
Total	1.51	22.57		
Tata				
Trombay 5	10.91	195.00	474	425
Trombay 6	0.00	19.93	0	0
Trombay 7A	1.32	23.30	60	49
Trombay 7B	1.06	18.60	49	40
Trombay 8	5.96	104.74	250	247
TATA Hydro	4.81	69.94	409	0
Total	24.06	431.51		
R-INFRA				
1-2	6.23	197.99	261	253
Total	6.23	197.99		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	122.62	2186.57
MSPGCL Thml+Gas	129.30	2280.51

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	28.62	410.66
MSPGCL Total	157.93	2691.17

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	20.63	268.55
State Total	298.90	5249.74

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 18/Apr/2015

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	5237	1399	281	6917	183	3912	0	4445	4207	-1424	13795	61	13856	2517	16373	49.96
2	5247	1163	280	6690	202	3871	0	4324	3974	-1266	13471	45	13516	2290	15806	49.97
3	5215	832	282	6329	195	3973	0	4238	4280	-1107	13670	45	13715	2136	15851	50.02
4	5200	581	283	6064	313	3913	0	4164	3658	-965	12983	45	13028	2027	15055	50.01
5	5221	565	281	6067	414	3989	0	4068	3751	-907	13314	45	13359	1970	15329	50.01
6	5229	810	282	6321	435	4096	0	4054	3855	-946	13761	48	13809	2005	15814	50.01
7	5261	1178	281	6720	294	4120	8	4083	3947	-937	14152	51	14203	2003	16206	50.09
8	5252	1270	280	6802	213	4147	37	4184	3811	-978	14032	51	14083	2061	16144	50.08
9	5311	1260	279	6850	223	4371	92	4327	4177	-1118	14595	51	14646	2274	16920	50.04
10	5325	1532	278	7135	275	4372	155	4419	4086	-1398	14625	51	14676	2653	17329	50.00
11	5345	1763	278	7386	440	4435	184	4540	4144	-1529	15060	59	15119	2918	18037	50.00
12	5332	1276	278	6886	555	4478	201	4664	4178	-1600	14698	175	14873	3061	17934	49.99
13	5141	1236	278	6655	612	4322	209	4670	4441	-1597	14642	71	14713	3085	17798	49.97
14	4912	1260	278	6450	705	4004	195	4602	4496	-1492	14358	46	14404	2983	17387	49.96
15	5009	1442	277	6728	627	3982	177	4620	4761	-1567	14708	38	14746	3033	17779	49.92
16	5178	1450	275	6903	554	4142	142	4629	4567	-1575	14733	42	14775	3036	17811	49.89
17	5230	1372	275	6877	593	4281	82	4565	4153	-1571	14415	46	14461	2979	17440	49.91
18	5029	716	274	6019	408	4206	28	4293	4273	-1524	13410	46	13456	2849	16305	49.99
19	4874	595	276	5745	375	4260	1	4274	4003	-1462	12922	45	12967	2754	15721	49.98
20	4783	1576	276	6635	338	4257	0	4562	4644	-1422	14452	42	14494	2846	17340	49.97
21	4813	1579	278	6670	316	4282	0	4598	4491	-1494	14265	40	14305	2846	17151	49.96
22	4808	1413	278	6499	328	4129	0	4652	4512	-1389	14079	40	14119	2597	16716	50.00
23	4834	1116	278	6228	449	4072	0	4571	4597	-1278	14068	40	14108	2617	16725	49.92
24	4833	1241	280	6354	424	4077	0	4541	4680	-1293	14242	40	14282	2591	16873	49.97
MUs	122.62	28.63	6.69	157.93	9.47	99.69	1.51	106.09	101.69	-31.84	338.45	1.26	339.71	62.13	401.84	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Apr/2015

Position as on 6.30 Hrs of 19/Apr/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Parli Unit 3	210	13/02/2013	23:50		Continued.	Water Shortage	
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refuelling Work. (60 Days)	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Renovation and Modification work	
MSPGCL	Khaparkheda Unit 2	210	01/04/2015	03.16		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	WPCL U-2	135	18/02/2014	00.02		Continued.	Ash conveying Problem	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	PA Fan Vibration Problem	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
CPP	WPCL U-4	135	18/03/2015	02.34		Continued.	Withdrawn	
IPP	RPL(AMT) U-1	270	21/03/2015	23.28		Continued.	Turbine vibration high.	
MSPGCL	Chandrapur Unit-8	500	29/03/2015	18.26		Continued.	Withdrawn	
MSPGCL	Koradi Unit-8	660	30/03/2015	20.22		Continued.	BLR Tripped.	
MSPGCL	Uran Unit 6	108	01/04/2015	16.35		Continued.	Gas shortage	
IPP	RPL(AMT) U-4	270	03/04/2015	11.42		Continued.	Boiler feed Pump problem.	
IPP	RPL(AMT) U-5	270	03/04/2015	14.22		Continued.	turbine Shaft Vibration high.	
MSPGCL	Uran Unit A0	120	04/04/2015	14.38		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 3	210	04/04/2015	22.52		Continued.	Gland Steam Temp. High.	
IPP	RPL(AMT) U-3	270	05/04/2015	22.01		Continued.	Governor AVR Problem.	
TPC-G	Trombay 6	500	06/04/2015	16.27		Continued.	Economic shut down.	
IPP	Adani U-2	660	09/04/2015	15.50		Continued.	Boiler feed Pump Problem.	
IPP	WPCL U-3	135	11/04/2015	23.56	19/04/2015	11.27	ID Fan Vibration Problem.	
MSPGCL	Parli Unit 4	210	13/04/2015	11.27		Continued.	Turbine vibration high.	
IPP	Adani U-5	660	14/04/2015	16.10	18/04/2015	04.08	PA Fan problem	
MSPGCL	Parli Unit 6	250	15/04/2015	18.00		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Apr/2015

Position as on 6.30 Hrs of 19/Apr/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
RINFRA-G	REL Unit 1	250	16/04/2015	14.55	19/04/2015	07.34	Boiler Tube Leakage	
MSPGCL	Uran Unit 7	108	17/04/2015	00.07		Continued.	Gas turbine problem	
CPP	WPCL U-1	135	19/04/2015	14.10		Continued.	Turbine problem	
MSPGCL	Koradi Unit 7	210	19/04/2015	15.01		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Apr/2015

Statement-VII

Position as on 6.30 Hrs of 19/Apr/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Wardha(PG)-Aurangabad(PG) I	InterState	15/04/2015	09.25		Continued.	HT	To Control 400kv Line Loading.
Wardha PG -Aurangabad PG III	IntraState	19/04/2015	12.55	19/04/2015	19.37	HT	Over Voltage
400 KV LINE Outages/Trippings							
Akola II - RPL(Rattanindia) Ckt I	InterState	07/04/2015	00.27		Continued.	T	Over Current Protection
Parli (PG) - Talegaon(PG)- I	InterState	16/04/2015	12.10	19/04/2015	00.14	PO	Tower leg bending work
Parli (PG) - Talegaon(PG)- II	InterState	16/04/2015	12.30	19/04/2015	00.26	PO	Tower leg bending work
Wardha (Pg) Warora I	InterState	17/04/2015	09.23	18/04/2015	01.21	PO	Crossing work Of 765kv Raipur-Wardha D/C By PGCIL.
Wardha (PG)-Warora II	InterState	17/04/2015	09.33	18/04/2015	01.30	PO	Crossing work Of 765kv Raipur-Wardha D/C By PGCIL.
Kolhapur Mapusa I	InterState	17/04/2015	17.11	18/04/2015	08.46	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	18/04/2015	04.47	19/04/2015	06.52	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	18/04/2015	18.17	19/04/2015	06.59	HT	Over Voltage
Kolhapur Mapusa II	InterState	18/04/2015	22.03	19/04/2015	07.19	HT	Over Voltage
Wardha (Pg) Warora I	InterState	19/04/2015	13.20	19/04/2015	20.59	T	Distance Protection
Kolhapur Solapur(PG) I	InterState	19/04/2015	17.08		Continued.	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	19/04/2015	18.21		Continued.	HT	Over Voltage
Babhaleshwar-Taptitanda ckt-I	IntraState	08/04/2015	22.45		Continued.	HT	HT For Controlling 400KV BABLESHWER - PADGHA
karad -kolhapur-II	IntraState	17/04/2015	16.16	18/04/2015	08.40	HT	Over Voltage
Karad-Jaigad - I	IntraState	17/04/2015	16.38	18/04/2015	08.43	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	17/04/2015	18.04	18/04/2015	07.27	HT	Over Voltage
karad -kolhapur-I	IntraState	18/04/2015	17.04	19/04/2015	06.33	HT	Over Voltage
Karad-Jaigad - I	IntraState	18/04/2015	17.05	19/04/2015	06.40	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	18/04/2015	20.24	19/04/2015	07.16	HT	Over Voltage
Dhule - Bableshwar - li	IntraState	19/04/2015	09.25		Continued.	PO	Replacement work
Padghe - Kalwa- I	IntraState	19/04/2015	09.35	19/04/2015	12.08	PO	Taken on TBC
karad -kolhapur-II	IntraState	19/04/2015	16.30		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	19/04/2015	16.33		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	19/04/2015	18.03		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	19/04/2015	18.07		Continued.	HT	Over Voltage
Chandrapur-Parali III	IntraState	19/04/2015	20.20		Continued.	PO	Bus isolator problem
Bableshevar- Aurangabad (Waluj)	IntraState	19/04/2015	22.21		Continued.	EO	CT oil leakage
400 KV ICT Outages/Trippings							
400/220kv, 500 MVA ICT-II @Deepnagar	IntraState	17/04/2015	18.16	18/04/2015	17.58	T	Tripped On PRV
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	19/04/2015	20.00	19/04/2015	23.35	PO	Annual Maintenance Work
220 KV LINE Outages/Trippings							
Nasik Navsari II	InterState	16/04/2015	17.02	19/04/2015	09.55	HT	Nashik end to control bus section loading
Talandage - Chikodi	InterState	18/04/2015	05.58		Continued.	HT	Construction Work of 765kv Kudgi-kolhapur D/C Line by PGCIL.
Mudshingi - Chikodi	InterState	18/04/2015	05.58		Continued.	HT	Construction Work of 765kv Kudgi-kolhapur D/C Line by PGCIL.
Nasik Navsari I	InterState	19/04/2015	10.09	19/04/2015	19.05	PO	Insulator washing work
TBC @ Parli-II	IntraState	07/01/2015	15.48		Continued.	PO	Shifting of control panel
Sahara-Urse	IntraState	03/03/2015	11.06		Continued.	PO	Tower erection work (90Days)

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Apr/2015

Statement-VII

Position as on 6.30 Hrs of 19/Apr/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Chandrapur Gcr - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Chandrapur Gcr - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Apta - Taloja	IntraState	17/04/2015	08.05		Continued.	PO	CKT on TBC Breaker O/H Work.
Dhule - Malegaon	IntraState	18/04/2015	06.15	18/04/2015	19.36	HT	Construction Work Erection of Tower.
Chalisgaon-Malegaon	IntraState	18/04/2015	06.16	18/04/2015	20.52	HT	Construction Work Erection of Tower.
Bableshwar- Ranjangaon	IntraState	18/04/2015	07.40	18/04/2015	20.29	HT	Over Voltage
Dahanu Boisar Line	IntraState	18/04/2015	10.26	19/04/2015	07.53	HT	control line loading
Chalisgaon -Babhaleshwar	IntraState	18/04/2015	11.40	18/04/2015	20.55	HT	Over Voltage
Pedambe-Nerle	IntraState	18/04/2015	15.05	18/04/2015	18.23	PO	Bus Section II outage for Attending R Ph Conductor.
Bableshwar -Bhenda	IntraState	18/04/2015	15.44	18/04/2015	17.37	PO	Trip Trial taking of Breaker.
Pedambe-Pophali	IntraState	18/04/2015	15.50	18/04/2015	18.17	PO	Bus Section II outage for Attending R Ph Conductor.
Adlabs - Pedambe	IntraState	18/04/2015	15.53	18/04/2015	18.19	PO	Bus Section II outage for Attending R Ph Conductor.
Pedhambe - Oni	IntraState	18/04/2015	16.00	18/04/2015	18.35	PO	Bus Section II outage for Attending R Ph Conductor.
Vankuswade - Kdph	IntraState	18/04/2015	16.40	18/04/2015	17.10	T	Distance Protection
Bableshwar- Alephata	IntraState	18/04/2015	23.18	19/04/2015	17.21	HT	To control ICT loading
Mahape - TfipI	IntraState	19/04/2015	09.38	19/04/2015	13.10	PO	To attend Hot Spot
Talandge-Mudshingi Ckt-I	IntraState	19/04/2015	11.27	19/04/2015	18.40	PO	Line Maintenance work
Miraj - Mhaishal	IntraState	19/04/2015	14.47	19/04/2015	16.55	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Monkey Fault
220/132Kv 200MVA ICT-II @ Mudshingi	IntraState	16/04/2015	12.33	18/04/2015	19.25	PO	Replacement work
220/100 kV 200 MVA ICT II @Padghe	IntraState	17/04/2015	09.55	18/04/2015	00.33	PO	Attending Oil Leakage
220/132 Kv 200mva Ptr No 1 @Theur	IntraState	18/04/2015	10.25	18/04/2015	18.45	PO	Half yearly maintenance work
220/132Kv 200MVA ICT-II @ Mudshingi	IntraState	19/04/2015	22.45		Continued.	PO	Attending PNRV
110 KV LINE Outages/Trippings							
Tata Borivli MSETCL Borivli 1	IntraState	18/04/2015	09.03	18/04/2015	18.41	PO	Premonsoon Check.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage