

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Apr/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	58.528	1047.574	1) Gujrat	10.079	188.433
2) Hydro	26.394	336.588	2) Madhya Pradesh	14.094	281.062
3) Gas	6.755	125.584	3) Chattisgarh	6.670	139.050
Total MSPGCL	91.677	1509.746	4) Maharashtra	124.665	2226.114
B) 1) APLM	71.576	1110.101	5) Goa (Amona)	0.000	0.000
2) JSWEL	17.783	269.618	Total	155.508	2834.659
3) VIPL	0.000	0.000	a) Mumbai Schedule	19.428	308.795
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	18.744	255.744
5) WPCL	5.467	99.079	c) MSEDCL Bilateral *	53.368	919.228
6) Other IPP	7.757	147.654	Include PX	33.389	585.714
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	19.428	308.795
C) 1) TPCL Thermal	8.549	220.913	Include PX	3.258	114.461
2) TPCL Hydro	6.336	70.707	Standby	0.000	0.000
3) TPCL Gas	4.158	58.101	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.906	194.395	1) MSEDCL	352.486	6048.651
D) STATE			2) Mumbai Discoms	47.693	799.859
1) Thermal	179.566	3089.334	TOTAL STATE	400.179	6848.510
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	32.730	407.295			
3) Gas (A3+B7+C3)	10.913	183.685			
4) Wind	14.551	202.387			
6) SOLAR	6.911	131.151			
TOTAL STATE	244.671	4013.852			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	2481	2474	2333	2754
MSPGCL Hydro	812	938	1056	1094
MSPGCL Gas	277	268	285	276
MSPGCL Total Generation	3570	3680	3674	4124
Central Sector Receipt	7550	7905	5161	5756
WIND	288	374	1012	540
CPP / IPP Thermal	4268	4236	4293	4375
CPP / IPP Gas	0	0	0	0
SOLAR	959	861	0	0
Exchange with Mumbai	-756	-801	-815	-1099
MSEDCL DEMAND MET	15879	16255	13325	13696
Load Shedding	0	0	0	0
MSEDCL DEMAND	15879	16255	13325	13696
TPCL GENERATION	804	799	832	811
AEML GENERATION	373	374	376	374
MUMBAI DEMAND	1933	1974	2023	2284
STATE DEMAND MET	17812	18229	15348	15980
STATE DEMAND	17812	18229	15348	15980
Frequency (Hz)	50.02	50.01	50.01	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.24 Hz at 18.32 Hrs	49.77 Hz at 12.11 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 18/Apr/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	112.89	0	0
Unit 9	0.00	112.84	0	0
Unit 10	0.00	108.90	0	0
Total	0.00	334.63		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	13.91	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.97	0.97	289	0
Unit 7	0.00	0.00	0	0
Unit 8	11.05	140.03	488	360
Unit 9	11.12	166.81	485	360
Total	23.14	321.72		
Paras				
Unit 3	5.38	95.29	250	175
Unit 4	5.87	83.84	258	206
Total	11.25	179.13		
Khaparkheda				
Unit 1	4.03	23.34	175	155
Unit 2	4.38	28.67	190	160
Unit 3	0.13	25.80	134	0
Unit 4	4.46	25.74	190	160
Unit 5	11.14	108.55	495	360
Total	24.14	212.09		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.76	125.58	300	265
Total	6.76	125.58		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.18	2.35	54	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.18	2.35		
Koyna				
Stage 1-2	5.96	98.90	465	45
Stage 4	13.02	129.61	1005	0
Stage 3	4.28	49.58	260	0
Total	23.26	278.10		
Hydro				
KDPH	0.89	15.33	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.37	7.61	55	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.38	3.17	80	0
RNGR+BHTSA	0.31	5.30	14	13
BHANDARDRA	0.46	9.68	31	12
ELDARY	0.36	4.85	15	14
SMLHY_PTN	0.37	12.56	25	12
GHATGHAR	0.00	0.00	0	0
Total	3.13	58.49		
Wind				
Total	14.55	202.39	0	0
Total	14.55	202.39		
CPP				
APML(Mus)	71.58	1110.10	0	0
JSWEL(Mus)	17.78	269.62	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	5.47	99.08	0	0
Other(Mus)	7.76	147.65	0	0
Total	102.58	1626.45		
SOLAR				
Total	6.91	131.15	0	0
Total	6.91	131.15		
Tata				
Trombay 5	8.55	166.09	465	309
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.77	34.91	117	114
Trombay 7B	1.39	23.19	67	44
Trombay 8	0.00	54.82	0	0
TATA Hydro	6.34	70.71	412	151
Total	19.04	349.72		
AEML				
DTPS U-1&2	9.91	194.40	503	372
Total	9.91	194.40		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	58.53	1047.57	MSPGCL Total	91.68	1509.75
			MSPGCL Thml+Gas	65.28	1173.16	Koyna 1,2 & 4 Total	18.98	228.51
			MSPGCL Hydro	26.39	336.59	State Total	244.67	4013.85

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 18/Apr/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2478	1526	287	4291	815	4479	0	0	6047	6205	-917	14873	0	14873	2267	17140	50.01
2	2359	1690	289	4338	696	4487	0	0	5868	6014	-825	14710	0	14710	2162	16872	50.01
3	2354	1750	288	4392	709	4394	0	0	5785	5638	-738	14395	0	14395	2052	16447	50.00
4	2329	1625	288	4242	677	4342	0	0	5698	5809	-680	14390	0	14390	1974	16364	50.02
5	2325	1611	278	4214	736	4329	0	0	5910	6103	-628	14754	0	14754	1921	16675	50.02
6	2400	1706	300	4406	642	4373	0	0	6679	6772	-612	15581	0	15581	1907	17488	50.00
7	2395	1759	289	4443	549	4349	0	25	7232	7185	-548	16003	0	16003	1828	17831	49.97
8	2387	1585	279	4251	499	4338	0	177	7041	7099	-603	15761	0	15761	1741	17502	50.00
9	2413	1477	287	4177	379	4311	0	456	6687	6548	-731	15140	0	15140	1778	16918	50.00
10	2469	1208	283	3960	385	4280	0	686	6815	6748	-769	15290	0	15290	1861	17151	49.96
11	2456	687	269	3412	368	4242	0	836	7159	7098	-774	15182	0	15182	1906	17088	50.03
12	2481	812	277	3570	288	4268	0	959	7456	7550	-756	15879	0	15879	1933	17812	50.02
13	2474	812	265	3551	248	4187	0	956	7826	7637	-755	15824	0	15824	1934	17758	49.93
14	2469	849	278	3596	306	4170	0	931	7742	7717	-788	15932	0	15932	1944	17876	49.96
15	2474	938	268	3680	374	4236	0	861	7761	7905	-801	16255	0	16255	1974	18229	50.01
16	2474	909	278	3661	1035	4022	0	537	7756	7458	-771	15942	0	15942	1959	17901	50.01
17	2421	473	270	3164	601	3879	0	322	7114	7067	-693	14340	0	14340	1887	16227	50.01
18	2213	324	291	2828	864	4241	0	129	6454	6079	-667	13474	0	13474	1832	15306	50.05
19	1961	257	273	2491	950	4230	0	36	5514	5724	-742	12689	0	12689	1842	14531	50.05
20	2333	1056	285	3674	1012	4293	0	0	4965	5161	-815	13325	0	13325	2023	15348	50.01
21	2606	565	285	3456	883	4302	0	0	4695	4689	-866	12464	0	12464	2126	14590	49.99
22	2724	671	285	3680	553	4293	0	0	4970	5400	-955	12971	0	12971	2192	15163	49.98
23	2754	1094	276	4124	540	4375	0	0	5578	5756	-1099	13696	0	13696	2284	15980	50.01
24	2779	1010	287	4076	442	4163	0	0	6052	6146	-1211	13616	0	13616	2366	15982	50.03
MUs	58.53	26.39	6.75	91.68	14.55	102.58	0.00	6.91	154.80	155.51	-18.74	352.49	0.00	352.49	47.69	400.18	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Apr/2020

Position as on 6.30 Hrs of 19/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Parli Unit 8	250	23/03/2020	18.00		Continued.	Zero Schedule.	
MSPGCL	Chandrapur Unit 6	500	23/03/2020	21.59	18/04/2020	19.45	Clinker Removal Work (Given Zero Schedule On 29/3/2020 At 12hrs By MSEDCL).	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
IPP	JSW (J) U2	300	26/03/2020	00.13		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Apr/2020

Position as on 6.30 Hrs of 19/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 7	500	28/03/2020	23.56		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	10/04/2020	20.30		Continued.	Zero Schedule By MSEDCL	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 3	210	18/04/2020	01.00		Continued.	Boiler Tube Leakage	
MSPGCL	Koyana Unit 10	80	18/04/2020	04.15		Continued.	Governor Problem.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 19/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	30/03/2020	17.32		Continued.	HT	Over Voltage
Chandrapur Bhadravati III	InterState	19/04/2020	02.14	19/04/2020	05.37	T	Distance Protection
Chandrapur Bhadravati IV	InterState	19/04/2020	02.14	19/04/2020	06.22	T	Distance Protection
Karad - Jaigad - II	IntraState	23/03/2020	18.12		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	24/03/2020	20.20		Continued.	HT	Over Voltage
New Koyna - Dabhol-I	IntraState	25/03/2020	18.01		Continued.	T	Over Voltage
Kalwa - Talegaon(PG)	IntraState	28/03/2020	16.47		Continued.	HT	Over Voltage
Padghe - Kalwa-II	IntraState	06/04/2020	00.21		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/04/2020	23.58		Continued.	EO	To attend Hot Spot
Babhaleshtar - Padghe-I	IntraState	13/04/2020	17.21		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	17/04/2020	17.22		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	17/04/2020	18.08	18/04/2020	09.33	HT	Over Voltage
karad -kolhapur-I	IntraState	18/04/2020	17.44		Continued.	HT	Over Voltage
Warora -IEPL	IntraState	18/04/2020	18.02		Continued.	T	Over Voltage
Chandrapur-II - Nanded ckt I	IntraState	19/04/2020	02.17	19/04/2020	06.46	T	Distance Protection
Chandrapur - Parli	IntraState	19/04/2020	02.20		Continued.	T	Distance Protection
Chandrapur-II - Nanded ckt II	IntraState	19/04/2020	02.21		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	22/03/2020	10.13		Continued.	HT	Hand tripped from LV end to control Over Voltage.
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	25/03/2020	13.59		Continued.	EO	CT Tan Delta High.
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	25/03/2020	16.32		Continued.	HT	Outage availed for maint. work and ICT out LV side.
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	25/03/2020	17.57		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220/33kv 315mva Ict3 @Lonikand	IntraState	25/03/2020	22.01		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	28/03/2020	18.07		Continued.	HT	Over Voltage
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	17/04/2020	13.19		Continued.	PO	Attending Hot Spot
400/220 Kv 500 MVA ICT 3 @KOLHAPUR-III (TALANDGE)	IntraState	18/04/2020	16.50	18/04/2020	18.47	T	NDR Protection.
400/220 Kv 500 MVA ICT II @Jejuri	IntraState	19/04/2020	04.18		Continued.	T	Low Oil Level & Buchholz Relay.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Lonand-Baramati	IntraState	16/02/2020	09.37		Continued.	PO	Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand & Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 19/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Sawantwadi-Bidri	IntraState	17/04/2020	17.48	18/04/2020	08.37	HT	Over Voltage
Boisar Versova Line	IntraState	18/04/2020	07.15	18/04/2020	08.58	PO	Replacement of Abnormal Hot Insulators on Tower No.SS 267.
Aurangabad (Waluj)-Bhenda	IntraState	18/04/2020	09.56	18/04/2020	11.37	EO	Tree Cutting Between Location No. 71-72.
New Koyna - Niwali	IntraState	18/04/2020	10.03	18/04/2020	17.22	PO	Replacement of Insulator String At Loc. 24B R Phase (Niwali side).
Dahanu Ghodbunder Line 2	IntraState	18/04/2020	10.32	18/04/2020	12.12	PO	Replacement of Abnormal Hot Insulators On Tower No LS 204.
Shivajinagar-Gangapur	IntraState	18/04/2020	11.48		Continued.	HT	B Ph Current Showing Zero, Broken Conductor Indication Appear.
Vita - Pandharpur li Ckt-I	IntraState	18/04/2020	12.31	18/04/2020	17.25	T	LA Shorted.
Mahape - TIFIL	IntraState	18/04/2020	14.16	18/04/2020	16.03	PO	LA Replacement & Maintenance Work.
Sawantwadi-Bidri	IntraState	18/04/2020	16.10		Continued.	HT	Over Voltage
Walchandnagar-Bhigwan	IntraState	18/04/2020	17.43	18/04/2020	19.10	T	Over Current Protection
Trombay - Kalwa	IntraState	19/04/2020	05.05	19/04/2020	05.16	T	Distance Protection
220 KV ICT Outages/Trippings							
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS
220/100 Kv 200 MVA ICT IV @Padghe	IntraState	18/04/2020	08.56		Continued.	PO	Diagnostic Testing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage