

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/May/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	165.429	3049.106	1) Gujrat	-0.648	10.499
2) Hydro	32.187	321.569	2) Madhya Pradesh	5.662	129.698
3) Gas	8.228	125.977	3) Chattisgarh	3.660	76.280
Total MSPGCL	205.844	3496.652	4) Maharashtra	187.363	3337.546
B) 1) APLM	66.675	1154.956	5) Goa (Amona)	-2.031	-35.297
2) JSWEL	26.652	495.524	Total	194.006	3518.726
3) VIPL	0.000	0.000	a) Mumbai Schedule	43.099	766.668
4) RPL(AMT)	25.608	548.951	b) Mumbai Drawl	44.985	793.924
5) SWPGPL	12.295	220.289	c) MSEDCL Bilateral *	94.195	1460.431
6) Other IPP	16.728	309.343	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	43.099	766.668
C) 1) TPCL Thermal	14.346	224.335	Include PX	0.000	0.000
2) TPCL Hydro	5.720	89.702	Standby	0.000	0.000
3) TPCL Gas	4.142	69.614	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.721	175.203	1) MSEDCL	514.536	9298.606
D) STATE			2) Mumbai Discoms	80.914	1352.772
1) Thermal	339.454	6177.707	3) Other Discoms	11.795	206.288
(A1+C1+C4+(B1-B6))			TOTAL STATE	607.245	10857.666
2) Hydro (A2+C2)	37.907	411.271			
3) Gas (A3+B7+C3)	12.370	195.591			
4) Wind	6.915	251.859			
6) SOLAR	16.593	302.518			
TOTAL STATE	413.239	7338.946			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6394	6779	7151	7091
MSPGCL Hydro	427	1793	1508	344
MSPGCL Gas	277	376	379	290
MSPGCL Total Generation	7098	8948	9038	7725
Central Sector Receipt	9303	8587	8210	7791
WIND	158	312	571	161
CPP / IPP Thermal	5112	5546	6804	6523
CPP / IPP Gas	0	0	0	0
SOLAR	2239	1388	0	631
Exchange with Mumbai	-2241	-2161	-1752	-1691
MSEDCL DEMAND MET	21138	22102	22342	20638
Load Shedding	0	0	0	0
MSEDCL DEMAND	21138	22102	22342	20638
TPCL GENERATION	1029	1273	1253	612
AEML GENERATION	501	500	473	417
MUMBAI DEMAND	3771	3934	3478	2720
OTHER DISCOM DEMAND	531	518	529	502
STATE DEMAND MET	25440	26554	26349	23860
STATE DEMAND	25440	26554	26349	23860
Frequency (Hz)	49.91	49.95	50.02	50.05

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.146 Hz at 13:00 Hrs	49.84 Hz at 12:06 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.49	61.18	195	150
Unit 8	1.00	119.32	440	0
Unit 9	13.30	244.81	585	510
Unit 10	13.33	251.48	574	536
Total	32.12	676.78		
Bhusawal				
Unit 3	3.64	56.15	170	125
Unit 4	10.68	155.44	470	300
Unit 5	10.82	166.66	490	300
Total	25.15	378.26		
Parli				
Unit 6	4.73	80.91	242	144
Unit 7	4.28	77.49	220	144
Unit 8	4.78	75.11	242	146
Total	13.79	233.52		
Chandrapur				
Unit 3	3.60	64.39	163	130
Unit 4	3.69	66.16	165	125
Unit 5	9.02	156.74	420	280
Unit 6	0.00	118.62	0	0
Unit 7	9.57	165.37	447	294
Unit 8	10.22	185.39	455	298
Unit 9	10.73	198.45	492	313
Total	46.83	955.13		
Paras				
Unit 3	5.43	79.72	242	161
Unit 4	5.63	99.36	255	166
Total	11.06	179.08		
Khaparkheda				
Unit 1	3.09	63.34	170	80
Unit 2	4.03	74.79	194	126
Unit 3	3.90	70.08	175	137
Unit 4	4.17	68.78	193	152
Unit 5	11.31	169.02	497	415
Total	26.50	446.02		
Nasik				
Unit 3	3.40	52.03	151	128
Unit 4	3.17	65.54	135	124
Unit 5	3.40	62.75	161	117
Total	9.97	180.33		
Uran				
All Units	8.23	125.98	471	276
Total	8.23	125.98		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	5.19	0	0
Total	0.00	5.19		
Koyna				
Stage 1-2	5.62	75.47	550	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	17.66	133.32	1014	0
Stage 3	4.85	46.48	320	0
Total	28.13	255.27		
Hydro				
KDPH	0.64	11.75	27	26
VTRNA	0.80	14.81	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.90	35.37	82	75
GHATGHAR	0.72	4.38	250	0
Total	4.06	66.30		
Wind				
Total	6.92	251.86	0	0
Total	6.92	251.86		
CPP				
APML(Mus)	66.68	1154.96	0	0
JSWEL(Mus)	26.65	495.52	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.61	548.95	0	0
SWPGPL-Mus	12.30	220.29	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.74	93.31	267	180
Other(Mus)	6.64	128.51	0	0
JPL	4.35	87.53	270	133
Total	147.96	2729.06		
SOLAR				
Total	16.59	302.52	0	0
Total	16.59	302.52		
Tata				
Trombay 5	9.56	155.11	462	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	43.06	108	108
Trombay 7B	1.55	26.56	65	64
TATA Hydro	5.72	89.70	421	37
Trombay 8	4.78	69.23	230	130
Total	24.21	383.65		
AEML				
DTPS U-1&2	11.72	175.20	502	417
Total	11.72	175.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	165.43	3049.11	MSPGCL Total	205.84	3496.65
			MSPGCL Thml+Gas	173.66	3175.08	Koyna 1,2 & 4 Total	23.28	208.79
			MSPGCL Hydro	32.19	321.57	State Total	413.24	7338.95

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 18/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7157	2291	467	9915	264	6804	0	0	6864	7077	-1759	21869	0	0	21869	3492	432	25793	50.00
2	7180	1696	471	9347	140	6780	0	0	7466	7280	-1547	21570	0	0	21570	3213	430	25213	50.02
3	7172	1947	299	9418	134	6699	0	0	7234	6893	-1573	21176	0	0	21176	2981	395	24552	50.00
4	7088	1797	288	9173	156	6682	0	0	7490	7223	-1684	21169	0	0	21169	2811	381	24361	50.01
5	7132	1551	289	8972	152	6718	0	0	7504	7274	-1655	21050	0	0	21050	2741	411	24202	50.01
6	7171	1633	288	9092	151	6622	0	0	7774	7480	-1651	21267	0	0	21267	2741	427	24435	50.03
7	7229	1428	289	8946	169	6605	0	136	7939	7512	-1633	21255	0	0	21255	2710	480	24445	50.04
8	7091	344	290	7725	161	6523	0	631	8267	7791	-1691	20638	0	0	20638	2720	502	23860	50.05
9	6639	148	287	7074	136	5663	0	1231	8686	8480	-1803	20278	0	0	20278	2914	503	23695	49.99
10	6731	153	284	7168	114	5264	0	1728	9084	8964	-2019	20717	0	0	20717	3242	502	24461	49.98
11	6551	152	280	6983	141	5147	0	2064	9562	9408	-2158	21052	0	0	21052	3575	533	25160	49.98
12	6394	427	277	7098	158	5112	0	2239	9716	9303	-2241	21138	0	0	21138	3771	531	25440	49.91
13	5860	1122	276	7258	218	5094	0	2153	9713	8787	-2105	20884	0	0	20884	3837	521	25242	49.95
14	5555	1283	366	7204	291	4966	0	2000	9407	9159	-2118	21007	0	0	21007	3769	495	25271	50.00
15	6577	1407	374	8358	320	5205	0	1719	9269	8895	-2156	21829	0	25	21829	3871	512	26212	49.95
16	6779	1793	376	8948	312	5546	0	1388	8844	8587	-2161	22102	0	29	22102	3934	518	26554	49.95
17	7118	1549	375	9042	376	6243	0	882	8633	8041	-2108	21953	0	5	21953	3816	523	26292	50.04
18	6719	1185	375	8279	421	6181	0	379	8714	8246	-2037	20921	0	2	20921	3658	548	25127	50.01
19	6861	1334	374	8569	469	6263	0	43	8386	8112	-2002	20908	0	0	20908	3579	546	25033	50.02
20	7042	2007	377	9426	551	6716	0	0	8063	7731	-1898	21993	0	0	21993	3618	533	26144	50.00
21	7151	1508	379	9038	571	6804	0	0	8278	8210	-1752	22342	0	0	22342	3478	529	26349	50.02
22	7212	1670	379	9261	508	6786	0	0	7810	7727	-1725	22022	0	0	22022	3451	535	26008	49.99
23	7459	2088	382	9929	533	6769	0	0	7790	7793	-1752	22752	0	0	22752	3485	520	26757	50.03
24	7561	1674	386	9621	469	6766	0	0	8352	8033	-1757	22643	0	0	22643	3507	489	26639	50.04
MUs	165.43	32.19	8.23	205.84	6.91	147.96	0.00	16.59	200.84	194.01	-44.98	514.54	0.00	0.06	514.54	80.91	11.80	607.25	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

132 kV BBLR to Rahuri line overload, DLS carried out due to emergency outage on 400kV Shikrapur-PGCIL line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/May/2024

Position as on 6.30 Hrs of 19/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Koradi Unit 8	660	14/05/2024	22:17	18/05/2024	20:07	SUSPECTED BTL	19/05/2024
MSPGCL	Chandrapur Unit 6	500	17/05/2024	16:44		Continued.	Boiler Tube Leakage	20/05/2024
MSPGCL	Paras Unit 4	250	19/05/2024	23:30		Continued.	Generator Mechanical protection operated.	
Total Capacity MSPGCL		1530						
IPP								
IPP	RPL(AMT) U-5	270	17/05/2024	05:55	19/05/2024	19:32	Cooling Water Line Problem	19/05/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2120						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	18/05/2024	01:58		Continued.	No Schedule from MSEDCL	
MSPGCL	Uran Unit 5	108	18/05/2024	02:15	18/05/2024	12:55	No Schedule from MSEDCL	
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
Total Capacity MSPGCL		324						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		324						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/May/2024

Statement-VII

Position as on 6.30 Hrs of 19/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
33KV ANJUR- PADGHE ELECTRODE LINE @ PADGHE HVDC	IntraState	17/05/2024	23:20	18/05/2024	04:56	HT	For emergency line maintenance work.
400 KV LINE Outages/Trippings							
PUNE(GIS) - TALEGAON(PG) CKT - 3	InterState	18/05/2024	12:17	18/05/2024	18:24	HT	Emergency outage by powergrid
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
STATION TRANSFORMER - 1 @ NANDGAON PETH	IntraState	18/05/2024	06:20			PO	Following work will be carried out during Station Transformer-1 outage Period :- 1. ST#1- OLTC maintenance work(Before & After DCRM testing, oil Filtration & Diverter Switch Maintenance) 2. Complete ST#1 transformer testing. 3. FDS & SFRA test of transformer. 4. Testing of LA, MCT & MCVT.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	18/05/2024	15:25	18/05/2024	18:06	HT	H/T for load management
PARLI - KARJAT CKT - 2	IntraState	18/05/2024	19:26	19/05/2024	01:10	PO	Hardware tightening and cold line Cleaning
PARLI - KARJAT CKT - 2	IntraState	19/05/2024	15:35	19/05/2024	16:16	T	Tripped on distance protection
PARLI - KARJAT CKT - 1	IntraState	19/05/2024	21:09		Continued.	PO	Hardware tightening and cold line Cleaning
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	17/05/2024	07:28			PO	Replacement of R Ph & Y Ph Unit Neutral Bushing along with oil filtration
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
AAREY - AEML SAKI CKT - 2	IntraState	08/05/2024	21:48			T	Tripped on Yph to ground fault
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	13/05/2024	13:27	18/05/2024	13:18	PO	To make the LILO point connection at Loc. 1 (Loc. 19 of 220kV Nashik - Navsari Line) of new 220kV CPRI Line & substation
PADGHE - PAL DOMBIVALI	IntraState	16/05/2024	10:21	18/05/2024	19:01	PO	Permission for shifting of 220kV Padghe-Pal line on TBC for pole overhauling work of own CB of 220kV Padghe- Pal Line

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/May/2024

Statement-VII

Position as on 6.30 Hrs of 19/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR II - BOISAR (PG) CKT - 1	IntraState	18/05/2024	05:20	18/05/2024	10:02	PO	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
WAGHIVALI - DHARAVI 8	IntraState	18/05/2024	06:39	18/05/2024	09:21	PO	MANDALE PROJECT WORK IN VICINITY
VSNL- KHADKI	IntraState	18/05/2024	08:21	18/05/2024	19:48	PO	For Stringing between New Monopole Loc No. 30 B to 31
CHANDRAPUR GCR - SICOM I	IntraState	18/05/2024	08:56	18/05/2024	17:45	PO	Distance protection relay retrofitting work and maintenance work.
GHATODI-NANDED	IntraState	18/05/2024	09:40	18/05/2024	17:22	PO	LMSD Work.
PARAS-BALAPUR I	IntraState	18/05/2024	09:52	18/05/2024	13:18	EO	Dislocated pilot suspension clamp fixing work.
PARAS-BALAPUR III	IntraState	18/05/2024	10:12	18/05/2024	13:20	EO	Dislocated pilot suspension clamp fixing work.
MAIN BUS - 1 @ SOUTH SOLAPUR	IntraState	18/05/2024	10:40	18/05/2024	13:15	PO	Outage is required for Erection of main Bus isolators for main bus-I & main bus-II for 250MW Maruti Wind power project
CHALISGAON -BABHALESHWAR	IntraState	18/05/2024	11:17	18/05/2024	16:43	PO	Emergency outage at B Shwer end.
MAIN BUS - 2 @ SOUTH SOLAPUR	IntraState	18/05/2024	14:00	18/05/2024	16:15	PO	Outage is required for Erection of main Bus isolators for main bus-I & main bus-II for 250MW Maruti Wind power project
NERLE - PEDAMBE	IntraState	18/05/2024	17:41	18/05/2024	19:10	T	Tripped on distance protection
PEDAMBE-KALAMBANI(TSS)	IntraState	18/05/2024	20:11	18/05/2024	21:40	T	Tripped on distance protection
ADLABS - PEDAMBE	IntraState	18/05/2024	20:21	18/05/2024	20:45	T	tripped on distance protection
TROMBAY MSETCL TIE - 1	IntraState	18/05/2024	23:37	19/05/2024	06:58	PO	L.A. replacement
KANDALGAON - PIRANGUT	IntraState	19/05/2024	05:13	19/05/2024	15:05	PO	For double jumpering work & attending hot spot at various locations.
KALWA - MULUND 1	IntraState	19/05/2024	07:15	19/05/2024	15:51	PO	Rph CT replacement Work due to high tan-d value.
KALWA - SALESETTE CKT - 5	IntraState	19/05/2024	08:35	19/05/2024	09:17	PO	REMOVAL OF BIRD NEST
VANKUSWADE - KDPH	IntraState	19/05/2024	09:55	19/05/2024	14:30	PO	Replacement of flashover string at loc no.50 R ph & replacement of damaged jump at loc no.53 Y ph
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	19/05/2024	15:40	19/05/2024	19:19	T	Tripped on distance protection
TILLARI - AMONA LINE	IntraState	19/05/2024	16:30	19/05/2024	18:05	T	Tripped on distance protection
HALKARNI - TILARI LINE	IntraState	19/05/2024	19:25	19/05/2024	20:33	T	Zone 2 tripping
TILLARI - AMONA LINE	IntraState	19/05/2024	19:25	19/05/2024	21:35	T	zone 2 trip.
PEDAMBE-KALAMBANI(TSS)	IntraState	19/05/2024	20:05	19/05/2024	21:24	T	Tripped on distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 23kv 250 MVA ICT 3 @ SALSETTE	IntraState	18/05/2024	00:34	18/05/2024	05:45	PO	PM CHECK
220/132/11 KV 200 MVA ICT 2 @ AMRAVATI	IntraState	18/05/2024	08:02	18/05/2024	16:43	PO	Diagnostic testing work
200 MVA 220/132 KV ICT - 1 @ VIRODA	IntraState	18/05/2024	10:25	18/05/2024	19:19	PO	Pre-monsoon maintenance work.
220/33KV 50MVA PTR 1@ PETH	IntraState	18/05/2024	14:08	18/05/2024	18:13	PO	Pre Monsoon Maintenance Work
220/132 KV 100 MVA ICT II	IntraState	18/05/2024	16:43	18/05/2024	18:14	PO	Pre-monsoon maintenance & Diagnostic testing work.
220/110/33KV 250 MVA ICT-4 @ MAHALAXMI GIS (T)	IntraState	19/05/2024	10:02	19/05/2024	18:48	PO	R/M AND TESTING

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/May/2024

Statement-VII

Position as on 6.30 Hrs of 19/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
KHOPOLI - BHOKARPADA	IntraState	17/05/2024	22:27	18/05/2024	04:23	PO	RECONNECTION OF CT
110 KV BUSBAR Outages/Trippings							
ZONE 1 (BUS SECTION 1+2+3) @ BHIVPURI	IntraState	19/05/2024	06:00	19/05/2024	19:18	PO	R/M AND TESTING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage