

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Jun/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	157.910	2961.112	1) Gujrat	-4.963	-103.751
2) Hydro	14.755	227.968	2) Madhya Pradesh	5.191	77.558
3) Gas	3.446	78.812	3) Chattisgarh	2.310	43.640
Total MSPGCL	176.111	3267.892	4) Maharashtra	183.519	3055.082
B) 1) APLM	69.295	1288.001	5) Goa (Amona)	-0.934	-17.279
2) JSWEL	15.010	311.456	Total	185.123	3055.250
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.244	612.036
4) RPL(AMT)	25.016	453.664	b) Mumbai Drawl	38.424	674.793
5) SWPGPL	9.343	152.469	c) MSEDCL Bilateral *	82.431	1280.806
6) Other IPP	11.530	252.110	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.244	611.828
C) 1) TPCL Thermal	13.335	273.153	Include PX	0.000	0.000
2) TPCL Hydro	3.376	85.563	Standby	0.000	0.209
3) TPCL Gas	0.322	29.093	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.140	194.070	1) MSEDCL	475.099	8573.625
D) STATE			2) Mumbai Discoms	66.597	1256.673
1) Thermal	312.579	5886.035	3) Other Discoms	9.133	169.369
(A1+C1+C4+(B1-B6))			TOTAL STATE	550.829	9999.667
2) Hydro (A2+C2)	18.131	313.531			
3) Gas (A3+B7+C3)	3.768	107.905			
4) Wind	22.927	465.942			
6) SOLAR	8.301	171.003			
TOTAL STATE	365.706	6944.416			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6921	6696	6278	6958
MSPGCL Hydro	1136	939	442	333
MSPGCL Gas	148	138	153	154
MSPGCL Total Generation	8205	7773	6873	7445
Central Sector Receipt	8483	8925	7174	6895
WIND	177	257	1803	843
CPP / IPP Thermal	5456	5299	5536	5578
CPP / IPP Gas	0	0	0	0
SOLAR	1154	1051	0	0
Exchange with Mumbai	-1940	-1918	-1531	-1254
MSEDCL DEMAND MET	21128	20995	19445	19204
Load Shedding	0	0	0	0
MSEDCL DEMAND	21128	20995	19445	19204
TPCL GENERATION	747	756	914	588
AEML GENERATION	446	483	462	489
MUMBAI DEMAND	3133	3157	2907	2331
OTHER DISCOM DEMAND	407	392	410	303
STATE DEMAND MET	24668	24544	22762	21838
STATE DEMAND	24668	24544	22762	21838
Frequency (Hz)	49.85	49.96	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 13.05 Hrs	49.74 Hz at 11.15 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Jun/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.12	76.30	180	145
Unit 7	0.00	0.00	0	0
Unit 8	12.80	222.88	560	468
Unit 9	11.98	206.66	525	462
Unit 10	12.90	213.30	560	470
Total	41.78	719.13		
Bhusawal				
Unit 3	2.75	59.74	130	105
Unit 4	10.78	184.96	470	430
Unit 5	10.62	166.44	460	415
Total	24.14	411.14		
Parli				
Unit 6	4.06	87.03	250	0
Unit 7	4.40	78.63	227	122
Unit 8	3.18	56.35	140	124
Total	11.64	222.02		
Chandrapur				
Unit 3	3.18	52.74	146	115
Unit 4	0.02	51.00	15	0
Unit 5	7.21	151.64	365	0
Unit 6	4.75	160.48	380	0
Unit 7	0.00	113.41	0	0
Unit 8	10.77	193.43	474	425
Unit 9	10.69	143.58	462	422
Total	36.61	866.28		
Paras				
Unit 3	5.30	87.90	239	168
Unit 4	5.11	83.21	223	176
Total	10.40	171.11		
Khaparkheda				
Unit 1	3.44	57.46	145	135
Unit 2	3.22	62.58	150	120
Unit 3	4.24	74.49	182	158
Unit 4	0.00	13.16	0	0
Unit 5	10.89	193.98	470	430
Total	21.80	401.66		
Nasik				
Unit 3	3.84	68.54	180	137
Unit 4	3.78	53.53	179	135
Unit 5	3.90	47.70	180	122
Total	11.53	169.77		
Uran				
All Units	3.45	78.81	154	138
Total	3.45	78.81		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	4.66	0	0
Total	0.00	4.66		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.03	52.78	495	40
Stage 4	4.26	42.72	505	0
Stage 3	2.16	23.56	160	80
Total	8.45	119.06		
Hydro				
KDPH	0.06	8.00	19	0
VTRNA	0.00	0.00	0	0
TILLARI	0.45	3.70	58	0
BHIRA T.R.	0.18	4.79	73	0
SMLHY_PTN	5.26	85.62	230	211
GHATGHAR	0.36	2.13	125	0
Total	6.30	104.25		
Wind				
Total	22.93	465.94	0	0
Total	22.93	465.94		
CPP				
APML(Mus)	69.30	1288.00	0	0
JSWEL(Mus)	15.01	311.46	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.02	453.66	0	0
SWPGPL-Mus	9.34	152.47	0	0
Other(Mus)	11.53	252.11	0	0
Total	130.19	2457.70		
SOLAR				
Total	8.30	171.00	0	0
Total	8.30	171.00		
Tata				
Trombay 5	8.70	177.40	448	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.18	17.72	45	0
Trombay 7B	0.14	11.38	37	0
TATA Hydro	3.38	85.56	326	35
Trombay 8	4.63	95.75	228	132
Total	17.03	387.81		
AEML				
DTPS U-1&2	11.14	194.07	496	382
Total	11.14	194.07		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	157.91	2961.11	MSPGCL Total	176.11	3267.89
			MSPGCL Thml+Gas	161.36	3039.92	Koyna 1,2 & 4 Total	6.29	95.50
			MSPGCL Hydro	14.76	227.97	State Total	365.71	6944.42

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Jun/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6950	419	144	7513	1119	6009	0	0	6755	6884	-1465	19716	0	19716	2816	344	22876	50.03
2	6882	381	143	7406	1001	5743	0	0	6785	7011	-1409	19428	0	19428	2605	324	22357	49.99
3	6945	374	144	7463	915	5723	0	0	6844	6788	-1299	19284	0	19284	2440	306	22030	49.97
4	6958	333	154	7445	843	5578	0	0	6804	6895	-1254	19204	0	19204	2331	303	21838	49.99
5	6970	362	143	7475	681	5627	0	0	6958	7103	-1286	19297	0	19297	2265	303	21865	49.93
6	6969	572	145	7686	539	5374	0	3	7907	8125	-1320	20079	0	20079	2284	328	22691	50.01
7	6944	552	154	7650	369	5386	0	89	8244	8424	-1347	20191	0	20191	2266	380	22837	50.00
8	7010	432	144	7586	265	5625	0	296	7976	7944	-1521	19795	0	19795	2345	400	22540	50.02
9	6945	743	142	7830	284	5360	0	583	7846	7896	-1664	19887	0	19887	2571	402	22860	49.99
10	6740	1028	140	7908	243	4992	0	926	8160	8088	-1666	20094	0	20094	2870	397	23361	49.96
11	6809	960	141	7910	174	5056	0	1054	8528	8501	-1827	20465	0	20465	3068	403	23936	49.93
12	6921	1136	148	8205	177	5456	0	1154	8500	8483	-1940	21128	0	21128	3133	407	24668	49.85
13	6696	939	138	7773	257	5299	0	1051	9002	8925	-1918	20995	0	20995	3157	392	24544	49.96
14	6397	897	139	7433	356	5376	0	1022	8851	8617	-1791	20613	0	20613	3039	400	24052	50.09
15	6169	791	138	7098	689	5645	0	802	9016	8882	-1812	20897	0	20897	3058	407	24362	50.00
16	6025	559	141	6725	1050	5293	0	671	9665	9132	-1859	20619	0	20619	3096	393	24108	50.06
17	6119	395	140	6654	1506	5102	0	401	8654	8379	-1816	19816	0	19816	3047	410	23273	49.95
18	5918	1129	141	7188	1770	4538	0	205	7212	7402	-1726	18970	0	18970	2972	407	22349	50.00
19	6175	654	142	6971	2089	5344	0	44	6810	6642	-1489	19163	0	19163	2903	438	22504	50.02
20	6136	521	142	6799	1950	5197	0	0	7396	7273	-1514	19281	0	19281	2902	424	22607	49.91
21	6278	442	153	6873	1803	5536	0	0	7346	7174	-1531	19445	0	19445	2907	410	22762	50.03
22	6272	366	144	6782	1815	5757	0	0	7201	6630	-1656	18933	0	18933	2833	395	22161	50.03
23	6323	406	143	6872	1577	5503	0	0	7417	7104	-1717	18957	0	18957	2810	382	22148	49.95
24	6359	364	143	6866	1455	5675	0	0	7002	6821	-1597	18844	0	18844	2879	377	22100	49.91
MUs	157.91	14.76	3.45	176.11	22.93	130.19	0.00	8.30	186.88	185.12	-38.42	475.10	0.00	475.10	66.60	9.13	550.83	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 18/Jun/2022

Position as on 6.30 Hrs of 19/Jun/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkhedha Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna STG-IV Unit-2	250	13/06/2022	00:00		Continued.	Commissioning and installation of New TSLG governor	30/06/2022
IPP	RPL(AMT) U-5	270	15/06/2022	00:00		Continued.	Annual Overhaul	25/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 5	108	11/06/2022	14:29		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	13/06/2022	00:25		Continued.	Gas shortage	
MSPGCL	Uran Unit 6	108	13/06/2022	00:25		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Turbine Gland steam temperature not maintained	22/06/2022
MSPGCL	Chandrapur Unit 4	210	18/06/2022	00:05		Continued.	Ash handling problem.	20/06/2022
TPC-G	Trombay 7B	60	18/06/2022	03:55		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	18/06/2022	04:12		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 6	500	18/06/2022	12:53		Continued.	Boiler Tube Leakage	
IPP	RPL(AMT) U-3	270	18/06/2022	16:50	18/06/2022	18:24	turbine overspeed relay operated	
MSPGCL	Parli Unit 6	250	18/06/2022	18:37		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (409) OF FUTURE BAY AND ICT - 3 @ JEJURI	IntraState	17/06/2022	12:58	18/06/2022	21:29	PO	For stringing work from gantry at 400 kV jehuri s/s to L.N.1 of LILO on 400 kV Lonikand-Karad line for 400 kV jehuri s/s.
400 KV TBC Outages/Trippings							
BUS COUPLER @ CHAKAN	IntraState	18/06/2022	13:03	18/06/2022	16:05	EO	For attending Hotspots at Y phase 89 A PG Isolators IPS Tube L clamp of 400 KV Bus coupler bay.
400 KV MAINBAY Outages/Trippings							
MAIN BAY (410) OF FUTURE BAY @ JEJURI	IntraState	17/06/2022	13:00	18/06/2022	21:28	PO	For stringing work from gantry at 400 kV jehuri s/s to L.N.1 of LILO on 400 kV Lonikand-Karad line for 400 kV jehuri s/s.
400 KV LINE Outages/Trippings							
DHULE - KHANDWA CKT - 2	InterState	18/06/2022	02:15	18/06/2022	09:52	T	DP
DHULE - KHANDWA CKT - 1	InterState	18/06/2022	15:31	18/06/2022	20:22	HT	Emergency outage at Khandwa end
KORADI - BHILAI	InterState	18/06/2022	15:52	19/06/2022	00:01	HT	CT cable found broken
KALWA - TALEGAON (PG)	InterState	19/06/2022	06:21	19/06/2022	18:50	PO	1) Cold line cleaning, Chemical cleaning of Insulators and addition jumpuring work by fire wedge connector. 2) Additional work to replace existing disc type insulator strings with Anti fog long rod insulator in D/C portion.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/06/2022	16:32			HT	Load management
KORADI - KHAPERKHEDA CKT - 2	IntraState	18/06/2022	13:16	18/06/2022	21:34	HT	H/T DUE TO HEAVY SPARKING AT KORADI END
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	18/06/2022	19:17		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	06/06/2022	12:33			PO	For CB replacement work. ICT will be in service through TBC.
431 BAY OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	17/06/2022	23:20	18/06/2022	04:22	EO	Attending DC leakage in NIFPS of ICT 2
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	18/06/2022	05:35	18/06/2022	08:20	PO	Premonsoon maintenance work. Premonsoon work still pending, outage proposed on dtd 05 & 12 June 2022 were disapproved.
500 MVA 400/220 KV ICT - II @ CHANDRAPUR 2	IntraState	18/06/2022	09:23	18/06/2022	13:58	PO	For premonsoon activities and allied bay maintenance work
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:08	T	220KV Bus Fault at Padghe
400/220 KV 500 MVA ICT - 5 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:13	T	220KV Bus Fault at Padghe
400/220 KV 3X105 MVA ICT - 1 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:06	T	220KV Bus Fault at Padghe
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:30	T	220KV Bus Fault at Padghe
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	19/06/2022	15:38	19/06/2022	16:47	EO	To close 89L R-ph (ICT-2 HV) to proper position (Tilted to opening side due to stormy winds)
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	IntraState	19/06/2022	19:15		Continued.	EO	"For attending 220kV side Y phase Stub Bus Hot spot attending work." "
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
PADGHE - TEMGHAR - 2	IntraState	15/06/2022	00:11			PO	Bunching of 220KV Padgha-Temghar -1 & 2 line at Loc no. 80 and jumper removing at Loc. no.80 & 81 for diversion of 220KV Padgha-Temghar 2 line bay to 220KV Padgha-Temghar-1 line bay at Padgha S/s by availing simultaneous outages on 220KV Padgha-Temghar -1 & 2 line.
BOISAR - VERSOVA	IntraState	15/06/2022	06:51			PO	Bunching on Tower no BTL 16, to facilitate Modification / relocation of existing tower no BTL 13 to BTL 15 for NHSRCL projectNote: Post bunching of line, the configuration of line will change as below:1.220 kV Dahanu - Virar and 220 kV Viraj - Versova. 2.MSETCL Boisar will be disconnected from the AEML Versova and MSETCL Viraj for a period of 10 days (i.e.from 15/06/2022 to 24/06/2022). 3.Normalization of bunching shall be carried out on 25/06/2022
BOISAR II - VIRAJ	IntraState	15/06/2022	07:06			PO	Bunching on Tower no BTL 16, to facilitate Modification / relocation of existing tower no BTL 13 to BTL 15 for NHSRCL projectNote: Post bunching of line, the configuration of line will change as below:1.220 kV Dahanu - Virar and 220 kV Viraj - Versova. 2.MSETCL Boisar will be disconnected from the AEML Versova and MSETCL Viraj for a period of 10 days (i.e.from 15/06/2022 to 24/06/2022). 3.Normalization of bunching shall be carried out on 25/06/2022
WAGHIVALI - DHARAVI 8	IntraState	18/06/2022	00:04	18/06/2022	04:57	PO	FOR TWFL COMMISSIONING
DAHANU - GHODBUNDER CKT - 2	IntraState	18/06/2022	08:05	18/06/2022	20:22	PO	Project activity Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out: Re-stringing of conductors & OPGW cable.
TROMBAY - ANTOP HILL CKT - 2	IntraState	18/06/2022	08:19	18/06/2022	17:50	PO	CVT and Protection Testing AT TROMBAY
NEW KOYNA - NIWALI	IntraState	18/06/2022	09:45	18/06/2022	18:31	PO	For replacement of electro mechanical backup relay by numerical relay
MALEGAON-SATANA	IntraState	18/06/2022	09:58	18/06/2022	11:13	PO	Outage proposal for Quarterly maint. Work.
TALANDGE - SAWANTWADI	IntraState	18/06/2022	10:15	18/06/2022	13:25	PO	For fixing of repair Sleeve at loc No. 194-195
VITTAL SUGAR CO GEN (VSSK) - KARKAMBH	IntraState	18/06/2022	10:22	18/06/2022	18:38	PO	Outage is required for 1) For changing / replacement of faulty string at loc no. 114, 116, 117, 119, 121.
EKLAHARE (OCR) - PADGHE	IntraState	18/06/2022	12:20	18/06/2022	14:45	PO	For Bay maintenance & Diagnostic Testing work
KANDALGAON - BHIRA	IntraState	18/06/2022	12:55	18/06/2022	17:42	PO	Outage tree cutting work and other line maintenance work.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR II LINE	IntraState	18/06/2022	14:40	18/06/2022	15:34	EO	1) Moisture ingress observed in CB mechanism box & same to be attended on priority to avoid CB false tripping. 2) 220KV BORIVALI - BOISAR II will be shifted to TBC & will be in service.
KARAD - KADEGAON	IntraState	18/06/2022	16:13	18/06/2022	19:45	EO	To attend hot spot at loc. Y phase CT P1 side & B phase CT P2 side.
SALSETTE - SAHAR CKT	IntraState	19/06/2022	06:27	19/06/2022	09:01	PO	REPAIR TO SLEEVE ON C PHASE CONDUCTOR IN SPAN - 27-28
TROMBAY CARNAC - 5	IntraState	19/06/2022	09:17	19/06/2022	15:42	PO	FOR CVT AND PROTECTION TESTING AT TROMBAY
PADGHE - JAMBHUL 1	IntraState	19/06/2022	13:08	19/06/2022	14:17	T	220KV Bus Fault at Padghe
PADGHE - PAL DOMBIVALI	IntraState	19/06/2022	13:08	19/06/2022	14:17	T	220KV Bus Fault at Padghe
BUS - A @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:06	T	220KV Bus Fault at Padghe
PANDHARPUR - MALINAGAR	IntraState	19/06/2022	16:28	19/06/2022	19:27	PO	Outage is required for For changing / replacement of faulty string at loc no. 37, 38, 48 and 51.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/22KV 50 MVA PTR - 3 @ AKP	IntraState	18/06/2022	08:18	18/06/2022	12:40	PO	LV R phase 2 nos. of faulty cable joint and testing work.
220/132kV 200MVA ICT-2 @ KOPARGAON	IntraState	18/06/2022	10:02	18/06/2022	18:30	PO	For Attending oil leakage of Rph HV Bushing turret gasket joint
220/33kV 50MVA TF-2 @ KOPARGAON	IntraState	18/06/2022	16:00	18/06/2022	20:41	PO	For attending oil Leakage from top plate of TF
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	18:50	T	220KV Bus Fault at Padghe
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:18	T	220KV Bus Fault at Padghe
220/100 KV 200 MVA ICT 3 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:15	T	220KV Bus Fault at Padghe
220/100 KV 200 MVA ICT 1 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:16	T	220KV Bus Fault at Padghe
220/100 KV 200 MVA ICT 2 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:14	T	220KV Bus Fault at Padghe
220/22 KV 50 MVA PTR 2 @ PADGHE	IntraState	19/06/2022	13:08	19/06/2022	14:20	T	220KV Bus Fault at Padghe
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 18/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
KALYAN KALWA SALSETTE 1	IntraState	18/06/2022	09:06	18/06/2022	20:30	PO	THIRD PARTY WORK-DFCC LINE SHIFTING WORK AT LOC-30

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage