

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 18/Jul/2016 MONDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	70.884	1489.196	1) Gujrat	2.843	-122.074
2) Hydro	12.154	115.438	2) Madhya Pradesh	18.191	212.100
3) Gas	9.282	129.610	3) Chattisgarh	4.720	120.410
<b>Total MSPGCL</b>	<b>92.320</b>	<b>1734.244</b>	4) Maharashtra Net	84.338	1051.442
B) 1) APLM	45.258	877.459	5) Goa (Amona)	-0.524	-12.797
2) JSWEL	21.190	354.166	6) TAPS 1&2 Injection	3.639	63.297
3) VIPL	6.912	169.141	7) RGPPL Injection	11.695	205.433
4) RPL(AMT)	0.000	3.657	8) Pench (MS)	0.218	3.626
5) WPCL	4.475	59.977	9) Pench (Excess)	-0.218	-3.626
6) Other IPP	2.260	43.490	<b>Total</b>	<b>124.684</b>	<b>1514.185</b>
C) 1) TPCL Thermal	15.782	262.972	a) Mumbai Schedule	22.957	359.863
2) TPCL Hydro	4.155	56.956	b) Mumbai Drawl	24.770	434.930
3) TPCL Gas	2.134	65.611	c) MSEDCL Bilateral *	34.073	445.212
4) R-INFRA Thermal	11.309	187.057	Include PX	0.000	-141.710
D) STATE			d) Mumbai Bilateral *	22.957	359.863
1) Thermal	178.070	3447.115	Include PX	5.280	24.311
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	16.309	172.394	<b>H) ENERGY CATERED (MUs)</b>		
3) Gas	11.416	195.221	1) MSEDCL	299.129	5051.583
4) Wind	26.196	717.169	2) Mumbai Discoms	58.150	1007.527
6) SOLAR	0.604	13.025	<b>TOTAL STATE</b>	<b>357.279</b>	<b>6059.110</b>
<b>TOTAL STATE</b>	<b>232.595</b>	<b>4544.924</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	2760	2819	3137	2927
MSPGCL Hydro	629	316	814	67
MSPGCL Gas	432	437	319	415
MSPGCL Total Generation	3821	3572	4270	3409
Central Sector Receipt	6322	5655	5668	4482
WIND	1051	1148	1175	1075
CPP / IPP	3371	3350	3365	3141
SOLAR	76	64	0	0
Exchange with Mumbai	-1311	-1359	-1062	-686
<b>MSEDCL DEMAND MET</b>	<b>13330</b>	<b>12430</b>	<b>13416</b>	<b>11421</b>
Load Shedding	0	0	0	0
MSEDCL DEMAND	13330	12430	13416	11421
TPCL GENERATION	1186	1091	1136	601
R-INFRA GENERATION	506	510	494	402
<b>MUMBAI DEMAND</b>	<b>3003</b>	<b>2960</b>	<b>2692</b>	<b>1689</b>
STATE DEMAND MET	16333	15390	16108	13110
<b>STATE DEMAND</b>	<b>16333</b>	<b>15390</b>	<b>16108</b>	<b>13110</b>
Frequency (Hz)	50.01	50.03	49.97	49.90

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.22 Hz at 08.03 Hrs	49.72 Hz at 06.18 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation, Maximum, Minimum for 18/Jul/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 5	0.00	0.32	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.60	0	0
Unit 8	5.96	215.62	551	0
<b>Total</b>	<b>5.96</b>	<b>216.54</b>		
<b>Bhusawal</b>				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	30.01	0	0
Unit 4	0.00	9.10	0	0
Unit 5	0.00	9.00	0	0
<b>Total</b>	<b>0.00</b>	<b>48.11</b>		
<b>Parli</b>				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>Chandrapur</b>				
Unit 3	3.73	65.20	185	115
Unit 4	4.10	67.28	175	160
Unit 5	7.70	148.64	340	305
Unit 6	9.81	157.40	445	360
Unit 7	0.00	132.42	0	0
Unit 8	8.09	75.70	382	266
<b>Total</b>	<b>33.43</b>	<b>646.64</b>		
<b>Paras</b>				
Unit 3	5.67	90.21	251	208
Unit 4	5.30	87.18	230	198
<b>Total</b>	<b>10.98</b>	<b>177.39</b>		
<b>Khaparkheda</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	19.12	0	0
Unit 3	0.00	19.82	0	0
Unit 4	0.00	28.00	0	0
Unit 5	11.81	182.86	505	400
<b>Total</b>	<b>11.81</b>	<b>249.81</b>		
<b>Nasik</b>				
Unit 3	4.36	73.91	200	165
Unit 4	0.00	0.00	0	0
Unit 5	4.34	73.42	198	165
<b>Total</b>	<b>8.71</b>	<b>147.33</b>		
<b>Uran</b>				
All Units	9.28	129.61	437	282
<b>Total</b>	<b>9.28</b>	<b>129.61</b>		
<b>PENCH (MS)</b>				
Pench (MS)	0.22	3.63	53	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Total</b>	<b>0.22</b>	<b>3.63</b>		
<b>Koyna</b>				
Stage 1-2	3.94	42.70	560	40
Stage 4	3.78	9.10	767	0
Stage 3	2.31	26.26	240	0
<b>Total</b>	<b>10.04</b>	<b>78.06</b>		
<b>Hydro</b>				
KDPH	0.00	0.00	0	0
VTRNA	0.21	3.96	61	0
TILLARI	0.00	6.60	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.34	7.10	80	0
RNGR+BHTSA	0.00	0.12	0	0
BHANDARDRA	0.63	6.80	27	26
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.00	0.00	0	0
GHATGHAR	0.93	12.80	250	0
<b>Total</b>	<b>2.12</b>	<b>37.38</b>		
<b>Wind</b>				
Total	26.20	717.17	0	0
<b>Total</b>	<b>26.20</b>	<b>717.17</b>		
<b>CPP</b>				
APML(Mus)	45.26	877.46	0	0
JSWEL(Mus)	21.19	354.17	0	0
VIPL(Mus)	6.91	169.14	0	0
RPLAMT(Mus)	0.00	3.66	0	0
WPCL(Mus)	4.48	59.98	0	0
Other(Mus)	2.26	43.49	0	0
<b>Total</b>	<b>80.10</b>	<b>1507.89</b>		
<b>SOLAR</b>				
Total	0.60	13.02	0	0
<b>Total</b>	<b>0.60</b>	<b>13.02</b>		
<b>Tata</b>				
Trombay 5	10.29	166.55	476	312
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.19	41.00	50	49
Trombay 7B	0.94	24.61	40	39
Trombay 8	5.49	96.43	248	200
TATA Hydro	4.16	56.96	387	4
<b>Total</b>	<b>22.07</b>	<b>385.54</b>		
<b>R-INFRA</b>				
1-2	11.31	187.06	512	401
<b>Total</b>	<b>11.31</b>	<b>187.06</b>		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	0.00	1.92
Koradi 9	0.00	0.00
Koradi 10	0.00	1.46
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	70.88	1489.20
MSPGCL Thml+Gas	80.17	1618.81
MSPGCL Hydro	12.15	115.44

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	92.32	1734.24
Koyna 1,2 & 4 Total	7.73	51.80
State Total	232.60	4544.92

**State Load Despatch Center,Airoli (MSETCL)**  
**Hourly Load Data As on 18/Jul/2016**

**Annexure-2**

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	3139	153	351	3643	1154	3414	0	4119	4180	-759	11632	0	11632	2004	13636	49.99
2	3063	67	382	3512	1128	3415	0	4047	4152	-673	11534	0	11534	1845	13379	50.01
3	3055	72	415	3542	1132	3349	0	4373	4107	-679	11451	0	11451	1742	13193	50.03
4	2927	67	415	3409	1075	3141	0	4354	4482	-686	11421	0	11421	1689	13110	49.90
5	2911	212	418	3541	1032	3091	0	4156	4592	-670	11586	0	11586	1679	13265	49.95
6	3116	414	420	3950	950	3163	0	4260	4941	-794	12210	0	12210	1802	14012	49.94
7	2915	1274	426	4615	809	3294	3	4395	5057	-812	12966	0	12966	1954	14920	49.99
8	2773	1751	432	4956	823	3360	20	4693	5052	-867	13344	0	13344	2191	15535	50.10
9	2719	1515	418	4652	955	3392	41	5136	5427	-1014	13453	0	13453	2459	15912	50.02
10	2723	1222	423	4368	1012	3383	74	5401	5775	-1176	13436	0	13436	2741	16177	50.01
11	2760	629	432	3821	1051	3371	76	5621	6322	-1311	13330	0	13330	3003	16333	50.01
12	2794	486	424	3704	1045	3386	83	5596	5763	-1323	12658	0	12658	3022	15680	49.98
13	2819	316	437	3572	1148	3350	64	5774	5655	-1359	12430	0	12430	2960	15390	50.03
14	2724	248	435	3407	1048	3365	71	5832	5623	-1298	12216	0	12216	2823	15039	49.98
15	2731	211	424	3366	1195	3380	73	5494	5629	-1285	12358	0	12358	2805	15163	49.99
16	2842	197	418	3457	1276	3368	54	5376	5660	-1257	12558	0	12558	2799	15357	49.99
17	2855	138	384	3377	1500	3361	34	5114	5032	-1195	12109	0	12109	2785	14894	49.95
18	2790	137	391	3318	1382	3241	10	4899	5359	-1353	11957	0	11957	2750	14707	49.96
19	2917	461	376	3754	1275	3235	1	5169	5615	-1372	12508	0	12508	2769	15277	49.99
20	3137	814	319	4270	1175	3365	0	5492	5668	-1062	13416	0	13416	2692	16108	49.97
21	3250	629	282	4161	1170	3417	0	5399	5547	-988	13307	0	13307	2611	15918	49.97
22	3315	565	293	4173	939	3431	0	5135	5269	-956	12856	0	12856	2464	15320	49.98
23	3314	350	283	3947	925	3414	0	5035	5197	-982	12501	0	12501	2358	14859	49.98
24	3295	226	284	3805	997	3409	0	4595	4580	-899	11892	0	11892	2203	14095	50.01
<b>MUs</b>	<b>70.88</b>	<b>12.15</b>	<b>9.28</b>	<b>92.32</b>	<b>26.20</b>	<b>80.10</b>	<b>0.60</b>	<b>119.46</b>	<b>124.68</b>	<b>-24.77</b>	<b>299.13</b>	<b>0.00</b>	<b>299.13</b>	<b>58.15</b>	<b>357.28</b>	<b>49.99</b>

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 18/Jul/2016**

Position as on 6.30 Hrs of 19/Jul/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
<b>PLANNED OUTAGE</b>								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
CENT.SECTOR	Tarapur 2	160	10/09/2015	12.55		Continued.	Refuelling work	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 4	210	19/06/2016	00.20		Continued.	Capital Overhaul.	
IPP	JSW (J) U3	300	21/06/2016	18.15		Continued.	Capital Overhaul	
MSPGCL	Khaparkheda Unit 1	210	25/06/2016	23.45		Continued.	A.O.H.(Zero Schedule by MSEDCL from 00.00Hrs Dt.18-7-16)	
MSPGCL	Koyna Unit 8	80	29/06/2016	08.20		Continued.	Turbine Maintenance Work.	
MSPGCL	Bhusawal Unit 4	500	01/07/2016	23.55		Continued.	Zero Shedule By MSEDCL(Convert into A/O from 00 hrs.Dt.17-7-16)	
IPP	VIPL U-2	300	15/07/2016	00.16		Continued.	Genrator Inspection.	
<b>FORCED OUTAGE</b>								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
RGPPL	Dabhol 3A	230	07/05/2016	18.44		Continued.	Low Vaccum	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-2	270	18/06/2016	06.54		Continued.	Zero Shedule By MSEDCL.	
RGPPL	Dabhol 2B	230	20/06/2016	13.03		Continued.	Change Over.	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	30/06/2016	10.11		Continued.	Zero Shedule By MSEDCL.	

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 18/Jul/2016**

**Position as on 6.30 Hrs of 19/Jul/2016**

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 5	200	01/07/2016	02.23		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Koradi Unit 7	210	01/07/2016	04.43		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-1	270	01/07/2016	18.40		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 5	500	01/07/2016	23.59		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Chandrapur Unit 9	500	02/07/2016	07.26		Continued.	M.S.Temp.Low.	
MSPGCL	Khaparkheda Unit 2	210	05/07/2016	23.46		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkheda Unit 3	210	05/07/2016	23.52		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkheda Unit 4	210	08/07/2016	03.07		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	08/07/2016	23.57		Continued.	ID Fan Problem (Converted to Zero schedule by MSEDCL from 11-07-2016)	
IPP	Adani U-4	660	13/07/2016	02.22		Continued.	Zero Shedule By MSEDCL.	
IPP	Adani U-1	660	13/07/2016	02.29		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Chandrapur Unit 7	500	17/07/2016	21.41		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit-8	660	18/07/2016	06.18	18/07/2016	13.48	BCS Failuar.	

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 18/Jul/2016**

**Statement-VII**

Position as on 6.30 Hrs of 19/Jul/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>500 KV LINE Outages/Trippings</b>							
HVDC Pole-I	IntraState	18/07/2016	17.38	18/07/2016	18.05	PO	Power Supply card Replacement.
<b>400 KV LINE Outages/Trippings</b>							
Chandrapur Bhadravati III	InterState	10/07/2016	21.01		Continued.	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	13/07/2016	21.44		Continued.	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	16/07/2016	16.45		Continued.	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	18/07/2016	02.01		Continued.	T	Over Voltage
Koradi Bhilai	InterState	18/07/2016	10.21	18/07/2016	19.21	PO	Line Maintenance work
Ektuni-Bableshtar ckt I	IntraState	01/07/2016	18.00		Continued.	HT	To control Load on Padgha-BBLSR Line
Bhusawal-Aurangabad	IntraState	02/07/2016	16.24		Continued.	HT	Over Voltage
Khadka- Deepnagar Ckt 1	IntraState	12/07/2016	13.11		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	13/07/2016	03.35		Continued.	T	Over Voltage
Karad - Jaigad - II	IntraState	16/07/2016	16.36		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	18/07/2016	12.15		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	18/07/2016	23.07		Continued.	HT	Over Voltage
<b>400 KV ICT Outages/Trippings</b>							
400/220kv, 500 MVA ICT-III @Bableshtar	IntraState	24/06/2016	19.25		Continued.	PO	shifted on TBC for main bus 1&2 outage
400/220/33 kV 315 MVA ICT-I @Chandrapur	IntraState	18/07/2016	11.41	18/07/2016	23.04	PO	R.M.Work.
<b>220 KV LINE Outages/Trippings</b>							
Boisar(MS) - Boisar (PG) - I	InterState	15/07/2016	11.19		Continued.	PO	MK Box Replacement work.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Aurangabad (Waluj)-Bhenda	IntraState	22/06/2016	23.02		Continued.	HT	Hand Tripped.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Dahanu-Viraj	IntraState	13/07/2016	14.02		Continued.	HT	To control Kalwa-Borivali Line Load
Jejuri ( 400 Kv)-Jejuri- li	IntraState	14/07/2016	09.25		Continued.	PO	Maintenance Work.
Padghe - Wada	IntraState	15/07/2016	17.08		Continued.	T	Y Phase CT Burst load affected at Wada Line.
Karad(400kv) -Nigade	IntraState	18/07/2016	11.50	18/07/2016	17.28	PO	Line Maintenance work
New Koyna - Pedambe	IntraState	18/07/2016	17.55	18/07/2016	21.12	T	Bus Fault.
Mahad - Pedambe	IntraState	18/07/2016	17.55	18/07/2016	21.10	T	Bus Fault.
Main Bus Section-I@ Pedambe	IntraState	18/07/2016	17.55	18/07/2016	21.07	T	Bus Fault.
Pedambe-Pophali	IntraState	18/07/2016	17.55	18/07/2016	21.30	T	Bus Fault.
<b>220 KV ICT Outages/Trippings</b>							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 Kv 200 MVA ICT II @Kalmeshwar	IntraState	14/07/2016	10.51		Continued.	PO	Replacement of LV Side B Ph CT Replacement due to High Tan Delta Value.
220/110 Kv 200 Mva Vel Ptr 1 @Kolhapur-li (Mudshingi)	IntraState	15/07/2016	10.09		Continued.	PO	R & M Wrok.
<b>132 KV LINE Outages/Trippings</b>							

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 18/Jul/2016**

**Statement-VII**

Position as on 6.30 Hrs of 19/Jul/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Eklahara (Ocr)-Adgaon	IntraState	14/07/2016	08.42		Continued.	T	132 KV Bus Bar Operated.
Ranjangaon-Whirlpool	IntraState	17/07/2016	09.30		Continued.	PO	Taken On TBC For OWN CB Overhauling.
Theur-Sanaswadi	IntraState	18/07/2016	20.30	18/07/2016	21.10	T	Due to B Ph CT Blast @ SPSL,Sanaswadi & SPSL Charged from 220KV Theur S/S.
John Deere - SPSL	IntraState	18/07/2016	20.30		Continued.	T	Due to B Ph CT Blast @ SPSL.
Spsl - Sanaswadi	IntraState	18/07/2016	20.30	18/07/2016	21.39	T	Due to B Ph CT Blast @ SPSL,Sanaswadi & SPSL Charged from 220KV Theur S/S.
<b>100 KV LINE Outages/Trippings</b>							
Vasai-li - Vasai 1 Line	IntraState	29/06/2016	11.28		Continued.	HT	To Control Kalwa-Salsette-6 Line Loading.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage