

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Jul/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	96.129	2100.225	1) Gujrat	-8.228	-159.307
2) Hydro	18.531	200.659	2) Madhya Pradesh	6.784	84.839
3) Gas	3.146	71.575	3) Chattisgarh	5.000	71.750
Total MSPGCL	117.806	2372.459	4) Maharashtra	140.200	2510.182
B) 1) APLM	51.988	827.903	5) Goa (Amona)	-1.513	-26.326
2) JSWEL	13.443	244.052	Total	142.243	2481.138
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.892	605.127
4) RPL(AMT)	23.644	378.125	b) Mumbai Drawl	36.912	646.216
5) SWPGPL	8.124	135.431	c) MSEDCL Bilateral *	70.170	1372.586
6) Other IPP	2.373	120.383	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.892	603.048
C) 1) TPCL Thermal	11.074	176.447	Include PX	0.000	0.000
2) TPCL Hydro	8.557	81.812	Standby	0.000	2.080
3) TPCL Gas	0.000	6.389	H) ENERGY CATERED (MUs)		
4) AEML Thermal	3.941	139.940	1) MSEDCL	363.978	6785.165
D) STATE			2) Mumbai Discoms	60.483	1050.804
1) Thermal	210.716	4122.506	3) Other Discoms	8.793	157.105
(A1+C1+C4+(B1-B6))			TOTAL STATE	433.254	7993.074
2) Hydro (A2+C2)	27.088	282.471			
3) Gas (A3+B7+C3)	3.146	77.964			
4) Wind	46.615	923.338			
6) SOLAR	3.447	105.657			
TOTAL STATE	291.012	5511.936			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4000	3845	3961	4357
MSPGCL Hydro	843	501	1911	330
MSPGCL Gas	130	129	128	130
MSPGCL Total Generation	4973	4475	6000	4817
Central Sector Receipt	7354	6635	6192	4276
WIND	2098	2265	1514	1948
CPP / IPP Thermal	4556	3588	4448	3937
CPP / IPP Gas	0	0	0	0
SOLAR	278	500	0	0
Exchange with Mumbai	-1932	-2050	-1479	-1029
MSEDCL DEMAND MET	16916	15013	16271	13652
Load Shedding	0	0	82	0
MSEDCL DEMAND	16916	15013	16353	13652
TPCL GENERATION	761	778	1103	666
AEML GENERATION	167	150	171	160
MUMBAI DEMAND	2860	2978	2753	1855
OTHER DISCOM DEMAND	411	400	404	297
STATE DEMAND MET	20187	18391	19428	15804
STATE DEMAND	20187	18391	19510	15804
Frequency (Hz)	49.93	49.99	49.66	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 13:00 Hrs	49.42 Hz at 19:20 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.19	40.53	130	40
Unit 7	0.00	0.00	0	0
Unit 8	0.00	43.27	0	0
Unit 9	8.40	108.89	385	320
Unit 10	8.37	193.60	403	315
Total	18.96	386.29		
Bhusawal				
Unit 3	0.00	44.11	0	0
Unit 4	4.36	144.12	350	0
Unit 5	6.24	130.33	295	205
Total	10.60	318.56		
Parli				
Unit 6	4.46	81.22	203	158
Unit 7	4.09	64.06	198	140
Unit 8	4.38	24.26	206	147
Total	12.92	169.53		
Chandrapur				
Unit 3	0.00	20.97	0	0
Unit 4	1.61	41.53	92	33
Unit 5	5.53	120.00	250	210
Unit 6	4.66	109.00	237	155
Unit 7	0.00	0.00	0	0
Unit 8	7.80	167.42	407	287
Unit 9	8.08	169.25	419	287
Total	27.68	628.17		
Paras				
Unit 3	1.18	66.93	151	0
Unit 4	1.23	65.96	154	0
Total	2.40	132.89		
Khaparkheda				
Unit 1	3.00	50.84	135	115
Unit 2	3.12	53.54	145	115
Unit 3	3.78	56.51	165	141
Unit 4	3.13	14.45	141	118
Unit 5	8.17	162.36	380	300
Total	21.20	337.69		
Nasik				
Unit 3	2.35	55.82	138	0
Unit 4	0.00	39.36	0	0
Unit 5	0.00	31.92	0	0
Total	2.35	127.09		
Uran				
All Units	3.15	71.58	140	127
Total	3.15	71.58		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.58	3.14	27	22
Total	0.58	3.14		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.00	37.38	555	40
Stage 4	3.90	14.82	702	0
Stage 3	1.88	24.17	240	0
Total	9.78	76.37		
Hydro				
KDPH	0.86	4.60	36	36
VTRNA	0.87	12.28	61	0
TILLARI	0.72	8.48	58	0
BHIRA T.R.	0.46	6.77	77	0
SMLHY_PTN	5.25	89.02	234	203
GHATGHAR	0.00	0.00	0	0
Total	8.17	121.15		
Wind				
Total	46.62	923.34	0	0
Total	46.62	923.34		
CPP				
APML(Mus)	51.99	827.90	0	0
JSWEL(Mus)	13.44	244.05	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	23.64	378.12	0	0
SWPGPL-Mus	8.12	135.43	0	0
Other(Mus)	2.37	120.38	0	0
Total	99.57	1705.89		
SOLAR				
Total	3.45	105.66	0	0
Total	3.45	105.66		
Tata				
Trombay 5	7.38	106.27	446	259
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.82	0	0
Trombay 7B	0.00	2.57	0	0
TATA Hydro	8.56	81.81	447	259
Trombay 8	3.70	70.18	237	131
Total	19.63	264.65		
AEML				
DTPS U-1&2	3.94	139.94	171	150
Total	3.94	139.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	96.13	2100.22	MSPGCL Total	117.81	2372.46
			MSPGCL Thml+Gas	99.28	2171.80	Koyna 1,2 & 4 Total	7.90	52.20
			MSPGCL Hydro	18.53	200.66	State Total	291.01	5511.94

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4477	331	129	4937	1794	4119	0	0	4519	4648	-1264	13935	0	13935	2166	299	16400	50.01
2	4454	326	140	4920	1911	4035	0	0	4474	4234	-991	13828	0	13828	2042	281	16151	50.00
3	4403	334	130	4867	1991	3902	0	0	4435	4073	-946	13605	0	13605	1935	282	15822	50.00
4	4357	330	130	4817	1948	3937	0	0	4412	4276	-1029	13652	0	13652	1855	297	15804	50.01
5	4253	339	139	4731	2239	3973	0	0	4420	4266	-1028	13869	0	13869	1849	312	16030	49.99
6	4113	383	129	4625	2248	4041	0	0	5290	5576	-1103	15059	0	15059	1957	328	17344	50.00
7	4136	833	129	5098	2317	4492	0	24	5785	5973	-1228	16310	0	16310	2107	366	18783	49.99
8	4028	608	130	4766	2156	4496	0	85	6649	6743	-1382	16496	0	16496	2291	368	19155	49.96
9	4046	672	139	4857	2163	4524	0	174	7052	7424	-1687	17069	0	17069	2583	386	20038	49.96
10	4000	843	130	4973	2098	4556	0	278	7207	7354	-1932	16916	0	16916	2860	411	20187	49.93
11	3798	563	129	4490	2007	4395	0	361	7830	7787	-2102	16535	0	16535	3038	403	19976	49.92
12	3821	508	139	4468	2050	3943	0	437	7731	7702	-2111	16077	0	16077	3059	412	19548	50.00
13	3845	501	129	4475	2265	3588	0	500	7315	6635	-2050	15013	0	15013	2978	400	18391	49.99
14	3652	505	129	4286	2083	3179	0	495	7101	6789	-1931	14513	0	14513	2855	388	17756	49.99
15	3697	843	128	4668	2221	3525	0	424	6381	6616	-1968	15085	0	15085	2899	401	18385	49.92
16	3956	556	127	4639	1959	3820	0	327	6492	5945	-1948	14357	0	14357	2880	385	17622	49.97
17	3860	531	128	4519	1980	4004	0	216	6794	6391	-1899	14863	0	14863	2832	348	18043	49.90
18	3866	622	137	4625	1711	4320	0	114	6529	6544	-1854	15059	0	15059	2788	401	18248	49.99
19	3891	1370	128	5389	1614	4445	0	12	6579	6515	-1749	15813	0	15813	2744	413	18970	49.88
20	3961	1911	128	6000	1514	4448	0	0	6208	6192	-1479	16271	82	16353	2753	404	19510	49.66
21	3944	1870	127	5941	1638	4460	0	0	5818	5503	-1369	15770	101	15871	2670	403	18944	49.78
22	4038	1709	137	5884	1689	4453	0	0	5398	5067	-1329	15379	0	15379	2559	385	18323	49.91
23	3807	1329	127	5263	1555	4445	0	0	5216	4946	-1291	14548	0	14548	2445	370	17363	49.97
24	3726	714	128	4568	1464	4472	0	0	5278	5044	-1242	13955	0	13955	2339	351	16645	50.01
MUs	96.13	18.53	3.15	117.81	46.62	99.57	0.00	3.45	144.91	142.24	-36.91	363.98	0.18	364.16	60.48	8.79	433.44	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Jul/2022

Position as on 6.30 Hrs of 19/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Annual Overhaul	18/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
IPP	Adani U-2	660	25/06/2022	04:18		Continued.	Annual Overhaul	22/07/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	18/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Ghatghar Unit-2	125	18/06/2022	10:00		Continued.	for Hydraulic Intake Gate Work	15/07/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	18/07/2022
MSPGCL	Uran Unit 6	108	06/07/2022	17:51		Continued.	Gas shortage	
MSPGCL	Koyna STG-IV Unit-1	250	06/07/2022	18:30		Continued.	Governor problem	19/07/2022
TPC-G	Trombay 7A	120	07/07/2022	01:09		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	07/07/2022	01:21		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	09/07/2022	11:58		Continued.	Furnace Pressure High	19/07/2022
MSPGCL	Nasik Unit 5	210	11/07/2022	17:00		Continued.	WET COAL	
AEML	AEML Unit 2	250	13/07/2022	00:38		Continued.	Coal Shortage	
IPP	SWPGPL U-3	135	14/07/2022	14:58		Continued.	FD Fan Problem.	18/07/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Jul/2022

Position as on 6.30 Hrs of 19/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
MSPGCL	Bhusawal Unit 3	210	16/07/2022	06:30	19/07/2022	03:01	Critical coal stock	
IPP	Dhariwal	300	18/07/2022	03:15		Continued.	Generator Elect. Fault	19/07/2022
MSPGCL	Bhusawal Unit 4	500	18/07/2022	04:40	18/07/2022	11:49	Flame Failure	18/07/2022
MSPGCL	Paras Unit 3	250	18/07/2022	09:38	19/07/2022	03:05	Coal bunkering problem	
MSPGCL	Paras Unit 4	250	18/07/2022	10:10	19/07/2022	05:55	Coal bunkering problem	
MSPGCL	Nasik Unit 3	210	18/07/2022	17:25	18/07/2022	20:52	Tripped due to AVR Tripped to 86G	
MSPGCL	Bhusawal Unit 4	500	18/07/2022	22:21	19/07/2022	03:01	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	15/07/2022	03:06	18/07/2022	01:59	PO	Oil Filtration of Pole-2 R-ph Converter Transformer due to Increase in dissolve gases and PPM as per recommended by OEM to immediately taken out the converter transformer and carry out hot oil circulation (HOC) to improve the oil property
400 KV TIEBAY Outages/Trippings							
TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	IntraState	18/07/2022	17:15	18/07/2022	17:53	EO	For removal of Bird Nest from 400 Kv 402 Bay Y ph CT
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	30/06/2022	07:24	18/07/2022	14:45	HT	H/T FOR CONTROLLING LINE LOADING
KARAD - LONIKAND I	IntraState	15/07/2022	12:32	18/07/2022	08:51	T	Due to overloading of Kolhapur PG - Kolhapur MSETCL line
KHADKA-AURANGABAD (WALUJ)	IntraState	17/07/2022	17:55	18/07/2022	07:45	HT	To control overvoltage
JAIGAD - KARAD CKT - 2	IntraState	17/07/2022	23:50	18/07/2022	09:59	HT	HAND TRIPPED DUE TO O/V
NEW KOYNA - DABHOL CKT - 1	IntraState	18/07/2022	09:32	18/07/2022	17:02	EO	Replacement of Faulty Insulators strings of Y.Ph. At loc.no. 35
JAIGAD - KARAD CKT - 1	IntraState	18/07/2022	23:15	19/07/2022	06:52	HT	To control overvoltage
KORADI - KHADKA	IntraState	19/07/2022	05:22	19/07/2022	07:03	T	tripped on overvoltage
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	17/07/2022	22:32	18/07/2022	11:50	T	TRIPPED ON NDR
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	18/07/2022	09:48	18/07/2022	17:25	T	tripped on OLTC buchoolz
220 KV LINE Outages/Trippings							
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
BOISAR - VERSOVA	IntraState	16/07/2022	00:30			PO	1. Metro-9 Project work(Erection of 02 new monopoles and shifting of existing lines at Mira Bhyander area)2. DFCCIL Project work(Erection of 03 new inline lattice type towers and shifting existing lines at Virar Area)3. NHSRCL project work(Erection of 02 new towers (01 ȳ Monopole & 01 Lattice) and shifting of existing lines at Vasai Area).
DAHANU - VERSOVA	IntraState	16/07/2022	01:07			PO	1. Metro-9 Project work (Erection of 02 new monopoles and shifting of existing lines at Mira Bhyander area) 2. DFCCIL Project work (Erection of 03 new inline lattice type towers and shifting existing lines at Virar Area) 3. NHSRCL project work (Erection of 02 new towers (01 ȳ Monopole & 01 Lattice) and shifting of existing lines at Vasai Area).

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY - SALSETTE CKT - 1	IntraState	17/07/2022	23:00	18/07/2022	07:02	PO	Project work , Erection of Proposed DF-5 type tower at loc.46A (Sahakar Plaza Metro -4 crossing)
TROMBAY SALSETTE LINE-2	IntraState	17/07/2022	23:22	18/07/2022	06:34	PO	Project Work, Erection of proposed DF-5 type tower at loc.46A (Sahakar Plaza Metro-4 crossing)
KALWA - COLOURCHEM	IntraState	18/07/2022	06:27	18/07/2022	08:23	EO	To attend red Hot spot in R-Ph CB jumper.
PEDAMBE-KALAMBANI(TSS)	IntraState	18/07/2022	09:17	18/07/2022	13:55	PO	Replacement of B phase main bus isolator to Bkr jumper, B phase CT oil top up & LS isolator checking work.
EKLAHARE (OCR) - PADGHE	IntraState	18/07/2022	10:19			HT	To control overloading on 220 kV nashik-babhleshwar lines
WARORA - WARDHA	IntraState	18/07/2022	12:13	18/07/2022	14:19	EO	For attending hot spot on R-ph CT clamp (above 160 C) towards Bus side.
BORIVALI - BOISAR (PG)	IntraState	18/07/2022	16:18			EO	Shifting of Line on TBC due to damaged B-Ph jumper (Twin) between Main Bus & Bus Isolator.
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	18/07/2022	19:05	18/07/2022	21:28	T	To Control Over Drawl at Low frequency.
220 PARLI U-8 - NEW GCR PARLI CKT I	IntraState	18/07/2022	19:27	18/07/2022	23:27	HT	To Control Over Drawl at Low frequency.
BHUGAON- WARDHA	IntraState	18/07/2022	19:30	18/07/2022	23:10	HT	To Control Over Drawl at Low frequency.
TROMBAY DHARAVI - 5	IntraState	18/07/2022	23:41	19/07/2022	03:15	EO	Attending to Hot Spot at loc,23
SATANA - GANGAPUR	IntraState	19/07/2022	02:29			T	bus coupler R ph conductor snapped
SHIVAJINAGAR - GANGAPUR	IntraState	19/07/2022	02:29	19/07/2022	05:01	T	Bus coupler R ph conductor snapped at Gangapur end
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33KV 100MVA PTR 2 @ 5 STAR MIDC, KAGAL	IntraState	18/07/2022	10:50	18/07/2022	18:40	PO	For attending Hot spot at L.V.side C.T. palm.
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	18/07/2022	13:12	18/07/2022	16:02	PO	Relay Testing Work
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	IntraState	18/07/2022	16:08	18/07/2022	17:25	PO	Relay Testing Work
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 19/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage