

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Jul/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	120.654	2422.396	1) Gujrat	3.281	26.437
2) Hydro	5.644	124.826	2) Madhya Pradesh	3.763	104.535
3) Gas	0.172	0.943	3) Chattisgarh	2.800	43.350
Total MSPGCL	126.470	2548.165	4) Maharashtra	172.748	2936.186
B) 1) APML	40.438	1079.102	5) Goa (Amona)	-0.966	-18.915
2) JSWEL	19.768	354.383	Total	181.626	3091.593
3) VIPL	0.000	0.000	a) Mumbai Schedule	39.015	644.612
4) RPL(AMT)	23.329	416.308	b) Mumbai Drawl	36.749	703.144
5) SWPGPL	9.746	159.825	c) MSEDCL Bilateral *	108.590	1647.783
6) Other IPP	6.363	115.985	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	39.015	643.761
C) 1) TPCL Thermal	11.272	135.597	Include PX	0.000	0.000
2) TPCL Hydro	4.109	85.745	Standby	0.000	0.851
3) TPCL Gas	2.945	63.078	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.076	160.726	1) MSEDCL	421.268	7826.574
D) STATE			2) Mumbai Discoms	64.151	1148.292
1) Thermal	240.646	4844.322	3) Other Discoms	9.920	177.088
(A1+C1+C4+(B1-B6))			TOTAL STATE	495.339	9151.954
2) Hydro (A2+C2)	9.753	210.571			
3) Gas (A3+B7+C3)	3.117	64.021			
4) Wind	54.885	755.716			
6) SOLAR	5.312	185.729			
TOTAL STATE	313.713	6060.359			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	4943	4416	4977	4790
MSPGCL Hydro	244	134	500	293
MSPGCL Gas	0	0	75	0
MSPGCL Total Generation	5187	4550	5552	5083
Central Sector Receipt	9548	8896	7132	5856
WIND	2562	2323	2442	2074
CPP / IPP Thermal	3866	3840	5251	4130
CPP / IPP Gas	0	0	0	0
SOLAR	649	709	0	0
Exchange with Mumbai	-2318	-1920	-1413	-1261
MSEDCL DEMAND MET	19047	17965	18521	15490
Load Shedding	0	0	0	0
MSEDCL DEMAND	19047	17965	18521	15490
TPCL GENERATION	622	791	1052	807
AEML GENERATION	289	501	423	400
MUMBAI DEMAND	3229	3212	2888	2468
OTHER DISCOM DEMAND	447	432	443	391
STATE DEMAND MET	22723	21610	21852	18350
STATE DEMAND	22723	21610	21852	18350
Frequency (Hz)	49.99	49.98	50.01	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 18.02 Hrs	49.76 Hz at 14.15 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.52	65.84	165	120
Unit 8	0.00	186.88	0	0
Unit 9	12.85	217.91	552	423
Unit 10	0.00	111.14	0	0
Total	16.37	581.77		
Bhusawal				
Unit 3	2.44	51.68	140	0
Unit 4	9.12	174.72	460	285
Unit 5	8.94	182.25	475	285
Total	20.50	408.64		
Parli				
Unit 6	3.14	29.30	160	74
Unit 7	4.01	21.79	238	144
Unit 8	3.71	10.31	199	142
Total	10.87	61.40		
Chandrapur				
Unit 3	1.16	52.47	76	0
Unit 4	1.63	51.71	90	43
Unit 5	0.00	0.00	0	0
Unit 6	7.04	139.30	340	220
Unit 7	6.70	141.90	320	245
Unit 8	9.82	178.54	448	340
Unit 9	10.21	188.91	468	336
Total	36.55	752.83		
Paras				
Unit 3	4.92	69.81	219	169
Unit 4	3.25	79.70	160	112
Total	8.17	149.51		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	2.88	47.27	128	108
Unit 3	3.73	69.07	177	127
Unit 4	3.94	63.62	193	129
Unit 5	10.44	160.22	470	325
Total	20.99	340.18		
Nasik				
Unit 3	3.64	52.43	173	120
Unit 4	3.56	63.30	165	116
Unit 5	0.00	12.33	0	0
Total	7.20	128.06		
Uran				
All Units	0.17	0.94	84	0
Total	0.17	0.94		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.17	0.94	25	0
Total	0.17	0.94		
Koyna				
Stage 1-2	1.36	38.04	210	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	6.91	0	0
Stage 3	1.06	16.37	150	0
Total	2.42	61.33		
Hydro				
KDPH	0.00	0.14	0	0
VTRNA	0.00	0.64	0	0
TILLARI	0.00	1.16	0	0
BHIRA T.R.	0.42	7.75	80	0
SMLHY_PTN	2.48	48.72	116	93
GHATGHAR	0.16	4.15	96	0
Total	3.05	62.56		
Wind				
Total	54.88	755.72	0	0
Total	54.88	755.72		
CPP				
APML(Mus)	40.44	1079.10	0	0
JSWEL(Mus)	19.77	354.38	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	23.33	416.31	0	0
SWPGPL-Mus	9.75	159.82	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.06	92.78	269	156
Other(Mus)	1.30	23.21	0	0
Total	99.64	2125.60		
SOLAR				
Total	5.31	185.73	0	0
Total	5.31	185.73		
Tata				
Trombay 5	7.47	66.70	453	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.75	38.53	108	39
Trombay 7B	1.20	24.55	64	36
TATA Hydro	4.11	85.74	391	43
Trombay 8	3.80	68.89	217	128
Total	18.33	284.42		
AEML				
DTPS U-1&2	9.08	160.73	501	289
Total	9.08	160.73		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	120.65	2422.40	MSPGCL Total	126.47	2548.16
			MSPGCL Thml+Gas	120.83	2423.34	Koyna 1,2 & 4 Total	1.36	44.95
			MSPGCL Hydro	5.64	124.83	State Total	313.71	6060.36

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 18/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5451	155	0	5606	2177	4270	0	0	6164	5669	-1200	16135	0	0	16135	2390	387	18912	50.02
2	5438	134	0	5572	2244	3980	0	0	6194	5913	-1109	16216	0	0	16216	2158	383	18758	50.02
3	5328	134	0	5462	2211	3876	0	0	6111	6007	-1037	16187	0	0	16187	2025	332	18544	50.01
4	5362	200	0	5562	2233	4021	0	0	5974	5898	-1009	16372	0	0	16372	2027	333	18732	50.00
5	5330	140	0	5470	2110	4239	0	0	6432	6341	-1031	16795	0	0	16795	1965	335	19094	50.00
6	5280	135	0	5415	2033	3994	0	0	8022	7473	-985	17561	0	0	17561	2080	368	20010	49.97
7	5101	173	0	5274	2055	3791	0	41	9172	9179	-1088	18846	0	0	18846	2254	407	21506	49.95
8	5029	270	0	5299	2234	3786	0	188	9439	9370	-1289	19173	0	0	19173	2479	415	22067	50.00
9	5304	256	0	5560	2317	4224	0	388	8832	8726	-1635	19152	0	0	19152	2793	428	22373	50.01
10	5132	263	0	5395	2490	4123	0	567	9082	9190	-2128	19175	0	0	19175	3070	462	22707	49.93
11	4943	244	0	5187	2562	3866	0	649	9508	9548	-2318	19047	0	0	19047	3229	447	22723	49.99
12	4727	220	0	4947	2440	3717	0	661	9537	9359	-2272	18423	0	0	18423	3272	429	22124	49.98
13	4416	134	0	4550	2323	3840	0	709	9148	8896	-1920	17965	0	0	17965	3212	432	21610	49.98
14	4627	135	0	4762	2371	3910	0	639	8315	7989	-1889	17355	0	0	17355	3053	426	20835	49.95
15	4938	159	0	5097	2349	3947	0	581	8072	7864	-1864	17541	0	0	17541	3013	433	20987	49.92
16	4808	176	0	4984	2273	3922	0	444	7955	7845	-1813	17206	0	0	17206	3021	449	20676	49.94
17	4958	316	0	5274	2333	4119	0	267	7881	7960	-1832	17672	0	0	17672	2966	449	21087	50.02
18	5046	152	0	5198	2262	4690	0	151	7776	7585	-1861	17578	0	0	17578	2930	447	20955	50.02
19	4991	271	8	5270	2222	4670	0	27	8175	7995	-1781	17944	0	0	17944	2912	459	21315	50.07
20	4977	500	75	5552	2442	5251	0	0	7638	7132	-1413	18521	0	0	18521	2888	443	21852	50.01
21	4923	375	84	5382	2490	4784	0	0	7209	6763	-1350	17643	0	0	17643	2776	425	20845	50.02
22	4904	470	5	5379	2359	4379	0	0	6649	6671	-1334	17032	0	0	17032	2661	422	20115	49.98
23	4851	339	0	5190	2281	4117	0	0	6721	6397	-1330	16239	0	0	16239	2509	416	19164	50.01
24	4790	293	0	5083	2074	4130	0	0	6291	5856	-1261	15490	0	0	15490	2468	391	18350	50.03
MUs	120.65	5.64	0.17	126.47	54.89	99.64	0.00	5.31	186.30	181.63	-36.75	421.27	0.00	0.00	421.27	64.15	9.92	495.34	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Jul/2023

Position as on 6.30 Hrs of 19/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	
IPP	Adani U-1	660	16/07/2023	00:00		Continued.	Annual Overhaul	07/08/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/07/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	25/07/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	25/07/2023
MSPGCL	Nasik Unit 5	210	04/07/2023	18:00		Continued.	Generator Swapping : nashik Unit-3 sync 16:35 Hrs and tolling agreement with IEPL	
MSPGCL	Koradi Unit 8	660	16/07/2023	10:25		Continued.	Boiler Tube Leakage	20/07/2023
MSPGCL	Uran Unit 6	108	17/07/2023	21:15		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	17/07/2023	21:26	18/07/2023	18:36	No Schedule	
MSPGCL	Bhusawal Unit 3	210	18/07/2023	18:59	18/07/2023	23:37	L.A CHATTERING AT GT END	19/07/2023
MSPGCL	Uran Unit 7	108	18/07/2023	21:12		Continued.	No Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Jul/2023

Position as on 6.30 Hrs of 19/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 4	210	18/07/2023	23:49		Continued.	Air heater problem	
MSPGCL	Koradi Unit 6	210	19/07/2023	03:19		Continued.	Flame Failure	
MSPGCL	Chandrapur Unit 3	210	19/07/2023	19:45		Continued.	Wet Coal	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 19/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20			PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	18/07/2023	11:27	18/07/2023	22:46	HT	Sparking on smoothing reactor bushing
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	18/07/2023	18:08	18/07/2023	22:46	EO	Sparking around Bushing of Pole II Smoothing Reactor is observed. To clean the Outdoor Bushing of Smoothing Reactor Outage is required.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR	IntraState	06/07/2023	08:38			PO	1. Maintenance and alignment work of Bus-1, Bus-2 Aus. Bus And HCB Isolator. 2. Maintenance of CB, CT and Synch CVT.
SPARE LINE-2 BAY (404) @ TAPTITANDA	IntraState	17/07/2023	12:09			PO	Circuit breaker mechanism overhauling work by M/s CGL service Engineer.
MAIN BAY (408) OF BABHALESHWAR CKT - 2 @ EKTUNI	IntraState	18/07/2023	10:27	18/07/2023	18:10	PO	Diagnostic Testing of CB, CT & Routine Maintenance
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
PARLI (PG) - SOLAPUR(PG) CKT - I	InterState	18/07/2023	10:09	18/07/2023	23:28	PO	For Amp of Line Bay
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	13/07/2023	08:03			HT	H/T Due to load management.
KHADKA-AURANGABAD (WALUJ)	IntraState	18/07/2023	00:26	18/07/2023	07:56	HT	HT for Overvoltage
AKOLA-NANDGAONPETH (RPL-AMT)	IntraState	18/07/2023	09:50	18/07/2023	17:51	PO	Routine Maintenance & Testing work
WARORA - IEPL	IntraState	18/07/2023	09:51	18/07/2023	20:01	PO	Outage proposal on 400 KV Warora -IEPL Ckt for for fixing of spacer and repair sleeve and tightening of Nut Bolts at various Location.
DABHOL - NEW KOYNA CKT - 1	IntraState	18/07/2023	10:07	18/07/2023	22:46	PO	Diagnostic testing & Relay testing work , Routine maint. Work
KHADKA-AURANGABAD (WALUJ)	IntraState	18/07/2023	22:55			HT	H/T For controlling overvoltages.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	IntraState	16/07/2023	10:00			PO	ABB Circuit Breaker Pole & Mechanism overhauling;HV CB DCRM/timing

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 19/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	17/07/2023	13:04			PO	1.Replacement of HV CB under LES Scheme. 2.ICT will be in service through TBC.
400/220/33 KV 315 MVA ICT - 1 @ DHULE	IntraState	18/07/2023	09:56	18/07/2023	14:50	PO	Changing of Tap position from TAP No 13 to 15 to match the tap position of running parallel ICT's.
400/220/33 KV 315 MVA ICT - 1 @ DHULE	IntraState	18/07/2023	09:56	18/07/2023	14:50	EO	Changing of Tap Position
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
DAHANU - VERSOVA	IntraState	10/07/2023	10:24			PO	Shifting of Lines on Newly constructed Towers for NHSRCL Project Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
BOISAR - VERSOVA	IntraState	10/07/2023	10:27			PO	Shifting of Lines on Newly constructed Towers for NHSRCL Project. Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
PEDHAMBE ONI LINE	IntraState	18/07/2023	04:59	18/07/2023	06:06	T	Distance Protection
PALGHAR - NALASOPARA	IntraState	18/07/2023	05:16	18/07/2023	08:46	PO	For replacement of rusted old Disc insulator string at location no. 79,94,95,97,98 & 99.
TROMBAY - MULUND	IntraState	18/07/2023	05:21	18/07/2023	08:57	PO	Outage is required for safety purpose by M/s KVTL during stringing of 400KV Khargar-Vikhroli line between loc no. AP 59- AP 60 & 61-62 by M/s KVTL.
TROMBAY - KALWA	IntraState	18/07/2023	05:22	18/07/2023	09:01	PO	Outage is required for safety purpose by M/s KVTL during stringing of 400KV Khargar-Vikhroli line between loc no. AP 59- AP 60 & 61-62 by M/s KVTL.
URAN - APTA CKT - 1	IntraState	18/07/2023	06:58	18/07/2023	14:15	HT	Tripped on distance protection.
KARAD - KADEGAON	IntraState	18/07/2023	09:00	18/07/2023	19:04	PO	Cold line washing of insulator string from Loc No.1 to 85.
KANDALGAON - KOYNA (POPHALI)	IntraState	18/07/2023	11:45	18/07/2023	20:15	EO	Replacement of damaged conductors of R,Y,B Phase at Pophali S/Y.
COLOURCHEM - TEMGHAR	IntraState	18/07/2023	19:57	18/07/2023	20:51	T	TRIPPED ONLY FROM TEMGHAR END END ONLY
220KV GIS DCHI - COLOURCHEM	IntraState	18/07/2023	19:57	18/07/2023	20:28	T	TRIPPED ONLY FROM GIS DCHI END ONLY
PADGHE - TEMGHAR - 1	IntraState	18/07/2023	19:57			T	TRIPPED ON DISTANCE PROTECTION
PADGHE - WADA	IntraState	19/07/2023	03:17	19/07/2023	04:50	T	Tripped due to trial taken on 220kV Padghe-Temghar ckt1

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 19/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - JINDAL	IntraState	19/07/2023	03:17	19/07/2023	04:53	T	Tripped due to trial taken on 220kV Padghe-Temghar ckt1
PADGHE - KAMBA 2	IntraState	19/07/2023	03:17	19/07/2023	04:51	T	Tripped due to trial taken on 220kV Padghe-Temghar ckt1
PALGHAR - NALASOPARA	IntraState	19/07/2023	05:20			PO	For replacement of rusted old Disc insulator string at location no. 79,94,95,97,98 & 99.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	15/07/2023	12:45			EO	Attending the SF6 Gas leakage . Present SF6 gas pressure is 5.7
220/132kV 100MVA ICT -2 @ LONI DEOKAR	IntraState	18/07/2023	10:00	18/07/2023	16:00	PO	OLTC Overhauling work
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	18/07/2023	14:53	18/07/2023	16:28	PO	Annual relay testing of ICT
220 KV BUSBAR Outages/Trippings							
AUXILIARY BUS @ PHALTAN MIDC-220 KV	IntraState	16/07/2023	10:02			PO	For Gantry replacement from AH type to AF type
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	17/07/2023	23:35	18/07/2023	00:57	EO	Bird nest removal at loc. no 136,137,145,146,152

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage