

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Aug/2016 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	84.198	1239.819	1) Gujrat	13.644	87.355
2) Hydro	11.875	241.797	2) Madhya Pradesh	14.514	213.038
3) Gas	6.844	150.826	3) Chattisgarh	6.310	120.640
Total MSPGCL	102.917	1632.442	4) Maharashtra Net	79.380	1122.310
B) 1) APML	29.062	539.866	5) Goa (Amona)	-0.636	-12.011
2) JSWEL	21.963	370.690	6) TAPS 1&2 Injection	7.606	135.735
3) VIPL	14.235	175.334	7) RGPPL Injection	11.895	210.077
4) RPL(AMT)	0.000	0.000	8) Pench (MS)	0.241	4.459
5) WPCL	4.602	78.893	9) Pench (Excess)	-0.241	-4.459
6) PGPL	0.012	22.991	Total	132.472	1872.685
7) Other IPP	2.233	39.773	a) Mumbai Schedule	21.609	329.364
C) 1) TPCL Thermal	16.868	245.849	b) Mumbai Drawl	19.222	410.166
2) TPCL Hydro	6.042	104.623	c) MSEDCL Bilateral *	28.701	486.937
3) TPCL Gas	3.528	66.295	Include PX	0.000	-28.856
4) R-INFRA Thermal	11.458	183.034	d) Mumbai Bilateral *	21.609	329.364
D) STATE			Include PX	0.774	34.040
1) Thermal	184.619	2873.258	Include Standby	0.000	0.000
(A1+C1+C4+(B1-B6))			H) ENERGY CATERED (MUs)		
2) Hydro	17.917	346.420	1) MSEDCL	324.197	5160.641
3) Gas	10.384	240.112	2) Mumbai Discoms	57.118	1009.967
4) Wind	34.787	822.769	TOTAL STATE	381.315	6170.608
6) SOLAR	1.136	15.364			
TOTAL STATE	248.843	4297.923			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	3442	3439	3701	3367
MSPGCL Hydro	1056	745	183	56
MSPGCL Gas	278	278	281	283
MSPGCL Total Generation	4776	4462	4165	3706
Central Sector Receipt	6266	5800	5795	4998
WIND	1659	1680	1339	1437
CPP / IPP Thermal	3015	2999	3004	2985
CPP / IPP Gas	0	0	0	0
SOLAR	150	146	0	0
Exchange with Mumbai	-1125	-1076	-773	-511
MSEDCL DEMAND MET	14741	14011	13530	12615
Load Shedding	0	0	0	0
MSEDCL DEMAND	14741	14011	13530	12615
TPCL GENERATION	1304	1294	1246	803
R-INFRA GENERATION	507	507	504	506
MUMBAI DEMAND	2936	2877	2523	1820
STATE DEMAND MET	17677	16888	16053	14435
STATE DEMAND	17677	16888	16053	14435
Frequency (Hz)	50.01	49.97	49.89	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 06.01 Hrs	49.75 Hz at 22.14 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 18/Aug/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.46	142.64	516	362
Total	10.46	142.64		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	10.56	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	10.56		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.41	36.93	194	169
Unit 4	3.90	61.51	179	137
Unit 5	9.32	147.50	415	350
Unit 6	10.51	137.77	455	410
Unit 7	9.69	153.56	427	379
Unit 8	8.47	83.38	401	251
Total	46.29	620.65		
Paras				
Unit 3	3.89	37.62	260	0
Unit 4	3.07	86.99	250	0
Total	6.96	124.60		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	11.63	182.22	500	470
Total	11.63	182.22		
Nasik				
Unit 3	4.40	71.26	195	165
Unit 4	4.46	60.68	199	156
Unit 5	0.00	10.04	0	0
Total	8.85	141.99		
Uran				
All Units	6.84	150.83	295	274
Total	6.84	150.83		
PGPL				
Unit 1	0.01	14.19	12	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	0.00	8.80	0	0
Total	0.01	22.99		
PENCH (MS)				
Pench (MS)	0.24	4.46	26	0
Total	0.24	4.46		
Koyna				
Stage 1-2	3.33	69.12	405	40
Stage 4	4.86	63.30	972	0
Stage 3	1.84	42.28	240	0
Total	10.03	174.71		
Hydro				
KDPH	0.00	5.89	0	0
VTRNA	0.00	14.96	0	0
TILLARI	0.18	5.04	61	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.46	8.27	80	0
RNGR+BHTSA	0.00	4.33	0	0
BHANDARDRA	0.00	7.97	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.35	6.64	24	11
GHATGHAR	0.86	14.01	250	0
Total	1.85	67.09		
Wind				
Total	34.79	822.77	0	0
Total	34.79	822.77		
CPP				
APML(Mus)	29.06	539.87	0	0
JSWEL(Mus)	21.96	370.69	0	0
VIPL(Mus)	14.24	175.33	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	4.60	78.89	0	0
Other(Mus)	2.23	39.77	0	0
Total	72.10	1204.56		
SOLAR				
Total	1.14	15.36	0	0
Total	1.14	15.36		
Tata				
Trombay 5	10.99	153.89	487	317
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.15	40.72	115	58
Trombay 7B	1.38	25.58	67	46
Trombay 8	5.88	91.96	248	241
TATA Hydro	6.04	104.62	387	0
Total	26.44	416.77		
R-INFRA				
1-2	11.46	183.03	507	402
Total	11.46	183.03		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	0.00	17.16
Koradi 9	0.00	0.00
Koradi 10	0.00	0.00
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	84.20	1239.82
MSPGCL Thml+Gas	91.04	1390.64
MSPGCL Hydro	11.88	241.80

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	102.92	1632.44
Koyna 1,2 & 4 Total	8.19	132.43
State Total	248.84	4297.92

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Aug/2016

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3380	240	282	3902	1383	3113	12	0	4669	4943	-666	12687	0	12687	2042	14729	49.97
2	3405	85	293	3783	1424	3004	0	0	4797	4927	-566	12572	0	12572	1922	14494	49.96
3	3367	56	283	3706	1437	2985	0	0	4869	4998	-511	12615	0	12615	1820	14435	49.97
4	3440	61	293	3794	1484	2987	0	0	4863	5025	-440	12850	0	12850	1762	14612	50.00
5	3372	51	283	3706	1423	2988	0	0	4865	5307	-515	12909	0	12909	1753	14662	49.98
6	3435	86	290	3811	1378	2992	0	0	5107	5737	-547	13371	0	13371	1846	15217	50.01
7	3529	675	279	4483	1287	2995	0	7	5398	5893	-574	14091	0	14091	1957	16048	49.99
8	3445	1554	292	5291	1210	3006	0	27	5398	5984	-625	14893	0	14893	2123	17016	49.98
9	3434	1804	283	5521	1289	2994	0	63	5461	5881	-784	14964	0	14964	2484	17448	50.01
10	3433	1522	276	5231	1442	3021	0	107	5632	6063	-950	14914	0	14914	2743	17657	50.00
11	3383	1212	292	4887	1479	3045	0	133	5738	6267	-1105	14706	0	14706	2913	17619	49.98
12	3442	1056	278	4776	1659	3015	0	150	5685	6266	-1125	14741	0	14741	2936	17677	50.01
13	3439	745	278	4462	1680	2999	0	146	5788	5800	-1076	14011	0	14011	2877	16888	49.97
14	3369	232	288	3889	1682	3004	0	158	5693	5935	-977	13691	0	13691	2748	16439	50.01
15	3393	202	278	3873	1734	3009	0	126	5792	6197	-953	13986	0	13986	2723	16709	50.00
16	3449	96	292	3837	1645	3005	0	120	5718	6147	-924	13830	0	13830	2704	16534	49.97
17	3601	187	274	4062	1566	3016	0	59	5293	5621	-872	13452	0	13452	2657	16109	49.99
18	3664	62	281	4007	1526	3043	0	33	4577	4430	-1008	12031	0	12031	2599	14630	50.03
19	3747	158	279	4184	1415	3030	0	7	5094	4548	-903	12281	0	12281	2473	14754	49.98
20	3717	409	289	4415	1286	3019	0	0	5385	5563	-786	13497	0	13497	2532	16029	49.97
21	3701	183	281	4165	1339	3004	0	0	5423	5795	-773	13530	0	13530	2523	16053	49.89
22	3699	382	291	4372	1260	2976	0	0	5111	5240	-845	13003	0	13003	2381	15384	49.90
23	3690	527	295	4512	1317	2928	0	0	4714	4985	-878	12864	0	12864	2358	15222	49.92
24	3664	290	294	4248	1442	2913	0	0	4761	4920	-819	12704	0	12704	2242	14946	49.99
MUs	84.20	11.88	6.84	102.92	34.79	72.10	0.01	1.14	125.83	132.47	-19.22	324.20	0.00	324.20	57.12	381.32	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 18/Aug/2016

Position as on 6.30 Hrs of 19/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkhedha Unit 1	210	25/06/2016	23.45		Continued.	Zero Schedule by MSEDCL from 00.00Hrs Dt.19-7-16 and A.O.H from 25/06/2016 to 18/07/2016	
MSPGCL	Khaparkhedha Unit 3	210	05/07/2016	23.52		Continued.	Zero Shedule By MSEDCL, converted for AOH from 00 Hrs Dt.25-7-16	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-2	270	18/06/2016	06.54		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	30/06/2016	10.11		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 5	200	01/07/2016	02.23		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Koradi Unit 7	210	01/07/2016	04.43		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-1	270	01/07/2016	18.40		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 5	500	01/07/2016	23.59		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkhedha Unit 2	210	05/07/2016	23.46		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Khaparkhedha Unit 4	210	08/07/2016	03.07		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	08/07/2016	23.57		Continued.	ID Fan Problem (Converted	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Aug/2016

Position as on 6.30 Hrs of 19/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							to Zero schedule by MSEDCL from 11-07-2016)	
IPP	Adani U-4	660	13/07/2016	02.22		Continued.	Zero Shedule By MSEDCL,Shedule Gliven On 21/08/2016	
MSPGCL	Nasik Unit 5	210	03/08/2016	17.30		Continued.	Zero shedule	
IPP	Adani U-1	660	05/08/2016	11.44	19/08/2016	00.21	Zero Schedule from MSEDCL	
IPP	Adani U-5	660	06/08/2016	23.54	19/08/2016	14.34	Zero schedule given by MSDCL.	
MSPGCL	Paras Unit 3	250	08/08/2016	00.01	18/08/2016	06.00	Zero schedule given by MSDCL.	
MSPGCL	Chandrapur Unit 9	500	11/08/2016	22.11		Continued.	Oil Shortage.	
MSPGCL	Uran Unit B0	120	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Bhusawal Unit 4	500	14/08/2016	21.28		Continued.	Zero schedule given by MSEDCL	
RGPL	Dabhol 3A	230	16/08/2016	17.24		Continued.	Change Over	
MSPGCL	Koyna Unit 8	80	17/08/2016	16.43	18/08/2016	00.45	Main Bus GOD B Phase Conductor Snapped of pedambe -II line	
PGPL	PGPL U2	126	18/08/2016	00.15		Continued.	Gas shortage	
PGPL	PGPL U1	262	18/08/2016	00.23		Continued.	Gas shortage	
MSPGCL	Koyna Unit 8	80	18/08/2016	06.40	18/08/2016	10.20	TGB Oil level very Low	
MSPGCL	Paras Unit 4	250	18/08/2016	07.02	18/08/2016	16.11	Furnace Pressure High	
MSPGCL	Koradi Unit-8	660	19/08/2016	10.17	19/08/2016	13.09	Air preheater problem.	
MSPGCL	Koyna Unit 8	80	19/08/2016	11.00		Continued.	High Vibration On LGB & UGB.	
IPP	VIPL U-2	300	19/08/2016	12.32		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit 5	108	19/08/2016	22.03		Continued.	Boiler trip.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 19/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Dhule Khandwa II	InterState	17/08/2016	23.33	18/08/2016	06.56	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	19/08/2016	20.20		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	27/07/2016	13.09		Continued.	HT	Over Voltage
Ektuni-Bableswhar ckt II	IntraState	01/08/2016	09.53		Continued.	HT	To control Padgha-BBLSR L/L
Padghe - Kharghar	IntraState	07/08/2016	17.07		Continued.	PO	Shifted on TBC at kharghar end
karad -kolhapur-I	IntraState	09/08/2016	14.48	19/08/2016	09.12	T	Over Voltage,Opportunity Outage from DT 16.08.2016.
Karad - Jaigad - II	IntraState	13/08/2016	13.02	18/08/2016	10.06	HT	Over Voltage
N.Koyna-Karad -Ckt II	IntraState	15/08/2016	16.49	18/08/2016	10.02	HT	Over Voltage
Lonikand2-Lonikand1 (Intrconector)	IntraState	18/08/2016	09.17	18/08/2016	15.15	PO	Half yearly maintenance work
Koradi-India Bulls	IntraState	18/08/2016	14.03	19/08/2016	06.21	T	Distance Protection
Karad - Jaigad - II	IntraState	18/08/2016	16.45	19/08/2016	09.58	HT	Over Voltage
Babhaleswar - Bhusawal II	IntraState	19/08/2016	09.09	19/08/2016	19.22	PO	Maintance work and relay testing work.
New Koyna - Koyna Stage IV-II	IntraState	19/08/2016	09.10	19/08/2016	19.44	PO	Testing Work
karad -kolhapur-II	IntraState	19/08/2016	09.20		Continued.	PO	For Isolator Assembly Replacement Work.
Main Bus II @ Chandrapur SW	IntraState	19/08/2016	09.25	19/08/2016	18.57	PO	Diagnostic testing work.
Jaigad-Karad Ckt-I	IntraState	19/08/2016	17.11		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	18/08/2016	11.25	18/08/2016	13.57	EO	Attending Hot Spot
Ict Spare Single Unit 167 Mva Ict @Jejuri	IntraState	18/08/2016	14.56	18/08/2016	18.58	PO	Testing Work
220 KV LINE Outages/Trippings							
Borivali - Tarapur	InterState	18/08/2016	14.20	19/08/2016	17.05	PO	shifted on TBC
Khaparkhedha-Butibori 3	InterState	19/08/2016	10.58	19/08/2016	15.25	PO	Jumper Tightening and Fixing of Nut Bolts
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Aurangabad (Waluj)-Bhenda	IntraState	22/06/2016	23.02	18/08/2016	05.01	HT	Hand Tripped.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Bableswhar- Alephata	IntraState	24/07/2016	07.57		Continued.	HT	Load Diversion.
Kandalgaon - Sona Alloys	IntraState	17/08/2016	09.05	18/08/2016	13.05	T	Distance Protection
Bableswhar -Bhenda	IntraState	18/08/2016	04.34	18/08/2016	10.15	T	Distance Protection
Pedambe-Nerle	IntraState	18/08/2016	08.20	18/08/2016	16.20	PO	Attending Hot Spot
Jejuri-Phursungi 2	IntraState	18/08/2016	10.30	18/08/2016	19.09	PO	Annual Maintenance Work
Jejuri (400 Kv)- Baramati li	IntraState	18/08/2016	16.36	18/08/2016	21.40	PO	CT Ratio changing
Lonand-Baramati	IntraState	18/08/2016	17.57	18/08/2016	18.23	PO	Bus Bar Protection Operated
Pophali - Kdph	IntraState	19/08/2016	00.20		Continued.	HT	Due to Snapping of conductor
Kalwa Salsette III	IntraState	19/08/2016	01.44	19/08/2016	05.15	PO	safety purpose for new tower foundation
Padgha - Temghar I	IntraState	19/08/2016	08.45	19/08/2016	12.11	PO	Air compressor release value changing work.
Aarey Saki Line 1	IntraState	19/08/2016	09.41	19/08/2016	18.28	PO	Annual Maintenance Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 19/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kharghar - Tss Panvel	IntraState	19/08/2016	10.23	19/08/2016	17.28	PO	Tree cutting work.
Harangul-Parly	IntraState	19/08/2016	11.06	19/08/2016	14.22	PO	Attending Hot Spot
IPCL - SPCL	IntraState	19/08/2016	11.44	19/08/2016	13.50	PO	Nut bolt tightening work.
New Koyana - Loteparshuram	IntraState	19/08/2016	12.47	19/08/2016	16.57	PO	Replacement of damaged jumper
Apta - Taloja	IntraState	19/08/2016	13.00	19/08/2016	16.02	PO	Replacement work and hot spot attending work.
Jejuri (400 Kv)- Baramati li	IntraState	19/08/2016	16.49	19/08/2016	18.50	PO	Attend Y phase CT leakage.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220 Kv /132 Kv 100 Mva Ptr @Chitegaon	IntraState	19/08/2016	11.43	19/08/2016	18.58	PO	Routine Maintenance Work
132 KV LINE Outages/Trippings							
Kurunda - Hingoli	IntraState	19/08/2016	08.01	19/08/2016	08.40	T	Distance Protection
Kurunda - Hingoli	IntraState	19/08/2016	08.49	19/08/2016	09.02	T	Tripped
Malegaon-Mangrulpir	IntraState	19/08/2016	18.07	19/08/2016	21.00	T	Load position.
Malegaon-Washim	IntraState	19/08/2016	18.10	19/08/2016	20.48	T	Load position.
100 KV LINE Outages/Trippings							
Vasai-li - Vasai 2 Line	IntraState	13/08/2016	08.53		Continued.	HT	ICT Problem.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage