

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Aug/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	114.347	2311.302	1) Gujrat	14.242	219.046
2) Hydro	30.081	288.576	2) Madhya Pradesh	7.930	133.675
3) Gas	4.394	11.464	3) Chattisgarh	2.020	30.680
Total MSPGCL	148.822	2611.342	4) Maharashtra	191.801	2902.097
B) 1) APLM	46.611	987.398	5) Goa (Amona)	-1.757	-28.799
2) JSWEL	21.858	265.213	Total	214.236	3256.699
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.519	571.201
4) RPL(AMT)	30.642	491.058	b) Mumbai Drawl	34.393	637.310
5) SWPGPL	11.858	165.177	c) MSEDCL Bilateral *	107.874	1649.213
6) Other IPP	7.213	104.366	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.508	571.191
C) 1) TPCL Thermal	14.033	210.509	Include PX	0.000	0.000
2) TPCL Hydro	7.937	100.006	Standby	0.011	0.011
3) TPCL Gas	2.371	52.248	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.283	168.679	1) MSEDCL	479.811	8072.562
D) STATE			2) Mumbai Discoms	69.017	1168.752
1) Thermal	256.845	4703.702	3) Other Discoms	10.323	179.662
(A1+C1+C4+(B1-B6))			TOTAL STATE	559.151	9420.976
2) Hydro	38.018	388.582			
(A2+C2)					
3) Gas	6.765	63.712			
(A3+B7+C3)					
4) Wind	36.169	803.260			
6) SOLAR	7.118	205.021			
TOTAL STATE	344.915	6164.277			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	4711	4682	4937	5033
MSPGCL Hydro	970	1369	1553	1193
MSPGCL Gas	182	181	186	188
MSPGCL Total Generation	5863	6232	6676	6414
Central Sector Receipt	11293	10372	8214	6788
WIND	1477	1373	1637	1336
CPP / IPP Thermal	4950	4939	4949	4686
CPP / IPP Gas	0	0	0	0
SOLAR	1008	1012	0	0
Exchange with Mumbai	-2184	-2098	-1394	-1071
MSEDCL DEMAND MET	21936	21382	19629	17749
Load Shedding	0	0	0	0
MSEDCL DEMAND	21936	21382	19629	17749
TPCL GENERATION	879	914	1208	1176
AEML GENERATION	328	397	499	473
MUMBAI DEMAND	3391	3409	3101	2720
OTHER DISCOM DEMAND	471	448	453	404
STATE DEMAND MET	25798	25239	23183	20873
STATE DEMAND	25798	25239	23183	20873
Frequency (Hz)	50.03	50.05	50.03	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 18.03 Hrs	49.77 Hz at 06.20 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.16	57.04	155	90
Unit 8	0.00	218.98	0	0
Unit 9	12.47	221.23	556	429
Unit 10	0.00	0.00	0	0
Total	15.62	497.25		
Bhusawal				
Unit 3	3.20	54.74	145	125
Unit 4	10.67	131.16	480	380
Unit 5	3.12	157.29	455	0
Total	16.99	343.20		
Parli				
Unit 6	5.41	47.88	250	125
Unit 7	5.61	47.36	248	187
Unit 8	3.64	45.81	161	146
Total	14.66	141.05		
Chandrapur				
Unit 3	3.37	53.93	151	112
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	102.86	0	0
Unit 7	6.97	130.14	312	248
Unit 8	10.44	184.93	490	385
Unit 9	10.86	183.95	488	405
Total	31.63	655.80		
Paras				
Unit 3	0.00	72.39	0	0
Unit 4	5.22	81.06	233	202
Total	5.22	153.46		
Khaparkheda				
Unit 1	2.96	38.42	150	100
Unit 2	2.77	47.79	122	95
Unit 3	3.52	66.80	178	120
Unit 4	3.96	70.28	183	125
Unit 5	9.42	173.37	425	330
Total	22.62	396.66		
Nasik				
Unit 3	0.00	46.24	0	0
Unit 4	3.83	49.19	167	143
Unit 5	3.78	28.46	167	137
Total	7.61	123.89		
Uran				
All Units	4.39	11.46	188	179
Total	4.39	11.46		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.71	15.43	51	0
Total	0.71	15.43		
Koyna				
Stage 1-2	5.17	55.22	375	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	15.20	85.61	756	245
Stage 3	4.58	34.61	240	80
Total	24.95	175.44		
Hydro				
KDPH	0.00	7.15	0	0
VTRNA	0.00	0.61	0	0
TILLARI	0.00	1.62	0	0
BHIRA T.R.	0.46	8.01	80	0
SMLHY_PTN	3.75	75.00	160	152
GHATGHAR	0.22	5.32	125	0
Total	4.42	97.70		
Wind				
Total	36.17	803.26	0	0
Total	36.17	803.26		
CPP				
APML(Mus)	46.61	987.40	0	0
JSWEL(Mus)	21.86	265.21	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.64	491.06	0	0
SWPGPL-Mus	11.86	165.18	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.15	86.19	265	239
Other(Mus)	1.06	18.18	0	0
Total	118.18	2013.21		
SOLAR				
Total	7.12	205.02	0	0
Total	7.12	205.02		
Tata				
Trombay 5	9.32	139.06	456	282
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.34	31.02	100	39
Trombay 7B	1.03	21.23	61	35
TATA Hydro	7.94	100.01	437	234
Trombay 8	4.72	71.44	221	122
Total	24.34	362.76		
AEML				
DTPS U-1&2	10.28	168.68	500	328
Total	10.28	168.68		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	114.35	2311.30	MSPGCL Total	148.82	2611.34
			MSPGCL Thml+Gas	118.74	2322.77	Koyna 1,2 & 4 Total	20.37	140.83
			MSPGCL Hydro	30.08	288.58	State Total	344.92	6164.28

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 18/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	4622	1126	182	5930	1770	4943	0	0	7717	7458	-1011	18691	0	0	18691	2567	399	21657	50.04
2	4600	1444	183	6227	1613	4973	0	0	7246	7184	-911	18707	0	0	18707	2380	379	21466	50.04
3	4577	1531	183	6291	1572	4924	0	0	7469	7529	-885	19084	0	0	19084	2225	346	21656	50.03
4	4574	1551	182	6307	1464	4940	0	0	7909	7683	-968	19083	0	0	19083	2128	343	21554	50.05
5	4578	1575	183	6336	1342	4946	0	0	8522	8253	-1037	19468	0	0	19468	2118	372	21958	49.99
6	4605	1545	183	6333	1331	4958	0	0	9093	9214	-903	20557	186	0	20743	2230	375	23349	49.94
7	4622	1548	183	6353	1306	4909	0	39	9813	9347	-868	20665	897	0	21562	2403	422	24386	49.95
8	4669	1536	182	6387	1286	4927	0	246	10306	9963	-1058	21319	62	15	21381	2611	432	24424	50.02
9	4690	1239	182	6111	1378	4898	0	633	10499	10555	-1396	21734	0	0	21734	2910	446	25089	50.00
10	4719	1069	183	5971	1520	4943	0	837	10856	10762	-2020	21550	0	0	21550	3200	463	25213	49.99
11	4711	970	182	5863	1477	4950	0	1008	11136	11293	-2184	21936	0	26	21936	3391	471	25798	50.03
12	4652	1158	182	5992	1311	4956	0	1012	11043	11268	-2210	21856	0	6	21856	3452	473	25781	50.03
13	4682	1369	181	6232	1373	4939	0	1012	10475	10372	-2098	21382	0	6	21382	3409	448	25239	50.05
14	4800	858	182	5840	1396	4906	0	866	10656	10537	-1934	21174	0	2	21174	3266	437	24877	50.03
15	4803	1036	184	6023	1486	4897	0	622	10406	10059	-1995	20639	0	2	20639	3308	452	24400	50.01
16	4831	950	181	5962	1705	4940	0	451	10025	9974	-1865	20722	0	0	20722	3333	444	24499	50.05
17	4811	1076	181	6068	1809	4932	0	265	9358	9272	-1874	20013	0	0	20013	3284	459	23756	50.04
18	4717	1311	183	6211	1738	4942	0	113	8482	8577	-1643	19472	0	13	19472	3210	466	23148	50.06
19	4804	1506	179	6489	1818	4944	0	14	8237	8111	-1511	19379	0	0	19379	3146	486	23011	50.06
20	4937	1553	186	6676	1637	4949	0	0	8361	8214	-1394	19629	0	0	19629	3101	453	23183	50.03
21	5110	852	186	6148	1553	4946	0	0	8034	7824	-1285	18728	0	0	18728	2987	458	22173	50.04
22	5121	993	186	6300	1513	4955	0	0	7089	6990	-1180	18124	0	0	18124	2865	454	21443	50.03
23	5079	1092	187	6358	1435	4883	0	0	6918	7010	-1092	18153	0	0	18153	2773	440	21367	50.03
24	5033	1193	188	6414	1336	4686	0	0	6839	6788	-1071	17749	0	0	17749	2720	404	20873	50.02
MUs	114.35	30.08	4.39	148.82	36.17	118.18	0.00	7.12	216.49	214.24	-34.39	479.81	1.15	0.07	480.96	69.02	10.32	560.30	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

- 1) 132 KV BBLR-Rahuri line overload.
- 2) 132 KV BBLR -sangamner line overload.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 18/Aug/2023

Position as on 6.30 Hrs of 19/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	27/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	31/08/2023
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	25/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	COH (Hot spot on Stator).	13/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	Annual Overhaul	18/09/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	25/08/2023
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	29/08/2023
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	02/09/2023
MSPGCL	Nasik Unit 3	210	13/08/2023	16:00		Continued.	Boiler Tube Leakage (Tolling from 15:00 hrs on Dt 14.08.2023.)	
MSPGCL	Chandrapur Unit 6	500	14/08/2023	06:30		Continued.	BTL	19/08/2023
MSPGCL	Paras Unit 3	250	16/08/2023	10:48	19/08/2023	20:22	Boiler Tube Leakage	19/08/2023
MSPGCL	Bhusawal Unit 5	500	17/08/2023	00:17	18/08/2023	14:50	Boiler Tube Leakage	
IPP	Adani U-2	660	17/08/2023	14:30		Continued.	APH A Hot PA bellow leakage.	21/08/2023
MSPGCL	Koradi Unit 8	660	17/08/2023	16:20		Continued.	Boiler Tube Leakage	24/08/2023
MSPGCL	Uran Unit 8	108	17/08/2023	23:17		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	18/08/2023	22:45		Continued.	Bottom Ash Evacuation Problem.	21/08/2023
MSPGCL	Khaparkheda Unit 3	210	19/08/2023	11:11		Continued.	Boiler Tube Leakage	21/08/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Aug/2023

Position as on 6.30 Hrs of 19/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	SWPGPL U-2	135	19/08/2023	19:02		Continued.	Generator protection operated	20/08/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 18/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 19/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BUSBAR Outages/Tripping							
MAIN BUS - 2 @ EKTUNI	IntraState	18/08/2023	10:11	18/08/2023	17:09	PO	Attending Hotspot Work.
MAIN BUS - 2 @ EKTUNI	IntraState	18/08/2023	10:11	19/08/2023	17:09	EO	Emergency Outage to attend visual hot-spot of 402-89B R-phase Isolator (Towards Bus) at 765KV Ektuni
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	19/08/2023	09:38	19/08/2023	22:05	PO	Replacement of connecting jumper of capacitor bank at Pole-1 base filter due to aging effect
400 KV TIEBAY Outages/Tripping							
Tie bay (405) of Deepnagar line @ Taptitanda	IntraState	18/08/2023	11:22	18/08/2023	17:33	PO	405 Tie bay 89B isolator B Phase, contacts alignment work.
400 KV TBC Outages/Tripping							
TBC @ NAGOTHANE	IntraState	18/08/2023	11:02			PO	CB replacement work
400 KV MAINBAY Outages/Tripping							
SPARE LINE-2 BAY (404) @ TAPTITANDA	IntraState	18/08/2023	11:22	18/08/2023	17:33	PO	To attend 405 bay 89 B Isolator B phase contacts alignment work.
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	18/08/2023	01:36	18/08/2023	11:44	T	Tripped on distance protection
DHULE - SSNNL CKT - 2	InterState	19/08/2023	17:55	19/08/2023	21:31	T	LBB Protection operated at SSNNL End
DHULE - SSNNL CKT - 1	InterState	19/08/2023	17:55	19/08/2023	19:22	T	LBB Protection operated at SSNNL End
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
KALWA - TALEGAON (PG)	InterState	19/08/2023	23:19		Continued.	PO	For bunching in between locations no. 153-154 for erection of newly proposed 2 nos. of Towers in between location no 195 to 197. The 400kV Kalwa- Talegaon line will be taken in service by temporary rerouting in between location no. 153 to 154 for 15 days.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of ȳȳȳ phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
KHADKA-AURANGABAD (WALUJ)	IntraState	17/08/2023	19:48	18/08/2023	08:34	HT	HT due to Overvoltage
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	IntraState	18/08/2023	14:22	18/08/2023	18:29	PO	Disc Insulator String Replacement Work of B-ph at Loc no.111 & 133
KHADKA-AURANGABAD (WALUJ)	IntraState	18/08/2023	20:04	19/08/2023	10:02	HT	H/T due to O/V
KALWA - KHARGHAR	IntraState	19/08/2023	23:43		Continued.	PO	For bunching in between locations no. 153-154 for erection of newly proposed 2 nos. of Towers in between location no 195 to 197. The 400kV Kalwa- Talegaon line will be taken in service by temporary rerouting in between location no. 153 to 154 for 15 days.
400 KV ICT Outages/Tripping							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 19/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ SALSETTE	IntraState	19/08/2023	00:34	19/08/2023	01:57	PO	Protection testing
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
AAREY - AEML BORIVALI	IntraState	06/08/2023	18:20			PO	Shifting of 220kV AIS Bay No 9 to New GIS Bay No 18.
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
KALWA - TFIPL	IntraState	16/08/2023	00:27	18/08/2023	08:12	PO	For removing the jumpers at Loc no.40 for making LILO through at 220KV Pawane GIS S/stn.
KHARGHAR - BORIVALI CKT - 2	IntraState	17/08/2023	23:21	18/08/2023	06:43	EO	For charging of 220KV Kalwa-TFIPL Line.
KHARGHAR - BORIVALI CKT - 2	IntraState	17/08/2023	23:21	18/08/2023	06:43	HT	For charging of 220KV Kalwa-TFIPL Line.
KHARGHAR - NET MAGIC GIS	IntraState	17/08/2023	23:44	18/08/2023	06:07	HT	For charging of 220KV Kalwa-TFIPL Line.
KHARGHAR - NET MAGIC GIS	IntraState	17/08/2023	23:44	18/08/2023	06:07	EO	For charging of 220KV Kalwa-TFIPL Line.
VITA - GHATNANDRE	IntraState	18/08/2023	01:22	18/08/2023	05:42	HT	Emergency outage to attend heavy sparking
VITA - GHATNANDRE	IntraState	18/08/2023	01:22	18/08/2023	05:42	EO	Replacement of Insulator at Loc 1 CP loc Rph and attending Hotspot.
220KV KURUNDA -GIRWALI CKT	IntraState	18/08/2023	11:07	18/08/2023	12:47	PO	Replacement of Disc Insulators Loc no. 350 Y ph.
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	19/08/2023	11:28	19/08/2023	13:24	PO	: Replacement of R ph Flashover String At Loc no 31 observed during Vertical Patrolling.
TIFIL - KALWA	IntraState	19/08/2023	17:43	19/08/2023	21:10	HT	Emergency outage for T formation with 220 Kv Pawane ss
KHARGHAR - BORIVALI CKT - 2	IntraState	19/08/2023	17:45	19/08/2023	20:24	HT	Emergency outage availed for safety purpose for T formation with 220 KV PAWANE SS
KHARGHAR - NET MAGIC GIS	IntraState	19/08/2023	18:10	19/08/2023	20:37	HT	Emergency outage availed for safety purpose for T formation with 220 KV PAWANE SS
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22-22 KV 100 MVA PTR 2 @ PARVATI	IntraState	17/08/2023	14:40	19/08/2023	21:15	PO	EHV CB overhauling work
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	18/08/2023	10:17	18/08/2023	10:09	PO	CTR maintenance work
220/33kV 50MVA TF-2 @ KOPARGAON	IntraState	19/08/2023	10:17	19/08/2023	14:35	PO	For inspection and attending problem of OLTC
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	IntraState	19/08/2023	10:24	19/08/2023	18:10	PO	For replacing OTI & WTI.
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	IntraState	19/08/2023	10:27	19/08/2023	14:01	PO	CTR Maintenance work.
220 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 19/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57		Continued.	HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage