

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Sep/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	100.445	2056.238	1) Gujrat	9.944	165.402
2) Hydro	10.555	225.890	2) Madhya Pradesh	7.166	48.398
3) Gas	2.114	50.950	3) Chattisgarh	3.950	61.570
Total MSPGCL	113.114	2333.078	4) Maharashtra	128.691	2729.159
B) 1) APLM	61.485	1149.715	5) Goa (Amona)	-1.232	-21.125
2) JSWEL	17.386	329.346	Total	148.519	2983.404
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.022	596.349
4) RPL(AMT)	15.409	290.415	b) Mumbai Drawl	27.799	653.394
5) SWPGPL	2.696	81.799	c) MSEDCL Bilateral *	67.231	990.020
6) Other IPP	5.034	102.347	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.022	596.196
C) 1) TPCL Thermal	10.524	209.513	Include PX	0.000	0.000
2) TPCL Hydro	6.801	92.294	Standby	0.000	0.153
3) TPCL Gas	0.000	13.433	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.614	168.366	1) MSEDCL	362.701	6983.192
D) STATE			2) Mumbai Discoms	53.738	1137.002
1) Thermal	221.593	4387.739	3) Other Discoms	8.488	161.701
(A1+C1+C4+(B1-B6))			TOTAL STATE	424.927	8281.895
2) Hydro (A2+C2)	17.356	318.184			
3) Gas (A3+B7+C3)	2.114	64.383			
4) Wind	25.065	371.371			
6) SOLAR	10.280	156.812			
TOTAL STATE	276.408	5298.489			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	3907	3997	4566	4197
MSPGCL Hydro	305	671	1963	178
MSPGCL Gas	89	88	86	90
MSPGCL Total Generation	4301	4756	6615	4465
Central Sector Receipt	7060	6070	5546	5467
WIND	1059	911	1236	935
CPP / IPP Thermal	4022	3766	5028	4183
CPP / IPP Gas	0	0	0	0
SOLAR	1176	1262	0	0
Exchange with Mumbai	-1318	-1453	-1103	-920
MSEDCL DEMAND MET	15936	14956	16915	13837
Load Shedding	0	0	0	0
MSEDCL DEMAND	15936	14956	16915	13837
TPCL GENERATION	621	602	929	758
AEML GENERATION	444	480	481	282
MUMBAI DEMAND	2383	2535	2513	1960
OTHER DISCOM DEMAND	364	356	407	293
STATE DEMAND MET	18683	17847	19835	16090
STATE DEMAND	18683	17847	19835	16090
Frequency (Hz)	49.98	50.02	49.91	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 06:02 Hrs	49.68 Hz at 19:06 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	8.65	182.55	420	0
Unit 9	0.00	0.00	0	0
Unit 10	10.00	182.62	450	375
Total	18.65	404.52		
Bhusawal				
Unit 3	2.10	36.67	125	0
Unit 4	7.22	145.68	460	0
Unit 5	8.99	30.74	455	275
Total	18.32	213.09		
Parli				
Unit 6	4.22	77.20	210	146
Unit 7	4.16	60.73	194	144
Unit 8	3.56	66.70	180	127
Total	11.94	204.63		
Chandrapur				
Unit 3	3.09	50.62	160	110
Unit 4	2.27	53.60	110	81
Unit 5	6.64	89.86	300	245
Unit 6	0.00	100.58	0	0
Unit 7	0.00	107.66	0	0
Unit 8	0.00	49.00	0	0
Unit 9	8.78	171.78	434	275
Total	20.77	623.09		
Paras				
Unit 3	4.21	77.54	190	146
Unit 4	3.84	77.71	175	143
Total	8.06	155.25		
Khaparkheda				
Unit 1	2.59	47.00	125	80
Unit 2	0.00	38.82	0	0
Unit 3	3.49	59.91	180	128
Unit 4	3.24	51.98	165	125
Unit 5	8.19	146.13	425	270
Total	17.51	343.83		
Nasik				
Unit 3	0.00	32.57	0	0
Unit 4	2.46	28.11	122	53
Unit 5	2.74	51.15	122	103
Total	5.20	111.82		
Uran				
All Units	2.11	50.95	91	85
Total	2.11	50.95		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	10.51	27	23
Total	0.60	10.51		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.09	42.04	400	35
Stage 4	1.65	35.23	976	0
Stage 3	0.94	20.45	160	0
Total	4.68	97.71		
Hydro				
KDPH	0.43	3.10	18	18
VTRNA	0.86	13.75	61	0
TILLARI	0.70	9.17	58	0
BHIRA T.R.	0.49	7.67	80	0
SMLHY_PTN	2.58	79.82	111	94
GHATGHAR	0.21	4.16	125	0
Total	5.28	117.67		
Wind				
Total	25.06	371.37	0	0
Total	25.06	371.37		
CPP				
APML(Mus)	61.48	1149.72	0	0
JSWEL(Mus)	17.39	329.35	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	15.41	290.42	0	0
SWPGPL-Mus	2.70	81.80	0	0
Other(Mus)	5.03	102.35	0	0
Total	102.01	1953.62		
SOLAR				
Total	10.28	156.81	0	0
Total	10.28	156.81		
Tata				
Trombay 5	7.08	141.06	377	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	8.68	0	0
Trombay 7B	0.00	4.76	0	0
TATA Hydro	6.80	92.29	411	36
Trombay 8	3.44	68.46	173	132
Total	17.32	315.24		
AEMIL				
DTPS U-1&2	8.61	168.37	481	282
Total	8.61	168.37		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	100.44	2056.24	MSPGCL Total	113.11	2333.08
			MSPGCL Thml+Gas	102.56	2107.19	Koyna 1,2 & 4 Total	3.74	77.26
			MSPGCL Hydro	10.56	225.89	State Total	276.41	5298.49

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4232	214	89	4535	1093	4313	0	0	5415	5494	-1079	14008	0	14008	2203	348	16559	49.99
2	4191	177	90	4458	1050	4255	0	0	5514	5373	-1009	13810	0	13810	2066	317	16193	50.00
3	4197	178	90	4465	935	4183	0	0	5741	5467	-920	13837	0	13837	1960	293	16090	50.01
4	4252	186	91	4529	732	4200	0	0	5930	5912	-892	14199	0	14199	1893	282	16374	50.00
5	4314	190	90	4594	663	4307	0	0	6014	6000	-872	14390	0	14390	1874	302	16566	49.99
6	4421	205	90	4716	856	4799	0	0	6066	6134	-895	15275	0	15275	1935	335	17545	50.01
7	4453	226	88	4767	943	5023	0	48	6447	6460	-884	16001	0	16001	1968	356	18325	50.03
8	4486	242	89	4817	896	4420	0	389	7084	6946	-1011	16091	0	16091	2037	366	18494	50.00
9	4243	291	89	4623	1064	4126	0	851	7302	6933	-1162	16074	0	16074	2180	361	18615	49.99
10	3907	305	89	4301	1059	4022	0	1176	7004	7060	-1318	15936	0	15936	2383	364	18683	49.98
11	3886	377	88	4351	994	3965	0	1348	6726	6966	-1451	15800	0	15800	2483	373	18656	49.95
12	3870	626	88	4584	891	3905	0	1235	6630	6670	-1492	15416	0	15416	2538	377	18331	49.94
13	3997	671	88	4756	911	3766	0	1262	6107	6070	-1453	14956	0	14956	2535	356	17847	50.02
14	3850	469	86	4405	908	3814	0	1227	6307	6063	-1389	14682	0	14682	2443	346	17471	50.02
15	3768	353	87	4208	1013	3212	0	1104	6852	6797	-1394	14616	0	14616	2300	324	17240	50.01
16	3646	306	87	4039	942	3512	0	926	6654	6787	-1251	14618	0	14618	2232	337	17187	50.02
17	3808	306	86	4200	1128	3693	0	553	6626	6712	-1157	14771	0	14771	2219	358	17348	50.00
18	4387	306	87	4780	1294	4004	0	160	6598	6465	-1156	15165	0	15165	2232	382	17779	49.99
19	4512	1268	85	5865	1226	4741	0	1	6010	5678	-1143	15969	0	15969	2408	399	18776	49.91
20	4566	1963	86	6615	1236	5028	0	0	5414	5546	-1103	16915	0	16915	2513	407	19835	49.91
21	4630	694	87	5411	1325	4834	0	0	5984	5650	-1200	15630	0	15630	2454	390	18474	49.99
22	4531	421	88	5040	1306	4948	0	0	5805	5811	-1205	15524	0	15524	2388	376	18288	49.92
23	4234	331	88	4653	1336	4654	0	0	5917	5640	-1215	14696	0	14696	2296	372	17364	50.01
24	4064	250	88	4402	1264	4286	0	0	6008	5885	-1148	14325	0	14325	2198	364	16887	50.00
MUs	100.44	10.55	2.11	113.11	25.06	102.01	0.00	10.28	150.15	148.52	-27.80	362.70	0.00	362.70	53.74	8.49	424.93	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 18/Sep/2022

Position as on 6.30 Hrs of 19/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Chandrapur Unit 6	500	14/09/2022	21:51	19/09/2022	22:44	PRIAMARY AIR PREHEATER BASKET REPLACEMENT AND OTHER WORKS WILL BE TAKEN TENTATIVELY TILL 20.09.2022.	20/09/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
IPP	RPL(AMT) U-4	270	31/08/2022	00:00	18/09/2022	20:35	Coal Shortage	
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	
IPP	SWPGPL U-2	135	14/09/2022	04:12		Continued.	Vibration high ID fan	25/09/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Sep/2022

Position as on 6.30 Hrs of 19/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 7A	120	14/09/2022	05:36		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	14/09/2022	05:50		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	14/09/2022	21:39		Continued.	ID Fan Problem	25/09/2022
MSPGCL	Chandrapur Unit 7	500	16/09/2022	10:09		Continued.	Boiler Tube Leakage	20/09/2022
MSPGCL	Bhusawal Unit 4	500	16/09/2022	15:15	18/09/2022	01:52	Buchholz relay operated.	17/09/2022
MSPGCL	Khaparkheda Unit 2	210	17/09/2022	13:00		Continued.	wet coal	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59		Continued.	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	29/09/2022
MSPGCL	Bhusawal Unit 3	210	18/09/2022	14:55	18/09/2022	17:04	Flame Failure	
MSPGCL	Koradi Unit 8	660	18/09/2022	22:15	19/09/2022	04:45	HEAVY HIGH PRESSURE REHEAT STEAM LEAKAGE NEAR LP BYPASS VALVE OF MAIN TURBINE.	
MSPGCL	Bhusawal Unit 5	500	19/09/2022	02:47	19/09/2022	05:44	Furnace Pressure High	22/09/2022
MSPGCL	Parli Unit 7	250	19/09/2022	03:20	19/09/2022	06:12	Furnace Pressure High	
IPP	SWPGPL U-1	135	19/09/2022	03:32	19/09/2022	08:55	Bus Bar Protection operated	
MSPGCL	Bhusawal Unit 5	500	19/09/2022	22:30		Continued.	Boiler Tube Leakage	24/09/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 19/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	17/09/2022	23:48	18/09/2022	06:23	EO	For Pole-1 2Y2 ph Converter transformer oil filling
400 KV TIEBAY Outages/Trippings							
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	13/09/2022	21:00		Continued.	T	Reason awaited
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	19/09/2022	09:24	19/09/2022	18:25	PO	replacement of PID suspicious disc insulator strings and other routine maintenance work.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38		Continued.	T	Y Phase Ground Fault
KHADKA-AURANGABAD (WALUJ)	IntraState	15/09/2022	21:37		Continued.	HT	To control OV
JAIGAD - KARAD CKT - 1	IntraState	17/09/2022	02:00	18/09/2022	10:14	HT	HT for Overvoltage Control
KARAD - LONIKAND I	IntraState	17/09/2022	08:47		Continued.	HT	For load Management
PADGHE - PADGHE HVDC CKT- 1	IntraState	18/09/2022	00:14	18/09/2022	08:46	EO	"1) Replacement of Bph CT (7core) as existing CT is 5 core so as to avoid the Power Restriction on HDDC pole 2) Bay maint work 3) Dignostic Testing work 4) MTAMC work. 5) For attending Hotspot"
KHARGHAR - TALEGAON (PG)	IntraState	18/09/2022	10:06	18/09/2022	18:38	PO	Addition jumpuring work by fire wedge connector
JEJURI- KOYNA STAGE-IV	IntraState	18/09/2022	10:41	18/09/2022	15:55	PO	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	19/09/2022	10:39	19/09/2022	18:03	PO	(1) C & Tan delta measurement of CTs. (2)Bay maintenance work.
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ KORADI	IntraState	14/09/2022	19:45	19/09/2022	09:00	HT	ICT-2 SHIFTED FROM OWN CB TO TBC. FOR MAIN CB REPLACEMENT WORK
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	19/09/2022	09:09	19/09/2022	20:25	PO	Quarterly. Maint. work
220 KV MAINBAY Outages/Trippings							
BUS SECTION - 2 @ BIDRI	IntraState	19/09/2022	09:44	19/09/2022	18:44	PO	Bus Bar relay testing & other QMW
220 KV LINE Outages/Trippings							
BOISAR - VERSOVA	IntraState	15/09/2022	10:39		Continued.	PO	Bunching of lines at location no.SS 82 to facilitate the following project work:NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223.DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 19/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - VERSOVA	IntraState	15/09/2022	11:00		Continued.	PO	Bunching of lines at location no.SS 82 to facilitate the following project work:NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223.DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
RANJANGAON-LONIKAND	IntraState	18/09/2022	10:32	18/09/2022	16:50	PO	for Isolator Maintenance Work
BUS SECTION-6 @ TROMBAY	IntraState	19/09/2022	00:18	19/09/2022	06:05	EO	for Main bus-6 jumper connection on Trombay Carnac -6 line breaker GOD
KHARGHAR - BORIVALI CKT - 2	IntraState	19/09/2022	06:11	19/09/2022	13:18	T	Tripped on Dist. Protection.
KALWA - SIEMENS	IntraState	19/09/2022	08:22	19/09/2022	13:09	EO	For safety purpose during replacement of faulty R ph LA of 220 kV Kharghar Borivali 2 line which has tripped.
EKLAHARE (OCR) - PADGHE	IntraState	19/09/2022	08:40		Continued.	HT	H/T TO CONTROL LINE LOADING OF BBLR
TALANDGE - BIDRI	IntraState	19/09/2022	09:35	19/09/2022	18:18	HT	Out in Bus section outage
BUS SECTION - 1 @ BIDRI	IntraState	19/09/2022	09:35	19/09/2022	18:20	PO	Bus Bar relay testing & other QMW
TALANDGE - SAWANTWADI	IntraState	19/09/2022	09:44	19/09/2022	18:44	HT	Out in Bus section outage
THEUR-JEJURI	IntraState	19/09/2022	10:08	19/09/2022	19:27	PO	1) L.N.-1- R Phase, Double Jumepring work (1to56) 2) L.N.-56 ESN & CB Fixing work (1 to 56) 3) L.N.-2-B Phase & L.N.-29-R phase SSN Clamp Replacement work. 4) L.N.-12- R,Y,B Phase Double Jumpering 5) L.N.-61& 69 , SSN Clamp Replacement work 6) L.N.-105 B & R Phase, Double Jumepring work (1 to 105) 7) Fixing of VD at L.N.-76 8) L.N.-79 , Quarter D Shackle replacement work 9) L.N.-39, Cleaning
TROMBAY CARNAC - 6	IntraState	19/09/2022	11:03	19/09/2022	20:54	PO	for line CVT and CT testing at Trombay generating station .
MAIN BUS - 1 @ TALANDGE	IntraState	19/09/2022	13:12	19/09/2022	18:47	PO	String replacement work of ICT 3 bay which is found Faulty in PID testing .
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33KV 25MVA TF NO.2 @ SAYNE	IntraState	15/09/2022	15:40		Continued.	PO	Work of Replacement of 220/33kv 25 MVA TF2 by 220/33kv 50MVA BHEL TF
220/33KV 50MVA PTR 1 @ 5 STAR MIDC, KAGAL	IntraState	19/09/2022	10:05	19/09/2022	14:40	PO	for diagnostic testing, Hotspot attending work(Bus -1), quarterly maintenance work.
220/33kv 100 MVA TF 1 @ GHODBUNDER	IntraState	19/09/2022	10:28	19/09/2022	12:12	PO	Checking of NGT Low Oil alarm.
220/132 KV 100 MVA ICT 2 @ RANJANGAON	IntraState	19/09/2022	11:15	19/09/2022	19:19	PO	for Isolator maintenance work, Dignostic Testing, Half yearly maintenance work
220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR	IntraState	19/09/2022	12:10	19/09/2022	17:30	PO	Outage is required for Diagnostic testing work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 19/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage