

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Oct/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	119.370	2128.940	1) Gujrat	8.203	185.793
2) Hydro	11.964	149.164	2) Madhya Pradesh	4.066	118.378
3) Gas	2.177	39.942	3) Chattisgarh	5.690	97.490
Total MSPGCL	133.511	2318.046	4) Maharashtra	153.908	2890.456
B) 1) APLM	62.996	941.281	5) Goa (Amona)	-1.424	-23.301
2) JSWEL	13.926	280.665	Total	170.443	3268.816
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.736	599.496
4) RPL(AMT)	25.236	417.764	b) Mumbai Drawl	38.318	657.607
5) SWPGPL	7.498	130.985	c) MSEDCL Bilateral *	62.971	1200.046
6) Other IPP	8.316	136.940	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.736	599.484
C) 1) TPCL Thermal	12.598	182.727	Include PX	0.000	0.000
2) TPCL Hydro	4.299	72.139	Standby	0.000	0.012
3) TPCL Gas	3.416	44.600	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.835	169.946	1) MSEDCL	386.388	7042.791
D) STATE			2) Mumbai Discoms	68.466	1126.996
1) Thermal	259.775	4389.248	3) Other Discoms	9.324	165.608
(A1+C1+C4+(B1-B6))			TOTAL STATE	464.178	8335.395
2) Hydro (A2+C2)	16.263	221.303			
3) Gas (A3+B7+C3)	5.593	84.542			
4) Wind	3.011	201.718			
6) SOLAR	9.093	169.791			
TOTAL STATE	293.735	5066.602			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5305	4564	4714	4890
MSPGCL Hydro	249	986	2074	217
MSPGCL Gas	90	88	90	92
MSPGCL Total Generation	5644	5638	6878	5199
Central Sector Receipt	7753	7073	7479	5995
WIND	43	213	193	166
CPP / IPP Thermal	4827	5429	5716	4711
CPP / IPP Gas	0	0	0	0
SOLAR	879	86	0	0
Exchange with Mumbai	-1771	-1631	-1383	-1311
MSEDCL DEMAND MET	16946	16388	18451	14455
Load Shedding	0	0	0	0
MSEDCL DEMAND	16946	16388	18451	14455
TPCL GENERATION	883	1090	1234	607
AEML GENERATION	493	496	497	297
MUMBAI DEMAND	3147	3217	3114	2215
OTHER DISCOM DEMAND	429	420	432	305
STATE DEMAND MET	20522	20025	21997	16975
STATE DEMAND	20522	20025	21997	16975
Frequency (Hz)	49.99	49.97	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 15.02 Hrs	49.85 Hz at 11.49 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Oct/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.52	31.64	170	125
Unit 7	0.00	0.00	0	0
Unit 8	8.61	132.27	471	0
Unit 9	7.32	59.24	464	0
Unit 10	9.17	174.21	400	345
Total	28.63	397.36		
Bhusawal				
Unit 3	0.00	32.53	0	0
Unit 4	5.80	141.82	420	0
Unit 5	3.89	145.12	420	0
Total	9.68	319.47		
Parli				
Unit 6	4.05	73.11	215	147
Unit 7	3.99	61.03	216	130
Unit 8	3.62	48.29	168	143
Total	11.66	182.43		
Chandrapur				
Unit 3	0.00	49.32	0	0
Unit 4	3.25	49.42	161	124
Unit 5	7.00	121.31	325	275
Unit 6	7.39	130.83	375	285
Unit 7	7.05	128.12	340	267
Unit 8	8.68	55.80	440	278
Unit 9	8.58	152.45	440	282
Total	41.95	687.25		
Paras				
Unit 3	4.50	73.89	205	164
Unit 4	0.00	0.00	0	0
Total	4.50	73.89		
Khaparkheda				
Unit 1	2.53	50.62	145	85
Unit 2	2.62	50.67	135	45
Unit 3	3.18	61.19	155	106
Unit 4	2.99	57.44	135	105
Unit 5	5.76	142.40	480	0
Total	17.07	362.32		
Nasik				
Unit 3	0.00	25.32	0	0
Unit 4	2.99	55.77	164	107
Unit 5	2.89	25.13	149	108
Total	5.88	106.22		
Uran				
All Units	2.18	39.94	92	88
Total	2.18	39.94		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.59	10.69	25	24
Total	0.59	10.69		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.31	37.24	535	30
Stage 4	3.60	32.56	1000	0
Stage 3	1.42	17.20	240	0
Total	7.34	87.00		
Hydro				
KDPH	0.76	5.68	36	18
VTRNA	0.00	1.82	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.28	4.88	77	0
SMLHY_PTN	2.71	35.49	117	103
GHATGHAR	0.28	3.60	125	0
Total	4.03	51.48		
Wind				
Total	3.01	201.72	0	0
Total	3.01	201.72		
CPP				
APML(Mus)	63.00	941.28	0	0
JSWEL(Mus)	13.93	280.66	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.24	417.76	0	0
SWPGPL-Mus	7.50	130.98	0	0
Other(Mus)	8.32	136.94	0	0
Total	117.97	1907.64		
SOLAR				
Total	9.09	169.79	0	0
Total	9.09	169.79		
Tata				
Trombay 5	8.62	115.88	468	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.05	25.07	107	48
Trombay 7B	1.36	19.53	65	42
TATA Hydro	4.30	72.14	390	26
Trombay 8	3.98	66.84	231	130
Total	20.31	299.47		
AEML				
DTPS U-1&2	9.84	169.95	497	297
Total	9.84	169.95		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	119.37	2128.94	MSPGCL Total	133.51	2318.05
			MSPGCL Thml+Gas	121.55	2168.88	Koyna 1,2 & 4 Total	5.92	69.80
			MSPGCL Hydro	11.96	149.16	State Total	293.74	5066.60

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Oct/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4950	239	91	5280	134	4677	0	0	6361	6246	-1470	14511	0	14511	2573	356	17440	50.01
2	4919	217	92	5228	180	4699	0	0	6158	6204	-1413	14569	0	14569	2364	329	17262	49.96
3	4890	217	92	5199	166	4711	0	0	6143	5995	-1311	14455	0	14455	2215	305	16975	49.99
4	4968	215	92	5275	52	4686	0	0	6099	6091	-1215	14595	0	14595	2114	293	17003	50.00
5	5284	221	92	5597	79	4704	0	0	5966	6093	-1186	14980	0	14980	2092	307	17379	50.02
6	5797	217	92	6106	66	5117	0	0	6142	6167	-1201	15915	0	15915	2171	340	18426	50.02
7	5851	218	92	6161	28	5363	0	34	6651	6865	-1204	16888	0	16888	2299	358	19546	50.00
8	5883	213	91	6187	41	5440	0	254	6997	7153	-1411	17262	0	17262	2504	401	20168	50.01
9	5705	253	91	6049	39	5391	0	590	7340	7044	-1735	16960	0	16960	2833	419	20211	49.99
10	5305	249	90	5644	43	4827	0	879	7837	7753	-1771	16946	0	16946	3147	429	20522	49.99
11	5017	247	90	5354	51	4566	0	1281	8123	7542	-1977	16398	0	16398	3350	419	20167	50.02
12	4502	246	90	4838	43	4289	0	1298	8146	7935	-2045	15953	0	15953	3407	405	19765	49.95
13	4530	282	90	4902	89	4013	0	1226	7782	7921	-2046	15681	0	15681	3377	424	19482	49.97
14	4573	219	91	4883	77	4110	0	1199	8001	7594	-2176	15272	0	15272	3235	416	18922	50.03
15	4511	454	90	5055	112	3962	0	1072	8100	7795	-2044	15530	0	15530	3308	421	19260	50.04
16	4378	456	91	4925	59	4211	0	767	8188	8532	-1913	16156	0	16156	3339	425	19920	50.03
17	4729	462	89	5280	175	5054	0	407	7673	7480	-1729	16230	0	16230	3297	437	19964	49.99
18	4564	986	88	5638	213	5429	0	86	7356	7073	-1631	16388	0	16388	3217	420	20025	49.97
19	4587	2083	88	6758	239	5685	0	0	6838	7468	-1509	18205	0	18205	3209	436	21850	50.00
20	4714	2074	90	6878	193	5716	0	0	7003	7479	-1383	18451	0	18451	3114	432	21997	50.03
21	4849	877	90	5816	172	5497	0	0	7492	7509	-1386	17199	0	17199	2978	410	20586	50.01
22	5040	437	91	5568	211	5487	0	0	7315	7135	-1514	16496	0	16496	2850	392	19737	50.03
23	4934	443	92	5469	264	5379	0	0	6879	6822	-1547	16006	0	16006	2770	381	19157	50.02
24	4890	439	92	5421	285	4961	0	0	6549	6547	-1501	15342	0	15342	2703	371	18416	50.01
MUs	119.37	11.96	2.18	133.51	3.01	117.97	0.00	9.09	171.14	170.44	-38.32	386.39	0.00	386.39	68.47	9.32	464.18	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Oct/2022

Position as on 6.30 Hrs of 19/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	22/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	22/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High	20/10/2022
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	28/10/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	28/10/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
MSPGCL	Koradi Unit 8	660	12/10/2022	18:53	18/10/2022	01:58	Boiler Tube Leakage	16/10/2022
IPP	SWPGPL U-4	135	16/10/2022	14:55		Continued.	Lube oil Pressure Low due to AOP tripping	19/10/2022
MSPGCL	Chandrapur Unit 3	210	17/10/2022	07:28		Continued.	Boiler Tube Leakage	20/10/2022
MSPGCL	Bhusawal Unit 5	500	18/10/2022	10:00		Continued.	Boiler Tube Leakage	20/10/2022
MSPGCL	Bhusawal Unit 4	500	18/10/2022	11:00	18/10/2022	14:38	Flame Failure	
IPP	IEPL Unit 1	270	18/10/2022	14:32	18/10/2022	18:01	Due to excitation failure	
MSPGCL	Bhusawal Unit 4	500	18/10/2022	14:58	18/10/2022	18:20	Due to load fluctuation.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Oct/2022

Position as on 6.30 Hrs of 19/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 5	500	18/10/2022	15:08	18/10/2022	20:43	Due to UPS failure.	
MSPGCL	Koradi Unit 9	660	18/10/2022	17:15		Continued.	Boiler Tube Leakage	20/10/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 19/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	IntraState	18/10/2022	09:16	18/10/2022	17:44	PO	Annual Maintenance of Bay Equipments
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	18/10/2022	01:15	18/10/2022	04:22	EO	Emergency Outage on HVDC Pole-2 2 BASE FILTER for attending RED HOT at pole-2 base filter Z21-Z2 B-PH AND Z21-Z1 R-PH at jumper connecting to Capacitor bushing.
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	19/10/2022	01:34	19/10/2022	05:55	EO	Emergency shutdown of HVDC Pole 1 - Base Filter Z11-Z1 & Z11-Z2 for attending the red hot observed at connecting jumper of capacitor bushing
400 KV TIEBAY Outages/Trippings							
TIE BREAKER (411) OF KORADI CKT 1 AND STATION TF-2 @ NANDGAONPETH	InterState	13/10/2022	11:42			EO	SF6 Gas Replenishment in Tie breaker (411) due to low SF6 Gas Alarm is coming intermittently and Density Monitor level is showing near alarm value.
411 TIE BAY OF EKTUNI CKT 2 AND ICT 3	InterState	18/10/2022	11:19	18/10/2022	14:58	PO	CB Diagnostic Testing
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KARAD - LONIKAND I	IntraState	10/10/2022	09:28			PO	1. Errection of 315A & 316 in line tower. 2. Loc no. 315 to 315A S/C stringing. 3. Loc no. 315A to 33(D/C LILO tower) stringing. 4. Loc No. 316 to 33(D/C LILO tower) stringing. 5. Dismantling of existing in line tower at loc no 316.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	11/10/2022	08:52	19/10/2022	06:28	HT	H/T FOR LOAD MANAGEMENT
KALWA - KHARGHAR	IntraState	17/10/2022	21:17	18/10/2022	00:49	EO	R ph wave trap fitting rod broken at Kalwa end & wave trap hanging on only two rod.
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	18/10/2022	09:21	18/10/2022	18:06	PO	Replacement of damaged/broken spacer at critical locations
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	18/10/2022	13:49			HT	H/T TO CONTROL LINE LOADING OF PUNE-PUNE GIS
400 KV ICT Outages/Trippings							
400/220/33KV 500 MVA ICT - 1 @ KUDUS	IntraState	18/10/2022	10:02	18/10/2022	16:42	PO	Outage is required for safety purpose for work of Air-cell replacement of Y&B-phase of 400/220/33 kV ICT-2
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	18/10/2022	10:32	18/10/2022	18:34	PO	Diagonastic testing work of bushings,DFRA and other routine maint.work.
400/220/33 KV 315MVA ICT - 1 @ CHAKAN	IntraState	18/10/2022	23:45	19/10/2022	02:31	EO	For topping up oil in conservator tank of R phase unit.
400 KV BR Outages/Trippings							
BUS REACTOR - 2 @ TIRORA	IntraState	18/10/2022	09:10	18/10/2022	19:26	PO	For bay equipment maintenance and testing work
220 KV TBC Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 18/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 19/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS COUPLER @ MULUND	IntraState	18/10/2022	10:10	18/10/2022	12:45	PO	DIAGNOSTIC TESTING 1) CT TAN DELTA 2) CT IR 3) RM WORK
220 KV MAINBAY Outages/Tripping							
BUS COUPLER @ TALANDGE	IntraState	18/10/2022	11:06	18/10/2022	16:03	PO	Annual relay and Diagnostic testing work
220 KV LINE Outages/Tripping							
EKLAHARE (OCR) - PADGHE	IntraState	08/10/2022	22:52			HT	For load management
NEW KOYNA - NIWALI	IntraState	17/10/2022	16:50	18/10/2022	01:47	T	Tripped on dist Protection
TEMGHAR - KALWA	IntraState	18/10/2022	01:05	18/10/2022	08:06	EO	To attend hot spot at Loc No. 10, 15, 28, 34, 36 & 39.
BIDRI - SAWANTWADI	IntraState	18/10/2022	08:28	18/10/2022	14:57	PO	Insulator Cleaning
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	18/10/2022	08:31	18/10/2022	22:23	HT	To control overloading
HINJAWADI I- CHINCHWAD	IntraState	18/10/2022	09:03	18/10/2022	11:52	HT	to control overloading
VITA - MIRAJ	IntraState	18/10/2022	09:11	18/10/2022	16:01	PO	String Replacement work at Loc No.109 R ph & 102 B Ph
GOREGAON - VERSOVA CKT - 2	IntraState	18/10/2022	09:17	18/10/2022	19:41	PO	Replacement of in-service polymer insulators with high creepage polymer insulators (VAB 1 to VAB). Also attending to hotspot is 4 locations.
BORIVALI - TARAPUR	IntraState	18/10/2022	09:21			PO	Conductor replacement work under Scheme from Loc No.19-28 (Yph & Bph).
NIGADE- PETH LINE	IntraState	18/10/2022	10:01	18/10/2022	19:26	PO	Quarterly maintenance & diagnostic testing work.
URAN - APTA CKT - 1	IntraState	18/10/2022	10:33	18/10/2022	12:45	HT	Sparking observed on Wave trap Coupling device
OSMANABAD - SOLAPUR (BALE)	IntraState	18/10/2022	10:59	18/10/2022	19:43	PO	Outage is required for Quarterly Maintenance
NEW KOYNA - NIWALI	IntraState	18/10/2022	11:35	18/10/2022	15:04	T	Tripped on distance protection
PEDAMBE-KALAMBANI(TSS)	IntraState	18/10/2022	11:58	18/10/2022	18:25	PO	Bay R/M work
220 KV ICT Outages/Tripping							
220 / 110 / 22KV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/33 KV 25 MVA PTR 2 @ BIDRI	IntraState	18/10/2022	09:45	18/10/2022	15:57	PO	For Tan delta testing
220/33 KV 50 MVA PTR NO 3 @ ALEPHATA	IntraState	18/10/2022	12:54	18/10/2022	16:28	PO	Annual relay testing work
220 KV BUSBAR Outages/Tripping							
MAIN BUS - 1 @ URAN	IntraState	18/10/2022	11:41	18/10/2022	18:12	PO	For MAIN BUS insulator string replacement work.
110 KV LINE Outages/Tripping							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 19/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage