

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Nov/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.141	2596.411	1) Gujrat	-7.829	-149.772
2) Hydro	6.129	148.659	2) Madhya Pradesh	-2.720	-34.958
3) Gas	2.229	33.591	3) Chattisgarh	6.460	109.700
Total MSPGCL	144.499	2778.661	4) Maharashtra	172.772	3048.433
B) 1) APML	75.144	1156.020	5) Goa (Amona)	-1.331	-25.276
2) JSWEL	11.292	225.747	Total	167.352	2948.127
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.343	579.731
4) RPL(AMT)	31.251	469.542	b) Mumbai Drawl	36.562	656.366
5) SWPGPL	8.489	127.381	c) MSEDCL Bilateral *	69.257	1265.911
6) Other IPP	37.893	582.779	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.343	579.728
C) 1) TPCL Thermal	10.738	194.721	Include PX	0.000	0.000
2) TPCL Hydro	3.677	68.480	Standby	0.000	0.002
3) TPCL Gas	0.000	6.990	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.028	158.105	1) MSEDCL	452.924	7928.545
D) STATE			2) Mumbai Discoms	60.005	1084.662
1) Thermal	319.976	5510.706	3) Other Discoms	9.354	168.283
(A1+C1+C4+(B1-B6))			TOTAL STATE	522.283	9181.490
2) Hydro	9.806	217.139			
(A2+C2)					
3) Gas	2.229	40.581			
(A3+B7+C3)					
4) Wind	10.812	249.960			
6) SOLAR	12.108	214.977			
TOTAL STATE	354.931	6233.363			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6207	5776	6217	4742
MSPGCL Hydro	375	187	627	126
MSPGCL Gas	91	89	91	95
MSPGCL Total Generation	6673	6052	6935	4963
Central Sector Receipt	8170	7822	7196	5865
WIND	348	290	220	452
CPP / IPP Thermal	6860	6851	6985	6842
CPP / IPP Gas	0	0	0	0
SOLAR	1666	1790	1	0
Exchange with Mumbai	-1815	-1844	-1657	-1454
MSEDCL DEMAND MET	21455	20532	19258	16293
Load Shedding	0	0	0	0
MSEDCL DEMAND	21455	20532	19258	16293
TPCL GENERATION	684	670	829	458
AEML GENERATION	486	498	376	295
MUMBAI DEMAND	2985	3012	2862	2207
OTHER DISCOM DEMAND	447	429	422	375
STATE DEMAND MET	24887	23973	22542	18875
STATE DEMAND	24887	23973	22542	18875
Frequency (Hz)	49.98	49.98	50.02	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 06:01 Hrs	49.81 Hz at 00:07 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.83	83.74	215	175
Unit 7	0.00	0.00	0	0
Unit 8	12.08	229.29	542	367
Unit 9	12.68	228.98	545	495
Unit 10	0.08	91.82	66	0
Total	29.67	633.84		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.69	164.96	420	280
Unit 5	9.75	169.08	475	280
Total	18.44	334.04		
Parli				
Unit 6	3.95	71.55	218	144
Unit 7	3.91	67.70	216	140
Unit 8	3.70	59.18	190	142
Total	11.56	198.42		
Chandrapur				
Unit 3	3.30	56.62	160	123
Unit 4	3.14	53.02	163	119
Unit 5	6.56	115.64	320	240
Unit 6	0.00	107.25	0	0
Unit 7	7.61	130.98	374	279
Unit 8	9.31	175.89	477	277
Unit 9	7.84	167.33	439	0
Total	37.76	806.73		
Paras				
Unit 3	5.22	87.36	232	181
Unit 4	5.72	42.08	252	219
Total	10.94	129.45		
Khaparkheda				
Unit 1	2.65	48.79	135	95
Unit 2	2.94	48.68	145	75
Unit 3	3.71	55.37	182	130
Unit 4	3.45	62.04	167	129
Unit 5	8.52	173.79	390	285
Total	21.27	388.66		
Nasik				
Unit 3	0.00	1.31	0	0
Unit 4	3.32	47.88	164	115
Unit 5	3.19	56.08	156	110
Total	6.50	105.26		
Uran				
All Units	2.23	33.59	97	88
Total	2.23	33.59		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	11.14	25	0
Total	0.14	11.14		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.14	41.22	355	40
Stage 4	0.36	33.13	249	0
Stage 3	0.55	16.33	160	0
Total	3.04	90.68		
Hydro				
KDPH	0.43	5.92	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.46	3.54	58	0
BHIRA T.R.	0.22	3.46	77	0
SMLHY_PTN	1.66	29.10	73	67
GHATGHAR	0.17	4.81	125	0
Total	2.95	46.83		
Wind				
Total	10.81	249.96	0	0
Total	10.81	249.96		
CPP				
APML(Mus)	75.14	1156.02	0	0
JSWEL(Mus)	11.29	225.75	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.25	469.54	0	0
SWPGPL-Mus	8.49	127.38	0	0
Other(Mus)	37.89	582.78	0	0
Total	164.07	2561.47		
SOLAR				
Total	12.11	214.98	0	0
Total	12.11	214.98		
Tata				
Trombay 5	7.36	132.09	383	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.91	0	0
Trombay 7B	0.00	3.08	0	0
TATA Hydro	3.68	68.48	430	5
Trombay 8	3.38	62.63	171	129
Total	14.42	270.19		
AEML				
DTPS U-1&2	9.03	158.10	498	282
Total	9.03	158.10		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.14	2596.41	MSPGCL Total	144.50	2778.66
			MSPGCL Thml+Gas	138.37	2630.00	Koyna 1,2 & 4 Total	2.49	74.35
			MSPGCL Hydro	6.13	148.66	State Total	354.93	6233.36

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 18/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5146	302	95	5543	630	6372	0	0	6047	6188	-1403	16981	0	16981	2155	349	19485	49.94
2	5280	156	95	5531	628	6675	0	0	6053	5884	-1308	17084	0	17084	2022	326	19432	49.93
3	5129	125	96	5350	737	6807	0	0	6012	5802	-1222	17166	0	17166	1912	308	19386	49.98
4	5169	126	96	5391	761	6821	0	0	6027	6039	-1136	17586	0	17586	1833	290	19709	50.01
5	5334	127	96	5557	763	6820	0	0	6214	6332	-1141	18019	0	18019	1829	312	20160	50.05
6	5738	126	96	5960	875	6864	0	0	6884	6990	-1243	19099	0	19099	1937	347	21383	50.00
7	6030	221	97	6348	771	6854	0	14	7317	7458	-1324	19756	0	19756	2097	365	22218	49.94
8	6270	441	97	6808	672	6851	0	305	7312	7524	-1427	20331	0	20331	2253	402	22986	50.00
9	5956	145	95	6196	478	6823	0	823	7655	7709	-1560	20041	0	20041	2508	428	22977	50.01
10	5931	533	93	6557	428	6829	0	1289	7448	7616	-1646	20650	0	20650	2820	423	23893	49.95
11	6207	375	91	6673	348	6860	0	1666	7995	8170	-1815	21455	0	21455	2985	447	24887	49.98
12	5863	204	92	6159	355	6851	0	1752	8366	8189	-1867	20998	0	20998	3037	441	24476	49.99
13	5776	187	89	6052	290	6851	0	1790	7765	7822	-1844	20532	0	20532	3012	429	23973	49.98
14	5669	192	89	5950	273	6848	0	1666	7493	7635	-1699	20271	0	20271	2879	402	23552	50.01
15	5892	185	88	6165	223	6783	0	1375	7935	7823	-1706	20263	0	20263	2905	400	23568	50.02
16	5986	206	88	6280	199	6792	0	947	7848	7799	-1632	19974	0	19974	2940	411	23325	50.01
17	6005	305	89	6399	172	6912	0	430	7160	7234	-1559	19167	0	19167	2913	421	22501	49.99
18	6270	512	89	6871	162	6977	0	50	6642	6835	-1618	18852	0	18852	2859	425	22136	49.98
19	6217	627	91	6935	220	6985	0	1	7120	7196	-1657	19258	0	19258	2862	422	22542	50.02
20	5943	416	91	6450	266	6967	0	0	7064	6935	-1640	18563	0	18563	2747	415	21725	50.03
21	5657	225	92	5974	348	6914	0	0	6148	6116	-1631	17300	0	17300	2577	421	20298	50.01
22	5087	138	94	5319	379	6898	0	0	6010	6142	-1556	16778	0	16778	2423	404	19605	50.02
23	4844	129	95	5068	382	6873	0	0	5936	6049	-1474	16506	0	16506	2293	392	19191	50.00
24	4742	126	95	4963	452	6842	0	0	5945	5865	-1454	16293	0	16293	2207	375	18875	50.03
MUs	136.14	6.13	2.23	144.50	10.81	164.07	0.00	12.11	166.40	167.35	-36.56	452.92	0.00	452.92	60.00	9.35	522.28	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Nov/2022

Position as on 6.30 Hrs of 19/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	22/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30	19/11/2022	16:12	BOILER PROBLEM	19/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	
CENT.SECTOR	Tarapur 3	540	07/11/2022	02:00		Continued.	For maintenance on reactor side	22/11/2022
IPP	JSW (J) U3	300	09/11/2022	08:08	18/11/2022	09:47	Generator Elect. Fault	16/11/2022
MSPGCL	Koradi Unit-10	660	10/11/2022	22:13	18/11/2022	22:37	Boiler Tube Leakage	19/11/2022
MSPGCL	Nasik Unit 3	210	11/11/2022	03:16		Continued.	Boiler Tube Leakage (under tolling from 06:33 hrs dtd-13/11/2022)	20/11/2022
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.	23/11/2022
MSPGCL	Chandrapur Unit 6	500	16/11/2022	14:06		Continued.	ID Fan Problem	21/11/2022
MSPGCL	Chandrapur Unit 9	500	18/11/2022	21:28		Continued.	withdrawn due to LPBP warm line leakage	22/11/2022
MSPGCL	Koyna STG-IV Unit-3	250	19/11/2022	09:25		Continued.	Trunnion Seal repair work.	22/11/2022
MSPGCL	Paras Unit 4	250	19/11/2022	10:57		Continued.	Boiler Tube Leakage	22/11/2022
MSPGCL	Bhusawal Unit 4	500	19/11/2022	18:31		Continued.	Boiler Tube Leakage	22/11/2022
MSPGCL	Nasik Unit 5	210	19/11/2022	23:20		Continued.	Boiler Tube Leakage	24/11/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 19/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY - 702 OF BUS REACTOR AND 765/400kV 1500MVA ICT @ AKOLA 2	IntraState	18/11/2022	09:18	18/11/2022	19:04	PO	Annual Maintenance of Bay Equipment
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	18/11/2022	00:36			PO	For Pole 1 Scheduled Annual Outage and Pole1 Y Phase Converter Transformer replacement work.
400 KV TIEBAY Outages/Trippings							
TIE BAY- 402 OF 400/220/33 KV 500 MVA ICT - 1 AND PARLI @ LAMBOTI	IntraState	14/11/2022	10:43	18/11/2022	17:27	PO	Overhauling of 402-52 CB
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (416) OF CHANDRAPUR ckt-2 @ WARORA	IntraState	18/11/2022	09:52	18/11/2022	13:26	PO	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
GT-10 @ KORADI-2	IntraState	12/11/2022	11:44	18/11/2022	22:37		1) Routine maintenance of isolator. 2) Health check up of CB 402-Q52 by M/S Siemens(OEM) 3) Routine Bay maintenance work. 4) Erection, testing and commissioning of dedicated metering CT and IVT for the metering arrangement for GT-10 bay at 400 kV Koradi II S/s.
KARAD - TALANDGE CKT - 1	IntraState	15/11/2022	17:03			PO	Overhauling of A bus, B Bus PG isolators.
PADGHE - PADGHE HVDC CKT- 1	IntraState	18/11/2022	00:36			PO	1) Bay Maint work 2) Diagnostic Testing work 3)A Bus :- PG Isolator replacement of 400kV HVDC-I Y&B-phz 4) Bhel CB Pole Overhauling work. If pole overhauling not completed within outage period line will be charge on TBC.
DEEPNAGAR - THAPTI TANDA	IntraState	18/11/2022	02:39	18/11/2022	04:18	T	Distance Protection
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	18/11/2022	06:01	18/11/2022	18:50	PO	1) String Disc Replacement Work 2) Maintenance Work
NEW KOYNA - STAGE IV CKT - 2	IntraState	18/11/2022	10:01	18/11/2022	11:45	PO	For CB time testing work.
220 KV DHULE(400KV) - MALEGAON CKT	IntraState	18/11/2022	10:17	18/11/2022	15:48	PO	For routine testing and maintenance work
DHULE- - BABLESHWAR - II	IntraState	18/11/2022	11:04	18/11/2022	19:01	PO	cold line washing of insulator string and routine Line maintenance work, CT Tan D & Bay maintenance work
TBC @ CHAKAN	IntraState	18/11/2022	11:15	18/11/2022	14:47	PO	CB DCRM,CRM and breaker timing testing
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	19/11/2022	06:27	19/11/2022	18:55	PO	1) String Disc Replacement Work 2) Maintenance Work
220 KV INTERCONNECTOR - I	IntraState	19/11/2022	12:16	19/11/2022	20:24	PO	For routine testing and maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 19/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LONIKAND I - KOYNA STAGE-IV	IntraState	19/11/2022	18:23			EO	For shifting 400kV Lonikand-Stage IV line on 400kV TBC due to hotspot on 29 B Isolator B phase on hanger rod assembly
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	18/11/2022	09:43	18/11/2022	18:50	PO	Diagnostic testing work of CB and other routine maint.work.
220 KV MAINBAY Outages/Trippings							
TBC @ HINJEWADI-2	IntraState	19/11/2022	09:15	19/11/2022	11:07	PO	Half yearly maintenance work
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/11/2022	08:24	19/11/2022	09:07	HT	For Load Management
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - PADGHE	IntraState	15/11/2022	08:45		Continued.	HT	For Load Management
URAN - KHARGHAR 2	IntraState	18/11/2022	09:14	18/11/2022	17:58	PO	1) For Insulator string replacement work. 2) Bay Maintaince Work and Diagnostic Testing Work.
TALANDGE - HAMIDWADA	IntraState	18/11/2022	09:30	18/11/2022	17:59	PO	Quarterly Maintainance Work, Diagnostic testing. Attending Hot spot.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	18/11/2022	09:34	18/11/2022	18:00	PO	Routine bay maintenance & Line maintenance
MALEGAON-SATANA	IntraState	18/11/2022	10:05	18/11/2022	15:54	HT	H/T TO CONTROL LINE LOADING
JAMBHUL - ANANDNAGAR	IntraState	18/11/2022	10:14	18/11/2022	20:18	PO	1) For attending hot spot 2) CB CRM, Timing and IR 3) Bay R&M work
MAIN BUS - 1 @ AAREY	IntraState	18/11/2022	10:25	18/11/2022	16:53	PO	Annual Maintenance of Main Bus-1 and Bus Side Isolators
BUS COUPLER @ AAREY	IntraState	18/11/2022	10:25	18/11/2022	16:54	PO	Annual Maint of Bus Coupler.facilitating outage of 220kV Main Bus 1
NAGAR BELWANDI CKT 1	IntraState	18/11/2022	11:20	18/11/2022	15:59	PO	For DIAGNOSTIC TESTING WORK
URSE-CHINCHWAD	IntraState	18/11/2022	21:30	19/11/2022	12:00	T	Tripped on Distance protection
KALWA - MULUND 1	IntraState	19/11/2022	06:27	19/11/2022	08:44	EO	Y ph LA replacement work due to high LCM value (596)
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	09:13	19/11/2022	14:33	PO	Routine bay maintenance & Line maintenance
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	19/11/2022	10:15	19/11/2022	13:25	PO	Annual Diagnostic Testing Work.
NERUL - SEAWOOD CABLE CKT - 2	IntraState	19/11/2022	11:06	19/11/2022	15:03	PO	Diagnostic and R.M.Work
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 19/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KANDALGAON - KOYNA (POPHALI)	IntraState	19/11/2022	16:05	19/11/2022	18:40	EO	For replacement of damaged insulator string at loc no 107 top R phase.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
250 MVA ICT-5 @ TROMBAY	IntraState	18/11/2022	08:24	18/11/2022	19:20	PO	110 KV RING BUS 2 & 3 OUTAGE FOR GOD REPLACEMENT
220/132KV 200MVA ICT 6 @ EKLAHARE (GCR)	IntraState	18/11/2022	09:02	18/11/2022	14:10	PO	diagnostic testing work
220/132 KV 200 MVA ICT 1 @ BOISAR-II	IntraState	18/11/2022	09:26	18/11/2022	15:26	PO	Bay Maintenance Works
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	IntraState	18/11/2022	10:07	19/11/2022	18:43	PO	TF oil filtration & QM work
220/132 KV 200 MVA ICT 2 @ BOISAR-II	IntraState	18/11/2022	15:54	18/11/2022	20:24	PO	Bay Maintenance Works
220/132 KV 100 MVA ICT-3 @ BHENDA	IntraState	19/11/2022	09:24	19/11/2022	13:34	PO	For Quarterly Maintenance work.
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	19/11/2022	09:40	19/11/2022	14:25	PO	Diagnostic Testing work of ICT ,HV & LV CTs.
220/22 KV 50 MVA PTR 1 @ CHAKAN	IntraState	19/11/2022	12:11	19/11/2022	17:17	PO	Outage required for overhauling of OLTC and routine testing along with Maintenance of 220/22kV 50MVA PTR-1
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	19/11/2022	12:18	19/11/2022	20:43	PO	For attending the OLTC diverter leakage issue.
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	18/11/2022	09:37	18/11/2022	16:58	PO	1) For MAIN BUS 2 insulator string replacement work.
110 KV LINE Outages/Trippings							
AMBERNATH - KALYAN CKT - 1	IntraState	18/11/2022	19:50	18/11/2022	22:15	PO	Project work for installation of New 110 KV breaker at OFA.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage