

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 19/Jan/2020 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 114.898        | 2257.014        | 1) Gujrat                      | 7.049          | 86.782          |
| 2) Hydro            | 14.551         | 246.347         | 2) Madhya Pradesh              | 11.149         | 250.063         |
| 3) Gas              | 6.914          | 93.703          | 3) Chattisgarh                 | 6.410          | 134.980         |
| <b>Total MSPGCL</b> | <b>136.363</b> | <b>2597.064</b> | 4) Maharashtra                 | 120.049        | 2176.685        |
| B) 1) APLM          | 74.303         | 1341.062        | 5) Goa (Amona)                 | -0.110         | -9.768          |
| 2) JSWEL            | 20.624         | 454.776         | <b>Total</b>                   | <b>144.547</b> | <b>2638.742</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 16.883         | 395.757         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 15.727         | 411.718         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 31.519         | 513.388         |
| 6) Other IPP        | 15.781         | 291.989         | Include PX                     | 7.491          | 91.665          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 16.883         | 395.757         |
| C) 1) TPCL Thermal  | 14.885         | 275.255         | Include PX                     | 2.889          | 145.374         |
| 2) TPCL Hydro       | 1.486          | 61.172          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 2.754          | 34.792          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 5.386          | 127.789         | 1) MSEDCL                      | 386.635        | 7188.077        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 40.238         | 910.728         |
| 1) Thermal          | 245.877        | 4747.885        | <b>TOTAL STATE</b>             | <b>426.873</b> | <b>8098.805</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 16.037         | 307.519         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 9.668          | 128.495         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 4.587          | 169.260         |                                |                |                 |
| 6) SOLAR            | 6.157          | 106.902         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>282.326</b> | <b>5460.061</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4818                      | 4833                  | 5012                      | 4336                      |
| MSPGCL Hydro             | 1452                      | 1421                  | 345                       | 163                       |
| MSPGCL Gas               | 285                       | 270                   | 284                       | 307                       |
| MSPGCL Total Generation  | 6555                      | 6524                  | 5641                      | 4806                      |
| Central Sector Receipt   | 7605                      | 7325                  | 5544                      | 5016                      |
| WIND                     | 272                       | 232                   | 209                       | 146                       |
| CPP / IPP Thermal        | 4798                      | 4786                  | 4747                      | 4172                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 947                       | 938                   | 0                         | 0                         |
| Exchange with Mumbai     | -712                      | -709                  | -835                      | -492                      |
| <b>MSEDCL DEMAND MET</b> | <b>19465</b>              | <b>19096</b>          | <b>15306</b>              | <b>13648</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 19465                     | 19096                 | 15306                     | 13648                     |
| TPCL GENERATION          | 1046                      | 999                   | 929                       | 575                       |
| AEML GENERATION          | 250                       | 249                   | 248                       | 189                       |
| <b>MUMBAI DEMAND</b>     | <b>2008</b>               | <b>1957</b>           | <b>2012</b>               | <b>1256</b>               |
| STATE DEMAND MET         | 21473                     | 21053                 | 17318                     | 14904                     |
| <b>STATE DEMAND</b>      | <b>21473</b>              | <b>21053</b>          | <b>17318</b>              | <b>14904</b>              |
| Frequency (Hz)           | 50.07                     | 49.95                 | 50.04                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.19 Hz at 06.01 Hrs | 49.81 Hz at 16.54 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 19/Jan/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 7.71         | 212.23        | 425      | 272      |
| Unit 9             | 6.40         | 209.31        | 450      | 50       |
| Unit 10            | 10.66        | 171.57        | 550      | 303      |
| <b>Total</b>       | <b>24.76</b> | <b>593.11</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 39.82         | 0        | 0        |
| Unit 7             | 0.00         | 45.72         | 0        | 0        |
| Unit 8             | 5.41         | 79.24         | 250      | 191      |
| <b>Total</b>       | <b>5.41</b>  | <b>164.78</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.21         | 78.96         | 187      | 163      |
| Unit 4             | 3.87         | 72.02         | 168      | 143      |
| Unit 5             | 6.95         | 151.50        | 300      | 236      |
| Unit 6             | 9.54         | 194.78        | 470      | 15       |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 10.66        | 203.68        | 470      | 360      |
| Unit 9             | 10.80        | 198.48        | 480      | 370      |
| <b>Total</b>       | <b>46.04</b> | <b>899.43</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.01         | 87.62         | 238      | 190      |
| Unit 4             | 5.42         | 101.51        | 251      | 34       |
| <b>Total</b>       | <b>10.42</b> | <b>189.14</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 4.10         | 32.36         | 185      | 160      |
| Unit 2             | 4.23         | 33.04         | 185      | 160      |
| Unit 3             | 4.18         | 34.37         | 190      | 158      |
| Unit 4             | 3.94         | 37.62         | 190      | 150      |
| Unit 5             | 10.95        | 199.26        | 500      | 370      |
| <b>Total</b>       | <b>27.39</b> | <b>336.65</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.81         | 69.92         | 161      | 0        |
| Unit 4             | 0.06         | 3.98          | 36       | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.87</b>  | <b>73.91</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.91         | 93.70         | 307      | 266      |
| <b>Total</b>       | <b>6.91</b>  | <b>93.70</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.19         | 2.09          | 41       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.19</b>   | <b>2.09</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 4.04          | 64.78          | 570      | 40       |
| Stage 4         | 6.27          | 102.20         | 1000     | 0        |
| Stage 3         | 2.04          | 35.84          | 240      | 0        |
| <b>Total</b>    | <b>12.34</b>  | <b>202.81</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 4.12           | 0        | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.48          | 8.85           | 60       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.10          | 2.65           | 63       | 0        |
| RNGR+BHTSA      | 0.38          | 6.47           | 16       | 15       |
| BHANDARDRA      | 0.00          | 0.00           | 0        | 0        |
| ELDARY          | 0.00          | 0.05           | 0        | 0        |
| SMLHY_PTN       | 0.27          | 6.30           | 12       | 11       |
| GHATGHAR        | 0.98          | 15.09          | 125      | 0        |
| <b>Total</b>    | <b>2.21</b>   | <b>43.53</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 4.59          | 169.26         | 0        | 0        |
| <b>Total</b>    | <b>4.59</b>   | <b>169.26</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 74.30         | 1341.06        | 0        | 0        |
| JSWEL(Mus)      | 20.62         | 454.78         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 0.00          | 0.00           | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 15.78         | 291.99         | 0        | 0        |
| <b>Total</b>    | <b>110.71</b> | <b>2087.83</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 6.16          | 106.90         | 0        | 0        |
| <b>Total</b>    | <b>6.16</b>   | <b>106.90</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.65          | 177.29         | 478      | 275      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.59          | 19.74          | 88       | 48       |
| Trombay 7B      | 1.16          | 15.05          | 57       | 38       |
| Trombay 8       | 5.24          | 97.96          | 244      | 184      |
| TATA Hydro      | 1.49          | 61.17          | 222      | 0        |
| <b>Total</b>    | <b>19.12</b>  | <b>371.22</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 5.39          | 127.79         | 250      | 187      |
| <b>Total</b>    | <b>5.39</b>   | <b>127.79</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 114.90      | 2257.01       | MSPGCL Total        | 136.36      | 2597.06       |
|                |             |         | MSPGCL Thml+Gas | 121.81      | 2350.72       | Koyna 1,2 & 4 Total | 10.30       | 166.98        |
|                |             |         | MSPGCL Hydro    | 14.55       | 246.35        | State Total         | 282.33      | 5460.06       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 19/Jan/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4341        | 68    | 300  | 4709   | 231  | 4529      | 0    | 0     | 5226        | 5044        | -655                 | 13858                 | 0                    | 13858                     | 1442             | 15300           | 50.03         |
| 2                  | 4344        | 98    | 296  | 4738   | 211  | 4199      | 0    | 0     | 5102        | 5301        | -564                 | 13885                 | 0                    | 13885                     | 1331             | 15216           | 50.00         |
| 3                  | 4336        | 163   | 307  | 4806   | 146  | 4172      | 0    | 0     | 5207        | 5016        | -492                 | 13648                 | 0                    | 13648                     | 1256             | 14904           | 50.00         |
| 4                  | 4412        | 83    | 298  | 4793   | 125  | 4168      | 0    | 0     | 5306        | 5299        | -475                 | 13910                 | 0                    | 13910                     | 1227             | 15137           | 50.00         |
| 5                  | 4715        | 73    | 296  | 5084   | 142  | 4187      | 0    | 0     | 5380        | 5338        | -479                 | 14272                 | 0                    | 14272                     | 1216             | 15488           | 50.01         |
| 6                  | 4920        | 313   | 298  | 5531   | 199  | 4418      | 0    | 0     | 5663        | 5772        | -543                 | 15377                 | 0                    | 15377                     | 1306             | 16683           | 50.03         |
| 7                  | 4908        | 218   | 297  | 5423   | 274  | 4837      | 0    | 2     | 6395        | 6185        | -420                 | 16301                 | 0                    | 16301                     | 1412             | 17713           | 50.01         |
| 8                  | 4844        | 840   | 298  | 5982   | 234  | 4791      | 0    | 71    | 6723        | 6823        | -449                 | 17452                 | 0                    | 17452                     | 1509             | 18961           | 49.97         |
| 9                  | 4937        | 1330  | 298  | 6565   | 199  | 4772      | 0    | 288   | 6628        | 6408        | -575                 | 17657                 | 0                    | 17657                     | 1670             | 19327           | 49.93         |
| 10                 | 4853        | 1561  | 303  | 6717   | 224  | 4593      | 0    | 566   | 7033        | 6877        | -689                 | 18288                 | 0                    | 18288                     | 1840             | 20128           | 49.98         |
| 11                 | 4850        | 1490  | 289  | 6629   | 214  | 4793      | 0    | 784   | 7416        | 7344        | -751                 | 19013                 | 0                    | 19013                     | 1956             | 20969           | 49.99         |
| 12                 | 4818        | 1452  | 285  | 6555   | 272  | 4798      | 0    | 947   | 7681        | 7605        | -712                 | 19465                 | 0                    | 19465                     | 2008             | 21473           | 50.07         |
| 13                 | 4833        | 1421  | 270  | 6524   | 232  | 4786      | 0    | 938   | 7191        | 7325        | -709                 | 19096                 | 0                    | 19096                     | 1957             | 21053           | 49.95         |
| 14                 | 4871        | 1170  | 278  | 6319   | 183  | 4745      | 0    | 841   | 7159        | 7160        | -686                 | 18562                 | 0                    | 18562                     | 1875             | 20437           | 50.02         |
| 15                 | 4708        | 978   | 274  | 5960   | 148  | 4783      | 0    | 761   | 7264        | 7224        | -647                 | 18229                 | 0                    | 18229                     | 1813             | 20042           | 50.05         |
| 16                 | 4766        | 786   | 266  | 5818   | 115  | 4767      | 0    | 561   | 6996        | 7098        | -595                 | 17764                 | 0                    | 17764                     | 1766             | 19530           | 49.99         |
| 17                 | 4797        | 852   | 279  | 5928   | 117  | 4765      | 0    | 322   | 6218        | 6236        | -585                 | 16783                 | 0                    | 16783                     | 1755             | 18538           | 49.95         |
| 18                 | 4821        | 637   | 280  | 5738   | 82   | 4769      | 0    | 76    | 5652        | 5800        | -624                 | 15841                 | 0                    | 15841                     | 1793             | 17634           | 50.01         |
| 19                 | 4909        | 387   | 271  | 5567   | 156  | 4799      | 0    | 0     | 5454        | 5526        | -747                 | 15301                 | 0                    | 15301                     | 1932             | 17233           | 49.98         |
| 20                 | 5012        | 345   | 284  | 5641   | 209  | 4747      | 0    | 0     | 5449        | 5544        | -835                 | 15306                 | 0                    | 15306                     | 2012             | 17318           | 50.04         |
| 21                 | 5127        | 72    | 285  | 5484   | 230  | 4620      | 0    | 0     | 5339        | 5298        | -953                 | 14679                 | 0                    | 14679                     | 1945             | 16624           | 49.97         |
| 22                 | 5116        | 72    | 288  | 5476   | 209  | 4646      | 0    | 0     | 5018        | 4837        | -928                 | 14240                 | 0                    | 14240                     | 1872             | 16112           | 50.01         |
| 23                 | 4952        | 76    | 299  | 5327   | 193  | 4496      | 0    | 0     | 4901        | 4903        | -869                 | 14050                 | 0                    | 14050                     | 1746             | 15796           | 50.03         |
| 24                 | 4708        | 66    | 275  | 5049   | 242  | 4528      | 0    | 0     | 4916        | 4584        | -745                 | 13658                 | 0                    | 13658                     | 1599             | 15257           | 50.03         |
| MUs                | 114.90      | 14.55 | 6.91 | 136.36 | 4.59 | 110.71    | 0.00 | 6.16  | 145.32      | 144.55      | -15.73               | 386.64                | 0.00                 | 386.64                    | 40.24            | 426.87          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center, Airoli (MSETCL) Statement-VI

## Details of Generating Unit Outages/Trippings for 19/Jan/2020

Position as on 6.30 Hrs of 20/Jan/2020

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                            | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                             |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                                                             |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 27/07/2019   | 00.00        |            | Continued. | Annual Overhaul                                                                             |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 25/09/2019   | 04.20        |            | Continued. | Withdrawn On Shaft Seal Water Leakage. Converted to AOH From 1 Nov 2019.                    |               |
| AEML                  | AEML Unit 2             | 250      | 06/01/2020   | 18.44        |            | Continued. | Annual Overhaul                                                                             |               |
| MSPGCL                | Nasik Unit 3            | 210      | 17/01/2020   | 17.00        | 19/01/2020 | 17.15      | Zero Schedule.                                                                              |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                             |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                     |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                           |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                           |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                 |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                 |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                      |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                                                                |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                                                                 |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                                               |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                                               |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |            | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs) |               |
| IPP                   | RPL(AMT) U-1            | 270      | 01/09/2019   | 09.11        |            | Continued. | Generator Protection operated                                                               |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |            | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL                | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                   | RPL(AMT) U-3            | 270      | 25/10/2019   | 02.00        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                   | RPL(AMT) U-2            | 270      | 25/10/2019   | 22.00        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                   | RPL(AMT) U-5            | 270      | 09/11/2019   | 03.00        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                   | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL                | Uran Unit 8             | 108      | 30/11/2019   | 19.14        |            | Continued. | Over Speed Bolt Trip.                                                                       |               |
| MSPGCL                | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 04.25Hrs DT. 13-12-2019)                          |               |
| MSPGCL                | Bhusawal Unit 5         | 500      | 23/12/2019   | 22.05        |            | Continued. | Boiler Tube Leakage(Converted to Zero Schedule from 22.00Hrs DT. 26-12-2019)                |               |
| MSPGCL                | Uran Unit B0            | 120      | 28/12/2019   | 22:48        |            | Continued. | Gas shortage                                                                                |               |
| MSPGCL                | Uran Unit 7             | 108      | 28/12/2019   | 22:48        |            | Continued. | Gas shortage                                                                                |               |
| MSPGCL                | Bhusawal Unit 4         | 500      | 29/12/2019   | 00.57        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 19/Jan/2020**

**Position as on 6.30 Hrs of 20/Jan/2020**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage            | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------|---------------|
| MSPGCL             | Parli Unit 6            | 250      | 12/01/2020   | 00.00        |            | Continued. | Zero Schedule By MSEDCL.    |               |
| MSPGCL             | Parli Unit 7            | 250      | 12/01/2020   | 00.00        |            | Continued. | Zero Schedule By MSEDCL.    |               |
| MSPGCL             | Koyna Unit 9            | 80       | 18/01/2020   | 08.00        |            | Continued. | Transformer shifted work.   |               |
| MSPGCL             | Chandrapur Unit 6       | 500      | 18/01/2020   | 12.36        | 19/01/2020 | 00.51      | Bus fault.                  |               |
| MSPGCL             | Nasik Unit 4            | 210      | 19/01/2020   | 00.16        | 19/01/2020 | 04.06      | Low Vacuum                  |               |
| MSPGCL             | Nasik Unit 4            | 210      | 19/01/2020   | 04.35        |            | Continued. | Governing problem.          |               |
| IPP                | JSW (J) U1              | 300      | 19/01/2020   | 08.46        | 19/01/2020 | 21.23      | Governer Rectification work |               |
| MSPGCL             | Paras Unit 4            | 250      | 19/01/2020   | 23.13        |            | Continued. | suspected Leakage           |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Jan/2020**

**Statement-VII**

Position as on 6.30 Hrs of 20/Jan/2020

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                         |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                          |
| Karad Solapur (PG)                     | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403 |
| Dhule Sar'Sarovar I                    | InterState                | 18/01/2020   | 19.29        | 19/01/2020 | 10.41      | HT          | Over Voltage                                             |
| Chakan Talegaon(Pg)                    | InterState                | 19/01/2020   | 15.21        | 19/01/2020 | 16.58      | T           | Bus Bar-2 Operated                                       |
| Dhule Sar'Sarovar II                   | InterState                | 19/01/2020   | 18.36        |            | Continued. | HT          | Over Voltage                                             |
| Khadka-Aurangabad (Waluj)              | IntraState                | 18/01/2020   | 19.05        | 19/01/2020 | 10.40      | HT          | Over Voltage                                             |
| Koradi-Khaperkheda I                   | IntraState                | 19/01/2020   | 09.44        |            | Continued. | PO          | Annual Maintenance Work                                  |
| Main Bus 1 @ New Koyna                 | IntraState                | 19/01/2020   | 11.11        | 19/01/2020 | 19.21      | PO          | Replacement of Damage Conductor of Bus 1.                |
| N.Koyna-Karad -Ckt I                   | IntraState                | 19/01/2020   | 12.20        |            | Continued. | PO          | outage of Main Bus-1 at New Koyna(RFC at 21:36hrs.)      |
| Khadka-Aurangabad (Waluj)              | IntraState                | 19/01/2020   | 18.36        |            | Continued. | HT          | Over Voltage                                             |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                          |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe    | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                |
| 400/220/33 Kv 315 MVA ICT -I @Kharghar | IntraState                | 19/01/2020   | 13.40        | 19/01/2020 | 21.00      | PO          | To attend OLTC Y-Phase Oil Leakage                       |
| 400/220 Kv 315 Mva Ict -2 @New Koyna   | IntraState                | 19/01/2020   | 14.02        | 19/01/2020 | 15.16      | HT          | Sparking on B-phase Isolator                             |
| 400/220 Kv 315 MVA ICT-II @Chakan      | IntraState                | 19/01/2020   | 15.21        | 19/01/2020 | 17.07      | T           | Bus Bar-2 Operated                                       |
| 400/220 Kv 600 MVA ICT-II @Kalwa       | IntraState                | 20/01/2020   | 05.49        |            | Continued. | PO          | To attending Oil Leakage Y-Phase PRV                     |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                          |
| Mudshingi Chikodi                      | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.(close at Mudshingi end only)                |
| Talandage - Chikodi                    | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                  |
| Boisar(MS) - Boisar (PG) II            | InterState                | 17/01/2020   | 07.35        | 19/01/2020 | 22.53      | PO          | Construction Work.                                       |
| Boiser(M)-Boiser(PG) -III              | InterState                | 19/01/2020   | 09.06        | 19/01/2020 | 19.41      | PO          | Construction Work                                        |
| BOISAR BORIVALI                        | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)             |
| MAHAPE - RELIANCE GIS                  | IntraState                | 08/01/2020   | 10:44        |            | Continued. | HT          | At Mahape End For New Configuration.                     |
| Kalwa - Mulund 2                       | IntraState                | 15/01/2020   | 09.02        |            | Continued. | PO          | Stringing of HTLS conductor.                             |
| Wardha-Yeotmal                         | IntraState                | 16/01/2020   | 12.13        |            | Continued. | PO          | Shifting/Diversion work of 220KV Deoli-Pusad D/C Line    |
| Boisar Versova Line                    | IntraState                | 17/01/2020   | 07.03        | 19/01/2020 | 22.55      | HT          | Outage on 220KV Boiser-Boiser PG CKT-2 & CKT-3.          |
| Boisar(M) - Ghodbunder                 | IntraState                | 18/01/2020   | 07.35        | 19/01/2020 | 22.59      | HT          | Control loading.                                         |
| Bhira Dharavi 7                        | IntraState                | 18/01/2020   | 08.08        |            | Continued. | PO          | Maintenance work.                                        |
| Boisar-Viraj                           | IntraState                | 18/01/2020   | 08.14        | 19/01/2020 | 22.24      | HT          | Control loading.                                         |
| Nalasopara-Boisar                      | IntraState                | 19/01/2020   | 08.35        | 19/01/2020 | 19.56      | PO          | Construction Work                                        |
| REL Borivali Aarey Line                | IntraState                | 19/01/2020   | 13.19        | 19/01/2020 | 21.21      | PO          | Annual Maintenance Work                                  |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                          |
| 220/100 Kv 200 MVA ICT IV @Padghe      | IntraState                | 18/01/2020   | 09.59        |            | Continued. | PO          | Maintenance work.                                        |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage