

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Feb/2019 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	144.323	2569.750	1) Gujrat	1.405	35.996
2) Hydro	9.780	150.985	2) Madhya Pradesh	14.655	264.600
3) Gas	7.199	131.611	3) Chattisgarh	5.830	117.750
Total MSPGCL	161.302	2852.346	4) Maharashtra	94.962	1892.993
B) 1) APLM	71.652	1136.256	5) Goa (Amona)	-0.506	-9.196
2) JSWEL	23.248	387.761	Total	116.346	2302.143
3) VIPL	0.000	0.000	a) Mumbai Schedule	16.118	303.112
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	17.952	327.053
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	8.016	290.637
6) Other IPP	12.653	242.885	Include PX	-6.286	9.709
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	16.118	302.218
C) 1) TPCL Thermal	13.596	257.433	Include PX	3.808	94.375
2) TPCL Hydro	3.759	59.024	Standby	0.000	0.894
3) TPCL Gas	4.199	77.012	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.877	182.771	1) MSEDCL	380.080	6895.861
D) STATE			2) Mumbai Discoms	49.383	903.290
1) Thermal	275.349	4776.856	TOTAL STATE	429.463	7799.151
(A1+C1+C4+(B1-B6))					
2) Hydro	13.539	210.009			
(A2+C2)					
3) Gas	11.398	208.623			
(A3+B7+C3)					
4) Wind	5.697	184.040			
6) SOLAR	7.134	117.483			
TOTAL STATE	313.117	5497.011			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6406	6393	6083	5299
MSPGCL Hydro	724	586	555	139
MSPGCL Gas	289	285	292	315
MSPGCL Total Generation	7419	7264	6930	5753
Central Sector Receipt	5704	5501	4606	4392
WIND	225	261	206	233
CPP / IPP Thermal	4919	4739	4601	3825
CPP / IPP Gas	0	0	0	0
SOLAR	996	1003	0	0
Exchange with Mumbai	-1010	-973	-952	-346
MSEDCL DEMAND MET	18253	17795	15391	13857
Load Shedding	0	0	0	0
MSEDCL DEMAND	18253	17795	15391	13857
TPCL GENERATION	1052	1052	1071	634
AEML GENERATION	501	500	375	374
MUMBAI DEMAND	2563	2525	2398	1354
STATE DEMAND MET	20816	20320	17789	15211
STATE DEMAND	20816	20320	17789	15211
Frequency (Hz)	50.02	49.99	50.01	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 18.02 Hrs	49.75 Hz at 21.08 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 19/Feb/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.60	30.41	180	130
Unit 7	0.00	0.00	0	0
Unit 8	8.90	194.72	419	305
Unit 9	11.46	203.56	502	405
Unit 10	8.90	195.50	405	310
Total	32.86	624.20		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.28	184.18	500	350
Unit 5	10.20	152.93	500	350
Total	20.48	337.11		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.50	81.78	196	169
Unit 4	4.36	56.86	191	161
Unit 5	9.68	122.91	430	353
Unit 6	10.32	158.26	460	365
Unit 7	10.04	184.33	450	373
Unit 8	11.15	201.15	497	360
Unit 9	10.61	198.74	490	370
Total	60.66	1004.04		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	5.37	70.18	250	187
Total	5.37	70.18		
Khaparkheda				
Unit 1	3.33	68.32	160	125
Unit 2	3.76	69.44	165	140
Unit 3	0.00	66.67	0	0
Unit 4	3.81	71.24	165	155
Unit 5	10.07	180.70	480	375
Total	20.97	456.36		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	30.01	0	0
Unit 5	3.99	47.85	186	157
Total	3.99	77.86		
Uran				
All Units	7.20	131.61	318	283
Total	7.20	131.61		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	0.26	20	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.03	0.26		
Koyna				
Stage 1-2	2.02	43.40	300	40
Stage 4	1.22	21.44	384	0
Stage 3	0.70	14.32	80	0
Total	3.93	79.17		
Hydro				
KDPH	0.89	6.09	37	37
VTRNA	0.68	12.63	62	0
TILLARI	0.60	4.14	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.19	2.88	80	0
RNGR+BHTSA	0.28	5.82	12	11
BHANDARDRA	0.51	1.36	45	11
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.49	10.44	21	20
GHATGHAR	2.21	28.47	250	0
Total	5.85	71.82		
Wind				
Total	5.70	184.04	0	0
Total	5.70	184.04		
CPP				
APML(Mus)	71.65	1136.26	0	0
JSWEL(Mus)	23.25	387.76	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	12.65	242.88	0	0
Total	107.55	1766.90		
SOLAR				
Total	7.13	117.48	0	0
Total	7.13	117.48		
Tata				
Trombay 5	8.66	158.91	486	303
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.64	48.15	117	75
Trombay 7B	1.56	28.86	68	54
Trombay 8	4.93	98.53	220	199
TATA Hydro	3.76	59.02	395	0
Total	21.55	393.47		
AEML				
DTPS U-1&2	9.88	182.77	502	373
Total	9.88	182.77		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	144.32	2569.75	MSPGCL Total	161.30	2852.35
			MSPGCL Thml+Gas	151.52	2701.36	Koyna 1,2 & 4 Total	3.23	64.85
			MSPGCL Hydro	9.78	150.98	State Total	313.12	5497.01

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Feb/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5269	159	312	5740	198	3957	0	0	4597	4614	-530	13979	0	13979	1594	15573	50.00
2	5277	139	314	5730	234	3960	0	0	4490	4474	-410	13988	0	13988	1469	15457	50.02
3	5280	124	304	5708	241	3882	0	0	4434	4432	-363	13900	0	13900	1393	15293	50.01
4	5299	139	315	5753	233	3825	0	0	4335	4392	-346	13857	0	13857	1354	15211	49.96
5	5293	129	315	5737	274	3933	0	0	4571	4548	-357	14135	0	14135	1363	15498	49.98
6	5613	159	316	6088	263	4036	0	0	4972	5113	-449	15051	0	15051	1469	16520	49.98
7	6218	254	318	6790	227	4504	0	11	5220	4996	-451	16077	0	16077	1628	17705	50.00
8	6336	783	306	7425	197	4922	0	128	5174	5519	-474	17717	0	17717	1844	19561	50.00
9	6338	1003	315	7656	149	4936	0	419	5325	5382	-657	17885	0	17885	2123	20008	49.94
10	6336	903	296	7535	173	4953	0	668	5408	5379	-864	17844	0	17844	2426	20270	49.94
11	6397	810	293	7500	201	4931	0	881	5563	5666	-1011	18168	0	18168	2534	20702	50.01
12	6406	724	289	7419	225	4919	0	996	5645	5704	-1010	18253	0	18253	2563	20816	50.02
13	6393	586	285	7264	261	4739	0	1003	5427	5501	-973	17795	0	17795	2525	20320	49.99
14	6389	516	284	7189	221	4499	0	975	5307	5161	-909	17136	0	17136	2377	19513	50.02
15	6266	511	285	7062	263	4492	0	823	5272	5254	-1004	16890	0	16890	2396	19286	50.02
16	6095	502	283	6880	322	4445	0	641	5185	5482	-950	16820	0	16820	2406	19226	49.94
17	6337	334	287	6958	324	4495	0	458	5003	5084	-938	16381	0	16381	2407	18788	49.96
18	6314	244	289	6847	395	4479	0	131	4483	4735	-930	15657	0	15657	2381	18038	50.04
19	6201	287	291	6779	306	4453	0	0	4623	4589	-946	15181	0	15181	2388	17569	50.04
20	6083	555	292	6930	206	4601	0	0	4665	4606	-952	15391	0	15391	2398	17789	50.01
21	6064	385	295	6744	174	4740	0	0	3924	4015	-941	14732	0	14732	2337	17069	49.95
22	6099	212	297	6608	199	4696	0	0	3917	4019	-878	14644	0	14644	2174	16818	49.96
23	6271	182	310	6763	163	4761	0	0	3887	3638	-847	14478	0	14478	2007	16485	50.01
24	5749	140	308	6197	248	4395	0	0	4354	4043	-762	14121	0	14121	1827	15948	49.97
MUs	144.32	9.78	7.20	161.30	5.70	107.55	0.00	7.13	115.78	116.35	-17.95	380.08	0.00	380.08	49.38	429.46	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Feb/2019

Position as on 6.30 Hrs of 20/Feb/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	14/12/2018	16.30		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	RPL(AMT) U-2	270	27/12/2018	19.30		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/01/2019	19.30		Continued.	Zero Schedule	
IPP	Dhariwal	300	12/01/2019	10.15		Continued.	Coal Shortage	
MSPGCL	Parli Unit 8	250	12/01/2019	12.00		Continued.	Zero Schedule by MSEDCL	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	19/01/2019	18.21		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-1	270	27/01/2019	02.17		Continued.	Withdrawn On RSD.	
MSPGCL	Nasik Unit 4	210	08/02/2019	05.18		Continued.	Zero schedule	
MSPGCL	Khaparkheda Unit 3	210	18/02/2019	17:21		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 6	500	20/02/2019	22.07		Continued.	Rotor Earth Fault	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Feb/2019

Statement-VII

Position as on 6.30 Hrs of 20/Feb/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Tirora ckt-II	IntraState	19/02/2019	12.49	19/02/2019	18.05	EO	Y Phase Metering ct Red Hot Spot Attending Work.
Ektuni-Akola II Ckt 2	IntraState	20/02/2019	23.48		Continued.	T	Distance Protection,Y PH,Z1.59.9KM,5.2KA From Akola
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dabhol Newkoyna li	InterState	16/02/2019	08.55	20/02/2019	13.38	PO	PM & testing work RFC 20.30 hrs. CVT problem at RGPPL.
Dhule Sar'Sarovar II	InterState	18/02/2019	18.16		Continued.	HT	Over Voltage
Akola Aurangabad(PG) II	InterState	19/02/2019	02.43	19/02/2019	19.41	EO	HT Due To oil Leakage CB Compressor Motor
Boisar (PG)- Aurangabad (PG)-II	InterState	20/02/2019	13.48	20/02/2019	17.20	PO	Remove Kite Thread At Loc.No.520.
Dhule Sar'Sarovar I	InterState	20/02/2019	14.25	20/02/2019	15.35	T	Distance Protection Operated Bph/Z2/203KM/1.81KA.
Kalwa - Talegaon(PG)	IntraState	16/02/2019	08.59		Continued.	PO	Construction Work for height raising.
Kalwa - Kharghar	IntraState	16/02/2019	09.46		Continued.	PO	Construction Work for height raising.
Akola - Bhusawal	IntraState	18/02/2019	08.56	19/02/2019	19.26	PO	Restranging of Conductor.(RFC 20.45)
New Koyna - Dabhol - li	IntraState	18/02/2019	09.04	20/02/2019	09.00	PO	Le Scheme For Insulator String Replacement
TBC @ chandrapur	IntraState	18/02/2019	09.55	19/02/2019	13.54	PO	PG Isolator Problem.
Karad - Jaigad - II	IntraState	18/02/2019	18.10	19/02/2019	09.32	HT	Over Voltage
Padghe - Nagothane - I	IntraState	18/02/2019	22.19	19/02/2019	09.38	HT	Over Voltage
Akola - Bhusawal	IntraState	19/02/2019	10.24	19/02/2019	19.26	PO	Railway Work Already Out.
Koradi-Bhusawal	IntraState	19/02/2019	14.01	19/02/2019	15.21	T	Distance Protection,Z1,YPH 3.76 kA, 92.4KM-Koradi End Z1,Y PH.1.5KA,250KM-Khadka end.
Khadka-Aurangabad (Waluj)	IntraState	19/02/2019	19.29	20/02/2019	07.40	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	19/02/2019	20.23		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	19/02/2019	22.06	20/02/2019	08.38	HT	Over Voltage
Deepnagar Taptitanda	IntraState	20/02/2019	07.45	20/02/2019	18.03	PO	Mid Span Joint Work.
Akola - Bhusawal	IntraState	20/02/2019	09.58	20/02/2019	17.50	PO	Conductor straining Work.
Bhusawal-Aurangabad	IntraState	20/02/2019	21.39		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.
Gadchandur-Ultratech II	IntraState	13/02/2019	18.00		Continued.	PO	Metering C.T.Replacement Work.
BOISAR BORIVALI	IntraState	19/02/2019	07.15	19/02/2019	11.45	PO	CT Tan Delta.
Miraj - Tilwani	IntraState	19/02/2019	08.18	19/02/2019	21.53	PO	Line Insulator Cleaning Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Feb/2019

Statement-VII

Position as on 6.30 Hrs of 20/Feb/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Khadka-Chalisgaon-1	IntraState	19/02/2019	09.16		Continued.	PO	For Erection Of Inline Tower.
Koradi-Butibori Rly Tss	IntraState	19/02/2019	09.28	19/02/2019	14.00	EO	Attending Hot Spot
Khadka-Chalisgaon-2	IntraState	19/02/2019	09.28		Continued.	PO	For Erection Of Inline Tower.
Vankuswade - Kdph	IntraState	19/02/2019	10.25	19/02/2019	15.10	PO	Quarterly Maintainance Work
AKOLA ANJANGAON (VIHIGAON) CKT-II	IntraState	19/02/2019	10.38	19/02/2019	13.55	PO	Tree Cutting Work.
Tata Borivli MSETCL Borivli 4	IntraState	19/02/2019	12.24	19/02/2019	19.52	PO	Routine Maintenance Work
Vankuswadi- Ajinkyatara	IntraState	19/02/2019	16.05	19/02/2019	19.30	PO	Quarterly Maintainance Work
TPC Borivali Aarey Line 1	IntraState	20/02/2019	00.31	20/02/2019	05.59	PO	Outage for metro.
Trombay Salsette 1 Backbay	IntraState	20/02/2019	07.40	20/02/2019	10.20	PO	For Replacement Of Compartment 5 SF 6 Gauge.
Padegaon-Sawangi	IntraState	20/02/2019	08.48	20/02/2019	18.10	PO	Line Maintenance work
Aurangabad - Chitegaon	IntraState	20/02/2019	10.05	20/02/2019	14.19	PO	Diagnostic Testing Work.
Lamboti - Pandharpur li	IntraState	20/02/2019	10.08	20/02/2019	13.26	PO	Diagnostic Testing Work.
Butibori-Sunvijay	IntraState	20/02/2019	10.14	20/02/2019	19.17	PO	Diagnostic Testing Work.
Kalwa - Mulund 1	IntraState	20/02/2019	10.38	20/02/2019	11.02	T	During Hot Line Washing.
Koradi-Khaperkheda	IntraState	20/02/2019	10.40	20/02/2019	12.51	PO	Relay Testing Work.
Talandge(400)- Mudshingi 2 Line	IntraState	20/02/2019	11.02	20/02/2019	17.55	PO	B PH Insulator String Replacement Work.
Yeotmal- Pusad	IntraState	20/02/2019	11.07	20/02/2019	11.34	HT	O/G At Yeotmal On PT Bay.
Uran - Ongc Uran	IntraState	20/02/2019	11.16	20/02/2019	17.01	PO	Diagnostic Testing Work.
Raymond - Washala	IntraState	20/02/2019	11.20	20/02/2019	16.40	EO	Insulator Decapping Work.
Pusad-Ghatodi	IntraState	20/02/2019	11.22	20/02/2019	20.25	HT	O/G At Yeotmal On PT Bay.
Solapur(Bale) - Tuljapur	IntraState	20/02/2019	11.35	20/02/2019	18.35	PO	Outage At Vairag End
220 KV ICT Outages/Trippings							
220/66 Kv 150 Mva Emco Ict 2 @Gadchandur	IntraState	13/02/2019	11.35		Continued.	PO	LV Bushing Replacement,Work For 10 Days
220/132 Kv 200 Mva Vijay Ict 2 @Malegaon	IntraState	16/02/2019	09.46	20/02/2019	16.28	PO	OIL FILTREAION WORK.
220/132 Kv 200MVA ICT II @Dhule	IntraState	18/02/2019	19.44	20/02/2019	19.53	PO	Oil Leakage On Rph Bushing.
220/100kv 200MVA ICT @ Ogalewadi	IntraState	19/02/2019	14.52	19/02/2019	17.51	PO	Bus Bar Testing Work.
220/100 Kv 200 MVA ICT-I @Borivali	IntraState	20/02/2019	09.24	20/02/2019	19.43	PO	Routine Maintenance Work & Diagnostic Testing Work.
220/132 Kv 200mva Kanohar Ict 3 @Bale (Solapur 2)	IntraState	20/02/2019	10.45	20/02/2019	18.00	PO	Quarterly Maintainance Work
220/22 Kv 50 Mva Bhel Ptr 1 @Padghe	IntraState	20/02/2019	11.11	20/02/2019	19.35	PO	Oil Leakage Attending Work.
220/132 Kv 200MVA ICT II @Dhule	IntraState	20/02/2019	21.04	20/02/2019	21.47	HT	For Air Venting Before Taking load.
132 KV LINE Outages/Trippings							
Mansar Pench	InterState	22/10/2018	18.40		Continued.	HT	CB Closed At Pench & In view Of Outage On 132kv Kanhan-Mansar Line.
Kanhan-Pench	IntraState	22/01/2019	18.44		Continued.	HT	After Completion of Outage.
Malegaon(220kv)-Malegaon(132kv) I	IntraState	16/02/2019	09.34	20/02/2019	16.40	HT	Ict 2 Outage At 220KV Malegaon.
Malegaon(220kv)-Malegaon(132kv) li	IntraState	16/02/2019	09.37	20/02/2019	16.40	HT	Ict 2 Outage At 220KV Malegaon.
Beed(220kv) -Telgaon	IntraState	19/02/2019	14.00	19/02/2019	14.25	T	Z1 Distance Protection 2.47KA,BKR Not Tripped At Beed
Pusad-Jambazar	IntraState	20/02/2019	11.20	20/02/2019	20.34	HT	O/G At Yeotmal On PT Bay.
Solapur II(Bale)-Naldurg	IntraState	20/02/2019	16.27		Continued.	T	Distance Protection Z1,R-YPH,1.26KA,62kM.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage