

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 19/Mar/2019 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 134.089        | 2436.305        | 1) Gujrat                      | 1.996          | 44.414          |
| 2) Hydro            | 13.017         | 181.071         | 2) Madhya Pradesh              | 18.714         | 331.153         |
| 3) Gas              | 6.997          | 130.130         | 3) Chattisgarh                 | 6.650          | 105.920         |
| <b>Total MSPGCL</b> | <b>154.103</b> | <b>2747.506</b> | 4) Maharashtra                 | 123.414        | 2154.466        |
| B) 1) APLM          | 60.283         | 1351.030        | 5) Goa (Amona)                 | -0.528         | -7.260          |
| 2) JSWEL            | 24.066         | 419.494         | <b>Total</b>                   | <b>150.246</b> | <b>2628.693</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 22.418         | 368.004         |
| 4) RPL(AMT)         | 5.784          | 57.709          | b) Mumbai Drawl                | 21.247         | 384.901         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 21.444         | 269.918         |
| 6) Other IPP        | 15.256         | 234.298         | Include PX                     | -0.989         | -27.803         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 22.418         | 368.004         |
| C) 1) TPCL Thermal  | 15.156         | 263.726         | Include PX                     | 14.206         | 155.263         |
| 2) TPCL Hydro       | 6.077          | 85.882          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.351          | 82.299          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 10.683         | 188.945         | 1) MSEDCL                      | 408.768        | 7427.387        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 57.514         | 1005.755        |
| 1) Thermal          | 265.317        | 4951.507        | <b>TOTAL STATE</b>             | <b>466.282</b> | <b>8433.142</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 19.094         | 266.953         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.348         | 212.429         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 13.367         | 237.890         |                                |                |                 |
| 6) SOLAR            | 6.910          | 135.668         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>316.036</b> | <b>5804.447</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5863                      | 5883                  | 5822                      | 5066                      |
| MSPGCL Hydro             | 1479                      | 1027                  | 206                       | 240                       |
| MSPGCL Gas               | 270                       | 281                   | 290                       | 298                       |
| MSPGCL Total Generation  | 7612                      | 7191                  | 6318                      | 5604                      |
| Central Sector Receipt   | 6767                      | 6602                  | 6051                      | 5892                      |
| WIND                     | 179                       | 180                   | 929                       | 693                       |
| CPP / IPP Thermal        | 4518                      | 4544                  | 4588                      | 3853                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 919                       | 925                   | 0                         | 0                         |
| Exchange with Mumbai     | -1129                     | -1051                 | -1173                     | -579                      |
| <b>MSEDCL DEMAND MET</b> | <b>18866</b>              | <b>18391</b>          | <b>16713</b>              | <b>15463</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 18866                     | 18391                 | 16713                     | 15463                     |
| TPCL GENERATION          | 1353                      | 1354                  | 1144                      | 696                       |
| AEML GENERATION          | 502                       | 501                   | 374                       | 373                       |
| <b>MUMBAI DEMAND</b>     | <b>2984</b>               | <b>2906</b>           | <b>2691</b>               | <b>1648</b>               |
| STATE DEMAND MET         | 21850                     | 21297                 | 19404                     | 17111                     |
| <b>STATE DEMAND</b>      | <b>21850</b>              | <b>21297</b>          | <b>19404</b>              | <b>17111</b>              |
| Frequency (Hz)           | 50.02                     | 50.03                 | 50.03                     | 49.95                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 18.03 Hrs | 49.76 Hz at 22.09 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 19/Mar/2019

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 1.75         | 67.06         | 175      | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 9.49         | 186.96        | 440      | 327      |
| Unit 9             | 10.21        | 170.05        | 560      | 321      |
| Unit 10            | 9.24         | 190.29        | 513      | 296      |
| <b>Total</b>       | <b>30.68</b> | <b>614.36</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 10.86        | 146.48        | 505      | 350      |
| Unit 5             | 10.90        | 192.46        | 505      | 355      |
| <b>Total</b>       | <b>21.76</b> | <b>338.94</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 5.48         | 26.38         | 249      | 191      |
| <b>Total</b>       | <b>5.48</b>  | <b>26.38</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.58         | 84.55         | 194      | 180      |
| Unit 4             | 4.38         | 81.67         | 187      | 176      |
| Unit 5             | 9.65         | 180.39        | 410      | 391      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 33.34         | 0        | 0        |
| Unit 8             | 10.99        | 207.78        | 484      | 420      |
| Unit 9             | 10.90        | 201.72        | 480      | 434      |
| <b>Total</b>       | <b>40.50</b> | <b>789.45</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 6.01         | 108.84        | 255      | 245      |
| <b>Total</b>       | <b>6.01</b>  | <b>108.84</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.96         | 74.84         | 195      | 0        |
| Unit 2             | 4.10         | 73.12         | 175      | 150      |
| Unit 3             | 1.05         | 67.31         | 180      | 0        |
| Unit 4             | 4.42         | 66.64         | 200      | 147      |
| Unit 5             | 11.55        | 196.06        | 500      | 469      |
| <b>Total</b>       | <b>25.09</b> | <b>477.96</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.56         | 80.36         | 210      | 160      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>4.56</b>  | <b>80.36</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.00         | 130.13        | 310      | 270      |
| <b>Total</b>       | <b>7.00</b>  | <b>130.13</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.03         | 2.02          | 28       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.03</b>   | <b>2.02</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 4.47          | 58.39          | 500      | 40       |
| Stage 4         | 2.99          | 21.30          | 469      | 0        |
| Stage 3         | 1.42          | 17.73          | 160      | 0        |
| <b>Total</b>    | <b>8.88</b>   | <b>97.41</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.89          | 15.41          | 37       | 37       |
| VTRNA           | 0.54          | 17.60          | 61       | 0        |
| TILLARI         | 0.60          | 6.31           | 60       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.37          | 4.70           | 80       | 0        |
| RNGR+BHTSA      | 0.30          | 5.57           | 13       | 12       |
| BHANDARDRA      | 0.42          | 8.39           | 35       | 9        |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.47          | 10.78          | 20       | 19       |
| GHATGHAR        | 0.54          | 14.90          | 125      | 0        |
| <b>Total</b>    | <b>4.14</b>   | <b>83.66</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 13.37         | 237.89         | 0        | 0        |
| <b>Total</b>    | <b>13.37</b>  | <b>237.89</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 60.28         | 1351.03        | 0        | 0        |
| JSWEL(Mus)      | 24.07         | 419.49         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 5.78          | 57.71          | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 15.26         | 234.30         | 0        | 0        |
| <b>Total</b>    | <b>105.39</b> | <b>2062.53</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 6.91          | 135.67         | 0        | 0        |
| <b>Total</b>    | <b>6.91</b>   | <b>135.67</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.85          | 165.97         | 486      | 311      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.77          | 52.32          | 117      | 114      |
| Trombay 7B      | 1.58          | 29.98          | 67       | 65       |
| Trombay 8       | 5.30          | 97.75          | 231      | 200      |
| TATA Hydro      | 6.08          | 85.88          | 459      | 0        |
| <b>Total</b>    | <b>25.58</b>  | <b>431.91</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 10.68         | 188.94         | 503      | 373      |
| <b>Total</b>    | <b>10.68</b>  | <b>188.94</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 134.09      | 2436.30       | MSPGCL Total        | 154.10      | 2747.51       |
|                |             |         | MSPGCL Thml+Gas | 141.09      | 2566.44       | Koyna 1,2 & 4 Total | 7.46        | 79.69         |
|                |             |         | MSPGCL Hydro    | 13.02       | 181.07        | State Total         | 316.04      | 5804.45       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 19/Mar/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5106        | 260   | 295  | 5661   | 797   | 4302      | 0    | 0     | 6049        | 6162        | -821                 | 16101                 | 0                    | 16101                     | 1952             | 18053           | 49.97         |
| 2                  | 5055        | 120   | 306  | 5481   | 855   | 4340      | 0    | 0     | 6014        | 5944        | -704                 | 15916                 | 0                    | 15916                     | 1804             | 17720           | 49.98         |
| 3                  | 5090        | 305   | 298  | 5693   | 749   | 4037      | 0    | 0     | 5858        | 6030        | -638                 | 15871                 | 0                    | 15871                     | 1707             | 17578           | 49.99         |
| 4                  | 5066        | 240   | 298  | 5604   | 693   | 3853      | 0    | 0     | 5863        | 5892        | -579                 | 15463                 | 0                    | 15463                     | 1648             | 17111           | 49.95         |
| 5                  | 5122        | 235   | 309  | 5666   | 618   | 3965      | 0    | 0     | 5954        | 5955        | -574                 | 15630                 | 0                    | 15630                     | 1653             | 17283           | 49.93         |
| 6                  | 5418        | 603   | 310  | 6331   | 504   | 4370      | 0    | 0     | 6010        | 5955        | -488                 | 16672                 | 0                    | 16672                     | 1773             | 18445           | 50.00         |
| 7                  | 5691        | 1317  | 301  | 7309   | 496   | 4598      | 0    | 6     | 6165        | 6153        | -533                 | 18029                 | 0                    | 18029                     | 1934             | 19963           | 50.04         |
| 8                  | 5788        | 1008  | 310  | 7106   | 300   | 4651      | 0    | 148   | 6197        | 6285        | -611                 | 17879                 | 0                    | 17879                     | 2124             | 20003           | 50.09         |
| 9                  | 5834        | 634   | 297  | 6765   | 291   | 4742      | 0    | 406   | 6256        | 6509        | -755                 | 17958                 | 0                    | 17958                     | 2408             | 20366           | 50.06         |
| 10                 | 5750        | 482   | 287  | 6519   | 294   | 4665      | 0    | 651   | 6451        | 6482        | -895                 | 17716                 | 0                    | 17716                     | 2703             | 20419           | 49.96         |
| 11                 | 5782        | 855   | 282  | 6919   | 261   | 4574      | 0    | 827   | 6600        | 6680        | -1057                | 18204                 | 0                    | 18204                     | 2913             | 21117           | 49.97         |
| 12                 | 5863        | 1479  | 270  | 7612   | 179   | 4518      | 0    | 919   | 6630        | 6767        | -1129                | 18866                 | 0                    | 18866                     | 2984             | 21850           | 50.02         |
| 13                 | 5883        | 1027  | 281  | 7191   | 180   | 4544      | 0    | 925   | 6576        | 6602        | -1051                | 18391                 | 0                    | 18391                     | 2906             | 21297           | 50.03         |
| 14                 | 5784        | 536   | 281  | 6601   | 267   | 4535      | 0    | 928   | 6479        | 6335        | -996                 | 17670                 | 0                    | 17670                     | 2847             | 20517           | 49.97         |
| 15                 | 5794        | 497   | 270  | 6561   | 341   | 4551      | 0    | 811   | 6485        | 6612        | -1036                | 17840                 | 0                    | 17840                     | 2867             | 20707           | 50.00         |
| 16                 | 5818        | 520   | 281  | 6619   | 405   | 4538      | 0    | 678   | 6501        | 6568        | -929                 | 17879                 | 0                    | 17879                     | 2783             | 20662           | 50.01         |
| 17                 | 5826        | 514   | 282  | 6622   | 460   | 4549      | 0    | 434   | 6501        | 6514        | -1008                | 17571                 | 0                    | 17571                     | 2861             | 20432           | 50.00         |
| 18                 | 5912        | 253   | 284  | 6449   | 567   | 4499      | 0    | 163   | 6367        | 6356        | -947                 | 17087                 | 0                    | 17087                     | 2775             | 19862           | 50.04         |
| 19                 | 5891        | 213   | 286  | 6390   | 631   | 4438      | 0    | 14    | 6083        | 5931        | -1078                | 16326                 | 0                    | 16326                     | 2772             | 19098           | 50.04         |
| 20                 | 5822        | 206   | 290  | 6318   | 929   | 4588      | 0    | 0     | 6213        | 6051        | -1173                | 16713                 | 0                    | 16713                     | 2691             | 19404           | 50.03         |
| 21                 | 5527        | 283   | 291  | 6101   | 1058  | 4434      | 0    | 0     | 6130        | 5963        | -1153                | 16403                 | 0                    | 16403                     | 2571             | 18974           | 50.03         |
| 22                 | 5479        | 265   | 292  | 6036   | 976   | 3990      | 0    | 0     | 6102        | 6450        | -1081                | 16371                 | 0                    | 16371                     | 2414             | 18785           | 50.01         |
| 23                 | 5325        | 747   | 302  | 6374   | 810   | 3879      | 0    | 0     | 6196        | 5958        | -1024                | 15997                 | 0                    | 15997                     | 2281             | 18278           | 49.94         |
| 24                 | 5463        | 418   | 294  | 6175   | 706   | 4229      | 0    | 0     | 6127        | 6092        | -987                 | 16215                 | 0                    | 16215                     | 2143             | 18358           | 49.96         |
| MUs                | 134.09      | 13.02 | 7.00 | 154.10 | 13.37 | 105.39    | 0.00 | 6.91  | 149.81      | 150.25      | -21.25               | 408.77                | 0.00                 | 408.77                    | 57.51            | 466.28          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 19/Mar/2019**

**Position as on 6.30 Hrs of 20/Mar/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                            |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                                                                                            |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL) |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                            |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                                                                                          |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                    |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                          |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.                                                                                        |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                                                                                                          |               |
| MSPGCL                | Uran Unit B0            | 120      | 08/09/2018   | 12.19        |            | Continued. | T/F Shifting Work.                                                                                                         |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2018   | 22.08        |            | Continued. | Withdrawn Due To B0 & U-7                                                                                                  |               |
| MSPGCL                | Paras Unit 3            | 250      | 15/09/2018   | 00.55        |            | Continued. | Stator Earth Fault                                                                                                         |               |
| IPP                   | RPL(AMT) U-4            | 270      | 20/09/2018   | 00.01        |            | Continued. | Zero Schedule.                                                                                                             |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                                                                                               |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.                                                                                                             |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 14/12/2018   | 03.00        |            | Continued. | Zero Schedule.                                                                                                             |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                                                                                                |               |
| IPP                   | RPL(AMT) U-2            | 270      | 27/12/2018   | 19.30        |            | Continued. | Zero Schedule.                                                                                                             |               |
| IPP                   | RPL(AMT) U-5            | 270      | 28/12/2018   | 19.30        |            | Continued. | Zero Schedule.                                                                                                             |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                                                                              |               |
| MSPGCL                | Nasik Unit 3            | 210      | 09/01/2019   | 19.30        |            | Continued. | Zero Schedule                                                                                                              |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                                                                              |               |
| MSPGCL                | Koradi Unit 7           | 210      | 19/01/2019   | 18.21        |            | Continued. | Poor Coal Receipt                                                                                                          |               |
| IPP                   | RPL(AMT) U-1            | 270      | 27/01/2019   | 02.17        |            | Continued. | Withdrawn On RSD.                                                                                                          |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 20/02/2019   | 22.07        |            | Continued. | Rotor Earth Fault                                                                                                          |               |
| MSPGCL                | Nasik Unit 5            | 210      | 23/02/2019   | 17.20        |            | Continued. | Swapping with Unit 4                                                                                                       |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 13/03/2019   | 20.39        | 20/03/2019 | 05.37      | Turbine Over Speed Problem Malfunction.                                                                                    |               |
| MSPGCL                | Khaparkheda Unit 3      | 210      | 17/03/2019   | 16.05        | 19/03/2019 | 15.51      | Furnace Pressure High                                                                                                      |               |
| IPP                   | Adani U-3               | 660      | 17/03/2019   | 18.16        |            | Continued. | APH-B Hot PA Bellow Leakage.                                                                                               |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 19/Mar/2019**

Position as on 6.30 Hrs of 20/Mar/2019

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage  | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------|---------------|
| MSPGCL             | Koradi Unit 6           | 210      | 17/03/2019   | 23.10        | 19/03/2019 | 10.28      | DM Water Leakage. |               |
| MSPGCL             | Khaparkheda Unit 1      | 210      | 19/03/2019   | 22.41        |            | Continued. | Flame Failure     |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Tripping for 19/Mar/2019**

**Statement-VII**

Position as on 6.30 Hrs of 20/Mar/2019

| Name of Line                        | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|-------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Tripping</b> |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                  | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                               |
| Dhule Sar'Sarovar II                | InterState                | 18/03/2019   | 13.39        | 19/03/2019 | 09.09      | HT          | Over Voltage                                                                                                                           |
| Dabhol Nagothane I                  | InterState                | 19/03/2019   | 11.32        | 19/03/2019 | 20.39      | PO          | Tree Cutting Work.                                                                                                                     |
| Dhule Sar'Sarovar I                 | InterState                | 19/03/2019   | 18.26        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Chandrapur-II - Nanded ckt II       | IntraState                | 18/03/2019   | 09.50        | 19/03/2019 | 07.24      | PO          | Replacement of Broken Spacer Cum Vibration Damper                                                                                      |
| Jaigad-New Koyna Ckt-II             | IntraState                | 18/03/2019   | 10.14        |            | Continued. | PO          | Relay Retro Fitting Work.                                                                                                              |
| Khadka-Aurangabad (Waluj)           | IntraState                | 18/03/2019   | 17.06        | 19/03/2019 | 08.29      | HT          | Over Voltage                                                                                                                           |
| Parly(MS)- Nanded ckt I             | IntraState                | 19/03/2019   | 09.52        | 19/03/2019 | 14.22      | PO          | String Replacement Work.                                                                                                               |
| Dhule- Bableshtar - I               | IntraState                | 19/03/2019   | 10.11        | 19/03/2019 | 20.35      | PO          | Change CT Ratio At BBLR End..                                                                                                          |
| Khadka-Aurangabad (Waluj)           | IntraState                | 19/03/2019   | 18.09        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| <b>400 KV ICT Outages/Tripping</b>  |                           |              |              |            |            |             |                                                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                                                                                              |
| 400/220KV 500MVA ICT-II@Taptitanda  | IntraState                | 18/03/2019   | 23.37        | 19/03/2019 | 02.30      | T           | NDR Operated due to wild cat comes in induction zone of IPS II.                                                                        |
| 400/132 Kv 200 Mva Ict 2 @Khadka    | IntraState                | 19/03/2019   | 13.10        | 19/03/2019 | 13.43      | EO          | Nitrogen Filling Work.                                                                                                                 |
| <b>220 KV LINE Outages/Tripping</b> |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                 | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                 | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| Chandrapur GCR - Warora - I         | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.                   |
| Chandrapur GCR - Wani               | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107. |
| BOISAR BORIVALI                     | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading.                                                                                                               |
| Butibori-VIPL-IV GIS Bay            | IntraState                | 18/03/2019   | 10.00        | 19/03/2019 | 12.32      | PO          | Testing of CT/PT at VIPL end                                                                                                           |
| Niwali - Pawas Line                 | IntraState                | 19/03/2019   | 05.22        | 19/03/2019 | 19.13      | T           | Distance Protection, Zone-1, D-47KM, Y-E, IA 1079 AMP.                                                                                 |
| Pophli Pedhmbe Line- 1              | IntraState                | 19/03/2019   | 08.15        | 19/03/2019 | 17.20      | PO          | Line Maintenance work                                                                                                                  |
| Ambazari-Abhijeet                   | IntraState                | 19/03/2019   | 09.07        | 19/03/2019 | 13.46      | PO          | Fixing of Vibration Dampers.                                                                                                           |
| Kharghar-Borivali ckt I             | IntraState                | 19/03/2019   | 09.15        | 19/03/2019 | 18.33      | PO          | Stringing of OPGW Cable.                                                                                                               |
| Miraj - Mhaishal                    | IntraState                | 19/03/2019   | 09.54        | 19/03/2019 | 13.09      | PO          | Replacement of Double String.                                                                                                          |
| Karad(400kv) - Ogalewadi Ckt 1      | IntraState                | 19/03/2019   | 10.20        | 19/03/2019 | 18.01      | PO          | Testing Work                                                                                                                           |
| Pusad-Ghatodi                       | IntraState                | 19/03/2019   | 11.12        | 19/03/2019 | 19.07      | T           | In View of 220KV Pusad Wardha(PG) CKT Outage.                                                                                          |
| Kalmeshwar-Pandhurna                | IntraState                | 19/03/2019   | 11.19        | 19/03/2019 | 17.42      | T           | Work At Pandhurna End.                                                                                                                 |
| Pusad-WardhaPG(Deoli)               | IntraState                | 19/03/2019   | 11.19        | 19/03/2019 | 18.58      | T           | Fixing of Vibration Damper.                                                                                                            |
| Kanhan-Ultratech                    | IntraState                | 19/03/2019   | 11.31        | 19/03/2019 | 19.07      | PO          | Attending Hot Spot                                                                                                                     |
| Talandage - Sawantwadi I            | IntraState                | 19/03/2019   | 11.40        |            | Continued. | EO          | Auto Reclosure Scheme Commissioning.                                                                                                   |
| Shivajinagar-Gangapur               | IntraState                | 19/03/2019   | 12.33        | 19/03/2019 | 20.38      | T           | SN-DP OPTD, Z1, YB, 1.5KA, 19.49KM, GP-DP OPTD, Z1,YB, 2.3KA, 54.03KM.                                                                 |
| Waluj - Chitegaon I                 | IntraState                | 19/03/2019   | 15.17        | 19/03/2019 | 17.30      | PO          | Tan Delta Measurment of CTs                                                                                                            |
| Shivajinagar - Malegaon             | IntraState                | 19/03/2019   | 18.12        | 19/03/2019 | 20.35      | EO          | Tree Cutting Work.                                                                                                                     |
| Uran - Kharghar 2                   | IntraState                | 20/03/2019   | 06.21        |            | Continued. | T           | Distance Protection                                                                                                                    |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Mar/2019**

**Statement-VII**

Position as on 6.30 Hrs of 20/Mar/2019

| Name of Line                         | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                   |
|--------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|----------------------------------------------------|
| <b>220 KV ICT Outages/Trippings</b>  |                              |                 |                 |            |               |                |                                                    |
| 220/132 KV ICT II @ Kopergaon        | IntraState                   | 19/03/2019      | 09.00           | 19/03/2019 | 12.35         | PO             | Tan Delta Testing of Bushing.                      |
| <b>132 KV LINE Outages/Trippings</b> |                              |                 |                 |            |               |                |                                                    |
| Mansar Pench                         | InterState                   | 07/03/2019      | 15.40           |            | Continued.    | HT             | Hand trip Form Pench end for<br>system requirment. |
| Kanhan-Pench                         | IntraState                   | 22/01/2019      | 18.44           |            | Continued.    | HT             | After Completion of Outage.                        |
| Nandurbar - Visarwadi                | IntraState                   | 19/03/2019      | 14.22           | 19/03/2019 | 15.02         | T              | Distance Protection                                |
| Nandurbar - Visarwadi                | IntraState                   | 19/03/2019      | 15.10           | 19/03/2019 | 17.40         | T              | Distance Protection                                |