

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Apr/2024 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	171.949	3316.488	1) Gujrat	6.162	63.352
2) Hydro	15.258	232.132	2) Madhya Pradesh	12.901	224.060
3) Gas	10.256	132.798	3) Chattisgarh	3.440	74.360
Total MSPGCL	197.463	3681.418	4) Maharashtra	206.597	3553.076
B) 1) APLM	65.097	1280.320	5) Goa (Amona)	-2.667	-51.307
2) JSWEL	28.464	494.204	Total	226.433	3863.541
3) VIPL	0.000	0.000	a) Mumbai Schedule	45.146	707.289
4) RPL(AMT)	31.570	576.163	b) Mumbai Drawl	49.301	767.911
5) SWPGPL	11.002	208.920	c) MSEDCL Bilateral *	101.671	1718.666
6) Other IPP	21.470	447.513	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	45.146	707.289
C) 1) TPCL Thermal	13.796	239.393	Include PX	0.000	0.000
2) TPCL Hydro	7.171	90.096	Standby	0.000	0.000
3) TPCL Gas	4.131	76.002	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.544	189.105	1) MSEDCL	549.842	10126.199
D) STATE			2) Mumbai Discoms	79.943	1362.504
1) Thermal	348.892	6752.106	3) Other Discoms	10.792	205.882
(A1+C1+C4+(B1-B6))			TOTAL STATE	640.577	11694.585
2) Hydro	22.429	322.228			
(A2+C2)					
3) Gas	14.387	208.800			
(A3+B7+C3)					
4) Wind	13.348	247.249			
6) SOLAR	15.088	300.664			
TOTAL STATE	414.144	7831.047			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6550	6867	7330	7413
MSPGCL Hydro	891	1305	1356	203
MSPGCL Gas	370	451	386	311
MSPGCL Total Generation	7811	8623	9072	7927
Central Sector Receipt	10962	10744	9111	8516
WIND	230	446	518	413
CPP / IPP Thermal	5453	5872	7188	6820
CPP / IPP Gas	0	0	0	0
SOLAR	1990	1298	0	501
Exchange with Mumbai	-2457	-2508	-2259	-1786
MSEDCL DEMAND MET	23492	23982	23133	21943
Load Shedding	0	0	0	0
MSEDCL DEMAND	23492	23982	23133	21943
TPCL GENERATION	1150	1259	987	736
AEML GENERATION	228	204	216	233
MUMBAI DEMAND	3835	3971	3462	2755
OTHER DISCOM DEMAND	497	493	497	448
STATE DEMAND MET	27824	28446	27092	25146
STATE DEMAND	27824	28446	27092	25146
Frequency (Hz)	50.01	49.98	49.95	50.06

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.37 Hz at 13:02 Hrs	49.79 Hz at 14:25 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 19/Apr/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.16	63.15	195	135
Unit 8	14.08	264.27	615	533
Unit 9	14.13	263.00	622	560
Unit 10	14.94	166.96	641	595
Total	47.31	757.38		
Bhusawal				
Unit 3	3.52	67.57	175	115
Unit 4	0.00	188.70	0	0
Unit 5	9.90	169.90	470	305
Total	13.42	426.17		
Parli				
Unit 6	4.69	82.10	250	142
Unit 7	4.56	84.29	238	148
Unit 8	4.58	83.29	250	145
Total	13.82	249.68		
Chandrapur				
Unit 3	3.38	59.72	153	125
Unit 4	3.75	59.50	171	122
Unit 5	9.14	136.46	440	275
Unit 6	7.38	160.65	329	285
Unit 7	9.58	158.79	471	291
Unit 8	3.83	182.80	420	0
Unit 9	11.28	217.14	494	356
Total	48.35	975.06		
Paras				
Unit 3	5.14	93.00	245	153
Unit 4	4.87	106.05	255	151
Total	10.01	199.04		
Khaparkheda				
Unit 1	3.48	70.86	170	125
Unit 2	4.44	80.05	201	160
Unit 3	4.14	75.17	177	146
Unit 4	4.35	76.24	192	156
Unit 5	10.89	212.53	465	407
Total	27.30	514.85		
Nasik				
Unit 3	4.09	55.56	179	121
Unit 4	3.88	71.75	173	128
Unit 5	3.76	66.99	166	122
Total	11.73	194.30		
Uran				
All Units	10.26	132.80	482	287
Total	10.26	132.80		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.38	3.53	46	0
Total	0.38	3.53		
Koyna				
Stage 1-2	3.70	56.09	475	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	5.91	67.88	651	0
Stage 3	1.79	27.65	240	0
Total	11.39	151.62		
Hydro				
KDPH	0.79	15.65	33	33
VTRNA	0.77	15.64	60	0
TILLARI	0.00	1.62	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.01	42.52	95	75
GHATGHAR	0.30	5.08	100	0
Total	3.87	80.52		
Wind				
Total	13.35	247.25	0	0
Total	13.35	247.25		
CPP				
APML(Mus)	65.10	1280.32	0	0
JSWEL(Mus)	28.46	494.20	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.57	576.16	0	0
SWPGPL-Mus	11.00	208.92	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.39	101.03	269	155
Other(Mus)	10.86	271.56	0	0
JPL	5.21	74.92	264	181
Total	157.60	3007.12		
SOLAR				
Total	15.09	300.66	0	0
Total	15.09	300.66		
Tata				
Trombay 5	9.03	156.99	464	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	47.30	108	107
Trombay 7B	1.54	28.70	65	64
TATA Hydro	7.17	90.10	435	111
Trombay 8	4.76	82.40	234	133
Total	25.10	405.49		
AEML				
DTPS U-1&2	5.54	189.10	251	185
Total	5.54	189.10		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	171.95	3316.49	MSPGCL Total	197.46	3681.42
			MSPGCL Thml+Gas	182.20	3449.29	Koyna 1,2 & 4 Total	9.60	123.97
			MSPGCL Hydro	15.26	232.13	State Total	414.14	7831.05

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Apr/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7787	155	477	8419	1163	7164	0	0	8382	8620	-1847	23099	0	0	23099	3293	420	26812	50.03
2	7833	149	478	8460	948	7174	0	0	8371	8557	-1723	23035	0	0	23035	3019	381	26435	50.02
3	7769	154	480	8403	793	7170	0	0	8591	8350	-1731	22642	0	0	22642	2806	343	25791	50.00
4	7774	149	480	8403	736	7160	0	0	8479	8080	-1601	22427	0	0	22427	2674	351	25452	50.00
5	7741	149	482	8372	722	7135	0	0	8654	8286	-1574	22585	0	0	22585	2592	356	25533	49.99
6	7629	149	482	8260	649	7124	0	0	8965	8737	-1542	22860	0	0	22860	2603	368	25831	49.99
7	7619	159	469	8247	648	7175	0	88	9050	8619	-1351	23009	0	0	23009	2660	417	26086	50.06
8	7413	203	311	7927	413	6820	0	501	8883	8516	-1786	21943	0	0	21943	2755	448	25146	50.06
9	6826	212	287	7325	368	5967	0	1043	9580	9925	-2115	22052	0	2	22052	3069	461	25582	50.05
10	6965	335	302	7602	369	5702	0	1431	10168	10032	-2308	22344	0	8	22344	3438	484	26266	50.05
11	6694	593	370	7657	348	5444	0	1912	10906	10852	-2390	23342	0	25	23342	3710	481	27533	50.02
12	6550	891	370	7811	230	5453	0	1990	11001	10962	-2457	23492	0	49	23492	3835	497	27824	50.01
13	6559	800	375	7734	184	5514	0	2047	11023	10663	-2477	23187	0	126	23187	3846	478	27511	50.05
14	6134	992	453	7579	176	5403	0	1913	11272	10660	-2317	22939	0	324	22939	3779	475	27193	50.15
15	6131	881	458	7470	251	5411	0	1714	11828	11605	-2515	23456	0	196	23456	3903	480	27839	49.93
16	6867	1305	451	8623	446	5872	0	1298	11379	10744	-2508	23982	0	113	23982	3971	493	28446	49.98
17	7014	1133	458	8605	430	6297	0	797	11046	10691	-2437	23870	0	22	23870	3908	514	28291	49.98
18	7024	556	461	8041	532	6587	0	318	10558	9824	-2441	22338	0	12	22338	3746	523	26607	49.94
19	7037	370	439	7846	587	6967	0	37	9843	9405	-2379	21939	0	0	21939	3503	524	25966	49.97
20	7330	1356	386	9072	518	7188	0	0	9380	9111	-2259	23133	0	0	23133	3462	497	27092	49.95
21	7351	891	391	8633	526	7229	0	0	9035	8932	-1986	22842	0	0	22842	3379	492	26713	49.94
22	7317	1043	443	8803	689	7216	0	0	8323	8400	-1843	22792	0	0	22792	3306	473	26571	50.03
23	7294	1147	476	8917	769	7216	0	0	8387	8418	-1850	23064	0	0	23064	3333	406	26803	50.01
24	7291	1486	477	9254	853	7215	0	0	8388	8444	-1864	23472	0	0	23472	3353	430	27255	50.01
MUs	171.95	15.26	10.26	197.46	13.35	157.60	0.00	15.09	231.49	226.43	-49.30	549.84	0.00	0.88	549.84	79.94	10.79	640.58	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) 132 kV BBLR TO Rahuri line over Load Alarm 489A/103.08 MW.2)Due to overloading of 220kV Chakan-Bhosari line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Apr/2024

Position as on 6.30 Hrs of 20/Apr/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	20/04/2024
Total Capacity MSPGCL		80						
Total Capacity PLANNED OUTAGE		80						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Bhusawal Unit 4	500	18/04/2024	22:33		Continued.	Boiler Tube Leakage	21/04/2024
MSPGCL	Chandrapur Unit 8	500	19/04/2024	11:15		Continued.	Boiler Tube Leakage	21/04/2024
Total Capacity MSPGCL		1120						
AEML								
AEML	AEML Unit 2	250	18/04/2024	10:52		Continued.	Boiler Tube Leakage	21/04/2024
Total Capacity AEML		250						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1690						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	19/04/2024	07:01	19/04/2024	09:38	Zero Sch Given by MSEDCL	
MSPGCL	Uran Unit 5	108	19/04/2024	07:20	19/04/2024	12:46	Zero Sch Given by MSEDCL	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Apr/2024

Position as on 6.30 Hrs of 20/Apr/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 20/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
TIRORA - KORADI 3 CKT - 1	IntraState	19/04/2024	12:26	19/04/2024	16:53	PO	CT OIL SAMPLE COLLECTION FOR DGA
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	18/04/2024	22:50	19/04/2024	06:11	PO	To attend defects and cleaning of polluted insulator strings in Naneghat section
400 KV MAINBAY Outages/Trippings							
MAIN BAY (412) OF STATION TF 4 @ TIRORA	IntraState	19/04/2024	15:58	19/04/2024	18:12	PO	CT OIL SAMPLE COLLECTION FOR DGA
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	InterState	19/04/2024	12:55	19/04/2024	19:58	EO	Work at PG End.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
LONIKAND - JEJURI CKT - 2	IntraState	18/04/2024	21:55	19/04/2024	02:18	PO	Auto reclosure trials to be taken to ensure the healthiness of AR
DEEPNAGAR - THAPTI TANDA	IntraState	19/04/2024	06:18	19/04/2024	19:45	PO	Replacement of faulty disc insulators by LRP strings
DEEPNAGAR - THAPTI TANDA	IntraState	19/04/2024	06:21			PO	For string replacement work
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	19/04/2024	08:53			HT	For load management on 400 KV Talegaon - Chakan line.
PARLI - KARJAT CKT - 2	IntraState	19/04/2024	13:10	19/04/2024	13:59	HT	Line tripped on distance protection.
KARAD - TALANDGE CKT - 1	IntraState	19/04/2024	17:40	19/04/2024	18:59	T	Tripped at Kolhapur end only
DEEPNAGAR - THAPTI TANDA	IntraState	20/04/2024	06:48			PO	Replacement of faulty disc insulators by LRP strings
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	17/04/2024	22:47			HT	Tripped on pdr from lv side only.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	19/04/2024	17:37	19/04/2024	18:53	T	Tripped on NDR protection
400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	IntraState	20/04/2024	06:02			PO	For Pre-monsoon Maintenance work in all aspect with Tan delta testing of Bushings, Windings & MV Side CTs & both HV & MV Bay maintenance work to be carried out.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	17/04/2024	19:00			T	PLY --> B PH, 24.74KM ,6.35KA.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	16/03/2024	01:34			HT	Hand Tripped For Load management
DAHANU - VERSOVA	IntraState	09/04/2024	22:49			PO	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Bunching of lines will be done on Tower no 82.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 20/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR - VERSOVA	IntraState	09/04/2024	22:53				Shifting of Lines on Newly constructed Towers for DFCCIL 1. Bunching of lines will be done on Tower no 82.
PARLI 3(OLD GCR)-PARLI NEWTPS CKT 1	IntraState	17/04/2024	19:00			T	Tripped.
132KV GIRAWALI(220KV)-PARLI(132KV) CKT 2	IntraState	17/04/2024	19:00			T	Tripped.
ALKUD - VITA	IntraState	18/04/2024	17:55			PO	Polymer Insulator Replacement Work
FLAGSHIP-CHINCHWAD	IntraState	19/04/2024	08:22	19/04/2024	18:47	PO	C.B POLE Overhauling work & Half Yearly Maint,D.T
KHAREPATAN -PAWAS LINE	IntraState	19/04/2024	09:27	19/04/2024	15:41	PO	For carrying out insulator cleaning in 220kV Bus Section I and Wave trap & CT gantry beam for 220kV Pawas Kharepatan line bay at 220kV Pawas S/s.
MALHARPEETH SATARA MIDC	IntraState	19/04/2024	09:33	19/04/2024	15:07	PO	Replacement of Polymer Insulator String by AF
PAWAS - FINOLEX CKT - 2	IntraState	19/04/2024	09:52	19/04/2024	15:10	PO	For carrying out insulator cleaning in 220kV Bus Section I and Wave trap & CT gantry beam for 220kV Pawas Kharepatan line bay at 220kV Pawas S/s.
GHODBUNDER - MSETCL BORIVALI	IntraState	19/04/2024	10:12	19/04/2024	12:59	T	To control line loading on 220 Kv MSETCL Boisar- AEML Ghodbunder
AKOLA-PARAS CKT NO-I	IntraState	19/04/2024	11:48	19/04/2024	18:37	EO	Bus 1 & line isolator overhauling & jaw replacement work of 220kV Paras-Akola 2 bay at 220kV Paras SS.
AKOLA-PARAS CKT NO-II	IntraState	19/04/2024	11:48	19/04/2024	18:37	PO	Isolator alignment work.
CHINCHWAD-2 - TELCO	IntraState	19/04/2024	11:50	19/04/2024	12:42	HT	For load management.
GHODBUNDER - MSETCL BOISAR	IntraState	19/04/2024	12:54	19/04/2024	20:20	HT	Line tripped on Overcurrent.
BORIVALI - TARAPUR	IntraState	19/04/2024	14:23	19/04/2024	17:23	T	Tripped on overcurrent protection
TALANDGE - BIDRI	IntraState	19/04/2024	17:37			T	Tripped on R ph to ground fault
DAHANU - GHODBUNDER CKT - 2	IntraState	19/04/2024	22:45	20/04/2024	05:17	PO	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Connection of Jumpers 192A (Virar) 2. De-Bunching between LS & SS Lines - Virar & Vasai area.
DAHANU - GHODBUNDER CKT - 1	IntraState	20/04/2024	05:26	20/04/2024	08:49	PO	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Connection of Jumpers 192, 192A & 228A (Virar & Vasai) 2. De-Bunching between LS & SS Lines - Virar & Vasai area.
DAHANU - VERSOVA	IntraState	20/04/2024	08:59			PO	Shifting of Lines on Newly constructed Towers for DFCCIL 1. De-Bunching of lines will be done on Tower no 82.
BOISAR - VERSOVA	IntraState	20/04/2024	08:59			PO	Shifting of Lines on Newly constructed Towers for DFCCIL 1. De-Bunching of lines will be done on Tower no 82
TALANDGE - SAWANTWADI	IntraState	20/04/2024	09:27			PO	Replacement of flashover insulator

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 20/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NIWALI - PAWAS LINE	IntraState	20/04/2024	09:38			PO	For carrying out insulator cleaning work in 220kV Main Bus Section II at 220kV Pawas S/s.
PAWAS - FINOLEX CKT - 1	IntraState	20/04/2024	09:45			PO	For carrying out insulator cleaning work in 220kV Main Bus Section II at 220kV Pawas S/s.
220 KV ICT Outages/Trippings							
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	IntraState	19/04/2024	06:24	19/04/2024	07:00	PO	For inspection of oil leakage
220/33 KV 50 MVA PTR 1 @ MALEGAON	IntraState	19/04/2024	07:58	19/04/2024	10:36	PO	For TF Diagnostic testing work
220/33 KV 50 MVA PTR 2 @ MALEGAON	IntraState	19/04/2024	10:40	19/04/2024	13:10	PO	For TF Diagnostic testing work.
220/33 KV 50 MVA T/F 3 @ MALEGAON	IntraState	19/04/2024	14:06	19/04/2024	15:53	PO	For TF Diagnostic testin work.
220 / 110 / 22kV 250MVA ICT 1 @ BORIVALI (TATA)	IntraState	20/04/2024	08:45			PO	R/M AND TESTING
220/33 KV 25 MVA PTR - 2 @ PHALTAN MIDC	IntraState	20/04/2024	09:20			PO	For transformer winding tan delta testing
220/33KV 25MVA PTR 2 @ PAWAS	IntraState	20/04/2024	09:23			PO	For carrying out insulator cleaning work in 220kV Main Bus Section II at 220kV Pawas S/s.
220/33KV 25MVA PTR 1 @ PAWAS	IntraState	20/04/2024	09:23			PO	For carrying out insulator cleaning work in 220kV Main Bus Section II at 220kV Pawas S/s.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	19/04/2024	19:20			T	Tripped on B phase
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
NERAL - AMBERNATH	IntraState	19/04/2024	06:18	19/04/2024	07:30	PO	Installation of Vibration Dampers and Bird nest removal

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage