

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 19/Apr/2025 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	157.812	3181.335	1) Gujrat	2.623	30.957
2) Hydro	26.810	405.703	2) Madhya Pradesh	11.438	220.043
3) Gas	9.281	147.645	3) Chattisgarh	3.590	78.860
Total MSPGCL	193.903	3734.683	4) Maharashtra	230.809	4238.728
B) 1) APLM	66.433	1244.931	5) Goa (Amona)	-1.132	-41.721
2) JSWEL	27.588	509.522	Total	247.328	4526.867
3) VIPL	0.000	0.000	a) Mumbai Schedule	41.086	829.898
4) RPL(AMT)	30.758	594.323	b) Mumbai Drawl	48.352	926.686
5) SWPGPL	11.536	230.883	c) MSEDCL Bilateral *	151.789	2566.246
6) Other IPP	16.856	348.099	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	41.086	829.898
C) 1) TPCL Thermal	11.406	205.026	Include PX	0.000	0.000
2) TPCL Hydro	4.761	87.952	Standby	0.000	0.000
3) TPCL Gas	2.806	72.063	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.541	176.763	1) MSEDCL	582.130	10804.231
D) STATE			2) Mumbai Discoms	75.866	1468.489
1) Thermal	330.930	6490.882	3) Other Discoms	12.810	253.226
(A1+C1+C4+(B1-B6))			TOTAL STATE	670.806	12525.946
2) Hydro (A2+C2)	31.571	493.655			
3) Gas (A3+B7+C3)	12.087	219.708			
4) Wind	23.817	334.244			
6) SOLAR	25.073	460.591			
TOTAL STATE	423.478	7999.080			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	5133	6896	7365	6641
MSPGCL Hydro	887	1490	1899	1288
MSPGCL Gas	396	340	391	407
MSPGCL Total Generation	6416	8726	9655	8336
Central Sector Receipt	11531	10852	9804	8931
WIND	861	894	969	867
CPP / IPP Thermal	5222	6302	7045	6741
CPP / IPP Gas	0	0	0	0
SOLAR	3079	1371	0	786
Exchange with Mumbai	-2568	-2670	-1724	-1656
MSEDCL DEMAND MET	23955	24901	25168	23488
Load Shedding	0	0	0	0
MSEDCL DEMAND	23955	24901	25168	23488
TPCL GENERATION	617	631	1116	682
AEML GENERATION	285	304	499	294
MUMBAI DEMAND	3470	3605	3339	2632
OTHER DISCOM DEMAND	586	574	581	517
STATE DEMAND MET	28011	29080	29088	26637
STATE DEMAND	28011	29080	29088	26637
Frequency (Hz)	50.09	49.95	49.86	50.06

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.31 Hz at 13.05 Hrs	49.54 Hz at 22.12 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 19/Apr/2025

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.80	74.82	178	115
Unit 8	12.35	240.15	555	367
Unit 9	12.14	193.20	562	374
Unit 10	12.29	237.62	560	375
Total	40.59	745.79		
Bhusawal				
Unit 3	1.93	59.45	165	0
Unit 4	9.80	185.82	490	280
Unit 5	7.59	157.62	410	270
Unit 6	0.00	202.95	0	0
Total	19.31	605.84		
Parli				
Unit 6	4.84	85.53	249	143
Unit 7	4.46	71.74	248	133
Unit 8	4.30	81.30	211	149
Total	13.60	238.57		
Chandrapur				
Unit 3	1.06	27.17	155	0
Unit 4	3.28	63.12	148	121
Unit 5	8.48	161.83	405	275
Unit 6	9.58	177.70	464	280
Unit 7	9.10	174.44	448	286
Unit 8	8.76	173.61	425	276
Unit 9	0.00	0.00	0	0
Total	40.25	777.89		
Paras				
Unit 3	4.35	86.47	238	137
Unit 4	4.55	90.04	254	132
Total	8.91	176.51		
Khaparkheda				
Unit 1	3.54	70.99	175	115
Unit 2	4.06	74.42	189	117
Unit 3	4.01	77.70	188	129
Unit 4	3.92	61.67	177	128
Unit 5	10.43	180.46	475	320
Total	25.95	465.24		
Nasik				
Unit 3	3.35	43.74	164	115
Unit 4	3.54	66.74	176	123
Unit 5	2.30	61.02	100	91
Total	9.20	171.50		
Uran				
All Units	9.28	147.64	411	328
Total	9.28	147.64		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	1.60	46	0
Total	0.06	1.60		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.98	62.20	465	40
Stage 4	13.93	192.90	1005	0
Stage 3	3.94	55.79	320	0
Total	21.85	310.88		
Hydro				
KDPH	0.72	14.83	30	30
VTRNA	0.79	15.53	61	0
TILLARI	0.00	4.10	0	0
BHIRA T.R.	0.22	5.14	40	0
SMLHY_PTN	2.73	49.92	119	111
GHATGHAR	0.51	5.29	160	0
Total	4.96	94.82		
Wind				
Total	23.82	334.24	0	0
Total	23.82	334.24		
CPP				
APML(Mus)	66.43	1244.93	0	0
JSWEL(Mus)	27.59	509.52	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.76	594.32	0	0
SWPGPL-Mus	11.54	230.88	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.96	115.08	268	181
Other(Mus)	4.82	118.17	0	0
JPL	6.07	114.86	276	205
Total	153.17	2927.76		
SOLAR				
Total	25.07	460.59	0	0
Total	25.07	460.59		
Tata				
Trombay 5	7.46	135.36	474	259
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.73	44.60	109	0
Trombay 7B	1.08	27.46	64	0
TATA Hydro	4.76	87.95	408	42
Trombay 8	3.94	69.67	240	130
Total	18.97	365.04		
AEML				
DTPS U-1&2	8.54	176.76	499	281
Total	8.54	176.76		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	157.81	3181.34	MSPGCL Total	193.90	3734.68
			MSPGCL Thml+Gas	167.09	3328.98	Koyna 1,2 & 4 Total	17.91	255.10
			MSPGCL Hydro	26.81	405.70	State Total	423.48	7999.08

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 19/Apr/2025

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7251	1295	405	8951	1276	7031	0	0	10293	10339	-1944	25151	0	0	25151	3181	502	28834	49.95
2	7273	630	401	8304	1334	7046	0	0	10428	10267	-1663	24831	0	0	24831	2957	457	28245	49.96
3	7302	376	402	8080	1452	7026	0	0	10320	10142	-1528	24733	0	0	24733	2763	439	27935	49.98
4	7215	329	406	7950	1346	7002	0	0	10212	10094	-1552	24388	0	0	24388	2612	452	27452	50.03
5	7020	417	406	7843	1363	6926	0	0	10437	10543	-1483	24752	0	0	24752	2534	440	27726	49.98
6	6862	919	411	8192	1150	6992	0	0	10421	10462	-1467	24866	0	0	24866	2550	463	27879	49.92
7	7076	1304	406	8786	1070	6921	0	126	9961	9796	-1466	24734	0	0	24734	2555	499	27788	50.06
8	6641	1288	407	8336	867	6741	0	786	8825	8931	-1656	23488	0	0	23488	2632	517	26637	50.06
9	5769	1022	404	7195	701	5800	0	1733	9687	9772	-1925	22725	0	0	22725	2869	551	26145	50.07
10	5585	933	394	6912	630	5395	0	2466	10536	10721	-2243	23305	0	0	23305	3175	576	27056	50.00
11	5133	887	396	6416	861	5222	0	3079	11326	11531	-2568	23955	0	0	23955	3470	586	28011	50.09
12	5029	486	390	5905	870	4821	0	3324	11582	11904	-2703	23531	0	0	23531	3594	590	27715	50.14
13	5063	476	388	5927	830	4845	0	3401	11261	11639	-2693	23381	0	0	23381	3576	568	27525	50.08
14	5127	483	352	5962	796	4981	0	3140	11000	11504	-2619	23217	0	0	23217	3494	547	27258	50.11
15	5990	702	328	7020	834	5389	0	2830	11219	11052	-2735	23822	0	0	23822	3605	568	27995	49.91
16	6480	1270	335	8085	845	5802	0	2193	11311	11033	-2794	24579	0	0	24579	3678	585	28842	49.94
17	6896	1490	340	8726	894	6302	0	1371	10790	10852	-2670	24901	0	0	24901	3605	574	29080	49.95
18	7006	1581	360	8947	877	6787	0	555	10106	10005	-2483	24112	0	0	24112	3521	576	28209	50.00
19	7097	1550	384	9031	856	6918	0	69	9739	9833	-2096	24031	0	3	24031	3407	580	28018	50.04
20	7365	1899	391	9655	969	7045	0	0	9872	9804	-1724	25168	0	1	25168	3339	581	29088	49.86
21	7271	1576	392	9239	1096	7040	0	0	8908	9367	-1651	24549	0	0	24549	3255	542	28346	49.92
22	7177	1789	390	9356	1049	7042	0	0	8379	8932	-1552	24280	0	0	24280	3169	547	27996	49.89
23	7147	2056	393	9596	964	7046	0	0	8617	9292	-1539	24821	0	0	24821	3132	538	28491	49.81
24	7037	2052	400	9489	887	7051	0	0	8983	9513	-1598	24810	948	0	25758	3193	532	29483	49.97
MUs	157.81	26.81	9.28	193.90	23.82	153.17	0.00	25.07	244.21	247.33	-48.35	582.13	0.95	0.00	583.08	75.87	12.81	671.75	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

TF overload 220/22kV 50MVA at 220kV Chakan PH II S/S.

Maximum Demand scenario for the date 19/Apr/2025		
State Demand	MSEDC L Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
29483 MW	25758 MW	3678 MW
24 Hrs	24 Hrs	16 Hrs
Includes LS - 948 MW	Includes LS - 948 MW	--

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Apr/2025

Position as on 6.30 Hrs of 20/Apr/2025

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Chandrapur Unit 9	500	11/01/2025	18:55		Continued.	Generator Protection operated	01/05/2025
MSPGCL	Uran Unit 7	108	04/03/2025	14:15		Continued.	Turbine bearing vibration high	30/04/2025
MSPGCL	Chandrapur Unit 3	210	07/04/2025	15:34	19/04/2025	12:18	Furnace Temperature High	20/04/2025
MSPGCL	Bhusawal Unit 3	210	18/04/2025	10:39	19/04/2025	09:53	BTL (TOLLING FROM NASHIK TO BHUSAWAL & TPS from block no 43)	20/04/2025
MSPGCL	Bhusawal Unit 6	660	18/04/2025	15:52	20/04/2025	17:19	both TDBFP tripped	20/04/2025
MSPGCL	Bhusawal Unit 5	500	20/04/2025	00:49		Continued.	due to suspected BTL, CST level not maintaining	22/04/2025
MSPGCL	Bhusawal Unit 4	500	20/04/2025	18:00		Continued.	Boiler Tube Leakage	23/04/2025
MSPGCL	Chandrapur Unit 6	500	20/04/2025	19:52		Continued.	Drum level low	22/04/2025
MSPGCL	Bhusawal Unit 6	660	20/04/2025	20:31		Continued.	Economiser Inlet flow Low	
MSPGCL	Koyna Unit 9	80	20/04/2025	21:50		Continued.	Stator Earth fault	22/04/2025
Total Capacity MSPGCL		3928						
TPC-G								
TPC-G	Trombay 7B	60	19/04/2025	19:10	20/04/2025	22:58	Gas shortage	
TPC-G	Trombay 7A	120	19/04/2025	19:30	20/04/2025	19:45	Gas shortage	
Total Capacity TPC-G		180						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/06/2025
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2025
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		4428						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO		988						

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 19/Apr/2025

Position as on 6.30 Hrs of 20/Apr/2025

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
	NO PPA							

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Apr/2025

Statement-VII

Position as on 6.30 Hrs of 20/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	20/04/2025	00:50	20/04/2025	07:18	PO	For testing and commissioning of VESDA System at HVDC Valve hall
400 KV LR Outages/Trippings							
50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI	IntraState	05/03/2025	20:45			HT	Due to Voltage constraint LR kept out at Parly ss.
400 KV LINE Outages/Trippings							
PADGHE - BOISAR (PG)	InterState	19/04/2025	23:03	19/04/2025	23:36	HT	Emergency outage by PG for taking LR in service at Padghe
220KV KORADI II (400KV)- BUTIBORI 3 CKT I	IntraState	01/10/2024	13:10			HT	H/T From Butibori 3 end
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/03/2025	00:53			HT	IN VIEW OF 400KV TALEGAON - CHAKAN LINE LOADING
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	09/04/2025	21:25			HT	load management
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	10/04/2025	13:39			EO	Need to carry out SF6 gas Refilling (Top-up) in the EMVT of 400kV NTPP-1 B-phase at Plant End (GIS).
PADGHE - NAGOTHANE CKT - 2	IntraState	18/04/2025	10:45	19/04/2025	02:16	PO	During this outage, Line will be taken on ERS for erection of 2 No� of NDC + 18 mtr Towers work in Location No.165 to 168 �for the work of shifting /height rising of MRVCL work
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	18/04/2025	18:04	19/04/2025	02:42	HT	Emergency hand tripped as Y phase CVT ROD connected to line jumper is broken and sparking is observed at 400kV Waluj.
BABHALESHWAR - PADGHE CKT- 1	IntraState	18/04/2025	19:14	19/04/2025	03:51	EO	Work under HVDC TL O&M S-Dn, Junnar:- 1.Replacement of flashovered disc Insulator string at location 865, R Phase String ,R Phase Pilot string, B phase Pilot String, observed in monkey patrolling & cold washing of insulators in Naneghat area to avoid tripping due to dust accumulation on insulator disc
AKOLA - KHADKA (BHUSAWAL)	IntraState	19/04/2025	11:25	19/04/2025	19:58	EO	For alignment and trial of 410 89 B
PADGHE - NAGOTHANE CKT - 1	IntraState	19/04/2025	12:22			PO	During this outage, for the work of Erection of 2 No of NDC + 18 mtr towers, dismantling of towers and its conductor stringing at Location No.165 -168.
MAIN BUS - 1 @ AKOLA	IntraState	19/04/2025	18:21	19/04/2025	19:41	T	Busbar protection operated
BABHALESHWAR - PADGHE CKT - 2	IntraState	20/04/2025	17:44		Continued.	EO	Routine maintenance work, to attend defect identified in monkey patrolling & cleaning of insulators in Naneghat area to avoid tripping due to dust accumulation on insulator disc
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Apr/2025

Statement-VII

Position as on 6.30 Hrs of 20/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
105 MVA SPARE ICT @ CHAKAN	IntraState	26/02/2025	10:59			PO	Long Duration outage required for Rapid restoration scheme work of ICT at 400kV Chakan s/sn
95 MVA STN TF - II @KORADI 2	IntraState	18/04/2025	11:11	19/04/2025	16:44	T	Generation side LBB operated
400/220/33 KV 500MVA ICT - 1 @ KORADI 2	IntraState	19/04/2025	06:36	19/04/2025	11:06	EO	attending the oil leakage from top of Main Tank of Rph Unit by sealant method.
400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	IntraState	19/04/2025	08:57	19/04/2025	19:33	PO	For Construction of (incomplete / Balance) Firewall Between ICT3 & ICT4
400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	IntraState	19/04/2025	10:42	19/04/2025	19:45	PO	For Diagnostic Testing of ICT with Routine Pre-Monsoon Maintanance Work on Both HV & LV Bay
220 KV TIEBAY Outages/Trippings							
BUS COUPLER @ PHURSUNGI	IntraState	07/04/2025	06:57			HT	Hand Tripped.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
PRINT HOUSE - NAVI MUMBAI (PG)	InterState	05/12/2024	23:09			EO	1) For bunching at TL no 678/1 with 220kV Kalwa-Panchanand line to provide 2nd source to Panchanand & Taloja s/stn. 2)For opening jumpers at TL no 678/1.
220 KV HARANGUL - PARLY (PG) CKT	InterState	19/04/2025	09:39	19/04/2025	18:00	PO	For line bay annual maintenance work
220 KV HARANGUL - PARLY (PG) CKT	InterState	19/04/2025	09:39	19/04/2025	18:00	PO	For line bay annual maintenance work at Parli substation.
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
220KV KORADI II(400KV) - BUTIBORI 3 CKT II	IntraState	01/10/2024	13:11			HT	H/T From Koradi 2 end
KALWA - PANCHANAND	IntraState	17/10/2024	12:10			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
GIGAPLEX (PDG) - NTT NEON (DC 13) CKT	IntraState	18/04/2025	00:10			PO	Erection of Monopole for the proposed 220kV Datascape S/stn and for stringing of 2 spans with HTLS conductor as per the approved scheme of NTT and bunching at Loc no. 399B
ALEPHATA-PARGAON(KATHAPUR)	IntraState	18/04/2025	05:12	19/04/2025	21:44	HT	Load management
220 KV KHADKA (400 KV) -BHADLI TSS CKT-2	IntraState	18/04/2025	06:15	19/04/2025	02:23	PO	For distance and backup protection relays retrofitting work by agency
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	18/04/2025	20:45	19/04/2025	00:28	PO	Outage is required for Quarterly Maintenance
MAIN BUS - 1 @ SOUTH SOLAPUR	IntraState	18/04/2025	20:55	19/04/2025	00:20	PO	Outage is required for Quarterly Maintenance
NANDED 2 (WAGHALA) - PARBHANI	IntraState	19/04/2025	09:27	19/04/2025	18:07	PO	For re-sagging work
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	19/04/2025	10:29	20/04/2025	01:10	T	Distance protection operated

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Apr/2025

Statement-VII

Position as on 6.30 Hrs of 20/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 1	IntraState	19/04/2025	11:50	19/04/2025	18:41	PO	Relay Along with CB Testing.
KALWA - MULUND 1	IntraState	20/04/2025	05:15	20/04/2025	10:05	PO	Diagnostic testing and maintenance work
ALEPHATA-PARGAON(KATHAPUR)	IntraState	20/04/2025	06:50	20/04/2025	20:20	HT	H/T for load management.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	20/04/2025	07:15	20/04/2025	16:18	PO	For removing bunching of 220KV AKP-Nashik and 220KV NTT Estella- Bapgaon at Loc no. 398 to restore the lines.
NTT GLOBAL (Estella) - BAPGAON	IntraState	20/04/2025	07:15	20/04/2025	16:18	PO	For removing bunching of 220KV AKP-Nashik and 220KV NTT Estella- Bapgaon at Loc no. 398 to restore the lines.
LOTEPARSHURAM- DASTURI LINE	IntraState	20/04/2025	09:28	20/04/2025	20:55	PO	For dismantling of old rusted tower at loc no 96 & 99.
KANDALGAON - KOYNA (POPHALI)	IntraState	20/04/2025	09:30	20/04/2025	20:54	PO	For dismantling of old rusted tower at loc no 96 & 99.
HINJAWADI I- CHINCHWAD	IntraState	20/04/2025	11:02	20/04/2025	21:44	HT	H/T for load management.
BUTIBORI 3- VIPL CKT II	IntraState	20/04/2025	13:37	20/04/2025	18:00	T	B3-1.576KM, Z3,B PH, 3.615 KA, V-B PH, 0.3KM, Z1,16 KA.
BHUGAON - LLOYED STEEL	IntraState	20/04/2025	13:38	20/04/2025	14:50	T	PILOT DIFF PROT 23.4KM.
PADGHE - NALASOPARA - VASAI (T)	IntraState	20/04/2025	14:24	20/04/2025	21:44	PO	For SCADA Point to Point testing by agency under the supervision of Testing team Kalwa.
KHAPARKHEDA - BUTIBORI 3	IntraState	20/04/2025	18:32	20/04/2025	19:54	T	K-B PH, 0.8KM, 24 KA, B-B PH, 48.8KM, 2.7 KA.
220 KV ICT Outages/Trippings							
220/132 KV 80 MVA ICT 1 @ HINGANGHAT	IntraState	19/02/2025	12:45			HT	H/T Due to end of expected life of paper insulation of ICT
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	IntraState	19/04/2025	11:31	19/04/2025	14:17	PO	1)ICT-II - For replacement of the faulty Balloon of main conservators tank and attending oil leakage from the prismatic oil level indicator 2) ICT III- For Pre monsoon maintenance and replacement of faulty TNC switch
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	IntraState	19/04/2025	11:31	19/04/2025	14:17	PO	1)ICT-II - For replacement of the faulty Balloon of main conservators tank and attending oil leakage from the prismatic oil level indicator 2) ICT III- For Pre monsoon maintenance and replacement of faulty TNC switch
220 / 110 / 33kv 250MVA ICT 10 @ DHARAVI	IntraState	20/04/2025	09:12	20/04/2025	15:58	PO	R/M AND TESTING
220 / 110 / 33kv 250MVA AT 1 @ BACKBAY	IntraState	20/04/2025	10:14	20/04/2025	20:56	PO	R/M & testing.
220/110/33KV 250 MVA ICT-5 @ MAHALAXMI GIS (T)	IntraState	20/04/2025	10:25	20/04/2025	18:22	PO	ATTENDING OIL LEAKAGES
220/22KV 50MVA PTR - 2 @ PALAVA	IntraState	20/04/2025	11:02	20/04/2025	18:50	PO	Transformer painting work.
132 KV LINE Outages/Trippings							
CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP	IntraState	16/10/2024	07:02			HT	For Load Management
132 KV PATHRI-MAJALGAON CKT	IntraState	06/01/2025	13:05			HT	After completion of outage on 132kv patri parbhani ckt
132 KV UJANI - BASSK	IntraState	18/03/2025	13:10			T	Distance protection.
132 KV ICT Outages/Trippings							
132/33 KV 50 MVA PTR 2 @ DONDAICHA	IntraState	15/11/2024	11:40			T	Tripped on Buchholz alarm

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 19/Apr/2025

Statement-VII

Position as on 6.30 Hrs of 20/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
KHOPOLI - BHIVPURI CKT - 1	IntraState	19/04/2025	08:36	19/04/2025	14:18	PO	R/M AND TESTING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage