

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 19/May/2015 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 133.109        | 2299.750        | 1) Gujrat                      | 0.064          | -47.324         |
| 2) Hydro            | 14.364         | 370.171         | 2) Madhya Pradesh              | 11.429         | 241.887         |
| 3) Gas              | 6.456          | 123.934         | 3) Chattisgarh                 | 6.220          | 118.780         |
| <b>Total MSPGCL</b> | <b>153.929</b> | <b>2793.855</b> | 4) Maharashtra Net             | 100.744        | 1892.945        |
| B) 1) APML          | 54.350         | 1034.330        | 5) Goa                         | -7.301         | -137.150        |
| 2) JSWEL            | 14.893         | 406.672         | 6) TAPS 1&2 Injection          | 3.282          | 62.821          |
| 3) VIPL             | 10.361         | 211.680         | 7) RGPPL Injection             | 0.000          | 0.000           |
| 4) RPL(AMT)         | 4.760          | 102.830         | 8) Pench (MS)                  | 0.109          | 1.668           |
| 5) WPCL             | 7.490          | 156.273         | 9) Pench (Excess)              | -0.109         | -1.447          |
| 6) Other IPP        | 6.020          | 106.770         | <b>Total</b>                   | <b>114.329</b> | <b>2130.512</b> |
| C) 1) TPCL Thermal  | 16.620         | 315.442         | a) Mumbai Schedule             | 27.377         | 492.002         |
| 2) TPCL Hydro       | 3.802          | 66.785          | b) Mumbai Drawl                | 33.009         | 541.266         |
| 3) TPCL Gas         | 2.807          | 58.023          | c) MSEDCL Bilateral *          | 30.386         | 591.773         |
| 4) R-INFRA Thermal  | 11.118         | 226.422         | Include PX                     | -0.428         | 3.643           |
| <b>D) STATE</b>     |                |                 | d) Mumbai Bilateral *          | 27.077         | 491.652         |
| 1) Thermal          | 258.721        | 4860.169        | Include PX                     | 3.665          | 40.617          |
| (A1+C1+C4+(B1-B6))  |                |                 | Include Standby                | 0.300          | 0.350           |
| 2) Hydro            | 18.166         | 436.956         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 3) Gas              | 9.263          | 181.957         | 1) MSEDCL                      | 362.481        | 6672.310        |
| 4) Wind             | 28.092         | 246.814         | 2) Mumbai Discoms              | 67.356         | 1207.932        |
| 6) SOLAR            | 1.266          | 22.393          | <b>TOTAL STATE</b>             | <b>429.837</b> | <b>7880.242</b> |
| <b>TOTAL STATE</b>  | <b>315.508</b> | <b>5748.289</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 5 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6025                      | 5495                  | 5198                      | 5343                      |
| MSPGCL Hydro             | 1032                      | 896                   | 856                       | 193                       |
| MSPGCL Gas               | 273                       | 227                   | 270                       | 289                       |
| MSPGCL Total Generation  | 7330                      | 6618                  | 6324                      | 5825                      |
| Central Sector Receipt   | 4645                      | 6185                  | 4741                      | 4675                      |
| WIND                     | 787                       | 975                   | 1479                      | 1287                      |
| CPP / IPP                | 4428                      | 4062                  | 3620                      | 3625                      |
| SOLAR                    | 157                       | 145                   | 0                         | 0                         |
| Exchange with Mumbai     | -1517                     | -1533                 | -1460                     | -1100                     |
| <b>MSEDCL DEMAND MET</b> | <b>15830</b>              | <b>16452</b>          | <b>14704</b>              | <b>14312</b>              |
| Load Shedding            | 73                        | 43                    | 46                        | 47                        |
| MSEDCL DEMAND            | 15903                     | 16495                 | 14750                     | 14359                     |
| TPCL GENERATION          | 1160                      | 1251                  | 979                       | 686                       |
| R-INFRA GENERATION       | 516                       | 513                   | 518                       | 390                       |
| <b>MUMBAI DEMAND</b>     | <b>3193</b>               | <b>3297</b>           | <b>2957</b>               | <b>2176</b>               |
| STATE DEMAND MET         | 19023                     | 19749                 | 17661                     | 16488                     |
| <b>STATE DEMAND</b>      | <b>19096</b>              | <b>19792</b>          | <b>17707</b>              | <b>16535</b>              |
| Frequency (Hz)           | 49.98                     | 50.00                 | 49.94                     | 49.96                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.51 Hz at 18:03 Hrs | 49.68 Hz at 22:37 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 19/May/2015

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 3.68         | 61.52         | 165      | 87       |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.83         | 71.04         | 165      | 150      |
| <b>Total</b>       | <b>7.51</b>  | <b>132.56</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.88         | 195.47        | 505      | 365      |
| Unit 5             | 9.96         | 189.09        | 500      | 350      |
| <b>Total</b>       | <b>19.84</b> | <b>384.56</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 3             | 2.79         | 24.83         | 160      | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 3.52         | 58.11         | 152      | 140      |
| Unit 6             | 5.23         | 99.83         | 250      | 190      |
| Unit 7             | 5.06         | 99.19         | 234      | 194      |
| <b>Total</b>       | <b>16.60</b> | <b>281.96</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 3.37         | 50.20         | 144      | 132      |
| Unit 3             | 2.51         | 72.52         | 187      | 0        |
| Unit 4             | 4.30         | 65.66         | 190      | 168      |
| Unit 5             | 9.78         | 90.74         | 440      | 370      |
| Unit 6             | 9.31         | 147.16        | 415      | 360      |
| Unit 7             | 9.21         | 177.52        | 440      | 313      |
| <b>Total</b>       | <b>38.47</b> | <b>603.80</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.12         | 100.07        | 248      | 162      |
| Unit 4             | 5.35         | 101.19        | 255      | 193      |
| <b>Total</b>       | <b>10.47</b> | <b>201.26</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 4.15         | 77.95         | 200      | 145      |
| Unit 2             | 3.52         | 68.62         | 165      | 130      |
| Unit 3             | 4.28         | 65.06         | 195      | 168      |
| Unit 4             | 4.20         | 78.99         | 179      | 171      |
| Unit 5             | 10.40        | 167.84        | 480      | 375      |
| <b>Total</b>       | <b>26.55</b> | <b>458.46</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 4.65         | 87.80         | 210      | 180      |
| Unit 4             | 4.51         | 80.27         | 197      | 180      |
| Unit 5             | 4.51         | 69.08         | 199      | 179      |
| <b>Total</b>       | <b>13.68</b> | <b>237.15</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.46         | 123.93        | 293      | 211      |
| <b>Total</b>       | <b>6.46</b>  | <b>123.93</b> |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| Pench (MS)      | 0.11         | 1.67           | 37       | 0        |
| <b>Total</b>    | <b>0.11</b>  | <b>1.67</b>    |          |          |
| <b>Koyna</b>    |              |                |          |          |
| Stage 1-2       | 2.69         | 99.05          | 435      | 35       |
| Stage 4         | 5.87         | 142.58         | 785      | 0        |
| Stage 3         | 1.65         | 52.72          | 160      | 0        |
| <b>Total</b>    | <b>10.20</b> | <b>294.35</b>  |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.38         | 8.89           | 17       | 16       |
| VTRNA           | 0.86         | 16.99          | 61       | 0        |
| TILLARI         | 0.13         | 6.34           | 64       | 0        |
| BHTGR/VEER      | 0.06         | 1.17           | 3        | 2        |
| BHIRA T.R.      | 0.21         | 3.40           | 40       | 0        |
| RNGR+BHTSA      | 0.25         | 4.09           | 11       | 10       |
| BHANDARDRA      | 0.19         | 4.50           | 30       | 0        |
| ELDARY          | 0.00         | 2.50           | 0        | 0        |
| SMLHY_PTN       | 0.61         | 13.32          | 32       | 22       |
| GHATGHAR        | 1.48         | 14.62          | 250      | 0        |
| <b>Total</b>    | <b>4.16</b>  | <b>75.82</b>   |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 28.09        | 246.81         | 0        | 0        |
| <b>Total</b>    | <b>28.09</b> | <b>246.81</b>  |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 54.35        | 1034.33        | 0        | 0        |
| JSWEL(Mus)      | 14.89        | 406.67         | 0        | 0        |
| VIPL(Mus)       | 10.36        | 211.68         | 0        | 0        |
| RPLAMT(Mus)     | 4.76         | 102.83         | 0        | 0        |
| WPCL(Mus)       | 7.49         | 156.27         | 0        | 0        |
| Other(Mus)      | 6.02         | 106.77         | 0        | 0        |
| <b>Total</b>    | <b>97.87</b> | <b>2018.56</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 1.27         | 22.39          | 0        | 0        |
| <b>Total</b>    | <b>1.27</b>  | <b>22.39</b>   |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 10.90        | 203.75         | 498      | 315      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 1.60         | 34.56          | 95       | 57       |
| Trombay 7B      | 1.20         | 23.47          | 60       | 46       |
| Trombay 8       | 5.72         | 111.70         | 252      | 199      |
| TATA Hydro      | 3.80         | 66.78          | 453      | 0        |
| <b>Total</b>    | <b>23.23</b> | <b>440.25</b>  |          |          |
| <b>R-INFRA</b>  |              |                |          |          |
| 1-2             | 11.12        | 226.42         | 519      | 258      |
| <b>Total</b>    | <b>11.12</b> | <b>226.42</b>  |          |          |

| Summary         |             |               |
|-----------------|-------------|---------------|
| Particulars     | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal  | 133.11      | 2299.75       |
| MSPGCL Thml+Gas | 139.56      | 2423.68       |

| Summary      |             |               |
|--------------|-------------|---------------|
| Particulars  | Daily (Mus) | Monthly (Mus) |
| MSPGCL Hydro | 14.36       | 370.17        |
| MSPGCL Total | 153.93      | 2793.86       |

| Summary             |             |               |
|---------------------|-------------|---------------|
| Particulars         | Daily (Mus) | Monthly (Mus) |
| Koyna 1,2 & 4 Total | 8.56        | 241.64        |
| State Total         | 315.51      | 5748.29       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 19/May/2015

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5316        | 568   | 287  | 6171   | 1123  | 4257         | 0     | 4783        | 4831        | -1359                | 15023                 | 67                   | 15090                     | 2724             | 17814           | 49.96         |
| 2                  | 5450        | 128   | 287  | 5865   | 1146  | 4306         | 0     | 4707        | 4925        | -1163                | 15079                 | 47                   | 15126                     | 2528             | 17654           | 49.95         |
| 3                  | 5310        | 93    | 288  | 5691   | 1190  | 4125         | 0     | 4591        | 4982        | -1048                | 14940                 | 47                   | 14987                     | 2360             | 17347           | 49.97         |
| 4                  | 5314        | 98    | 289  | 5701   | 1193  | 3827         | 0     | 4462        | 4794        | -907                 | 14608                 | 47                   | 14655                     | 2255             | 16910           | 49.98         |
| 5                  | 5343        | 193   | 289  | 5825   | 1287  | 3625         | 0     | 4082        | 4675        | -1100                | 14312                 | 47                   | 14359                     | 2176             | 16535           | 49.96         |
| 6                  | 5641        | 100   | 293  | 6034   | 1277  | 3733         | 0     | 4430        | 4945        | -1165                | 14824                 | 50                   | 14874                     | 2179             | 17053           | 49.98         |
| 7                  | 5766        | 123   | 293  | 6182   | 1218  | 4165         | 4     | 4611        | 4434        | -1087                | 14916                 | 50                   | 14966                     | 2110             | 17076           | 50.03         |
| 8                  | 5961        | 181   | 278  | 6420   | 1055  | 4313         | 37    | 4721        | 4257        | -1053                | 15029                 | 50                   | 15079                     | 2210             | 17289           | 50.04         |
| 9                  | 5983        | 508   | 276  | 6767   | 788   | 4400         | 79    | 4956        | 4414        | -1156                | 15292                 | 50                   | 15342                     | 2483             | 17825           | 50.02         |
| 10                 | 6009        | 820   | 276  | 7105   | 737   | 4504         | 115   | 5103        | 4520        | -1348                | 15633                 | 50                   | 15683                     | 2903             | 18586           | 49.99         |
| 11                 | 6025        | 1032  | 273  | 7330   | 787   | 4428         | 157   | 5117        | 4645        | -1517                | 15830                 | 73                   | 15903                     | 3193             | 19096           | 49.98         |
| 12                 | 6059        | 1231  | 270  | 7560   | 964   | 4347         | 170   | 5270        | 4242        | -1578                | 15705                 | 75                   | 15780                     | 3280             | 19060           | 49.95         |
| 13                 | 6039        | 762   | 273  | 7074   | 783   | 4332         | 176   | 5288        | 4619        | -1541                | 15443                 | 52                   | 15495                     | 3285             | 18780           | 49.97         |
| 14                 | 5700        | 785   | 211  | 6696   | 940   | 4190         | 185   | 5127        | 4937        | -1476                | 15472                 | 46                   | 15518                     | 3252             | 18770           | 49.98         |
| 15                 | 5495        | 896   | 227  | 6618   | 975   | 4062         | 145   | 5355        | 6185        | -1533                | 16452                 | 43                   | 16495                     | 3297             | 19792           | 50.00         |
| 16                 | 5464        | 1331  | 250  | 7045   | 1086  | 4098         | 103   | 5284        | 5294        | -1513                | 16113                 | 43                   | 16156                     | 3313             | 19469           | 49.92         |
| 17                 | 5465        | 888   | 250  | 6603   | 1385  | 4180         | 63    | 5146        | 5158        | -1561                | 15828                 | 43                   | 15871                     | 3304             | 19175           | 50.12         |
| 18                 | 5445        | 181   | 240  | 5866   | 1424  | 4074         | 29    | 4748        | 4812        | -1589                | 14616                 | 43                   | 14659                     | 3154             | 17813           | 50.25         |
| 19                 | 5209        | 146   | 240  | 5595   | 1646  | 3545         | 3     | 4120        | 3881        | -1553                | 13117                 | 43                   | 13160                     | 2972             | 16132           | 50.10         |
| 20                 | 5198        | 856   | 270  | 6324   | 1479  | 3620         | 0     | 4280        | 4741        | -1460                | 14704                 | 46                   | 14750                     | 2957             | 17707           | 49.94         |
| 21                 | 5212        | 764   | 272  | 6248   | 1540  | 3857         | 0     | 4600        | 4520        | -1488                | 14677                 | 46                   | 14723                     | 2899             | 17622           | 49.97         |
| 22                 | 5244        | 551   | 274  | 6069   | 1460  | 3963         | 0     | 4629        | 4524        | -1616                | 14400                 | 46                   | 14446                     | 2881             | 17327           | 49.93         |
| 23                 | 5195        | 699   | 274  | 6168   | 1388  | 3965         | 0     | 4335        | 4772        | -1553                | 14740                 | 46                   | 14786                     | 2801             | 17587           | 49.85         |
| 24                 | 5266        | 1430  | 276  | 6972   | 1221  | 3958         | 0     | 4457        | 5222        | -1645                | 15728                 | 46                   | 15774                     | 2840             | 18614           | 49.92         |
| MUs                | 133.1<br>1  | 14.36 | 6.46 | 153.93 | 28.09 | 97.87        | 1.27  | 114.20      | 114.33      | -33.01               | 362.48                | 1.20                 | 363.68                    | 67.36            | 431.03          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center, Airoli (MSETCL) Statement-VI

## Details of Generating Unit Outages/Trippings for 19/May/2015

Position as on 6.30 Hrs of 20/May/2015

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                 |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 12/10/2014   | 22:39        |            | Continued. | Refuelling work                                                 |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Renovation and Modification work                                |               |
| MSPGCL                | Parli Unit 4            | 210      | 13/04/2015   | 11.27        |            | Continued. | Turbine vibration high.<br>Continued to AOH<br>w.e.f.01.05.2015 | 26/06/2015    |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                 |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                   |               |
| RGPL                  | Dabhol 3A               | 230      | 06/06/2013   | 08.28        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 2A               | 230      | 06/06/2013   | 09.10        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 2X               | 290      | 15/07/2013   | 15.09        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 2B               | 230      | 08/08/2013   | 15.03        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 3X               | 290      | 29/12/2013   | 05.47        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 3B               | 230      | 29/12/2013   | 06.14        |            | Continued. | Gas Shortage                                                    |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | PA Fan Vibration Problem                                        |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.                                              |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 13/09/2014   | 12.43        |            | Continued. | Economic shutdown                                               |               |
| IPP                   | RPL(AMT) U-1            | 270      | 21/03/2015   | 23.28        |            | Continued. | Turbine vibration high.                                         |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 29/03/2015   | 18.26        |            | Continued. | Withdrawn                                                       |               |
| MSPGCL                | Koradi Unit-8           | 660      | 30/03/2015   | 20.22        |            | Continued. | BLR Tripped.                                                    |               |
| MSPGCL                | Uran Unit 6             | 108      | 01/04/2015   | 16.35        |            | Continued. | Gas shortage                                                    |               |
| IPP                   | RPL(AMT) U-4            | 270      | 03/04/2015   | 11.42        |            | Continued. | Boiler feed Pump problem.                                       |               |
| IPP                   | RPL(AMT) U-5            | 270      | 03/04/2015   | 14.22        |            | Continued. | turbine Shaft Vibration high.                                   |               |
| IPP                   | RPL(AMT) U-3            | 270      | 05/04/2015   | 22.01        |            | Continued. | Governor AVR Problem.                                           |               |
| TPC-G                 | Trombay 6               | 500      | 06/04/2015   | 16.27        |            | Continued. | Economic shut down.                                             |               |
| MSPGCL                | Uran Unit 7             | 108      | 17/04/2015   | 00.07        |            | Continued. | Gas turbine problem                                             |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 20/04/2015   | 00.00        |            | Continued. | no buyer as per msdcl<br>regirment                              |               |
| IPP                   | Adani U-3               | 660      | 11/05/2015   | 00.52        |            | Continued. | Main Steam Drain MIY<br>Bonnet Leakage.                         |               |
| IPP                   | JSW (J) U1              | 300      | 14/05/2015   | 19.16        |            | Continued. | Turbine Bearing Problem                                         |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 16/05/2015   | 15.40        | 19/05/2015 | 04:43      | Bottam hash hopper work                                         |               |
| IPP                   | WPCL U-3                | 135      | 18/05/2015   | 03:07        |            | Continued. | Withdrawn                                                       |               |
| MSPGCL                | Koyana Unit 6           | 75       | 18/05/2015   | 11:25        |            | Continued. | Injector Replacement.                                           |               |
| MSPGCL                | Parli Unit 3            | 210      | 19/05/2015   | 18.12        |            | Continued. | Drum level low                                                  |               |
| RINFRA-G              | REL Unit 1              | 250      | 19/05/2015   | 20.44        |            | Continued. | Boiler Tube Leakage                                             |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/May/2015**

**Statement-VII**

**Position as on 6.30 Hrs of 20/May/2015**

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                   |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                    |
| Dhule Sar'Sarovar II                   | InterState                | 18/05/2015   | 17:55        | 19/05/2015 | 08.18      | HT          | Over Voltage                                                                                                       |
| Kolhapur Mapusa I                      | InterState                | 19/05/2015   | 16.42        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Dhule Sar'Sarovar I                    | InterState                | 19/05/2015   | 18.04        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Akola II - RPL(Rattanindia) Ckt I      | IntraState                | 07/04/2015   | 00.27        |            | Continued. | T           | "R" Phase Metering PT Burst.                                                                                       |
| Babhaleshwar-Taptitanda ckt-I          | IntraState                | 17/05/2015   | 21:23        |            | Continued. | HT          | Over Voltage                                                                                                       |
| karad -kolhapur-II                     | IntraState                | 18/05/2015   | 17:04        | 19/05/2015 | 07.13      | HT          | To Control Voltage.                                                                                                |
| Bhusawal-Aurangabad                    | IntraState                | 18/05/2015   | 18:08        | 19/05/2015 | 07.58      | HT          | To Control Voltage.                                                                                                |
| Padghe - Kalwa- I                      | IntraState                | 19/05/2015   | 06.28        | 19/05/2015 | 12.20      | PO          | Attending hot spot.                                                                                                |
| Karad - Lonikand 1                     | IntraState                | 19/05/2015   | 13.21        | 19/05/2015 | 13.43      | T           | Distance Protection                                                                                                |
| Karad - Lonikand 1                     | IntraState                | 19/05/2015   | 14.47        | 19/05/2015 | 20.02      | T           | Distance Protection                                                                                                |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                    |
| 400/220 KV 315 MVA ICT- I @Koradi      | IntraState                | 18/05/2015   | 11:47        |            | Continued. | PO          | Dismantling and Errection of Duct with LA.                                                                         |
| 400/220 Kv 315 MVA ICT -I @New Koyna   | IntraState                | 19/05/2015   | 10.41        | 19/05/2015 | 20.17      | PO          | Repl of 33KV PT.                                                                                                   |
| 400/220/33 Kv 315 Mva ICT- II @Padghe  | IntraState                | 19/05/2015   | 12.22        | 19/05/2015 | 13.56      | T           | OLTC Bucholz Prot Optd.                                                                                            |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                    |
| Khaparkheda-Butibori 3                 | InterState                | 19/05/2015   | 10.26        | 19/05/2015 | 13.18      | PO          | Measurement of CB timing and CRM.                                                                                  |
| Sahara-Urse                            | IntraState                | 03/03/2015   | 11.06        |            | Continued. | PO          | Tower erection work (90Days)                                                                                       |
| Chandrapur Gcr - Warora - I            | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107. |
| Chandrapur Gcr - Wani                  | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107. |
| Eklahara-(Ocr)-Navasari I              | IntraState                | 05/05/2015   | 23.09        |            | Continued. | HT          | To control Load on Bus section at Nasik GCR                                                                        |
| Mudshingi-Wathar                       | IntraState                | 18/05/2015   | 00.33        |            | Continued. | T           | R Phase CT Burst.                                                                                                  |
| Parvati - Hybrid Pass                  | IntraState                | 18/05/2015   | 08:42        |            | Continued. | HT          | To Control Chinchwad-Urse L/L.                                                                                     |
| Boisar II - Tarapur                    | IntraState                | 19/05/2015   | 07.42        | 19/05/2015 | 08.31      | PO          | Removing bird nest from gantry.                                                                                    |
| Raymond - Washala                      | IntraState                | 19/05/2015   | 08.45        | 19/05/2015 | 17.31      | PO          | Cold washing of disc.                                                                                              |
| TBC @ Nagothane                        | IntraState                | 19/05/2015   | 09.00        | 19/05/2015 | 11.00      | PO          | CT Tan Delta Work.                                                                                                 |
| Deepnagar Amalner                      | IntraState                | 19/05/2015   | 09.16        | 19/05/2015 | 12.50      | PO          | Attending Hot Spot                                                                                                 |
| Kadegaon-Miraj                         | IntraState                | 19/05/2015   | 10.10        | 19/05/2015 | 11.20      | PO          | Red hot on R-Ph CT.                                                                                                |
| Vankuswade - Kdph                      | IntraState                | 19/05/2015   | 11.00        | 19/05/2015 | 17.25      | PO          | Line crossing work of Karad - Koyna Ckt.                                                                           |
| Mumewadi-Belewadi                      | IntraState                | 19/05/2015   | 11.37        | 19/05/2015 | 17.35      | PO          | Scada commissioning work.                                                                                          |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                    |
| 220/110KV, 200MVA T/F-III at Mudshingi | InterState                | 19/05/2015   | 10.24        | 19/05/2015 | 17.28      | PO          | Attending hot spot.                                                                                                |
| 220/100 Kv 200 MVA ICT III @Borivali   | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Internal Fault                                                                                                     |
| 220/132 kV 150MVA ICT-II @ Satara      | IntraState                | 13/05/2015   | 16:30        |            | Continued. | T           | Differential protection                                                                                            |
| <b>132 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                    |
| Seloo - Mahatmasugar                   | InterState                | 19/05/2015   | 19.31        | 19/05/2015 | 20.30      | T           | Distance Protection                                                                                                |
| Mankapur - Hingna-I                    | IntraState                | 19/05/2015   | 11.23        | 19/05/2015 | 14.29      | T           | Distance Protection                                                                                                |
| Khapri-Besa                            | IntraState                | 19/05/2015   | 21.05        |            | Continued. | T           | Distance Protection                                                                                                |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage